

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-2101-2026 Revision: A
Title: Stroke test, XV-2101
Owner: Gopal Iyer
Issued: 04 March 2026

Primary equipment: XV-2101, Reactor isolation valve 1

Tester: Gopal Iyer
Equipment: XV-2101

Closure time 6.6 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.