

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-2102-2025 Revision: A
Title: Stroke test, XV-2102
Owner: Gopal Iyer
Issued: 12 September 2025

Primary equipment: XV-2102, Reactor isolation valve 2

Tester: Gopal Iyer
Equipment: XV-2102

Closure time 6.4 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed with an observation.