

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-2103-2026 Revision: A
Title: Stroke test, XV-2103
Owner: Gopal Iyer
Issued: 26 April 2026

Primary equipment: XV-2103, Reactor isolation valve 3

Tester: Gopal Iyer
Equipment: XV-2103

Closure time 5.2 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.