

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-3101-2026 Revision: A
Title: Stroke test, XV-3101
Owner: Gopal Iyer
Issued: 02 January 2026

Primary equipment: XV-3101, Steam isolation valve 1

Tester: Gopal Iyer
Equipment: XV-3101

Closure time 4.3 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.