

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-3102-2026 Revision: A
Title: Stroke test, XV-3102
Owner: Gopal Iyer
Issued: 20 April 2026

Primary equipment: XV-3102, Steam isolation valve 2

Tester: Gopal Iyer
Equipment: XV-3102

Closure time 5.7 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.