

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-3103-2026 Revision: A
Title: Stroke test, XV-3103
Owner: Gopal Iyer
Issued: 11 July 2026

Primary equipment: XV-3103, Steam isolation valve 3

Tester: Gopal Iyer
Equipment: XV-3103

Closure time 4.1 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed with an observation.