

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-4101-2026 Revision: A
Title: Stroke test, XV-4101
Owner: Gopal Iyer
Issued: 29 January 2026

Primary equipment: XV-4101, Flare header isolation valve

Tester: Gopal Iyer
Equipment: XV-4101

Closure time 6.3 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.