

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-5101-2026 Revision: A
Title: Stroke test, XV-5101
Owner: Gopal Iyer
Issued: 26 July 2026

Primary equipment: XV-5101, Dispatch isolation valve 1

Tester: Gopal Iyer
Equipment: XV-5101

Closure time 5.9 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.