

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-5102-2025 Revision: A
Title: Stroke test, XV-5102
Owner: Gopal Iyer
Issued: 28 October 2025

Primary equipment: XV-5102, Dispatch isolation valve 2

Tester: Gopal Iyer
Equipment: XV-5102

Closure time 4.7 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.