

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-5103-2025 Revision: A
Title: Stroke test, XV-5103
Owner: Gopal Iyer
Issued: 02 September 2025

Primary equipment: XV-5103, Dispatch isolation valve 3

Tester: Gopal Iyer
Equipment: XV-5103

Closure time 4.4 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.