

Veridian Petrochemicals
Bharuch Complex

Document no: TEST-XV-5104-2025 Revision: A
Title: Stroke test, XV-5104
Owner: Gopal Iyer
Issued: 12 November 2025

Primary equipment: XV-5104, Dispatch isolation valve 4

Tester: Gopal Iyer
Equipment: XV-5104

Closure time 4.6 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.