

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-XV-6101-2025 Revision: A
Title: Stroke test, XV-6101
Owner: Gopal Iyer
Issued: 24 December 2025

Primary equipment: XV-6101, Tank outlet valve 1

Tester: Gopal Iyer
Equipment: XV-6101

Closure time 4.1 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.