

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-XV-6102-2026 Revision: A
Title: Stroke test, XV-6102
Owner: Gopal Iyer
Issued: 17 May 2026

Primary equipment: XV-6102, Tank outlet valve 2

Tester: Gopal Iyer
Equipment: XV-6102

Closure time 4.7 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed with an observation.