

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-XV-6103-2026 Revision: A
Title: Stroke test, XV-6103
Owner: Gopal Iyer
Issued: 24 March 2026

Primary equipment: XV-6103, Tank outlet valve 3

Tester: Gopal Iyer
Equipment: XV-6103

Closure time 5.0 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed with an observation.