

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-XV-6104-2026 Revision: A
Title: Stroke test, XV-6104
Owner: Gopal Iyer
Issued: 08 March 2026

Primary equipment: XV-6104, Tank outlet valve 4

Tester: Gopal Iyer
Equipment: XV-6104

Closure time 6.4 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.