

Veridian Petrochemicals
Dahej Tank Farm

Document no: TEST-XV-6105-2026 Revision: A
Title: Stroke test, XV-6105
Owner: Gopal Iyer
Issued: 15 June 2026

Primary equipment: XV-6105, Tank outlet valve 5

Tester: Gopal Iyer
Equipment: XV-6105

Closure time 5.9 seconds.
Seat test passed, no visible leakage.
Limit switches and solenoid confirmed.
Result: passed.