

Veridian Petrochemicals

Dahej Tank Farm

Document no: TEST-XV-6106-2026 Revision: A

Title: Stroke test, XV-6106

Owner: Gopal Iyer

Issued: 02 April 2026

Primary equipment: XV-6106, Tank outlet valve 6

Tester: Gopal Iyer

Equipment: XV-6106

Closure time 5.6 seconds.

Seat test passed, no visible leakage.

Limit switches and solenoid confirmed.

Result: passed.