

CITY OF PHOENIX

2018 IECC FORMAL REPORT

Inspector: Saleem
HERS Rater/RFI ID: 6738249
Recent Inspection Date: 8/17/2023 12:00 AM
Inspection Phase: Framing & Rough HVAC

Desert Skies Energy
127 W Juanita Ave Suite 208
Mesa, Arizona 85210
RESNET Provider ID: 6738249

PROJECT & CLIENT DETAILS

125 main
Avondale, Arizona
New Construction, Single Family Detached Homes
Livable Sq. Footage: 4,019ft²

Client: ABC Builders
Contact: PM1
(480) 455-3587
pm1@gmail.com

MANDATORY TESTING & INSPECTION SUMMARY

Air barrier inspections <i>R402.4.1</i> NOT VERIFIED Builder Sign Off	Mechanical inspections <i>N/A</i> NOT VERIFIED Builder Sign Off
SF Duct Testing <i>N/A</i> VERIFIED - CFM/CFA: 0.04 Pass Target(CFM25): 760 Result(CFM25): 70	Insulation inspections <i>R402.2</i> VERIFIED null Attic Type: Vented
SF Ventilation Testing <i>N/A</i> Pass Required CFM: N/A Verified CFM: N/A Method: N/A	SF Blower Door Testing <i>R402.1</i> VERIFIED - 4.25 ACH50 Corrective Required Target(CFM50): 50 Result(CFM50): 30

INSPECTOR GENERAL NOTES:

Testing Testing3

Accredited HERS Rater Signature
Signed Date 8/30/2023

 **DESERTSKIES**
ENERGY SERVICES
info@desertskiesenergy.com | 602-282-0279