Project: Worked examples
Title: Insulation thickness (ISO 12241 formula route)
Status: DRAFT Author: TempestOS (2026-10-23) Checker: — (—) Issued: —

1. Scope and method

The insulation thickness on a pipe (cylinder) or a flat surface that meets a heat-flow limit, a limit on the surface temperature of a hot surface and an anti-condensation requirement for a cold one, each solved separately and the governing one reported; and for a chosen thickness the heat flow, the surface temperature and PASS/FAIL per criterion. Steady state, one layer, no thickness table of any standard. Pipe resistance per metre: R = ln(D_e/D_i)/(2π·λ) + 1/(h_se·π·D_e), D_e = D_i + 2t; with the inner film and pipe wall R_oth = 1/(h_i·π·D_p) + ln(D_i/D_p)/(2π·λ_w) added in series Flat resistance per square metre: R = t/λ + 1/h_se (+ 1/h_i + t_w/λ_w) Heat flow: q = (θ_i − θ_a)/R, positive from the process to the ambient Surface temperature: θ_se = θ_a + q/(h_se·π·D_e) (pipe), θ_a + q/h_se (flat) Surface coefficient: h_se as given, or h_se = h_c + h_r with h_r = ε·σ·(T_s² + T_a²)(T_s + T_a); h_c from free convection to air (laminar or turbulent, the larger), forced convection (cross-flow cylinder or flat plate) and their cube-law blend; solved with θ_se, which it depends on Heat-loss limit: the thickness beyond which |q| ≤ q_max; surface-temperature limit (hot): θ_se ≤ θ_se,max; anti-condensation (cold): θ_se ≥ θ_dew + margin, θ_dew entered (for example from B2) or from the Magnus relation at θ_a and RH Solve: each criterion's thickness by scanning t from 0 to 1 m for the last broken point and bisecting the bracket after it; governing t = max over the selected criteria Critical diameter: D_crit = 2λ/h_se; below it, insulation raises the heat flow until D_e passes D_crit

Ref: ISO 12241 formula route (clause numbers to be checked) — Thermal insulation for building equipment and industrial installations: calculation rules
Ref: Incropera, Fundamentals of Heat and Mass Transfer 7th ed., §7.2, §7.4, §9.6, §9.9 (to be checked) — External forced, free and mixed convection correlations
Ref: ISO 13788 cl. 6 (clause number to be checked against the owner's copy) — Magnus saturation vapour pressure (shared with B7)

2. Inputs

SYMBOL	DESCRIPTION	VALUE	UNIT	SOURCE	VALID RANGE
geometry	Surface	pipe (cylinder)		assumption: A round pipe.	any
D_i	Pipe outer diameter, the inside of the insulation (pipe)	90	mm	drawing: M-PIP-014 rev A	10 ... 1000 mm
theta_i	Process (fluid) temperature	6	degC	spec: SPEC-M-11 §3: chilled-water flow temperature	-50 ... 400 degC
theta_a	Ambient air temperature (also the radiation sink)	28	degC	spec: SPEC-M-11 §2: plant-room design temperature	-20 ... 50 degC
lambda	Thermal conductivity of the insulation	0.035	W/(m*K)	assumption: Closed-cell elastomeric insulation; take the maker's value at the mean temperature (W3 material)	0.015 ... 0.2 W/(m*K)

SYMBOL	DESCRIPTION	VALUE	UNIT	SOURCE	VALID RANGE
h_mode	Where the outer surface coefficient comes from	h_se as given		assumption: A surface coefficient is given, not computed.	any
h_se	Outer surface coefficient h_se (as given; generic default of 10 W/(m²K), replace with the value for your surface)	8	W/(m^2*K)	assumption: Still air in a plant room; replace with the project's own record.	3 ... 40 W/(m^2*K)
eps	Emissivity of the outer surface (correlation)	0.9		assumption: Not used: h_se is given.	0.05 ... 1
v_wind	Air speed over the surface (correlation; 0 = still air)	0	m/s	assumption: Not used: h_se is given.	0 ... 20 m/s
L_surf	Height or flow length of the flat surface (correlation, flat)	1	m	assumption: Not used: a pipe.	0.1 ... 10 m
q_max_m	Heat-loss limit per metre of pipe (generic default of 25 W/m, replace with your project limit; blank = not a criterion)	12	W/m	spec: SPEC-M-11 §5: heat gain not to exceed 12 W/m	1 ... 1000 W/m
dew_margin	Margin of the surface above the dew point, for a cold surface (blank = not a criterion)	1	K	spec: SPEC-M-11 §5: surface at least 1 K above the dew point	0 ... 5 K
RH_a	Relative humidity of the ambient air (anti-condensation)	70	%	spec: SPEC-M-11 §2: plant-room design humidity	20 ... 95 %
t_chosen	Chosen insulation thickness (blank = report at the required thickness, no checks; with it, nothing blocks)	25	mm	spec: Pipework schedule M-SCH-014: 25 mm sleeves	0 ... 300 mm

3. Assumptions

A1. Steady one-dimensional heat flow through a single homogeneous layer of constant conductivity; no thermal bridges at supports, no joints, no moisture in the insulation. λ is taken at the value entered: use the value at the mean insulation temperature shown on the sheet (optionally noted in 'Temperature the conductivity applies at'). (Formula route of the standard.)

A2. With the correlation, h_se = h_c + h_r. Radiation: h_r = ε·σ·(T_s² + T_a²)(T_s + T_a) to surroundings at the ambient air temperature. Free convection to air: Holman's simplified relations at atmospheric pressure, the larger of the laminar and turbulent forms (horizontal cylinder 1.32(ΔT/D)^0.25 and 1.24ΔT^(1/3); vertical surface 1.42(ΔT/L)^0.25 and 1.31ΔT^(1/3)). Forced convection: Churchill–Bernstein for a cylinder in cross-flow, the laminar/mixed flat-plate relations along a plate; air properties from fits at the film temperature, Pr = 0.71; blended with free convection as (h_nat³ + h_forced³)^(1/3). Indicative, not the standard's own correlation. (Incropera 7th ed. §7.2, §7.4, §9.6 free convection and §9.9 mixed convection (section numbers to be checked against the owner's copy); the free-convection constants are Holman's, Heat Transfer; the standard's own coefficients are not reproduced.)

A3. The dew point is entered (for example from B2) or is the Magnus relation at θ_a and RH, the same closed form B7 uses. Below 0 °C the relation is over ice, so RH is then taken relative to ice, whereas meteorological RH is usually relative to water: enter the dew point for sub-zero air. A margin above it is the

user's. (Derived; B7 shares the function.)
A4. Pipes are treated as horizontal for free convection and flat surfaces as vertical; air properties are fits (conductivity within about 3 %, viscosity within about 4 % over 250–400 K), Pr = 0.71. (Stated.)
A5. The required thickness is the least thickness beyond which the criterion holds for every thicker layer up to 1 m, which is what matters when thin insulation on a small pipe raises the heat flow (critical diameter). (Stated.)
A6. No thickness table is used or shipped: not BS 5422, not the tables of any standard. The conductivity is the user's input, from a W3 material or the maker's data. (Addendum B §B5.)
A7. geometry (Surface) is taken as pipe (cylinder). (A round pipe.)
A8. lambda (Thermal conductivity of the insulation) is taken as 0.035 W/(m*K). (Closed-cell elastomeric insulation; take the maker's value at the mean temperature (W3 material))
A9. h_mode (Where the outer surface coefficient comes from) is taken as h_se as given. (A surface coefficient is given, not computed.)
A10. h_se (Outer surface coefficient h_se (as given; generic default of 10 W/(m²K), replace with the value for your surface)) is taken as 8 W/(m^2*K). (Still air in a plant room; replace with the project's own record.)
A11. eps (Emissivity of the outer surface (correlation)) is taken as 0.9. (Not used: h_se is given.)
A12. v_wind (Air speed over the surface (correlation; 0 = still air)) is taken as 0 m/s. (Not used: h_se is given.)
A13. L_surf (Height or flow length of the flat surface (correlation, flat)) is taken as 1 m. (Not used: a pipe.)

4. Working

[11] theta_dew = inverse Magnus of RH·p_sat(□_a) — ISO 13788 (Magnus form, as B7)
= □_a = 28 °C, RH = 70 %
= 22.012 degC
Dew point of the ambient air

[12] t_q = t such that |q| ≤ 12 W/m for every thicker layer — ISO 12241
= scan 0 … 1000 mm, then bisection
= 17.814 mm
Required thickness, heat-gain limit

[13] t_dew = t such that □_se ≥ 23.012 °C for every thicker layer — ISO 12241
= scan 0 … 1000 mm, then bisection
= 13.162 mm
Required thickness, anti-condensation margin

[14] thickness = max over the selected criteria — ISO 12241
= t_q = 17.814 mm, t_dew = 13.162 mm
= 17.814 mm
Governing required thickness (heat-gain limit)

[16] D_e = D_i + 2t
= 90 mm + 2 × 25 mm
= 140 mm
Outer diameter of the insulation, chosen thickness

[17] R_ins = ln(D_e/D_i)/(2π·□) — ISO 12241
= ln(140/90)/(2π × 0.035)
= 2.0091 m·K/W
Resistance of the insulation

[18] R_se = 1/(h_se·π·D_e) — ISO 12241
= 1/(8 × π × 0.14 m)
= 0.28421 m·K/W
Resistance of the outer surface

[19] R = R_oth + R_ins + R_se — ISO 12241
= 0 + 2.0091 + 0.28421
= 2.2933 m·K/W
Total resistance per metre

[20] q_per_m = |θ_i − θ_a| / R ISO 12241
= 22 K / 2.2933
= 9.593 W/m
Heat flow per metre of pipe (heat gain, magnitude)
[21] theta_se = θ_a + q/(h_se·π·D_e) ISO 12241
= 28 °C − 9.593 / 3.5186
= 25.274 degC
Outer surface temperature
[22] theta_m = (θ_i + θ_se)/2
= (6 + 25.274)/2
= 15.637 degC
Mean temperature of the insulation: take λ at this temperature
[23] D_crit = 2λ/h_se at the bare surface ISO 12241
= 2 × 0.035 / 8
= 8.75 mm
Critical diameter at the bare-surface h_se: below it, insulation raises the heat flow
[24] u_q = |q| / q_max
= |q| ≤ 12 W/m
= 0.79941
Utilisation, heat-gain limit
[25] u_dew = (θ_a − θ_se)/(θ_a − (θ_dew + margin))
= θ_se ≥ 23.012 °C
= 0.54661
Utilisation, anti-condensation margin

5. Results

SYMBOL	VALUE	DESCRIPTION
theta_dew	22.012 degC	Dew point of the ambient air
t_q	17.814 mm	Required thickness, heat-gain limit
u_q	0.79941	Utilisation, heat-gain limit
t_dew	13.162 mm	Required thickness, anti-condensation margin
u_dew	0.54661	Utilisation, anti-condensation margin
thickness	17.814 mm	Governing required thickness
q_per_m	9.593 W/m	Heat flow per metre (heat gain)
theta_se	25.274 degC	Outer surface temperature
theta_m	15.637 degC	Mean insulation temperature
R	2.2933 m·K/W	Total resistance
D_crit	8.75 mm	Critical diameter (at the bare-surface h_se)
governing	"heat-gain limit"	Governing criterion

6. Checks (governing first)

RESULT	CHECK	DEMAND	CAPACITY	UTILISATION	REF
PASS	Chosen thickness against the heat-gain limit	u_q = 0.79941	u_q ≤ 1	0.799	ISO 12241

RESULT	CHECK	DEMAND	CAPACITY	UTILISATION	REF
PASS	Chosen thickness against the anti-condensation margin	u_dew = 0.54661	u_dew ≤ 1	0.547	ISO 12241

7. Applicability

WARNING — record: Tabulated values not taken from a reference record: lambda (Material properties); h_se (Outer surface coefficient); eps (Surface emissivity); q_max_m, dew_margin (Insulation criteria). Enter each as one so its source, edition and licence travel with it.

8. Verification

Template bs.insulation@1.1.0 Content hash 95960c18f73723e4 Engine calc-engine/1.0.0
Known-answer cases passed 14/14 Test run 2026-10-23 12:00 UTC TempestOS 0.26.0