Project: Worked examples
Title: Containment fill, bend radius and cable pulling
Status: DRAFT Author: TempestOS (2026-10-23) Checker: — (—) Issued: —

1. Scope and method

The fill of a conduit, trunking or tray by the cables in it against the space factor you enter, the bend radius of the route against the multiple of the largest cable diameter you enter, and the pull of the cables through a route of straight lengths and bends in both directions: the tension along the route, the sidewall pressure at each bend, and the pull direction that passes every check (the lower maximum tension when both do or neither does). Space factor, bend multiple, friction coefficient and pulling limits are your own records; no cable or conduit factor method is offered.
Cable area: $A_{cab} = \Sigma\, n_i \cdot \pi \cdot d_i^2/4$ (n_i cables of overall diameter d_i) Containment area: $A_{int} = \pi \cdot D^2/4$ (conduit, internal diameter D) or $W \cdot H$ (trunking or tray, internal width × depth) Fill: fill = A_{cab}/A_{int}; utilisation u_{fill} = fill/f_{max}, f_{max} the space factor from your record Bend radius: $R_{min} = n_{bend} \cdot d_{max}$, d_{max} the largest cable diameter, n_{bend} from your record; each bend $u_b = R_{min}/R$ Weight: $w = \Sigma\, n_i \cdot m_i$ (kg/m); force per metre $w \cdot g \cdot w_c$, g = 9.80665 m/s², w_c your weight-correction factor (1 = full weight) Straight length: $T_2 = T_1 + w \cdot g \cdot w_c \cdot \mu \cdot L$ Bend: $T_2 = T_1 \cdot e^{(w_c \cdot \mu \cdot \theta)}$ (capstan equation with the friction scaled by the weight-correction factor, θ in radians) Sidewall pressure at a bend: $SWP = T_2/R$ (N/m) Direction: the route is run in the listed order and in reverse; the direction that passes every tension and sidewall pressure check is recommended, and when both or neither pass, the one of lower maximum tension (equal tension: lower SWP) Cable limit: load shared equally, so each cable carries T/N (N cables); $T_{cab} = k_n \cdot N \cdot \min(T_{max,i})$, k_n your derating for more than 3 cables (1 if none); $u_T = \max_i (T/N)/(k_n \cdot T_{max,i}) = T/T_{cab}$ Grip limit: $u_{grip} = T/T_{grip}$, T_{grip} the limit of the grip or pulling eye (your record); sidewall pressure $u_P = SWP_{max}/P_{lim}$
Ref: BS 7671:2018 (as amended) reg. 522.8 — Other mechanical stresses on wiring systems (damage during installation, bending radius)
Ref: BS EN 61386-1 general — Conduit systems for cable management: general requirements
Ref: Beer and Johnston, Vector Mechanics for Engineers: Statics Ch. 8 — Friction: belt friction (the capstan equation)

2. Inputs

SYMBOL	DESCRIPTION	VALUE	UNIT	SOURCE	VALID RANGE
cables	Cables in the containment and pulled together	2 row(s)		spec: Cable data sheets CDS-21 (servo power) and CDS-22 (encoder): overall diameter, mass and maximum pulling tension	any
cables[1]		name = Servo power; od = 14 mm; count = 2; mass = 0.35 kg/m; T_max = 600 N			

SYMBOL	DESCRIPTION	VALUE	UNIT	SOURCE	VALID RANGE
cables[2]		name = Encoder and control; od = 9 mm; count = 4; mass = 0.12 kg/m; T_max = 200 N			
cont_type	Containment	Conduit (round)		drawing: CND-ROUTE-07 rev C	any
D_c	Conduit internal diameter (conduit)	40	mm	drawing: CND-ROUTE-07 rev C	10 … 300 mm
f_max	Space factor limit (fill limit, from your record)	0.5		reference: record: space factor for this arrangement (a value invented for this example; enter your own from your installation standard or company rule)	0.01 … 1
n_bend	Minimum bend radius as a multiple of the largest cable diameter (from your record)	10		reference: record: minimum bend radius multiple (a value invented for this example; enter the largest multiple from the cable data sheets)	1 … 100
route	Pull route in pull order (straight lengths and bends)	6 row(s)		drawing: CND-ROUTE-07 rev C	any
route[1]		kind = Straight; L = 6 m			
route[2]		kind = Bend; theta = 90 deg; R = 500 mm			
route[3]		kind = Straight; L = 14 m			

SYMBOL	DESCRIPTION	VALUE	UNIT	SOURCE	VALID RANGE
route[4]		kind = Bend; theta = 90 deg; R = 400 mm			
route[5]		kind = Straight; L = 9 m			
route[6]		kind = Bend; theta = 45 deg; R = 600 mm			
T_1	Tension at the start of the pull (pulling rope, drum or head)	150	N	spec: Pulling method statement PMS-4: 150 N rope and pulling-head tension at the start of the pull	0 ... 10000 N
mu	Coefficient of friction, cable sheath on containment (from your record)	0.3		reference: record: coefficient of friction, sheath on lubricated conduit (a value invented for this example; enter your own)	0 ... 2
P_lim	Sidewall pressure limit, force per metre of bend (from the cable maker)	3000	N/m	reference: record: sidewall pressure limit (a value invented for this example; enter the cable maker's figure)	1 ... 10000000 N/m

3. Assumptions

A1. Cables are circular and counted by overall diameter; there is no packing or cable and conduit factor method (the jam-ratio warning is the only jamming check). The space factor is yours, from your own record. (Fill by geometry; the factor is a user record.)
A2. Every cable is pulled together as one bundle on one pulling head with the load shared equally, so each cable carries T/N and the weakest cable governs: the cable limit is N times the lowest maximum pulling tension, optionally derated by your factor for more than 3 cables. The grip or pulling-eye limit is a separate limit you enter. (Equal sharing; unequal sharing is not modelled.)
A3. Straight lengths are horizontal and the cable weight bears on the containment over the full length; bends are taken in the plane of the route. Inclines, vertical runs and pulley or roller reductions are not modelled; fold them into μ. A cradled or triangular weight correction is entered as w_c, which scales the weight on the straight lengths and the friction in the bends (the contact force of a cradled or triangular arrangement is w_c times that of a flat one), so $T_2 = T_1 + w \cdot g \cdot w_c \cdot \mu \cdot L$ and $T_2 = T_1 \cdot e^{(w_c \cdot \mu \cdot \theta)}$. (Equivalent friction $w_c \cdot \mu$ in the capstan equation; blank w_c means 1.)
A4. The coefficient of friction is one constant for the whole route; static and running friction are not distinguished. (A user record with its source.)

A5. Sidewall pressure is the tension leaving the bend over the bend radius, for the bundle as a whole. Enter the cable maker's per-cable limit unchanged: the bundle T/R against it is conservative for a triangular arrangement and roughly equal for a cradled one. Do not multiply the limit by the number of cables. (SWP = T_2/R.)
A6. The bend radius uses the individual cable diameter; for a triplexed or bundled assembly, enter the assembly diameter from the cable maker as the overall diameter. (Cable data sheet.)
A7. The tension at the start of the pull is the same in both directions; a bend at the very start of a pull with no start tension adds nothing, so enter the pulling rope or drum tension when it matters. (Capstan equation.)

4. Working

[1] A_c1 = n·π·d²/4
= 2 × π × (14 mm)² / 4
= 307.88 mm²
Servo power: cross-section of 2 cable(s)
[2] A_c2 = n·π·d²/4
= 4 × π × (9 mm)² / 4
= 254.47 mm²
Encoder and control: cross-section of 4 cable(s)
[3] A_cab = Σ n_i·π·d_i²/4
= A_c1 + A_c2
= 562.35 mm²
Total cable cross-section
[4] OD_max = max d_i
= 14 mm
= 14 mm
Largest cable overall diameter
[5] w = Σ n_i·m_i
= 2 × 0.35 kg/m + 4 × 0.12 kg/m
= 1.18 kg/m
Mass per metre of the bundle
[8] A_int = pi * D_c^2 / 4
= π × (40 mm)^2 / 4
= 1256.6 mm²
Internal cross-section of the conduit
[10] fill = A_cab / A_int
= 562.35 mm² / 1256.6 mm²
= 44.75 %
Fill: cable cross-section over internal cross-section
[11] u_fill = A_cab / (A_int * f_max)
= 562.35 mm² / (1256.6 mm² × 0.5)
= 0.895
Fill utilisation against the space factor
[13] R_min = n_bend * OD_max
= 10 × 14 mm
= 140 mm
Minimum bend radius for the largest cable
[14] u_b2 = R_min/R
= 140 mm / 500 mm
= 0.28
Segment 2: bend radius utilisation
[15] u_b4 = R_min/R
= 140 mm / 400 mm
= 0.35

Segment 4: bend radius utilisation

[16] u_b6 = R_min/R
= 140 mm / 600 mm
= 0.23333

Segment 6: bend radius utilisation

[17] u_bend = max R_min/R
= 3 bend(s)
= 0.35

Bend radius utilisation (tightest bend)

[20] wg = w * 9.80665 m/s^2
= 1.18 kg/m × 9.80665 m/s^2
= 11.572 N/m

Weight per metre of the bundle on the containment

[21] Ta_1 = T₁ + w·g·w_c·□·L
= 150 N + 11.572 N/m × 0.3 × 6 m
= 170.83 N

Segment 1 (as listed): tension after the straight length

[22] Ta_2 = T₁·e^(w_c·□·□)
= 170.83 N × e^(1 × 0.3 × 1.5708 rad)
= 273.66 N

Segment 2 (as listed): tension after the bend

[23] Pa_2 = T₂/R
= 273.66 N / 0.5 m
= 547.33 N/m

Segment 2 (as listed): sidewall pressure

[24] Ta_3 = T₁ + w·g·w_c·□·L
= 273.66 N + 11.572 N/m × 0.3 × 14 m
= 322.27 N

Segment 3 (as listed): tension after the straight length

[25] Ta_4 = T₁·e^(w_c·□·□)
= 322.27 N × e^(1 × 0.3 × 1.5708 rad)
= 516.26 N

Segment 4 (as listed): tension after the bend

[26] Pa_4 = T₂/R
= 516.26 N / 0.4 m
= 1290.7 N/m

Segment 4 (as listed): sidewall pressure

[27] Ta_5 = T₁ + w·g·w_c·□·L
= 516.26 N + 11.572 N/m × 0.3 × 9 m
= 547.51 N

Segment 5 (as listed): tension after the straight length

[28] Ta_6 = T₁·e^(w_c·□·□)
= 547.51 N × e^(1 × 0.3 × 0.7854 rad)
= 692.98 N

Segment 6 (as listed): tension after the bend

[29] Pa_6 = T₂/R
= 692.98 N / 0.6 m
= 1155 N/m

Segment 6 (as listed): sidewall pressure

[30] Tb_6 = T₁·e^(w_c·□·□)
= 150 N × e^(1 × 0.3 × 0.7854 rad)
= 189.85 N

Segment 6 (reversed): tension after the bend

[31] Pb_6 = T_2/R
= 189.85 N / 0.6 m
= 316.42 N/m
Segment 6 (reversed): sidewall pressure
[32] Tb_5 = T_1 + w·g·w_c·□·L
= 189.85 N + 11.572 N/m × 0.3 × 9 m
= 221.1 N
Segment 5 (reversed): tension after the straight length
[33] Tb_4 = T_1·e^(w_c·□·□)
= 221.1 N × e^(1 × 0.3 × 1.5708 rad)
= 354.19 N
Segment 4 (reversed): tension after the bend
[34] Pb_4 = T_2/R
= 354.19 N / 0.4 m
= 885.48 N/m
Segment 4 (reversed): sidewall pressure
[35] Tb_3 = T_1 + w·g·w_c·□·L
= 354.19 N + 11.572 N/m × 0.3 × 14 m
= 402.8 N
Segment 3 (reversed): tension after the straight length
[36] Tb_2 = T_1·e^(w_c·□·□)
= 402.8 N × e^(1 × 0.3 × 1.5708 rad)
= 645.27 N
Segment 2 (reversed): tension after the bend
[37] Pb_2 = T_2/R
= 645.27 N / 0.5 m
= 1290.5 N/m
Segment 2 (reversed): sidewall pressure
[38] Tb_1 = T_1 + w·g·w_c·□·L
= 645.27 N + 11.572 N/m × 0.3 × 6 m
= 666.1 N
Segment 1 (reversed): tension after the straight length
[39] T_max_a = T at the end of the route, as listed
= 692.98 N
= 692.98 N
Maximum tension, pulling in the listed order
[40] T_max_b = T at the end of the route, reversed
= 666.1 N
= 666.1 N
Maximum tension, pulling in the reverse order
[41] P_max_a = max SWP, as listed
= 1290.7 N/m
= 1290.7 N/m
Maximum sidewall pressure, pulling in the listed order
[42] P_max_b = max SWP, reversed
= 1290.5 N/m
= 1290.5 N/m
Maximum sidewall pressure, pulling in the reverse order
[43] T_cab = N·min(T_max,i)
= 6 × 200 N
= 1200 N
Pulling tension limit of the bundle from the cables (equal load share, weakest cable)

[45] max_tension = min(T_max,a ; T_max,b)
= 692.98 N ; 666.1 N
= 666.1 N
Maximum pulling tension, recommended direction
[46] P_max = max SWP in the recommended direction
= 1290.5 N/m
= 1290.5 N/m
Maximum sidewall pressure, recommended direction
[47] u_Tc1 = (T/N)/(k_n·T_max,i)
= 111.02 N / (1 × 600 N)
= 0.18503
Servo power: share of the pull against its own limit
[48] u_Tc2 = (T/N)/(k_n·T_max,i)
= 111.02 N / (1 × 200 N)
= 0.55508
Encoder and control: share of the pull against its own limit
[49] u_T = max_tension / T_cab
= 666.1 N / 1200 N
= 0.55508
Tension utilisation against the cable limit (the weakest cable)
[50] u_P = P_max / P_lim
= 1290.5 N/m / 3000 N/m
= 0.43018
Sidewall pressure utilisation against the limit

5. Results

SYMBOL	VALUE	DESCRIPTION
A_cab	562.35 mm²	Total cable cross-section
A_int	1256.6 mm²	Internal cross-section
fill	44.75 %	Fill
u_fill	0.895	Fill utilisation
OD_max	14 mm	Largest cable diameter
w	1.18 kg/m	Mass per metre of the bundle
R_min	140 mm	Minimum bend radius
u_bend	0.35	Bend radius utilisation
T_max_a	692.98 N	Maximum tension, as listed
T_max_b	666.1 N	Maximum tension, reversed
P_max_a	1290.7 N/m	Maximum sidewall pressure, as listed
P_max_b	1290.5 N/m	Maximum sidewall pressure, reversed
max_tension	666.1 N	Maximum tension, recommended direction
P_max	1290.5 N/m	Maximum sidewall pressure, recommended direction
T_cab	1200 N	Pulling tension limit from the cables
u_T	0.55508	Cable tension utilisation
u_P	0.43018	Sidewall pressure utilisation

SYMBOL	VALUE	DESCRIPTION
direction	"Reverse: pull from segment 6 to segment 1"	Recommended pull direction

6. Checks (governing first)

RESULT	CHECK	DEMAND	CAPACITY	UTILISATION	REF
PASS	Fill against the space factor	u_fill = 0.895	u_fill ≤ 1	0.895	
PASS	Pulling tension against the weakest cable's limit	u_T = 0.55508	u_T ≤ 1	0.555	
PASS	Sidewall pressure against the limit	u_P = 0.43018	u_P ≤ 1	0.43	
PASS	Bend radius against the cable minimum	u_bend = 0.35	u_bend ≤ 1	0.35	cable maker's limit; cf. BS 7671 reg. 522.8
PASS	Largest cable fits the containment	largest cable 14 mm	conduit internal diameter 40 mm	0	

7. Applicability

WARNING — record: Tabulated values not taken from a reference record: f_max (Containment space factor); n_bend (Minimum bend radius multiple); mu (Pulling friction coefficient); P_lim (Pulling tension, grip and sidewall pressure limits). Enter each as one so its source, edition and licence travel with it.

8. Verification

Template elec.containment@1.1.0 Content hash 5dc54e0c879b636f Engine calc-engine/1.0.0
Known-answer cases passed 6/6 Test run 2026-10-23 12:00 UTC TempestOS 0.26.0