Project: Worked examples
Title: Column buckling (Perry–Robertson)
Status: DRAFT Author: TempestOS (2026-10-23) Checker: — (—) Issued: —

1. Scope and method

Compressive strength and resistance of a pin-ended strut of a given effective length, from Euler's critical stress reduced for initial imperfection by the Perry–Robertson formula, with the Robertson constant chosen by strut curve; utilisation against an applied axial load.
r = √(I/A); λ = L_E/r. p_E = π²E/λ²; P_E = p_E·A. λ_0 = 0.2·√(π²E/p_y). η = max(0.001·a·(λ − λ_0), 0). φ = (p_y + (η + 1)·p_E)/2. p_c = p_E·p_y/(φ + √(φ² − p_E·p_y)); P_c = p_c·A; u = P/P_c. Robertson constant a = 2.0, 3.5, 5.5, 8.0 for curves a–d.
Ref: BS 5950-1:2000 Annex C — Compressive strength (Perry strut formula)
Ref: BS 5950-1:2000 4.7.3.2 — Maximum slenderness
Ref: BS 5950-1:2000 Table 23 — Allocation of strut curve

2. Inputs

SYMBOL	DESCRIPTION	VALUE	UNIT	SOURCE	VALID RANGE
L_E	Effective length	3	m	drawing: DRG-ST-410 rev B	0.1 … 50 m
A	Cross-section area	2000	mm^2	spec: SPEC-ST-02 section schedule	10 … 1000000 mm^2
I	Second moment of area about the weaker axis	200	cm^4	spec: SPEC-ST-02 section schedule	0.01 … 10000000 cm^4
E	Modulus of elasticity	205	GPa	spec: BS 5950-1 3.1.3: E = 205 GPa	50 … 450 GPa
p_y	Design strength (yield)	275	MPa	spec: SPEC-ST-02: S275, t ≤ 16 mm	100 … 1000 MPa
curve	Strut curve (selects the Robertson constant)	c		spec: BS 5950-1 Table 23: welded box, curve c	any
P	Applied axial load	150	kN	assumption: Factored axial load from the frame analysis	0 … 100000 kN

3. Assumptions

A1. Pin-ended, prismatic strut under axial load only; buckling about the axis of the given second moment. (Effective length carries the end restraint.)
A2. Initial imperfection represented by the Perry factor η = 0.001·a·(λ − λ_0), with a from the strut curve. (Robertson's fit to strut tests.)
A3. P (Applied axial load) is taken as 150 kN. (Factored axial load from the frame analysis)

4. Working

`[8] α_R = 5.5` BS 5950-1 Annex C
`= 5.5`
Robertson constant for strut curve c

[9] r = sqrt(I / A)
= sqrt(200 cm⁴ / 2000 mm²)
= 31.623 mm
Radius of gyration
[10] lambda = L_E / r
= 3 m / 31.623 mm
= 94.868
Slenderness
[11] p_E = pi^2 * E / lambda^2 BS 5950-1 Annex C
= π^2 × 205 GPa / 94.868^2
= 224.81 MPa
Euler critical stress
[12] P_E = p_E * A
= 224.81 MPa × 2000 mm²
= 449.62 kN
Euler critical load
[13] lambda_0 = 0.2 * sqrt(pi^2 * E / p_y) BS 5950-1 Annex C
= 0.2 × sqrt(π^2 × 205 GPa / 275 MPa)
= 17.155
Limiting slenderness
[14] eta = max(0.001 * a_R * (lambda - lambda_0), 0) BS 5950-1 Annex C
= max(0.001 × 5.5 × (94.868 - 17.155), 0)
= 0.42742
Perry factor (initial imperfection)
[15] phi = (p_y + (eta + 1) * p_E) / 2
= (275 MPa + (0.42742 + 1) × 224.81 MPa) / 2
= 297.95 MPa
Perry–Robertson φ
[16] p_c = p_E * p_y / (phi + sqrt(phi^2 - p_E * p_y)) BS 5950-1 Annex C
= 224.81 MPa × 275 MPa / (297.95 MPa + sqrt((297.95 MPa)^2 - 224.81 MPa × 275 MPa))
= 133.78 MPa
Compressive strength
[17] P_c = p_c * A
= 133.78 MPa × 2000 mm²
= 267.56 kN
Compression resistance
[18] u = P / P_c
= 150 kN / 267.56 kN
= 0.56062
Utilisation

5. Results

SYMBOL	VALUE	DESCRIPTION
r	31.623 mm	Radius of gyration
lambda	94.868	Slenderness
p_E	224.81 MPa	Euler stress
P_E	449.62 kN	Euler load
lambda_0	17.155	Limiting slenderness
eta	0.42742	Perry factor
p_c	133.78 MPa	Compressive strength

SYMBOL	VALUE	DESCRIPTION
P_c	267.56 kN	Compression resistance
u	0.56062	Utilisation

6. Checks (governing first)

RESULT	CHECK	DEMAND	CAPACITY	UTILISATION	REF
PASS	Axial load against compression resistance	u = 0.56062	u ≤ 1	0.561	BS 5950-1 Annex C

7. Applicability

No warnings.

8. Verification

Template struct.column-buckling@1.0.0 Content hash 8f5b0ac422d1fc8b Engine calc-engine/1.0.0
Known-answer cases passed 3/3 Test run 2026-10-23 12:00 UTC TempestOS 0.26.0