Solar ESS Co. Ltd.
53 Moo 2 Tambon Nanglae, Amphoe Muang
Chiang Rai 57100, Thailand
Tel 063 151 6694, 089 632 5829
www.solaress.org · LINE: solaress1

SOLAR ESS MONTHLY REPORT · OCTOBER 2026 · SOLISCLOUD · PLANT REPORT


Healthy

Off-grid farm, Chiang Mai


Off-grid · oversized for load

6 kWp · 6 kW hybrid inverter · battery

159	1.11	100%	0.0	0	3.8
kWh solar	kWh/kWp/day	solar share of use	kWh/day bought	kWh exported	kWh/day from battery



24 October, 5-minute data



Daily totals, 1–24 October


What we found

• Off-grid: all load (≈4 kWh/day) on the backup port; battery full by 14:30.
• Low yield (1.1 kWh/kWp/day) only because there is little to power.

What to do

• No action; extra daytime loads can be added freely.

How this plant compares with the other SolisCloud plants (kWh per kWp per day, 1–24 Oct)



Rank 33 of 34 for yield per kWp. Dashed line ≈ 4.0, a typical clear month in the north and centre. A low yield is not always a fault – a full battery or little daytime load makes the inverter throttle the panels.

This plant report is part of the October 2026 SolisCloud fleet review on www.solaress.org (Technical → Monthly Report), which also lists the recommended standard settings. Figures are estimates from monitoring data; site name removed.

SOLAR ESS
www.solaress.org