SOUTHERN POWER DISTRIBUTION COMPANY OF TELANGANA LIMITED (TSSPDCL)
Corporate Office: Mint Compound, Hyderabad - 500063
OFFICE OF THE CHIEF GENERAL MANAGER (COMMERCIAL)

Ref: TSSPDCL/CGM/COM/HT/2026/D-8841 Date: 15-03-2026

To:
M/s Deccan Cloud Infrastructure Private Limited
Survey No. 42/1 & 43, Fab City, Raviryal Village,
Maheshwaram Mandal, Ranga Reddy District, Telangana.

Sub: Electricity - Sanction of HT Power Supply of 50 MW (55.5 MVA) at 220 kV level for Hyperscale Data Centre Campus (Phase 1) - Approval & Demand Note - Accorded.

Ref: Your Online Application Ref: TSSPDCL/HT/APP/2026/0419 dated 10-01-2026.

With reference to your application, technical feasibility report from TSTRANSCO, and approval of the competent authority, sanction is hereby accorded for High Tension Power Supply as detailed:

1. Category: HT Category-I(A) Data Centre Industrial
2. Sanctioned Grid Load: 50.0 MW
3. Contracted Maximum Demand: 55.5 MVA
4. Supply Voltage: 220 kV
5. Interconnection Substation: Fab City 220/33kV GIS Substation (Dedicated Bay)
6. Feeder Voltage: 220 kV (Double Circuit Overhead / UG Line)
7. Power Redundancy Level: Dual Feed (2N Grid Redundancy from Two Independent Bus Sections)
8. Scope of Sanction: Phase 1 Commercial Operations (Target CoD: 30-10-2027)

CONDITIONS OF SANCTION:
a) The consumer shall execute HT Agreement within 30 days of receipt of this letter.
b) The sanction is valid for 24 months from the date of issue (Valid until: 14-03-2028).
c) Dedicated 220 kV metering terminal bay equipment shall be erected at consumer cost.

Yours faithfully,
Chief General Manager (Commercial)
TSSPDCL, Hyderabad