GOVERNMENT OF INDIA
CENTRAL GROUND WATER AUTHORITY (CGWA)
Ministry of Jal Shakti, Department of Water Resources
18/11, Jamnagar House, New Delhi - 110011

NOC No: CGWA/NOC/IND/ORIG/2026/19420 Date: 12-01-2026

NO OBJECTION CERTIFICATE (NOC) FOR GROUND WATER ABSTRACTION

To:
M/s Deccan Cloud Infrastructure Private Limited
Fab City, Ranga Reddy District, Telangana.

1. Category of Assessment Unit: Semi-Critical
2. Purpose of Extraction: Emergency Standby & Potable Uses for Data Centre
3. Permitted Daily Ground Water Withdrawal: 50.0 KLD (Fifty Kilo-Litres per Day)
4. Permitted Annual Quantity: 18,250 m3/year
5. Number of Existing/Proposed Abstraction Structures: 2 Borewells
6. Validity: 3 Years from 12-01-2026 to 11-01-2029

SPECIAL CONDITIONS:
- Continuous digital water meter with telemetry shall be fitted.
- Ground water extraction shall NOT be utilized for regular cooling tower evaporation.
- Artificial recharge to groundwater structures (rainwater harvesting) must achieve minimum 150% recharge.

Member Secretary
Central Ground Water Authority