Samyak

TEST REPORT: 4" 4 DIGIT REMOTE DISPLAY UNIT

Serial No.	2610134100	Model type	SMIT-301L
Mains Power Supply		100VAC/240VAC	
Customer Name	VELTECH		

Logic Supply	5.01
Transmitter Power Supply	20.0
7- Segment Display	OK
Keyboard	OK
Serial RS232/RS485	OK (RS 485)
BAUD RATE	9600
1-RELAY FUNCTION	OK
PASS WORD	0101

1	DISPLAY CARD	OK
2	CPU CARD	OK
3	SMPS	OK

MECHANICAL FITTING
BURN IN TEST CONDUCTED FOR : 48 HOUR
SOFTWARE VERSION : 1.02R

SR.NO	PARAMETER	REMARK
1	PASS (Pass Ward)	0101
2	DP (Decimal Point)	0,1,2,
3	INPUT TYPE	MODBUS, ADC
4	BAUD (Baud Rate)	9600,19200,38400
5	PARITY	EVEN,ODD,NONE
6	UNIT N (Unit No.)	1-255
7	MODBS (Modbus)	MASTER , SLAVE
8	FUNCTION CODE	03, 04
9	REG NO (Register No.)	0-9999
10	DTYPE (Display Type)	S INTE,INTEGER , FLOAT , IFLOAT, LONG, ILONG
11	RES T (Response Time)	0-9999
12	IP ZR(Zero)	0-9999 (FOR ANALOG IP)
13	IP FS (Full Scale)	0-9999 (FOR ANALOG IP)
14	RLY 1(Relay 1)	LOW,HIGH,OFF
15	RLY (Relay 2)	LOW,HIGH,OFF
16	LO SP (Low Set point)	0-9999
17	HI SP (High Set point)	0-9999
18	HYST (Hysteresis)	0-9999

TESTED BY	CHAVDA SUMIRSINH	Date: 29/10/2026
APPROVED BY		Date: 30/10/2026

Samyak Instrumentation Pvt. Ltd.
901, 9th Floor, SKD Surya Icon, 132 Feet Road, AEC Cross Road,
Near Torrent Power Office, Naranpura, Ahmedabad – 380 013.
E-mail: sales@samyak.co.in url: www.samyak.co.in