

Well & Septic Inspection

Rural Property

Well

Flow Rate:	3.2 GPM
Water Quality:	Elevated iron — treatment recommended

Septic

System Type:	Conventional
Condition:	Fair — drain field showing stress
Estimated Remaining Life:	5-8 years
Replacement Cost Estimate:	\$15,000-\$22,000