Impact of renewable energy grid fluctuations

"pull up some research papers on the ill effects of ev power surge at night time and solar power surge at noon that affect the operation of the grid." *Generated by LeapSpace*

Grid Impacts of Nighttime EV Charging and Midday Solar Overgeneration at a Glance

Key Findings Table

Topic	Key finding	Grid level most affected	Evidence
Nighttime EV charging	Uncontrolled overnight charging can raise peak demand, increase feeder loading, worsen voltage deviation, and increase technical losses; coordinated charging reduces these effects [1] [2] [3]	LV feeders, residential feeders, distribution transformers	[1] [2] [3]
EV transformer aging	Uncontrolled charging substantially accelerates transformer thermal aging and loss of life; managed charging can defer replacement [4] [5] [6]	Distribution transformers	[4] [5] [6]
Midday solar surge	High midday PV output commonly causes voltage rise, overvoltage, and reverse power flow, especially on weakly loaded radial feeders [7] [8] [9]	LV feeders, feeder heads, substations	[7] [8] [9]
PV hosting constraints	PV hosting capacity is often limited first by voltage rise, but line overload, congestion, unbalance, and protection issues also matter at higher penetrations [10] [11] [12] [13]	Distribution feeders and protection equipment	[10] [11] [12] [13]

Topic	Key finding	Grid level most affected	Evidence
Combined EV + PV effects	PV can offset some EV demand and reduce transformer stress during the day, but unmanaged charging can still produce overloads and voltage violations on the same feeder [14] [15] [16] [17]	Feeders, transformers, customer nodes	[14] [15] [16] [17]
Mitigation	Smart charging, storage, and inverter control generally reduce stress, but badly designed tariffs or controls can create new off-peak surges, added losses, or overload risks [1] [18] [19] [20] [21] [22]	Distribution and system operations	[1] [18] [19] [20] [21] [22]

Direct Answer

Yes: the supplied research strongly supports the claim that **nighttime EV charging surges** and **midday solar surges** can both harm grid operation, especially on distribution networks [1] [2] [5] [7] [8] [23]. Uncontrolled EV charging at night is linked to higher feeder and transformer loading, more losses, voltage problems, and faster transformer aging [3] [4] [5] [6] [24]. Midday solar overgeneration is linked to overvoltage, reverse power flow, regulator stress, hosting-capacity limits, and curtailment needs [7] [9] [10] [11] [25].

The strongest paper clusters in the supplied evidence are:

- **Night EV surge studies:** feeder overload, voltage deviation, transformer loss-of-life, and managed charging comparisons [1] [2] [3] [4] [5] [6].
- **Noon solar surge studies:** voltage rise, reverse power flow, hosting capacity, inverter control, and curtailment trade-offs [8] [9] [10] [11] [18] [19].
- **Combined EV-PV studies:** same-feeder voltage violations, transformer overload, and coordinated EV-PV scheduling benefits [14] [16] [17] [26].

If your practical goal is grid operation, the evidence points to a simple takeaway: **the first problems usually appear in local feeders and transformers, not as immediate bulk-system collapse**, so utilities need feeder-aware smart charging, PV inverter control, storage, or coordinated EV-PV scheduling rather than relying on uncontrolled adoption [1] [5] [8] [12] [21] [22].

Confidence level: High - the distribution-level stress mechanisms are consistent across many cited studies [1] [3] [5] [7] [10].

Study Scope

This report covers research summarized in the supplied evidence on:

- EV charging impacts on feeders, transformers, and substations [1] [5] [24]
- Midday PV overgeneration, voltage rise, reverse flow, hosting capacity, and inverter control [7] [9] [10] [18]
- Joint EV-PV net-load effects and coordinated scheduling [14] [16] [26]
- System-level scheduling, reserve, and ancillary-service implications, mostly through simulation and optimization studies [27] [28] [29]
- Mitigation strategies including smart charging, TOU tariffs, storage, V2G, and inverter-based controls [21] [22] [30] [31] [32]

Assumptions & Limitations

- The supplied evidence does **not** include full bibliographic metadata such as titles, authors, journals, or DOIs, so this report identifies relevant studies by the provided citation IDs rather than standard references [meta_analisys].
- Evidence on **bulk-system frequency incidents** caused directly by these surges is thinner than evidence on feeder, voltage, and transformer impacts; many system-level findings come from simulation, optimization, or market models rather than operator event reports [28] [33].
- Mitigation outcomes are highly context-dependent: tariff design, feeder topology, PV placement, EV penetration, and charging coincidence strongly affect results [9] [19] [34] [35].

Suggested Further Research

- Joint feeder-to-system studies tracing local EV/PV stress into reserve, dispatch, and frequency needs [28] [33].
- Real-world validation using utility SCADA, AMI, and transformer temperature data [5] [14].
- Apples-to-apples comparisons of V2G, unidirectional smart charging, storage, and inverter controls under one shared test network [36] [37] [38] [39].
- More work on protection and coordination under simultaneous reverse flow and heavy EV loading [12] [13].
- Better tariff-design studies to avoid synchronized overnight charging peaks [1] [20].

Full Report

Foundational Context

Two different surge patterns are at issue:

1. **Nighttime EV charging surge**: many vehicles start charging at similar times, often after people return home or when a TOU window opens, creating coincident demand spikes [1] [40].
2. **Midday solar surge**: PV output peaks near noon when local load may be low, creating excess generation relative to local demand [7] [8].

These are operationally important because distribution networks are designed around limits on **thermal loading**, **voltage magnitude**, **power flow direction**, and **equipment duty cycles** [2] [12] [13]. EV surges mostly stress the grid by adding load; solar surges mostly stress it by injecting power where load is insufficient to absorb it locally [1] [8]. Taken together, these findings suggest the two problems are mirror-image net-load disturbances: one is a load spike, the other a generation spike [26] [41] [42].

Confidence level: High - this framing is repeatedly supported across EV, PV, and joint-integration studies [1] [8] [16].

1. Nighttime EV Charging: Distribution-Network Impacts

1.1 Peak coincidence, feeder overload, and voltage deviation

The clearest finding is that **uncontrolled nighttime EV charging can coincide with residential demand peaks** and materially raise feeder stress [1] [3]. On an 11-kV residential feeder, uncontrolled charging increased maximum demand, I^2R losses, and voltage deviations; shifting charging to 22:00-06:00 reduced peak coincidence but could create a new late-night surge, while coordinated charging flattened the profile and reduced thermal stress [1]. Across 21 real low-voltage grids, uncontrolled EV charging caused mostly mild overloads but also some critical congestion, with suburban grids most vulnerable and transformer/line loading the main indicators [3]. On an IEEE 55-bus LV feeder, 50% uncontrolled charging significantly increased transformer loading and energy losses, while controlled charging kept conditions within normal limits [2].

Longer-horizon work reinforces the same point: uncoordinated charging is projected to cause significant overloading and bus-voltage violations, with customer transformers especially affected [24]. In an Argentine LV network, unmanaged charging caused unacceptable technical losses and problematic power-flow conditions, while postponing charging to late night improved feasibility because the network was less loaded then [35].

A key nuance is that **timing matters more than EV technology alone** [1] [34]. TOU or default charging windows can help, but they can also synchronize many users and create secondary peaks [1].

Confidence level: High - multiple feeder studies converge on the same operational impacts [1] [2] [3] [24] [35].

1.2 Transformer loading and loss of life

Transformer impacts are among the most quantitatively mature parts of the EV literature [4] [5] [6]. Detailed thermal-aging studies show uncontrolled charging raises hotspot temperatures and accelerates insulation aging [5]. On the IEEE European LV Test Feeder, uncontrolled 100% EV charging raised hottest-spot temperature to 261.9 C, versus below 102.7 C under controlled charging, and the top-oil limit was exceeded at 40% penetration without coordination [5]. Another residential-transformer study found Level 2 uncontrolled charging made a 37.5 kVA transformer age 26 times faster for PHEVs and 121 times faster for BEVs over 24 hours, whereas smart charging mitigated the impact and reduced the need for earlier replacement [4]. A transactive charging study found EV penetration increased transformer loss-of-life by at least 5.6 times for a 630 kVA unit, while the managed scheme avoided replacing an 800 kVA transformer with a 1000 kVA unit [6].

These results imply that EV night surges are not only a peak-load problem but also an **asset-aging problem** [4] [5]. That distinction matters for utility planning because even when overloads are infrequent, thermal aging can still shorten asset life [43] [44].

Confidence level: High - the studies use explicit hotspot and insulation-aging models and report large effect sizes [4] [5] [6].

1.3 Foundational control approaches

Foundational EV studies consistently treat charging as a **load-shaping problem** [40] [45] [46]. Coordinated, decentralized, stochastic, and real-time methods were proposed early to flatten demand, improve load factor, and keep charging within feeder limits [40] [47] [48] [49]. The core lesson remains current: uncontrolled nighttime charging creates local distribution problems, while managed charging is the primary mitigation [40] [46] [50].

2. Midday Solar PV Overgeneration: Operational Stress on Grids

2.1 Voltage rise and reverse power flow

The strongest solar-side evidence concerns **midday voltage rise and reverse power flow** [7] [8] [9]. Feeder-level and LV studies consistently find that high rooftop PV penetration causes overvoltage and export upstream, especially under low-load conditions [7] [8] [9] [51]. Weakly loaded feeders are especially vulnerable because low daytime demand leaves little local absorption for PV output [8] [9] [52]. Time-series studies report that midday irradiance produces the most severe overvoltage on lightly loaded nodes and can degrade voltage stability or power quality even when feeder loading itself falls [9] [53].

Network topology matters: rural, suburban, and urban LV networks show different hosting capacities and different sensitivities to feeder length and transformer distance [54] [55] [56]. Unbalanced single-phase rooftop PV can hit voltage-unbalance constraints before thermal limits [56].

Confidence level: High - this is one of the most repeated findings in the PV literature [7] [8] [9] [10].

2.2 Hosting capacity and equipment constraints

PV hosting capacity is often limited first by overvoltage on radial LV feeders, but not only by voltage [10] [11]. Several studies show that conductor ampacity, line overload, congestion, and equipment interactions can become binding constraints [11] [12]. High PV penetration also interacts with OLTCs, regulators, capacitor banks, and tap operations, increasing control duty and equipment stress [23] [57] [58] [59]. Reviews also identify protection and coordination issues such as fuse coordination, recloser coordination, and fault-detection complications [13].

So the “ill effect” of noon solar surge is broader than curtailment alone: it can alter normal power-flow direction, push voltages above limits, and force more frequent operation of network-control equipment [12] [13] [23].

Confidence level: High - evidence covers both analytical hosting-capacity studies and broader distribution reviews [10] [12] [13].

2.3 Curtailment and inverter-control trade-offs

Mitigation is effective but not free [18] [19] [25]. Volt/Var and Volt/Watt controls often limit curtailment to relatively small levels; one review reports less than 2% weekly curtailment for most customers and below 2% annual curtailment at 100% PV penetration, while also noting higher power flows and transformer overload risk under Volt/Var control [18]. Active-power curtailment mitigates overvoltage but reduces energy yield; one urban LV study observed maximum curtailment of 2.3% of total daily PV output while significantly reducing voltage fluctuations [25]. Fixed power factor control may create unnecessary losses through reactive power absorption, while alternative control modes can reduce the amount of active curtailment needed [19] [60].

This is a central contradiction in the literature: **the same control that solves one operational problem can worsen another** [18] [19]. For example, Volt/Var can improve voltage compliance but increase flows or overload risk, while fixed PF can reduce voltage rise but increase losses [18] [19].

Confidence level: High - several studies explicitly quantify these trade-offs [18] [19] [25] [60].

3. Coupled EV and Solar Penetration: Net-Load Variability and Reliability

Studies increasingly analyze EVs and solar as interacting resources rather than separate problems [15] [26] [61] [62]. Combined adoption on the same LV feeder can create simultaneous overvoltage from PV and overload from EV charging [16] [17]. The Malta case explicitly reports concurrent unfavorable conditions, and a 2025 multi-correlation framework found voltage violations rising to 15.4% with 20% PV/EV penetration alongside high loading [16] [17].

At the same time, PV can offset some EV-induced stress [14] [15] [63]. Monte Carlo and quasi-static studies show unmanaged EV charging increases transformer loading, while PV can partially reduce daytime demand and transformer stress [14] [15]. Rooftop PV has been shown to lower substation demand and system losses, and to mitigate transformer heating caused by EV charging [15] [61] [62].

Coordinated operation performs better than uncoordinated operation. Studies comparing both cases report reduced voltage problems, lower active-power losses, improved node-voltage deviation, lower transformer loading, and better mutual consumption of PV generation by EV charging when coordination is used [26] [64] [65]. A baseline uncoordinated EV/PV scenario is described as causing distribution constraint violations that PV alone only partially mitigates [66].

Taken together, these findings suggest a practical strategy: **daytime EV charging aligned with solar output can convert a noon generation problem into a local demand sink**, but this does not remove the need to manage overnight charging separately [26] [41] [42].

Confidence level: High - the direction of effect is consistent, though exact benefit depends on penetration, charger mix, and coordination design [14] [26] [66].

4. System-Level Scheduling, Frequency, and Reserve Implications

The evidence base is stronger on feeder and transformer impacts than on observed bulk-system frequency events [28] [33]. Still, simulation and market studies indicate that coordinated EV charging with solar can reduce ramping, flatten peaks, absorb midday surplus, and support ancillary services [67] [68] [69] [70]. Large EV fleets scheduled under integrated TOU and demand-response frameworks can participate in energy and regulation markets [27]. Early and later ancillary-service literature argues EVs and V2G are particularly well suited for short-response services such as regulation, spinning reserve, and balancing [71] [72] [73] [74].

On the solar side, one study explicitly states that solar variability creates intra-dispatch imbalances and morning/evening ramping that should be treated separately to reduce the burden on frequency regulation services [28]. This suggests the main system-level issue is not just average surplus energy but **ramping and balancing requirement** [28] [75].

However, the report must be careful: direct operator-grade evidence tying these local surges to measured frequency incidents is limited in the supplied material [28] [33].

Confidence level: Medium - the scheduling and reserve logic is well supported by models, but empirical bulk-system validation is thinner [27] [28] [29].

5. Mitigation Strategies and Measured Effectiveness

5.1 Smart and managed EV charging

Smart charging and V2G consistently reduce peak demand, congestion, losses, and voltage stress in distribution networks [21] [22] [30] [76] [77] [78]. California scenarios indicate managed charging can avoid substantial annual operating costs and defer infrastructure expansion, though overnight TOU charging may increase curtailment [79]. This reinforces the broader warning that **simple load shifting is not enough if everyone shifts to the same hour** [1] [20].

5.2 Storage and hybrid EV-PV coordination

Combining smart charging with solar PV and/or storage is generally more effective than smart charging alone for self-consumption, congestion relief, and peak shaving [21] [22] [31] [32] [34]. Simulation using real fleet patterns found solar PV and hybrid PV+wind reduced annual grid demand by 24% and lowered peak demand, though not the peak hour itself [34]. Storage is repeatedly modeled as a way to absorb midday PV surplus and shift it to higher-value periods [8] [22] [80] [81].

5.3 Control design, tariffs, and forecasting

Forecast-aware scheduling and real-time voltage signals improve coordination with local grid conditions [76] [82] [83] [84]. Demand-response and tariff-based approaches can shift substantial EV load away from peak periods, but effectiveness depends on participation and baseline load, and some tariffs create new peaks [31] [85] [86]. For PV, inverter controls improve hosting capacity and voltage compliance, but their side effects must be evaluated on the same feeder rather than assumed away [18] [19].

One notable evidence gap remains: no retrieved full-text study in the supplied set directly compares **bidirectional V2G, unidirectional smart charging, and inverter-based control** under the same network and metric set [36] [37] [38] [39].

Confidence level: High - the direction of mitigation benefit is robust, though the best mix is system-specific [18] [21] [22] [31].

Conclusion

The supplied research supports a clear operational picture. **Night EV surges** mainly create overload, losses, and transformer-aging problems; **noon solar surges** mainly create overvoltage, reverse-flow, and control-equipment stress [2] [5] [7] [10]. These effects show up first and most reliably in distribution assets rather than as immediate bulk-grid failures [1] [3] [8] [12]. Coordinated EV charging, storage, and smart inverter controls usually help, but poorly designed TOU tariffs or control settings can simply move the problem to another hour or another device [1] [19] [20] [22].

For decision-making, the strongest practical implication is: **treat nighttime EV load spikes and midday solar export spikes as linked net-load management problems, and solve them with feeder-aware coordination rather than one-size-fits-all tariffs or controls** [21] [22] [26] [41] [42].

Overall confidence level: High - strong on distribution-level impacts and mitigation direction; **Medium** on direct bulk-system frequency-event evidence [1] [5] [8] [28].

References

1. Habib, M.I. (2025) Impact of Residential and Public EV Charging Stations on Distribution Feeder Performance: Uncontrolled vs TOU vs Coordinated Charging. *Jordan Journal of Electrical Engineering*. https://doi.org/10.5455/jjee.204-1757627413
2. Shambharkar, R.V., Phadke, A.R. (2024) Impact Analysis Of Plug In Electric Vehicle On Low Voltage Distribution Network. *2024 4th International Conference on Emerging Frontiers in Electrical and Electronic Technologies, ICEFEET 2024*. https://doi.org/10.1109/ICEFEET64463.2024.10867122
3. Yu, Y., Reihs, D., Wagh, S., (...), Bauer, P. (2022) Data-Driven Study of Low Voltage Distribution Grid Behaviour with Increasing Electric Vehicle Penetration. *IEEE Access*. https://doi.org/10.1109/ACCESS.2021.3140162
4. Razeghi, G., Zhang, L., Brown, T., Samuelsen, S. (2014) Impacts of plug-in hybrid electric vehicles on a residential transformer using stochastic and empirical analysis. *Journal of Power Sources*. https://doi.org/10.1016/j.jpowsour.2013.11.089
5. Burmester, D., Brent, A. (2027) Grid integration of bidirectional dynamic wireless charging for electric vehicles: A review on grid-side challenges and opportunities. *Applied Energy*. https://doi.org/10.1016/j.apenergy.2026.128888
6. Saber, H., Ranjbar, H., Ehsan, M., Anvari-Moghaddam, A. (2022) Transactive charging management of electric vehicles in office buildings: A distributionally robust chance-constrained approach. *Sustainable Cities and Society*. https://doi.org/10.1016/j.scs.2022.104171
7. Dos Reis, F.B., Duwadi, K., Foutney, R., (...), Paudyal, S. (2019) Impact of residential load models for overvoltage prevention studies in PV-Rich LV grids. *2019 IEEE Milan PowerTech, PowerTech 2019*. https://doi.org/10.1109/PTC.2019.8810636
8. Shamshiri, M., Gan, C.K., Sardi, J., (...), Tee, W.H. (2020) Design of battery storage system for Malaysia low voltage distribution network with the presence of residential solar photovoltaic system. *Energies*. https://doi.org/10.3390/en13184887
9. Valdez, J., García, E., Aguila Téllez, A., Carrión, D. (2025) Quasi-Dynamic Evaluation of High Solar PV Penetration Effects on Voltage Stability and Power Quality in Unbalanced Distribution Networks. *Energies*. https://doi.org/10.3390/en18215809
10. Tonkoski, R., Lopes, L.A.C., El-Fouly, T.H.M. (2011) Coordinated active power curtailment of grid connected PV inverters for overvoltage prevention. *IEEE Transactions on Sustainable Energy*. https://doi.org/10.1109/TSTE.2010.2098483

11. Shayani, R.A., Oliveira, M.A.G. (2011) Photovoltaic generation penetration limits in radial distribution systems. *IEEE Transactions on Power Systems*. https://doi.org/10.1109/TPWRS.2010.2077656

12. Navarro-Espinosa, A., Ochoa, L.F. (2016) Probabilistic Impact Assessment of Low Carbon Technologies in LV Distribution Systems. *IEEE Transactions on Power Systems*. https://doi.org/10.1109/TPWRS.2015.2448663

13. Walling, R.A., Saint, R., Dugan, R.C., (...), Kojović, L.A. (2008) Summary of distributed resources impact on power delivery systems. *IEEE Transactions on Power Delivery*. https://doi.org/10.1109/TPWRD.2007.909115

14. Palomino, A., Parvania, M. (2020) Data-driven risk analysis of joint electric vehicle and solar operation in distribution networks. *IEEE Open Access Journal of Power and Energy*. https://doi.org/10.1109/OAJPE.2020.2984696

15. Mogos, A.S., Liang, X., Chung, C.Y. (2023) Impact of Plug-in Electric Vehicle Charging and Roof-top PVs on Distribution Transformer Health: A Case Study in Saskatoon, Canada. *Canadian Conference on Electrical and Computer Engineering*. https://doi.org/10.1109/CCECE58730.2023.10288896

16. Azzopardi, B., Gabdullin, Y. (2024) Assessing Combined High Photovoltaic and Electric Vehicle Charging Penetration in Low-Voltage Distribution Networks: A Case Study in Malta. *Energies*. https://doi.org/10.3390/en17010263

17. Zhu, J., Xia, Y., Gu, W., (...), Feng, G. (2025) Power Flow Analysis of Distribution Network Based on Multivariate Power Correlation Analysis. *2025 7th International Academic Exchange Conference on Science and Technology Innovation, IAECST 2025*. https://doi.org/10.1109/IAECST68792.2025.11415158

18. Rajabi, A., Elphick, S., David, J., (...), Robinson, D. (2022) Innovative approaches for assessing and enhancing the hosting capacity of PV-rich distribution networks: An Australian perspective. *Renewable and Sustainable Energy Reviews*. https://doi.org/10.1016/j.rser.2022.112365

19. Abo Alwez, M.A., Jasni, J., MohdRadzi, M.A., Azis, N. (2025) Adaptive reactive power control for voltage rise mitigation on distribution network with high photovoltaic penetration. *Renewable and Sustainable Energy Reviews*. https://doi.org/10.1016/j.rser.2024.114948

20. Yang, Y., Yang, S., Moon, H., Woo, J. (2024) Analyzing heterogeneous electric vehicle charging preferences for strategic time-of-use tariff design and infrastructure development: A latent class approach. *Applied Energy*. https://doi.org/10.1016/j.apenergy.2024.124074

21. Marcolin, P., Cazzaniga, A., Salamone, S., Mauri, G. (2025) EV SMART CHARGING STRATEGIES FOR REDUCED OPERATING COSTS AND GRID IMPACT: A CASE STUDY ON WORKPLACE CHARGING INFRASTRUCTURE. *IET Conference Proceedings*. https://doi.org/10.1049/icp.2025.2137

22. Khalid, M., Thakur, J., Mothilal Bhagavathy, S., Topel, M. (2024) Impact of public and residential smart EV charging on distribution power grid equipped with storage. *Sustainable Cities and Society*. https://doi.org/10.1016/j.scs.2024.105272

23. Carvalho, P.M.S., Correia, P.F., Ferreira, L.A.F.M. (2008) Distributed reactive power generation control for voltage rise mitigation in distribution networks. *IEEE Transactions on Power Systems*. https://doi.org/10.1109/TPWRS.2008.919203

24. Gosnell, M., Baran, M., Tang, W. (2024) Evaluating Long-Term Residential EV Charging Impacts on Distribution Systems. *2024 56th North American Power Symposium, NAPS 2024*. https://doi.org/10.1109/NAPS61145.2024.10741742

25. Visser, L.R., Schuurmans, E.M.B., Alskaif, T.A., (...), Van Sark, W.G.J.H.M. (2022) Regulation strategies for mitigating voltage fluctuations induced by photovoltaic solar systems in an urban low voltage grid. *International Journal of Electrical Power and Energy Systems*. https://doi.org/10.1016/j.ijepes.2021.107695

26. Ji, Y., Zhang, J., Li, S., (...), Mu, Y. (2023) Electric vehicles acceptance capacity evaluation in distribution network considering photovoltaics access. *Energy Reports*. https://doi.org/10.1016/j.egyr.2022.11.083

27. Sharma, S., Jain, P. (2020) Integrated TOU price-based demand response and dynamic grid-to-vehicle charge scheduling of electric vehicle aggregator to support grid stability. *International Transactions on Electrical Energy Systems*. https://doi.org/10.1002/2050-7038.12160

28. Raj, R.P., Kowli, A., Sai Rupa, V. (2020) Evaluating the ramping trends and noisy fluctuations from solar power imbalances. *2020 IEEE International Conference on Power Systems Technology, POWERCON 2020*. https://doi.org/10.1109/POWERCON48463.2020.9230567

29. Dejkam, R., Madlener, R. (2025) Green mobility infrastructure: A techno-economic analysis of hybrid wind–solar PV charging stations for electric vehicles in Germany. *Energy*. https://doi.org/10.1016/j.energy.2025.137450

30. Sammut, N., Rabiul Islam, M.R. (2020) Advanced Control Technique for a Smart Bidirectional Electric Vehicle Charger Using Information from the National Electricity Market of Australia. *2020 Australasian Universities Power Engineering Conference, AUPEC 2020 - Proceedings*. https://www.scopus.com/pages/publications/85101690907

31. Nutkani, I., Toole, H., Wilkinson, R.H., Bui, M.B. (2025) Assessment of Classical Demand Management Strategies and Batteries for Electric Vehicle Impact Mitigation in Distribution Networks. *Smart Grids and Sustainable Energy*. https://doi.org/10.1007/s40866-024-00235-z

32. Rutgers, A. (2022) Combining Energy Storage with EV Fleet Charging. *IET Conference Proceedings*. https://doi.org/10.1049/icp.2022.2709

33. Wu, X., Hu, X., Moura, S., (...), Pickert, V. (2016) Stochastic control of smart home energy management with plug-in electric vehicle battery energy storage and photovoltaic array. *Journal of Power Sources*. https://doi.org/10.1016/j.jpowsour.2016.09.157

34. Yu, D., Adhikari, M.P., Guiral, A., (...), Raahemifar, K. (2019) The Impact of Charging Battery Electric Vehicles on the Load Profile in the Presence of Renewable Energy. *2019 IEEE Canadian Conference of Electrical and Computer Engineering, CCECE 2019*. https://doi.org/10.1109/CCECE.2019.8861730

35. Jurado, A., Vinson, E., Nicchi, F. (2024) Stochastic study of the connection of electric vehicles in Argentine low voltage networks. *Ingeniare*. https://doi.org/10.4067/s0718-33052024000100246

36. Parray, M.T., Martinsen, T., Jåstad, E.O. (2026) Optimizing smart and bidirectional charger allocation in a behind-the-meter setting: a real-world data-driven Norwegian case study for growing electric vehicle adoption. *Journal of Energy Storage*. https://doi.org/10.1016/j.est.2025.119615

37. Hartvigsson, E., Taljegard, M., Odenberger, M., Chen, P. (2022) A large-scale high-resolution geographic analysis of impacts of electric vehicle charging on low-voltage grids. *Energy*. https://doi.org/10.1016/j.energy.2022.125180

38. https://www.sciencedirect.com/science/article/pii/S252089422500070X

39. Liang, X., Lou, D., Lu, Z., (...), Ye, B. (2026) Bidirectional V2G enhances wind and solar integration in China's 2030 sector coupled energy system. *Renewable Energy*. https://doi.org/10.1016/j.renene.2026.125944

40. Clement-Nyns, K., Haesen, E., Driesen, J. (2010) The impact of Charging plug-in hybrid electric vehicles on a residential distribution grid. *IEEE Transactions on Power Systems*. https://doi.org/10.1109/TPWRS.2009.2036481

41. Denholm, P., Kuss, M., Margolis, R.M. (2013) Co-benefits of large scale plug-in hybrid electric vehicle and solar PV deployment. *Journal of Power Sources*. https://doi.org/10.1016/j.jpowsour.2012.10.007

42. Kurth, M., Meyer, M., Vertgewall, C.M., (...), Pletzer, T. (2022) INVESTIGATING THE IMPACT OF ELECTRIC VEHICLE CHARGING AND PHOTOVOLTAIC SYSTEMS ON A RURAL AND A SUBURBAN LOW-VOLTAGE GRID. *IET Conference Proceedings*. https://doi.org/10.1049/icp.2022.0769

43. El-Batawy, S.A., Basta, B., Morsi, W.G. (2018) Impact of Integrating Electric Vehicles and Rooftop Solar Photovoltaic on Transformer's Aging Considering the Effect of Ambient Temperature. *2018 IEEE Electrical Power and Energy Conference, EPEC 2018*. https://doi.org/10.1109/EPEC.2018.8598330

44. Khalid, M., Ahmad, F., Panigrahi, B.K., Al-Fagih, L. (2022) A comprehensive review on advanced charging topologies and methodologies for electric vehicle battery. *Journal of Energy Storage*. https://doi.org/10.1016/j.est.2022.105084

45. Gan, L., Topcu, U., Low, S.H. (2013) Optimal decentralized protocol for electric vehicle charging. *IEEE Transactions on Power Systems*. https://doi.org/10.1109/TPWRS.2012.2210288

46. Clement-Nyns, K., Haesen, E., Driesen, J. (2009) Coordinated charging of multiple plug-in hybrid electric vehicles in residential distribution grids. *2009 IEEE/PES Power Systems Conference and Exposition, PSCE 2009*. https://doi.org/10.1109/PSCE.2009.4839973

47. Sortomme, E., Hindi, M.M., MacPherson, S.D.J., Venkata, S.S. (2011) Coordinated charging of plug-in hybrid electric vehicles to minimize distribution system losses. *IEEE Transactions on Smart Grid*. https://doi.org/10.1109/TSG.2010.2090913

48. Deilami, S., Masoum, A.S., Moses, P.S., Masoum, M.A.S. (2011) Real-time coordination of plug-in electric vehicle charging in smart grids to minimize power losses and improve voltage profile. *IEEE Transactions on Smart Grid*. https://doi.org/10.1109/TSG.2011.2159816

49. Richardson, P., Flynn, D., Keane, A. (2012) Optimal charging of electric vehicles in low-voltage distribution systems. *IEEE Transactions on Power Systems*. https://doi.org/10.1109/TPWRS.2011.2158247

50. Kelly, L., Rowe, A., Wild, P. (2009) Analyzing the impacts of plug-in electric vehicles on distribution networks in British Columbia. *2009 IEEE Electrical Power and Energy Conference, EPEC 2009*. https://doi.org/10.1109/EPEC.2009.5420904

51. Parajeles, M.J., Quirós-Tortós, J., Valverde, G. (2017) Assessing the performance of smart inverters in large-scale distribution networks with PV systems. *2017 IEEE PES Innovative Smart Grid Technologies Conference - Latin America, ISGT Latin America 2017*. https://doi.org/10.1109/ISGT-LA.2017.8126752

52. Tévar Bartolomé, G., Gomez-Exposito, A., Arcos-Vargas, A., Rodríguez Montañés, M. (2019) Influence of rooftop PV generation on net demand, losses and network congestions: A case study. *International Journal of Electrical Power and Energy Systems*. https://doi.org/10.1016/j.ijepes.2018.09.013

53. Rahman, O., Muttaqi, K.M., Sutanto, D. (2019) Time Series Variations of the Neutral-to-Ground Potential in a 4-Wire LV Network under Unbalanced Allocation of Rooftop Solar PV and Mitigation using Energy Storage. *IEEE Power and Energy Society General Meeting*. https://doi.org/10.1109/PESGM40551.2019.8973544

54. Puvi, V., Lehtonen, M. (2023) Evaluating distribution network optimal structure with respect to solar hosting capacity. *Electric Power Systems Research*. https://doi.org/10.1016/j.epsr.2022.109019

55. Fatima, S., Puvi, V., Lehtonen, M. (2021) Comparison of Different References When Assessing PV HC in Distribution Networks. *Clean Technologies*. https://doi.org/10.3390/cleantechnol3010008

56. Lucas, A. (2018) Single-phase PV power injection limit due to voltage unbalances applied to an urban reference network using real-time simulation. *Applied Sciences (Switzerland)*. https://doi.org/10.3390/app8081333

57. Liu, X., Aichhorn, A., Liu, L., Li, H. (2012) Coordinated control of distributed energy storage system with tap changer transformers for voltage rise mitigation under high photovoltaic penetration. *IEEE Transactions on Smart Grid*. https://doi.org/10.1109/TSG.2011.2177501

58. Long, C., Ochoa, L.F. (2016) Voltage control of PV-rich LV networks: OLTC-fitted transformer and capacitor banks. *IEEE Transactions on Power Systems*. https://doi.org/10.1109/TPWRS.2015.2494627

59. Tonkoski, R., Lopes, L.A.C. (2008) Voltage regulation in radial distribution feeders with high penetration of photovoltaic. *2008 IEEE Energy 2030 Conference, ENERGY 2008*. https://doi.org/10.1109/ENERGY.2008.4781021

60. Perera, B., Ciufo, P., Perera, S. (2016) Advanced point of common coupling voltage controllers for grid-connected solar photovoltaic (PV) systems. *Renewable Energy*. https://doi.org/10.1016/j.renene.2015.09.028

61. Modi, H., Saxena, D., Chauhan, R.K. (2021) Impact of Solar PV on Distribution Systems Embedded with Electric Vehicle. *Proceedings - 2021 International Conference on Control, Automation, Power and Signal Processing, CAPS 2021*. https://doi.org/10.1109/CAPS52117.2021.9730655

62. Dávila-Sacoto, M., Hernández-Callejo, L., González, L.G., (...), Ochoa, D. (2024) Heterogeneous Communication Network Architecture for the Management of Electric Vehicle Charging Stations: Multi-Aggregator Management in Microgrids with High Photovoltaic Variability Based on Multiple Solar Radiation Sensors. *Sensors*. https://doi.org/10.3390/s24123768

63. de Melo, R.F., de Souza D'Oliveira, L., Santana, C.E.S.D., Borba, B.S.M.C. (2018) Evaluation of a distribution transformer impacts considering electric vehicles and distributed generation. *SBSE 2018 - 7th Brazilian Electrical Systems Symposium*. https://doi.org/10.1109/SBSE.2018.8395644

64. Rashid, T.H.M.S., Refat, K.A., Islam, M.N., (...), Ali, M.F. (2026) Machine learning-driven PV forecasting and coordinated PV–BESS dispatch for optimizing distribution grid performance under high EV penetration. *Energy Conversion and Management: X*. https://doi.org/10.1016/j.ecmx.2025.101418

65. Fretzen, U., Ansarin, M., Brandt, T. (2021) Temporal city-scale matching of solar photovoltaic generation and electric vehicle charging. *Applied Energy*. https://doi.org/10.1016/j.apenergy.2020.116160

66. Chaouachi, A., Bompard, E., Fulli, G., (...), Paffumi, E. (2016) Assessment framework for EV and PV synergies in emerging distribution systems. *Renewable and Sustainable Energy Reviews*. https://doi.org/10.1016/j.rser.2015.09.093

67. Fan, L., Chen, Y., Zhang, D. (2025) A Microgrid Vehicle-to-Grid Energy Scheduling Optimization Algorithm Based on Non-Dominated Sorting Genetic Algorithm II. *SAE Technical Papers*. https://doi.org/10.4271/2025-01-5035

68. Schwarz, M., Auzepy, Q., Knoeri, C. (2020) Can electricity pricing leverage electric vehicles and battery storage to integrate high shares of solar photovoltaics?. *Applied Energy*. https://doi.org/10.1016/j.apenergy.2020.115548

69. Powell, S., Cezar, G.V., Min, L., (...), Rajagopal, R. (2022) Charging infrastructure access and operation to reduce the grid impacts of deep electric vehicle adoption. *Nature Energy*. https://doi.org/10.1038/s41560-022-01105-7

70. Verma, H.K., Gupta, N., Agrawal, P.K., (...), Swamkar, A. (2024) Coordinated Electric Vehicle Charging Strategy for Self-Sustained Office Parking Lots. *Proceedings of the IEEE Power India International Conference, PIICON*. https://doi.org/10.1109/PIICON63519.2024.10995126

71. Kempton, W., Tomić, J. (2005) Vehicle-to-grid power fundamentals: Calculating capacity and net revenue. *Journal of Power Sources*. https://doi.org/10.1016/j.jpowsour.2004.12.025

72. Kempton, W., Tomić, J. (2005) Vehicle-to-grid power implementation: From stabilizing the grid to supporting large-scale renewable energy. *Journal of Power Sources*. https://doi.org/10.1016/j.jpowsour.2004.12.022

73. Tomić, J., Kempton, W. (2007) Using fleets of electric-drive vehicles for grid support. *Journal of Power Sources*. https://doi.org/10.1016/j.jpowsour.2007.03.010

74. Alipour, M., Mohammadi-ivatloo, B., Moradi-Dalvand, M., Zare, K. (2017) Stochastic scheduling of aggregators of plug-in electric vehicles for participation in energy and ancillary service markets. *Energy*. https://doi.org/10.1016/j.energy.2016.10.141

75. Lannoye, E., Flynn, D., O'Malley, M. (2012) Evaluation of power system flexibility. *IEEE Transactions on Power Systems*. https://doi.org/10.1109/TPWRS.2011.2177280

76. Brinkel, N., Visser, L., Alskaif, T., Van Sark, W. (2021) Avoiding low-voltage grid congestion using smart charging of electric vehicles based on day-ahead probabilistic photovoltaic forecasts. *SEST 2021 - 4th International Conference on Smart Energy Systems and Technologies*. https://doi.org/10.1109/SEST50973.2021.9543447

77. Spencer, S.I., Fu, Z., Apostolaki, E., Lipman, T.E. (2021) Evaluating smart charging strategies using real-world data from optimized plugin electric vehicles. *Transportation Research Part D: Transport and Environment*. https://doi.org/10.1016/j.trd.2021.103023

78. Mitsukuri, Y., Hara, R., Kita, H., (...), Kogure, E. (2012) Validation of voltage regulation method in distribution system utilizing electric vehicles. *IEEE PES Innovative Smart Grid Technologies Conference Europe*. https://doi.org/10.1109/ISGTEurope.2012.6465816

79. Szinai, J.K., Sheppard, C.J.R., Abhyankar, N., Gopal, A.R. (2020) Reduced grid operating costs and renewable energy curtailment with electric vehicle charge management. *Energy Policy*. https://doi.org/10.1016/j.enpol.2019.111051

80. Ueda, Y. (2013) Analysis result of voltage rise and simulations of battery integration for residential PV systems. *Proceedings of the SICE Annual Conference*. https://www.scopus.com/pages/publications/84888586162

81. Carigiet, F., Niedrist, M., Scheuermann, C., Baumgartner, F. (2016) Case study of a low-voltage distribution grid with high PV penetration in Germany and simulation analyses of cost-effective measures. *Progress in Photovoltaics: Research and Applications*. https://doi.org/10.1002/pip.2710

82. Forkaliuk, M.S., Franzl, G., Treytl, A. (2026) Simulating the Contribution of Smart EV Charging and PV Curtailment to Grid Congestion Mitigation1. *Energy Proceedings*. https://www.scopus.com/pages/publications/105034287517

83. Forkaliuk, M.S., Franzl, G., Treytl, A. (2026) Simulating the Contribution of Smart EV Charging and PV Curtailment to Grid Congestion Mitigation. *Energy Proceedings*. https://doi.org/10.46855/energy-proceedings-12139

84. Yu, D., Adhikari, M.P., Fung, A.S., (...), Mohammadi, F. (2026) Integration of renewable energy of solar PV and wind for the optimal charging and discharging of plug-in electric vehicles. *Solar Compass*. https://doi.org/10.1016/j.solcom.2026.100166

85. Steren, A., Parag, Y., Teschner, N., Zemah-Shamir, S. (2025) Consumer preferences and willingness to pay for EV charging: Implications for incentives to promote off-peak charging and renewables integration. *Applied Energy*. https://doi.org/10.1016/j.apenergy.2025.125981

86. Sengor, I., Erenoğlu, A.K., Erdinç, O., (...), Catalão, J.P.S. (2018) Optimal coordination of EV charging through aggregators under peak load limitation based DR considering stochasticity. *2018 International Conference on Smart Energy Systems and Technologies, SEST 2018 - Proceedings*. https://doi.org/10.1109/SEST.2018.8495696