

## PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. ACTX XI of 1860Date: 6/5/2026

It is certified that an inspection team headed by Dr. Mohan Singh Dogra (Name of officers with designation) from COMMUNITY HEALTH CENTER SAHASPUR (Name of Department/office) inspected the 5/5/2026 TIBTEN CHILDREN'S VILLAGE SCHOOL (Name and address of the School) on 5/5/2026 and found <sup>Satisfactory</sup> that the TIBTEN CHILDREN VILLAGE SCHOOL SELAQUI DEHRADUN (Name of School) has safe drinking water facilities for the students and members of staff of the institution and is maintain the hygienic sanitation conditions in the School building and the campus as per the norms prescribed by the Central /State/UT Govt.

This Certificate is valid for a period of \_\_\_\_\_

Signature with Seal : \_\_\_\_\_

Name

: DR. MOHAN SINGH DOGRA

Designation

: MEDICAL SUPERINTENDENT

To

THE PRINCIPAL
TIBTEN CHILDREN VILLAGE  
SCHOOL SELAQUI DEHRADUN

(Name and address of the Institution)


चिकित्सा अधीक्षक  
सामुहिक स्वास्थ्य केन्द्र  
सहसपुर

## SANITARY CERTIFICATE

Inspected the TIBETAN CHILDREN'S VILLAGE SCHOOL SELAKUI Building at Dhoolkot, Chakrata Road, Dehradun Uttarakhand and found that the management arrange sufficient building including playground. The Building have sufficient ventilation, lighting, drinking water and water supply, urinals and lavatories are arranged separately for boys and girls and maintained clean and comfortable. The institution sanitary condition is good.

Place: Dhoolkot (Dehradun)

Date:



चिकित्सा अधीक्षक  
सामु० स्वा० केन्द्र  
सहसपुर



**District Level Water Quality Testing and Monitoring Laboratory**  
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun



TC-13625

**TEST REPORT**

|                                               |                                                                    |                      |                                   |
|-----------------------------------------------|--------------------------------------------------------------------|----------------------|-----------------------------------|
| Name and Address of Organization/<br>Customer | Tibetan Children's Village School, Selaqui, Dehradun, Uttarakhand. |                      |                                   |
| Test Report ID                                | 30/UJS/DLWQTML/2026-27                                             | Reporting Date       | 23/04/2026                        |
| Date and Time of Sample Received:             | 21/04/26 & 10:20 AM                                                | Sample Location      | Selaqui, Dehradun,<br>Uttarakhand |
| Product Description                           | Drinking Water                                                     | Sample Collected by  | Customer                          |
| Reference Sample Identification:              | DLWQTML/UJS/2026-27/30                                             | Duration of Analysis | 21/04/2026 to 23/04/2026          |

| S.N. | Parameters | Test Method | Result | Requirement<br>(Acceptable Limit)<br>As per<br>(IS 10500:2012) | Permissible Limit<br>(IS 10500:2012)<br>in the<br>Absence of alternative<br>source |
|------|------------|-------------|--------|----------------------------------------------------------------|------------------------------------------------------------------------------------|
|------|------------|-------------|--------|----------------------------------------------------------------|------------------------------------------------------------------------------------|

**(A) Organoleptic and Physical Parameters**

|    |                                                |                   |              |            |               |
|----|------------------------------------------------|-------------------|--------------|------------|---------------|
| 1. | pH at 25°C                                     | IS 3025 (Part 11) | 6.70         | 6.5 to 8.5 | No Relaxation |
| 2. | Total Dissolved Solids (TDS),<br>at 180°C mg/L | IS 3025 (Part 16) | 156          | 500 Max    | 2000 Max      |
| 3. | Turbidity, NTU                                 | IS 3025 (Part 10) | 0.22         | 1 Max      | 5 Max         |
| 4. | Colour, CU                                     | IS 3025 (Part 4)  | Less than 01 | 5 Max      | 15 Max        |
| 5. | Odour                                          | IS 3025 (Part 5)  | Agreeable    | Agreeable  | Agreeable     |

**(B) General Parameters Concerning Substances**

|     |                                                   |                   |      |         |          |
|-----|---------------------------------------------------|-------------------|------|---------|----------|
| 6.  | Total Alkalinity (as CaCO <sub>3</sub> ),<br>mg/L | IS 3025 (Part 23) | 60   | 200 Max | 600 Max  |
| 7.  | Total Hardness (as CaCO <sub>3</sub> ),<br>mg/L   | IS 3025 (Part 21) | 36   | 200 Max | 600 Max  |
| 8.  | Calcium as Ca, mg/l                               | IS 3025 (Part 40) | 8    | 75 Max  | 200 Max  |
| 9.  | Chloride as Cl, mg/L                              | IS 3025 (Part 32) | 10   | 250 Max | 1000 Max |
| 10. | Magnesium as Mg, mg/l                             | IS 3025 (Part 46) | 3.88 | 30 Max  | 100 Max  |

**(C) Microbiological Parameters**

|     | Parameters                | Test method   | Results | Requirements as per IS 10500:2012            |
|-----|---------------------------|---------------|---------|----------------------------------------------|
| 11. | Total Coliform (in 100ml) | IS 15185:2016 | Absent  | Shall not be detectable in any 100 ml sample |
| 12. | E. coli, (in 100ml)       | IS 15185:2016 | Absent  | Shall not be detectable in any 100 ml sample |

Note:-

1. The results listed refer only to tested sample and applicable parameters 2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received 5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

\*\*\*\* End of Report\*\*\*\*

Review and Authorized By

*(Signature)*  
Dr. Vikash Kandari  
Technical Manager

Technical Manager  
DLWQTML

Uttarakhand Jal Sansthan  
Dehradun



**District Level Water Quality Testing and Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**

**TEST REPORT**

| Name and Address of Organization/<br>Customer       |                         | Tibetan Children's Village School, Selaqui, Dehradun, Uttarakhand. |                                |                                                                      |                                                                                    |
|-----------------------------------------------------|-------------------------|--------------------------------------------------------------------|--------------------------------|----------------------------------------------------------------------|------------------------------------------------------------------------------------|
| Test Report ID                                      | 30A/UJS/DLWQTML/2026-27 | Reporting Date                                                     | 23/04/2026                     |                                                                      |                                                                                    |
| Date and Time of Sample Received:                   | 21/04/26 & 10:20 AM     | Sample Location                                                    | Selaqui, Dehradun, Uttarakhand |                                                                      |                                                                                    |
| Product Description                                 | Drinking Water          | Sample Collected by                                                | Customer                       |                                                                      |                                                                                    |
| Reference Sample Identification:                    | DLWQTML/UJS/2026-27/30  | Duration of Analysis                                               | 21/04/2026 to 23/04/2026       |                                                                      |                                                                                    |
| SN                                                  | Parameters              | Test Method                                                        | Results                        | Requirement<br>(Acceptable<br>Limit)<br>As per<br>(IS<br>10500:2012) | Permissible Limit<br>(IS 10500:2012)<br>in the<br>Absence of<br>alternative source |
| <b>(D) General Parameters Concerning Substances</b> |                         |                                                                    |                                |                                                                      |                                                                                    |
| 1.                                                  | Fluoride, mg/L          | IS 3025 (Part60/Sec 1)                                             | Less than 0.2                  | 1.0 Max                                                              | 1.5 Max                                                                            |
| 2.                                                  | Nitrate, mg/L           | IS 3025 (Part34/Sec 1)                                             | Less than 01                   | 45 Max                                                               | No Relaxation                                                                      |
| 3                                                   | Iron, mg/l              | IS 3025 (Part53)                                                   | 0.06                           | 1.0                                                                  | No relaxation                                                                      |
| 4.                                                  | Sulfate, mg/L           | IS 3025 (Part24/Sec 1)                                             | 12                             | 200 Max                                                              | 400 Max                                                                            |

**Note:-**

1. The results listed refer only to tested sample and applicable parameters 2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received 5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

\*\*\*\* End of Report\*\*\*\*

**Review and Authorized By**

*(Signature)*  
23/04/26  
**(Dr. Vikash Kandari)**  
Technical Manager, Lab

**Technical Manager**  
**DLWQTML**  
Uttarakhand Jal Sansthan  
Dehradun