State Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun
Ph (O): 0135-2746137, E-mail: eenorth-ujs-uk@nic.in
(NABL Approved)

TC- 5372

URLNo.: TC5372180000000597F

Test Report ID: 899/UJS/SLWQTML/2021-22 **Dated: 24/06/2021**

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer	Tibetan Children's Village School, Village Dhvolkot, Selaqui		
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	**Sample Description**	One Water Sample collected from Tibetan Children School
Reference Sample Identification:	SLWQTML/UJS/TC-01		Date of Start of Analysis: 21/06/2021
			Date of End of Analysis: 24/06/2021
Date and Time of Sample Received: 21/06/21 & 10:44 AM		**Sample Collected by:**	Customer

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1	pH at 25^0C	6.88	6.5 to 8.5	No Relaxation	IS 3025 Pt-11-2002
2	Total Dissolved Solids (TDS), mg/L, *Max*	220	500	2000	IS 3025 Pt-16-2006
3	Turbidity, NTU, *Max*	0.52	1	5	IS 3025 Pt-10-2006
4	Total Alkalinity (as $CaCO_3$), mg/L, *Max*	170	200	600	IS 3025 (Part 23): 2003
5	Total Hardness (as $CaCO_3$), mg/L, *Max*	198	200	600	IS 3025 (Part 21): 2002
6	Fluoride, mg/L, *Max*	0.22	1.0	1.5	APHA 23rd Ed.-4500-F^--D
7	Nitrate, mg/L, *Max*	Less than 1.0	45	No Relaxation	APHA 23rd Ed.-4500-NO_3^--B
8	Sulfate, mg/L, *Max*	28	200	400	APHA 23rd Ed.-4500-SO_4^{2-}-E
9*	Chloride, mg/L, *Max*	18.8	250	1000	APHA 23rd Ed.-4500-Cl^-B
10*	Colour, Hazen, *Max*	Less than 01	5	15	APHA 23rd Ed.-2160-C
11*	Taste	Agreeable	Agreeable	Agreeable	APHA 23rd Ed.-2160-B
12*	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05-2002
	Bacteriological Parameters				
13*	Total Coliform, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B
14*	*E. coli*, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B

Note-: The parameters marked with an * are not accredited by NABL

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.

Vikash Kandari 24/06/21

(Dr. Vikash Kandari)
Authorised Signatory
SLWQTM, Lab
Uttarakhand Jal Sansthan
Dehradun

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.

Scanned with OKEN Scanner