

RFI-014 Foundation Pour Hold

Practice file: Cedarline Training Hall, job SYNTH-HALL-01.

Original text. Not a real project and not a platform export.

Number: RFI-014

Status: Open

Discipline: concrete

Spec section: 03 30 00 and 07 26 00

Location: slab on grade, grids A-D and 1-4

From: project engineer (practice role)

To: architect of record (practice role)

Question: Can the slab on grade be poured before the vapor barrier submittal is approved?

Response: No. The pour stays on hold.

Blocked activity: slab on grade foundation pour

Reason: open RFI-014 until the vapor barrier submittal is approved.

Official response status: answered, and the work stays waiting.

Due: 2026-04-18

Opened: 2026-04-02

Linked submittal: SB-21, vapor barrier, revise and resubmit.

What this file is not: it is not a change order, and it does not authorize a purchase.

Clearing it: a later revision of SB-21 marked approved is what removes this block. A verbal note does not.