

RFI-014 Foundation Pour Hold

Status: Open

Question: Can the slab on grade be poured before the vapor barrier submittal is approved?

Response: No. The pour stays on hold.

Blocked activity: slab on grade foundation pour

Reason: open RFI-014 until the vapor barrier submittal is approved.