

2.1 Strop
skala 1:50

Reinforcement details shown in the drawing:

- 4: 20 $\phi 12$ co 18, L = 250 /D
- 5: 6 $\phi 12$ co 18, L = 365 /D
- 6: 14 $\phi 12$ co 18, L = 485 /G
- 7: 14 $\phi 12$ co 18, L = 466 /D
- 8: 8 $\phi 12$ co 18, L = 825 /G
- 9: 26 $\phi 12$ co 18, L = 730 /G
- 10: 18 $\phi 12$ co 18, L = 325 /D
- 11: 18 $\phi 12$ co 18, L = 803 /D
- 12: 6 $\phi 12$ co 18, L = 385 /G
- 13: 13 $\phi 12$ co 18, L = 270 /G
- 14: 14 $\phi 12$ co 18, L = 245* /G
- 15: 7 $\phi 12$ co 36, L = 245* /G
- 16: 18 $\phi 12$ co 18, L = 825 /G
- 17: 26 $\phi 12$ co 18, L = 710 /D
- 18: 18 $\phi 12$ co 18, L = 345 /G
- 19: 14 $\phi 12$ co 18, L = 245* /G
- 20: 20 $\phi 12$ co 18, L = 245* /G

dozbrojenie krawędzi swobodnych
skala 1:25

ø 12
L = 103
co 18

14

70 ø 12 L = 104

14

45

45

BETON: C25/30
STAL: A-IIIIN RB500W
A-O StOS
OTULINA: 25mm

b	skorygowano zbrojenie wraz z zestawieniem	31.10.2023	M.Raducki
a	dodano otwór stropu	13.10.2023	M.Raducki
Rewizja	Opis	Data	Nazwisko

$\pm 0.00 = 225.50m \text{ n.p.m.}$

Faza	Skala	Branża	Nr rysunku	Data
PW	1:50	KONSTR.	K-18b	04.2023