

Rooftop Rainwater Harvesting Assessment Report

Location:	panch mahals, gujarat	Roof Area:	65.2 m²
Roof Surface Type:	RCC Concrete Flat Roof	Household Occupants:	3 members

ANNUAL HARVESTABLE VOLUME

44,849 Liters/year

Total potential rainwater captured from roof runoff

RECOMMENDED TANK SIZE

6,075 Liters capacity

Sized for peak monsoon runoff & 15-day domestic buffer

Underlying Meteorology Data: Average Annual Rainfall = 808.9 mm

Data Source: Based on verified district-level meteorological annual rainfall data.

Government Schemes & Subsidies

• Jal Shakti Abhiyan: Catch the Rain

Financial incentives and technical assistance for constructing artificial recharge structures and rooftop rainwater harvesting units in urban and rural areas.

Helpline: 1800-11-0707 | Portal: <https://jsactr.mowr.gov.in/>

• Atal Bhujal Yojana (Atal Jal)

Community-led groundwater management scheme providing grants for rooftop rainwater harvesting & aquifer recharge structures.

Helpline: 011-23383070 | Portal: <https://ataljal.mowr.gov.in>