

Table 1: Experiment B meter-level PR-AUC across paired source-building budgets.

Meter	K=10		K=20		K=50		K=100	
	Tree	TabPFN	Tree	TabPFN	Tree	TabPFN	Tree	TabPFN
Electricity	0.940	0.956	0.917	0.957	0.967	0.967	0.968	0.971
Chilled water	0.461	0.446	0.429	0.487	0.597	0.604	0.645	0.626
Steam	0.320	0.395	0.296	0.428	0.420	0.502	0.589	0.582
Hot water	0.589	0.720	0.651	0.735	0.628	0.697	0.612	0.660
<i>Macro</i>	0.577	0.629	0.573	0.652	0.653	0.693	0.704	0.710