

BILL OF MATERIALS 15HP VFD PANEL (20.09.2022)

SR NO	DISCRIPTION	CAT.NO	MAKE	QTY	UNIT
A	15HP VFD PANEL			1	
1	32AMP 4P MCB, C-CURVE , 10KA	BB40320C	L&T	1	NO
2	4C/O AUX CONTACT 230V COIL VALTAGE	4C/O 230V AC	OMRON	1	NO
3	15HP VARIABLE FREQUENCY DRIVE	FRN0029E2S-4GBX	FUJI	1	NO
4	6AMP SP MCB C-CURVE , 10 KA FOR CONTROL	BB10060C	L&T	1	NO
5	ON INDICATION LAMP, 240 V AC, LED TYPE, "RED"	230V AC	L&T	1	NO
6	OFF INDICATION LAMP, 240 V AC, LED TYPE, "RED"	230V AC	L&T	1	NO
7	TRIP INDICATION LAMP, 240 V AC, LED TYPE, "AMBER"	230V AC	L&T	1	NO
8	POTENTIO METER	10KA OHMS	STD	1	NO
9	START PUSH BUTTON WITH 1NO ELEMENT "GREEN"	FLUSH TYPE	C&S	1	NO
10	STOP PUSH BUTTON WITH 1NC ELEMENT "RED"	FLUSH TYPE	C&S	1	NO
11	INPUT CHOKE 15HP	15HP IP	STD	1	NO
12	OUTPUT CHOKE 15HP	15HP OP	STD	1	NO
13	PHASE INDICATING LAMPS	230V AC	STD	3	NO
14	CONTROL TERMINALS WITH END PLATE AND END STOP	KUT 2.5	ELMEX	12	NO
15	POWER TERMINALS WITH END PLATE AND END STOP (Shrouded)	KUT 6	ELMEX	7	NO
16	END PLATE		ELMEX	2	NO
17	4" COOLING FAN WITH FILTER GRILL 230V AC	CO-AXIAL	EBM-NADI	1	NO
18	INCOMING POWER WIRING	6sq mm	POLYCAB	1	LOT
19	CONTROL WIRING	1.5 sq mm	POLYCAB	2	LOT
C	FABRICATION & POWDER COATING			JOB	1
	Size : 1000(H) x 450(W) X 300(D) mm				
	FABRICATED FROM- 16SWG CRCA SHEET				
	PAINTING: POWDER COATED WITH SIEMENS GREY SHED(RAL 7032)				
	PRE TREATMENT- 7 TANK PROCESS				
D	Busbar - Electrolite Grade Aluminium,- CURRENT DENSITY - 0.6A/SQ.MM			LOT	1
	NOT REQUIRED				
E	Wiring of all feeders using wires of POLYCAB MAKE			JOB	1
1	15HP VFD PANEL				1
NOTE	B.O.M IS PREPARED AS PER DRAWING GIVEN BY YOU, AND AS PER B.O.M GIVEN MATERIAL IS IN OUR SCOPE AND EXTRA REQUIRED IN PARTY SCOPE.				