

NAYARA ENERGY LIMITED Formerly known as Essar Oil Limited
REFINERY LABORATORY-VADINAR
39KM, Jamnagar-Okha Highway, Vadinar
District- Devbhumi Dwarka – 361305, Gujarat, India
ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018 CERTIFIED



TEST REPORT
LIGHT DIESEL OIL (LDO)
For Shri Dutt (Namra Trivedi) BBELL SAYKHA

Sr.No.	Tests	Method	Unit	Limit	Test Result
1	Visual Appearance	Visual	...	Clear and Bright	Clear and Bright
2	Density at 15°C	ASTM D 4052	kg/m ³	0.77-0.88	0.87
3	Saybolt Colour	ASTM D 156	...	To report	+22
4	Distillation IBP	ASTM D 86	°C	135 Min	148.1
5	50 percent by volume recovered	ASTM D 86	°C	To report	180.0
6	95 percent by volume recovered	ASTM D 86	°C	225 Max	221.0
7	Final Boiling Point	ASTM D 86	°C	To report	238.1
8	Aromatic content	ASTM D 6379	Vol %	40 Max	17.0
9	Residue on Evaporation (Gum content)	IP 540	Wt%	0.005 Mmax	0.0010
10	Water Content by Karl Fischer	ISO 12937	Wt%	0.5 max	0.013
11	Copper strip corrosion for 3 h at 50°C	ASTM D 130	...	Not worse than NO.1	1a
12	Flash Point (Abel)	IP 170	°C	35 Min	60.0
13	Mercaptan Sulphur	ASTM D 3227	Wt%	0.0030 Max	0.0018
14	Total Sulphur	ASTM D 4294	Wt%	To report	1.23

Remarks

1. Result related to item tested only
2. Test Report shall not be reproduced without written permission of the laboratory
3. The sample is drawn by client and results apply to the sample as received

Printed on : 12/09/2025
Time : 4:32 pm

Authorised Test Report Signature
Nayara Energy Limited

END OF REPORT