

# VOLTECH POWER

**Ads. : - 56.Aadarsh Silver Estate, Near Kotak Mahindra Bank Road No.5, Kathwada GIDC  
Ahmedabad-382430.**

**GST NUM :- 24AATFV1169J1ZN    Email :- [voltechpower21@gmail.com](mailto:voltechpower21@gmail.com)**

Description of Panel :- MCC Panel

Qty of Panel :- 01 Nos.

| Sr.No.    | Description                                                                  | Cat. No                        | Rating      | Make    | Qty.     |            |
|-----------|------------------------------------------------------------------------------|--------------------------------|-------------|---------|----------|------------|
| <b>A</b>  | <b>Main incomer</b>                                                          |                                | <b>630A</b> |         | <b>1</b> | <b>No.</b> |
| 1         | 630A TP MCCB, 36KA with TMD Based Trip Unit O/L,S/C, E/F Release, Desine DN3 | CM94006OOT1OG                  | 630A        | L&T     | 1        | No.        |
| 2         | Extended Rotery Handle, DN3                                                  | CM99861O000                    | 630A        | L&T     | 1        | No.        |
| 3         | Spreaders with Phase barrier,DN3                                             | ST98054O000                    | 630A        | L&T     | 1        | No.        |
| 4         | Auxilari Switch + Trip Alarm Contact                                         | CM99804O000                    | 630A        | L&T     | 1        | No.        |
| 5         | Cast Resin Current Transformer for Metering                                  | 5VA CL-1                       | 600/5A      | Rishabh | 3        | No.        |
| 6         | Multifunctional Meter with RS485                                             | Elite 30A                      | Digital     | SECURE  | 1        | No.        |
| 7         | Control MCB SP,6A                                                            | BB10060C                       | 6A          | L&T     | 4        | No.        |
| 8         | Red LED Indicating Lamp- R Phase                                             | EPLR240A                       | 240VAC      | L&T     | 1        | No.        |
| 9         | Yellow LED Indicating Lamp- Y Phase                                          | EPLY240A                       | 240VAC      | L&T     | 1        | No.        |
| 10        | Blue LED Indicating Lamp- B Pahse                                            | EPLB240A                       | 240VAC      | L&T     | 1        | No.        |
| 11        | Red LED Indicating Lamp- ON                                                  | EPLR240A                       | 240VAC      | L&T     | 1        | No.        |
| 12        | Green LED Indicating Lamp- OFF                                               | EPLG240A                       | 240VAC      | L&T     | 1        | No.        |
| 13        | Amber LED Indicating Lamp- Trip                                              | EPLA240A                       | 240VAC      | L&T     | 1        | No.        |
| 14        | Wiring Lot                                                                   |                                |             | Polycab | 1        | Lot        |
| <b>B1</b> | <b>Outgoing DOL</b>                                                          | <b>5HP DOL Starter</b>         |             |         | <b>2</b> | <b>No.</b> |
| 1         | 25A TP MCB, 10KA                                                             | BB30250C                       | 25A         | L&T     | 2        | No         |
| 2         | Power Contactor MNX18                                                        | CS94100                        | 18A         | L&T     | 2        | No         |
| 3         | Thermal Over Load Relay                                                      | SS94142O0VO                    | 6-10A       | L&T     | 2        | No         |
| 4         | Addon Block INC                                                              | CS94121                        |             | L&T     | 2        | No         |
| 5         | Control MCB SP,6A,10KA                                                       | BB10060C                       | 6A          | L&T     | 2        | No         |
| 6         | Stop Red Push Button                                                         | EMNRFD1                        |             | L&T     | 2        | Nos.       |
| 7         | NC Element                                                                   | EC2C                           |             | L&T     | 2        | Nos.       |
| 8         | Start Green Push Button                                                      | EMNGFD1                        |             | L&T     | 2        | Nos.       |
| 9         | NO Element                                                                   | EC1C                           |             | L&T     | 2        | Nos.       |
| 10        | Red LED Indicating Lamp                                                      | EPLR240A                       | 240VAC      | L&T     | 2        | No.        |
| 11        | Green LED Indicating Lamp                                                    | EPLG240A                       | 240VAC      | L&T     | 2        | No.        |
| 12        | Amber LED Indicating Lamp- Trip                                              | EPLA240A                       | 240VAC      | L&T     | 2        | No.        |
| 13        | Neutral Link                                                                 | KULTD4                         | 4Sqmm       | Elmex   | 2        | Nos.       |
| 14        | End Clamp suitable for 35mm Rail                                             | SCKN                           |             | Elmex   | 4        | Nos.       |
| 15        | Terminal Control                                                             | KUT 2.5 Grey                   | 2.5Sqmm     | Elmex   | 6        | Nos.       |
| 16        | Terminal Control End Plates                                                  | KPNS                           | 2.5Sqmm     | Elmex   | 2        | Nos.       |
| 17        | Terminal Power                                                               | KUT 10                         | 10Sqmm      | Elmex   | 6        | Nos        |
| 18        | Wiring Lot                                                                   |                                |             | Polycab | 2        | Lot        |
| <b>B2</b> |                                                                              | <b>10HP Star Delta Starter</b> |             |         | <b>2</b> | <b>No.</b> |

|           |                                           |                                  |         |                     |          |            |
|-----------|-------------------------------------------|----------------------------------|---------|---------------------|----------|------------|
| 1         | 32A TP MCB, 10KA                          | BB30320C                         | 32A     | L&T                 | 2        | No.        |
| 2         | Contactor Main, MNX18                     | CS94100                          | 18A     | L&T                 | 2        | No.        |
| 3         | Contactor Delta, MNX18                    | CS94100                          | 18A     | L&T                 | 2        | No.        |
| 4         | Contactor Star, MNX18                     | CS94100                          | 18A     | L&T                 | 2        | No.        |
| 5         | Addon Block 1NO+1NC                       | CS94118                          |         | L&T                 | 6        | No         |
| 6         | Thermal Over Load Relay                   | SS94142OOVO                      | 6-10A   | L&T                 | 2        | No.        |
| 7         | Timer                                     | Star Delta                       | 240V    | EAPL                | 2        | No.        |
| 8         | Control MCB SP,6A,10KA                    | BB10060C                         | 6A      | L&T                 | 2        | No.        |
| 9         | Stop Red Push Button                      | EMNRFD1                          |         | L&T                 | 2        | Nos.       |
| 10        | NC Element                                | EC2C                             |         | L&T                 | 2        | Nos.       |
| 11        | Start Green Push Button                   | EMNGFD1                          |         | L&T                 | 2        | Nos.       |
| 12        | NO Element                                | EC1C                             |         | L&T                 | 2        | Nos.       |
| 13        | Red LED Indicating Lamp                   | EPLR240A                         | 240VAC  | L&T                 | 2        | No.        |
| 14        | Green LED Indicating Lamp                 | EPLG240A                         | 240VAC  | L&T                 | 2        | No.        |
| 15        | Amber LED Indicating Lamp- Trip           | EPLA240A                         | 240VAC  | L&T                 | 2        | No.        |
| 16        | Neutral Link                              | KULTD4                           | 4Sqmm   | Elmex               | 2        | Nos.       |
| 17        | End Clamp suitable for 35mm Rail          | SCKN                             |         | Elmex               | 4        | Nos.       |
| 18        | Terminal Control                          | KUT 2.5 Grey                     | 2.5Sqmm | Elmex               | 6        | Nos.       |
| 19        | Terminal Control End Plates               | KPNS                             | 2.5Sqmm | Elmex               | 2        | Nos.       |
| 20        | Terminal Power                            | KUT16                            | 16Sqmm. | Elmex               | 12       | Nos.       |
| 21        | Wiring Lot                                |                                  |         | Polycab             | 2        | Lot        |
| <b>B3</b> |                                           | <b>12.5HP Star Delta Starter</b> |         |                     | <b>2</b> | <b>No.</b> |
| 1         | 40A TP MCB, 10KA                          | BB30400C                         | 40A     | L&T                 | 2        | No.        |
| 2         | Contactor Main, MNX22                     | CS94980                          | 22A     | L&T                 | 2        | No.        |
| 3         | Contactor Delta, MNX22                    | CS94980                          | 22A     | L&T                 | 2        | No.        |
| 4         | Contactor Star, MNX22                     | CS94980                          | 22A     | L&T                 | 2        | No.        |
| 5         | Addon Block 1NO+1NC                       | CS94118                          |         | L&T                 | 6        | No         |
| 6         | Thermal Over Load Relay                   | SS94142OOBO                      | 9-15A   | L&T                 | 2        | No.        |
| 7         | Timer                                     | Star Delta                       | 240V    | EAPL                | 2        | No.        |
| 8         | Control MCB SP,6A,10KA                    | BB10060C                         | 6A      | L&T                 | 2        | No.        |
| 9         | Stop Red Push Button                      | EMNRFD1                          |         | L&T                 | 2        | Nos.       |
| 10        | NC Element                                | EC2C                             |         | L&T                 | 2        | Nos.       |
| 11        | Start Green Push Button                   | EMNGFD1                          |         | L&T                 | 2        | Nos.       |
| 12        | NO Element                                | EC1C                             |         | L&T                 | 2        | Nos.       |
| 13        | Red LED Indicating Lamp                   | EPLR240A                         | 240VAC  | L&T                 | 2        | No.        |
| 14        | Green LED Indicating Lamp                 | EPLG240A                         | 240VAC  | L&T                 | 2        | No.        |
| 15        | Amber LED Indicating Lamp- Trip           | EPLA240A                         | 240VAC  | L&T                 | 2        | No.        |
| 16        | Neutral Link                              | KULTD4                           | 4Sqmm   | Elmex               | 2        | Nos.       |
| 17        | End Clamp suitable for 35mm Rail          | SCKN                             |         | Elmex               | 4        | Nos.       |
| 18        | Terminal Control                          | KUT 2.5 Grey                     | 2.5Sqmm | Elmex               | 6        | Nos.       |
| 19        | Terminal Control End Plates               | KPNS                             | 2.5Sqmm | Elmex               | 2        | Nos.       |
| 20        | Terminal Power                            | KUT16                            | 16Sqmm. | Elmex               | 12       | Nos.       |
| 21        | Wiring Lot                                |                                  |         | Polycab             | 2        | Lot        |
| <b>B4</b> | <b>Outgoing VFD Starter</b>               | <b>15HP VFD</b>                  |         |                     | <b>5</b> | <b>No.</b> |
| 1         | 63A TP MCB, 10KA                          | BB30630C                         | 63A     | L&T                 | 5        | No.        |
| 2         | 15HP (HD) VFD Heavey Duty                 |                                  |         | <b>Cleint Scope</b> | 5        | No.        |
| 3         | 3NO+1NC Control Contactor for Controlling | CS94019                          |         | L&T                 | 5        | No.        |

|           |                                           |                 |         |                    |          |            |
|-----------|-------------------------------------------|-----------------|---------|--------------------|----------|------------|
| 4         | 2C/O Control Speed Up/Down                |                 |         | Salzer             | 10       | No.        |
| 5         | Input Choke F Class 3% Imepidance         |                 | 15HP    | SKT                | 5        | No.        |
| 6         | Control MCB SP,6A                         | BB10060C        | 6A      | L&T                | 10       | No.        |
| 7         | Neutral Link                              | KULTD4          | 4Sqmm   | Elmex              | 10       | No.        |
| 8         | 10K BONS pot with dial                    |                 |         | Pankaj /<br>Bourns | 5        | No.        |
| 9         | Red LED Indicating Lamp- ON               | EPLR240A        | 240VAC  | L&T                | 5        | No.        |
| 10        | Green LED Indicating Lamp- OFF            | EPLG240A        | 240VAC  | L&T                | 5        | No.        |
| 11        | Amber LED Indicating Lamp- Trip           | EPLA240A        | 240VAC  | L&T                | 5        | No.        |
| 12        | Start Green Push Button                   | EMNGFD1         |         | L&T                | 5        | No.        |
| 13        | Stop Red Push Button                      | EMNRFD1         |         | L&T                | 5        | No.        |
| 14        | Speed Up Blue Push Button                 | EMNBFD1         |         | L&T                | 5        | No.        |
| 15        | Speed Down Black Push Button              | EMNCFD1         |         | L&T                | 5        | No.        |
| 16        | NC Element                                | EC2C            |         | L&T                | 5        | No.        |
| 17        | NO Element                                | EC1C            |         | L&T                | 15       | No.        |
| 18        | Control Terminal for Gray                 | KUT2.5          | 2.5Sqmm | Elmex              | 15       | No.        |
| 19        | Control Terminal Speed Up Down            | KUT2.5          | 2.5Sqmm | Elmex              | 15       | No.        |
| 20        | End Plate                                 | KPNS            |         | Elmex              | 10       | No.        |
| 21        | Power Terminal R,Y,B                      | CBT110          | 50Sqmm  | Elmex              | 15       | No.        |
| 22        | End Clamp                                 | SCKN            |         | Elmex              | 15       | No.        |
| 23        | Space Heater with Thermostate             |                 | 240VAC  | Gelco              | 5        | No.        |
| 24        | 6" Fan With Filter Grill                  |                 | 240VAC  | Rexnord            | 5        | No.        |
| 25        | Wiring Lot                                |                 |         | Polycab            | 5        | No.        |
| <b>B5</b> | <b>Outgoing VFD Starter</b>               | <b>15HP VFD</b> |         |                    | <b>3</b> | <b>No.</b> |
| 1         | 63A TP MCB, 10KA                          | BB30630C        | 63A     | L&T                | 3        | No.        |
| 2         | 15HP (HD) VFD Heavey Duty                 | MS300 Series    |         | <b>Delta</b>       | 3        | No.        |
| 3         | 3NO+1NC Control Contactor for Controlling | CS94019         |         | L&T                | 3        | No.        |
| 4         | 2C/O Control Speed Up/Down                |                 |         | Salzer             | 6        | No.        |
| 5         | Input Choke F Class 3% Imepidance         |                 | 15HP    | SKT                | 3        | No.        |
| 6         | Control MCB SP,6A                         | BB10060C        | 6A      | L&T                | 6        | No.        |
| 7         | Neutral Link                              | KULTD4          | 4Sqmm   | Elmex              | 6        | No.        |
| 8         | 10K BONS pot with dial                    |                 |         | Pankaj /<br>Bourns | 3        | No.        |
| 9         | Red LED Indicating Lamp- ON               | EPLR240A        | 240VAC  | L&T                | 3        | No.        |
| 10        | Green LED Indicating Lamp- OFF            | EPLG240A        | 240VAC  | L&T                | 3        | No.        |
| 11        | Amber LED Indicating Lamp- Trip           | EPLA240A        | 240VAC  | L&T                | 3        | No.        |
| 12        | Start Green Push Button                   | EMNGFD1         |         | L&T                | 3        | No.        |
| 13        | Stop Red Push Button                      | EMNRFD1         |         | L&T                | 3        | No.        |
| 14        | Speed Up Blue Push Button                 | EMNBFD1         |         | L&T                | 3        | No.        |
| 15        | Speed Down Black Push Button              | EMNCFD1         |         | L&T                | 3        | No.        |
| 16        | NC Element                                | EC2C            |         | L&T                | 3        | No.        |
| 17        | NO Element                                | EC1C            |         | L&T                | 9        | No.        |
| 18        | Control Terminal for Gray                 | KUT2.5          | 2.5Sqmm | Elmex              | 9        | No.        |
| 19        | Control Terminal Speed Up Down            | KUT2.5          | 2.5Sqmm | Elmex              | 9        | No.        |
| 20        | End Plate                                 | KPNS            |         | Elmex              | 6        | No.        |
| 21        | Power Terminal R,Y,B                      | CBT110          | 50Sqmm  | Elmex              | 9        | No.        |
| 22        | End Clamp                                 | SCKN            |         | Elmex              | 9        | No.        |
| 23        | Space Heater with Thermostate             |                 | 240VAC  | Gelco              | 3        | No.        |
| 24        | 6" Fan With Filter Grill                  |                 | 240VAC  | Rexnord            | 3        | No.        |

|           |                                                      |                                                                                         |             |         |          |            |
|-----------|------------------------------------------------------|-----------------------------------------------------------------------------------------|-------------|---------|----------|------------|
| 25        | Wiring Lot                                           |                                                                                         |             | Polycab | 3        | No.        |
| <b>B6</b> | <b>Outgoing MCCB</b>                                 |                                                                                         | <b>200A</b> |         | <b>1</b> | <b>No.</b> |
| 1         | 160A TP MCCB,36KA with O/L,S/C, TMD Based Trip , DN2 | CM92009OON1OG                                                                           | 200A        | L&T     | 1        | No.        |
| 2         | Extended Rotery handle, DN2                          | CM99830O000                                                                             | 200A        | L&T     | 1        | No.        |
| 3         | Spreaders                                            | ST98053O000                                                                             | 200A        | L&T     | 1        | No.        |
| <b>B7</b> | <b>Outgoing MCB</b>                                  |                                                                                         | <b>63A</b>  |         | <b>3</b> | <b>No.</b> |
| 1         | 63A FP MCB, 10KA                                     | BB40630C                                                                                | 63A         | L&T     | 3        | No.        |
| 2         | Terminal Power                                       | KUT 25                                                                                  | 25Sqmm.     | Elmex   | 12       | No.        |
| 3         | Wiring Lot                                           |                                                                                         |             | Polycab | 3        | Lot        |
| <b>C</b>  | <b>Panel Design</b>                                  |                                                                                         |             |         |          |            |
| 1         | Dimensions                                           | <b>2500W X 2175H X 800D Double Front Compartmentalwise</b>                              |             |         |          |            |
| 2         | Base Frame                                           | 75 x 40MM for MCC Panel                                                                 |             |         |          |            |
| 3         | Structure, Gland Plate                               | 14 SWG                                                                                  |             |         |          |            |
| 4         | Doors, Partition                                     | 16 SWG                                                                                  |             |         |          |            |
| 5         | Busbar                                               | <b>EC Grade Alluminium Busbar 1Sqmm = 0.8Amp</b>                                        |             |         |          |            |
|           |                                                      | <b>Main Bus Bar 630A = 80x10mm -01 Nos for Phase &amp; 80x6mm -01 Nos for Neutral</b>   |             |         |          |            |
| 6         | Cable Entry                                          | Top Entry                                                                               |             |         |          |            |
| 7         | Paint                                                | <b>Epoxy Siemens Grey RAL7032 Powder coating after 7tank Treatment Cleaning Process</b> |             |         |          |            |