



**For Shri Dutt (Namra Trivedi) BBELL SAYKHA**

| Sr.No. | Tests                                               | Method      | Unit              | Limit               | Test Result      |
|--------|-----------------------------------------------------|-------------|-------------------|---------------------|------------------|
| 1      | Visual Appearance                                   | Visual      | ...               | Clear and Bright    | Clear and Bright |
| 2      | Density at 15 <sup>0</sup> C                        | ASTM D 4052 | kg/m <sup>3</sup> | 0.77-0.88           | 0.87             |
| 3      | Saybolt Colour                                      | ASTM D 156  | ...               | To report           | +22              |
| 4      | Distillation IBP                                    | ASTM D 86   | <sup>0</sup> C    | 135 Min             | 148.1            |
| 5      | 50 percent by volume recovered                      | ASTM D 86   | <sup>0</sup> C    | To report           | 180.0            |
| 6      | 95 percent by volume recovered                      | ASTM D 86   | <sup>0</sup> C    | 225 Max             | 221.0            |
| 7      | Final Boiling Point                                 | ASTM D 86   | <sup>0</sup> C    | To report           | 238.1            |
| 8      | Aromatic content                                    | ASTM D 6379 | Vol %             | 40 Max              | 17.0             |
| 9      | Residue on Evaporation (Gum content)                | IP 540      | Wt%               | 0.005 Mmax          | 0.0010           |
| 10     | Water Content by Karl Fischer                       | ISO 12937   | Wt%               | 0.5 max             | 0.013            |
| 11     | Copper strip corrosion for 3 h at 50 <sup>0</sup> C | ASTM D 130  | ...               | Not worse than NO.1 | 1a               |
| 12     | Flash Point (Abel)                                  | IP 170      | <sup>0</sup> C    | 35 Min              | 58.0             |
| 13     | Mercaptan Sulphur                                   | ASTM D 3227 | Wt%               | 0.0030 Max          | 0.0018           |
| 14     | Total Sulphur                                       | ASTM D 4294 | Wt%               | To report           | 1.23             |

1. Result related to item tested only
2. Test Report shall not be reproduced without written permission of the laboratory
3. The sample is drawn by client and results apply to the sample as received

Printed on : 04/10/2025  
Time : 8:30 pm

END OF REPORT