

Tax Invoice

(Issued under Sec31 of CGST act 2017)

No. 2, MIDC Thane-Belapur Road, Airoli,
Navi Mumbai 400 708
Tel: 91-22-2763 7200 / 2760 0401
Website: www.bharatbijlee.com

Date : 17.09.2021

Routine Test Certificate of 3 Phase, FLAME PROOF MOTOR. (Eff.Class : IE2)

Machine Number : M2121427

W.O. No. :

Client :

S.O. No. : /

Name Plate Data :

Frame	: 160M	Type	: 2J16M4C3	Encl.	: TEFC
kW	: 9.3	HP	: 12.5	Volts	: 415 + 10% - 10%
Conn.	: DELTA	Freq	: 50 + 5% - 5%	RPM	: 1465
Amps	: 17.6	Duty	: S1	Ins.	: F
Eff. %	: 89.4 (IE2)	P.F.	: 0.82	Amb.	: 45.0 °C
Weight	: 148 kg.	Eff. Class	: IE2	T.Rise	: B
Prot	: IP55	Mounting	: B3	StartStop	: S/Hr
Bearing No	: 6209 2Z C3 / 6209 2Z C3				

Test Observations :

Winding Resistance : 1.13 Ohms Per Phase at 30°C
Insulation resistance (Before and After HV Test) : Above 30 Mega Ohms.
H.V Test at 2 KV for 1 min : OK
Reduced voltage running up test at 239 volts in both directions : OK

No Load Test :

Volts : 415 Amps : 7.27 Watts : 530
Freq : 50HZ

Locked Rotor Test :

Volts : 100 Amps : 21.1 Watts : 1,610

Direction of rotation when facing the D-end : Clockwise

Earthing and Terminal marking : OK

Special Remarks :**GAS GROUP IIA, IIB**

Pressure Test : OK

Temp. class : T5 CLASS

Flame Paths/Gaps : OK

Approval Nos :

PESO : PESO:A/P/HQ/MH/104/6532(P482126/5)-01.09.20

IN/CIMFR/TR20/H02-13.05.20

This is to certify that the motor has been tested in accordance with IS/IEC 60034-1 and has been found to be electrically & mechanically sound.

Customer P.O No. :

Test Date : 26.08.2021

System Generated Certificate

