



HINDUSTAN PETROLEUM CORPORATION LIMITED
(A Government of India Enterprise)

MR-II TERMINAL
CTS NO. 382, ANIK VILLAGE.,
MUMBAI 400074, Maharashtra

CERTIFICATE OF ANALYSIS

Product	0984000 (HP INDUSTRIAL DIESEL OIL)	Inspection Lot	890000319299
Customer	41013639 (SANMIT INFRA LTD)	Plant	1554 (MR-II TERMINAL)
Invoice No	MH0140168389	Tank / Storage Location	TK8
Billing Document	9007942860	Date of Sampling	24.07.2024
Vehicle No	MH03CV2992	Sampled By	INTERTEK SURVEYOR
Batch No	LDO/HRM/TK_556/S002060/2024	Date of Shipment	27.07.2024

S.No	Characteristics	UOM	Test Method	Specifications	Result
1	APPEARANCE	-	VISUAL	APPEARANCE	FREE FROM GRIT, SUSPENDED MATTER AND OTHER VISIBLE IMPURITIES.
2	DENSITY AT 15°C	kg/m ³	IS 1448 P:16	TO REPORT	863.7
3	DENSITY AT 15°C, TOP	kg/m ³	IS 1448 P:16	TO REPORT	863.7
4	DENSITY AT 15°C, MIDDLE	kg/m ³	IS 1448 P:16	TO REPORT	863.7
5	DENSITY AT 15°C, BOTTOM	kg/m ³	IS 1448 P:16	TO REPORT	863.7
6	FLASH POINT, PMCC	°C	IS 1448 P:21	MIN 66.0	80.0
7	KINEMATIC VISCOSITY AT 40°C	cSt	IS 1448 P:25 SEC 1	2.5000 - 15.0000	4.712
8	TOTAL SULPHUR	% m/m	ASTM D4294	MAX 1.500	1.186
9	WATER CONTENT	% v/v	IS 1448 P:40	MAX 0.25	0.10
10	POUR POINT, SUMMER	°C	IS 1448 P:10 SEC 2	MAX 21	12

Note: This is a system generated certificate. Hence do not require signature.

