

TAX INVOICE

PH.NO: 257198, 291198

STANDARD ENTERPRISE

SPECIALIST IN : All Types Electrical Equipment Rewinding Job & Mech. Job.

STOKOIST IN : Telemechanics & Control (I) Ltd., Control & Switch Gear Co. Ltd.

WORKSHOP : Plote.no: E-339, GACL Chowkadi, Near Sitaram mall, GIDC DAHEJ-392130

M/s. BBELL Industry LLP

Saykha Industrial Estate, DP-119, GIDC

Ankleswar

STATE : GUJARAT

STATECODE : 24

GSTIN NO : 24AAPFK0441G1ZK

Bill No : T-0202/24-25

Dt 30-05-2024

D.C. No : 445

Dt 30-05-2024

W.O. No : ARC

Dt 30-05-2024

R.G.P No : 24-25/16

Dt 28-05-2024

Sr. No	W.O. No	Code No Plant Code	Job Discription	HSN/ SAC	Qty.	Rate Each	GST %	Amount
1			7.5kw, 10hp, Rpm-1400, Fr-E132M, Chaina Mke FLP Motor (01 Nos)					0.00
a			Motor Overhauling	998717	1	1057.50	18	1057.50
b			6208 ZZ C3 Our Bearing Repalce	998717	2	814.00	18	1628.00
c			DE Side Housing Sleeve Fixing	998717	1	581.00	18	581.00
d			Couple Size Welding & Turning & Key Way	998717	1	1162.00	18	1162.00
e			New Pvc Fan.	998717	1	343.00	18	343.00
f			New Fan Cover	998717	1	572.00	18	572.00
g			Making new key	998717	1	120.00	18	120.00
h			Drilling & Tapping	998717	4	75.00	18	300.00

GST %	GRS	CGST	SGST	IGST
18	5,763.50	518.72	518.72	0.00
	5,763.50	518.72	518.72	0.00

Total			5763.50
CGST%			518.72
SGST%			518.72
IGST %			0.00
ROUND UP			0.07

Rs. Six Thousand Eight Hundred One Only

Grand Total 6801.00

Bank Name : Bank of Baroda

A/c No : 26050400000041

Branch : Bank of Baroda, Dahej

ISFC Code : BARB0DAHEJX (Fifth Digit was Zero)

Terms & Conditions

Payment Immediatly/Within 30 Days by Cash/Chq/DD only.
 Payment If not made within time int. will @ 24% per amount.
 All Claim Must be notified in writing within 3 Days.
 No Amount Should be deducted from thew bill without our Confirmation.
 Subject to Bharuch Jurisdiction.

UDYAM-GJ-06-0020580

GSTIN : 24AAHFS2454D1ZH DT.1/4/17

State : Gujarat

State Code : 24

For STANDARD ENTERPRISE

Authorised Sign

Mo.: 94261 12911, 94268 80751

Email: info@standardenterprise.co.in

Email: standardenterprise@rediffmail.com

STANDARD ENTERPRISE

OFFICE & WORKSHOP: Plot No. E-339, GACL Chowkadi GIDC,

Dahej-392 130, Dist. Bharuch. Gujarat.

TEST CERTIFICATE OF ELECTRIC MOTOR

M/s.	BbELL Industries LLP	No.	189
	Saykha	Date :	30.05.24

Your RGP No.	24-25/16	Plant	Electrical	Date :	28.05.24
--------------	----------	-------	-------------------	--------	-----------------

Challan No.	445			Date :	30.05.24
-------------	-----	--	--	--------	-----------------

Motor Details	7.5kw,10hp,Rpm-1400,Fr-E132,Chaina Make FLP Motor	Tag No.	45-784
---------------	--	---------	---------------

Make	:	CGL/FLP	FLC	116
------	---	----------------	-----	------------

KW/HP	7.5kw/10hp	Volts	415
-------	-------------------	-------	------------

RPM	1400	Phase	3
-----	-------------	-------	----------

Frame	E 132	SrNo	
-------	--------------	------	--

Resistance With				Inductuns With				Meggar Value at 500 Volts			
RY		1.44 Ω		RY		10.8 mH		RE		500 MΩ	
YB		1.44 Ω		YB		10.8 mH		YE		500 MΩ	
BR		1.44 Ω		BR		10.8 mH		BE		500 MΩ	
Vibration				Bearing Temp.							
NDE				DE				NDE			
V-	0.6	V	0.9	39				38			
H-	0.8	H-	1.0.								
A-	0.5	A-	0.8								

No Load Current **R- 7.6 Y- 7.8 B - 8.0. Volts- 415 Δ**

Remarks	

At Client Site :

FLC **R** **Y** **B** **Amps**

Volts: **For, STANDARD ENTERPRISE**

Tested By _____

