



Allen-Bradley

PanelBuilder32

**Application Development
Software for PanelView
Standard Terminals**

Quick Start

**Rockwell
Automation**

Important User Information

Because of the variety of uses for the products described in this publication, those responsible for the application and use of this control equipment must satisfy themselves that all necessary steps have been taken to assure that each application and use meets all performance and safety requirements, including any applicable laws, regulations, codes and standards.

The illustrations, charts, sample programs and layout examples shown in this guide are intended solely for purposes of example. Since there are many variables and requirements associated with any particular installation, Allen-Bradley does not assume responsibility or liability (to include intellectual property liability) for actual use based upon the examples shown in this publication.

Allen-Bradley publication SGI-1.1, *Safety Guidelines for the Application, Installation and Maintenance of Solid-State Control* (available from your local Allen-Bradley office), describes some important differences between solid-state equipment and electromechanical devices that should be taken into consideration when applying products such as those described in this publication.

Reproduction of the contents of this copyrighted publication, in whole or part, without written permission of Rockwell Automation, is prohibited.

Throughout this manual we use notes to make you aware of safety considerations:

ATTENTION



Identifies information about practices or circumstances that can lead to personal injury or death, property damage or economic loss

Attention statements help you to:

- identify a hazard
 - avoid a hazard
 - recognize the consequences
-

IMPORTANT

Identifies information that is critical for successful application and understanding of the product.

Allen-Bradley, MicroLogix, ControlLogix, SLC, PLC, RSLogix, RSLinx, PanelView, PanelBuilder32 are trademarks of Rockwell Automation
DeviceNet is a trademark of The Open DeviceNet Vendors Association
Modbus is a trademark of Modicon, Inc.
Microsoft, Windows, and Windows NT are registered trademarks of Microsoft Corporation in the United States and/or other countries.

Preface

| | |
|---|---|
| Contents of this guide | 2 |
| What you need | 3 |
| Download cables | 3 |
| Communication cables | 4 |
| Personal computer | 4 |
| Software | 5 |
| Sample application and ladder logic | 5 |

Chapter 1 - System setup

| | |
|--|----|
| Safety guidelines | 7 |
| DH-485 connections | 8 |
| RS-232 connections (DH-485 protocol) | 9 |
| RS-232 connections (DF1 protocol) | 10 |
| Remote I/O connections | 11 |
| DH+ connections | 12 |
| DeviceNet connections | 13 |
| ControlNet connections | 14 |
| EtherNet/IP connections | 15 |
| Modbus connections | 16 |
| Controller ladder logic | 16 |

Chapter 2 - Overview of application

| | |
|---|----|
| Purpose of application | 17 |
| Application screens | 18 |
| Motor Control and Status screen | 19 |
| Set Motor Speed screen | 20 |
| Alarm Banner | 21 |
| Application tags | 22 |

Chapter 3 - Creating the application

Starting PanelBuilder32 23

Creating a new application..... 24

Creating the Set Motor Speed screen 26

Creating objects on the Motor Status screen 27

 Creating the Start Motor push button 27

 Creating the Stop Motor push button 29

 Creating the Motor Speed screen button..... 31

 Creating the Motor Speed display 32

 Creating the Motor Status indicator..... 34

 Creating the screen title for the Motor Status screen 36

Creating objects on the Set Motor Speed screen 37

 Creating a numeric entry object for setting the motor speed 37

 Creating the Motor Status screen button..... 39

 Creating the screen title for the Set Motor Speed screen 40

Creating a Goto Config Screen button..... 40

Creating the alarm banner and messages 41

 Creating the alarm banner..... 41

 Defining an alarm trigger 42

 Defining alarm messages 42

Closing the screens..... 44

Defining the startup screen for the application 44

Saving the application 45

Converting application for another terminal type 45

Chapter 4 - Configuring communications

Configuring DH-485 communications 48

Configuring DH+ communications 49

Configuring Remote I/O communications 50

Configuring DeviceNet communications..... 51

Configuring ControlNet communications 52

Configuring EtherNet/IP communications 53

Configuring DF1 communications 54

Configuring Modbus Communications 55

Saving the application 55

Chapter 5 - Entering application tags

| | |
|---|----|
| Opening the tag editor | 57 |
| Description of the application tags | 58 |
| DH-485, DH+, and DF1 application tags | 58 |
| Remote I/O application tags | 58 |
| ControlNet unscheduled application tags | 59 |
| ControlNet scheduled application tags | 59 |
| DeviceNet application tags | 60 |
| Ethernet/IP application tags | 60 |
| Modbus application tags | 61 |
| Entering the application tags | 61 |
| Saving the application | 63 |

Chapter 6 - Downloading the application

| | |
|---|----|
| Checking the application for errors | 65 |
| Downloading the application | 66 |
| Close the application and exit PanelBuilder32 | 69 |

Chapter 7 - Running the application

| | |
|-------------------------------|----|
| Motor Status screen | 71 |
| Motor Speed screen | 72 |
| Alarm Banner | 73 |

Appendix A - Application programs

| | |
|---|-----|
| PanelBuilder32 application programs | 76 |
| Ladder logic programs | 77 |
| Scanner programs | 120 |

Welcome to PanelBuilder32. To help you get started and become a successful user of PanelBuilder32, this guide provides you with a sample application. It will take you through all the steps required to create, download, and run the application in a PanelView terminal.

Application tags and ladder logic are provided so that you can run the application on the following communication networks:

- DH+ or DH-485
- EtherNet/IP
- ControlNet (unscheduled and scheduled)
- DeviceNet (I/O messaging)
- Remote I/O
- DF1
- Modbus

For more information on PanelBuilder32 software features, refer to the Getting Results manual and the extensive online help available within PanelBuilder32.

PanelBuilder32 runs in the Microsoft Windows environment. You should be familiar with basic window operations such as using menus, dialogs and toolbars.

Contents of this guide

- Preface
An overview of this guide and what you need to create, download and run the sample application.
- Chapter 1 - *Initial system setup*
Describes the setup of system components.
- Chapter 2 - *Overview of sample application*
Provides a description of the sample application and its function.
- Chapter 3 - *Creating the sample application*
Provides step-by-step procedures for creating the sample application.
- Chapter 4 - *Configuring communications*
Shows how to configure network communications for your PanelView terminal and logic controller.
- Chapter 5 - *Entering application tags*
Shows how to use the tag editor to enter your application tags.
- Chapter 6 - *Downloading the application*
Shows how to validate and download your application to the PanelView terminal.
- Chapter 7 - *Running the application*
Shows how to run the application in the PanelView terminal.
- Appendix A - *Application Programs*
Listing of the available ladder logic programs suitable for your application. Also provides a printout of each program.

What you need

This section lists the requirements for creating, downloading and running the application on a Remote I/O, DH+, DH-485, ControlNet, DeviceNet, EtherNet/IP, DF1, or Modbus network.

Download cables

Your terminal has an RS-232 (DF1), RS-232 (DH485), or DH-485 port through which applications are transferred. Use the appropriate cable from the lists below.

RS-232 Programming Port - To download an application to an RS-232 programming port on a PanelView terminal, you will need a download cable. Use one of the following cables:

- Catalog No. 2706-NC13 (3 m/10 ft)
- Catalog No. 2711-NC13 (5 m/16.4 ft)
- Catalog No. 2711-NC14 (10 m/32.7 ft)

For the PanelView 300 Micro terminal, use one these cables:

- Catalog No. 2711-CBL-PM05 (5 m/15 ft)
- Catalog No. 2711-CBL-PM10 (10 m/30 ft)
- Catalog No. 1761-CBL-AP00 (.5 m/1.5 ft)
- Catalog No. 1761-CBL-PM02 (2 m/6.5 ft).

DH-485 Programming Port - To download an application to a DH-485 terminal you will need:

- Personal Computer Interface Converter (PIC), Catalog No. 1747-PIC and one these cables:
Catalog No. 1747-C10, -C11, -C20.

or

- 1761-NET-AIC link coupler and one these cables: 1747-CP3, 1761-CBL-AS03 (3 m/9.8 ft), or
1761-CBL-AS09 (9.9 m/27.5 ft).

The Personal Computer Interface Converter receives power from an SLC controller. If you are downloading to a terminal without an SLC connected, you will need either a power supply (Catalog No. 1747-NP1) or a powered link coupler (Catalog No. 1747-NET-AIC).

Communication cables

DH-485 PanelView Terminals - To connect a PanelView DH-485 port to a DH-485 connector on an SLC, use DH-485 cable (Catalog No. 1747-C10, -C11, -C20).

RS-232 (DF1 or DH485) PanelView Terminals - To connect a PanelView RS-232/DF1 or DH485 communications port to an RS-232 port on a controller, use RS-232 cable (Catalog No. 2706-NC13, 2711-NC13, or NC14). To connect to the 8-pin RS-232 port on the MicroLogix 1000/1200/1500LSP controller, use Catalog No. 2711-NC21 or -NC22. (Refer to the AIC+ Advanced Interface Converter user manual (1761-6.4) for additional network configurations.)

For the 300 Micro, use one of these cables: Catalog No. 2711-CBL-HM05, -HM10, -PM05, or -PM10.

Remote I/O Terminals - To connect a PanelView RIO port to an RIO port on a PLC, use cable (Catalog No. 1770-CD) which is equivalent to Belden 9463.

DH + PanelView Terminals - To connect a PanelView DH+ port to a DH+ port on a PLC, use cable Catalog No. 1770-CD which is equivalent to Belden 9463.

ControlNet Terminals - To connect a PanelView to a ControlNet network, use coaxial cable Catalog No. 1786-CP.

EtherNet/IP Terminals - To connect a PanelView to an EtherNet/IP network, use a Category 5 shielded and unshielded twisted-pair cable with RJ45 connectors.

DeviceNet Terminals -To connect a PanelView to a DeviceNet network, use cable Catalog No. 1485C-P1A50, -P1A150, -P1A300. (Refer to the AIC+ Advanced Interface Converter user manual (1761-6.4) for additional network configurations.)

Modbus Terminals - To connect a PanelView to a MicroLogix 1200/1500 controller on a Modbus network, use cable Catalog No. 2711-NC21 or -NC22.

Personal computer

The minimum requirements for running PanelBuilder32 are:

- 100MHz Pentium Class 2 or greater PC compatible
- 30 MB free hard disk space required for a minimum installation
- 270 MB free hard disk space required for a full package installation
- 32 MB of installed RAM (48 MB RAM recommended)
- CD-ROM drive
- 500K free conventional memory

Software

In addition to PanelBuilder32, you will also need to load the applicable controller programming and network configuration software:

SLC or MicroLogix

Advanced Programming Software (APS), SLC-500 AI Software, RSLogix 500

PLC

- 6200 Series Programming Software, PLC-5 AI Software, RSLogix 5

ControlLogix

- RSLogix 5000, version 2.01 or greater
- RSNetworks for DeviceNet or DeviceNet Manager
- RSNetworks for ControlNet

Sample application and ladder logic

IMPORTANT

Installing the sample applications on your computer's hard drive is an option available during the installation of PanelBuilder32. If these files were not installed, you can still access them off the installation CD from the autorun menu.

The PanelBuilder32 installation CD contains:

- Sample applications (.PBA) for each of the PanelView terminals.
- Ladder logic to run the application for each of the communication protocols.

Refer to Appendix A for a list of these files.

PanelBuilder32 Application (.pba) files are located in the Quick Start\PV directory on the PanelBuilder32 installation CD.

Ladder Logic Program (.rss, .rsp, .acd) files are located in the Quick Start\SLC, \ML, \CL or \PLC directories on the PanelBuilder32 installation CD.

All other program files, such as DeviceNet SDN, scanner files are located in the Quick Start\DNet, or \CNet directories on the PanelBuilder32 installation CD.

System setup

PanelView terminals are available with many different communication options. In this chapter we provide a brief summary of the minimum equipment setups required to run the sample application. For specifics such as cable termination and baud rates, we recommend that you refer to the user and/or communications manual provided with your terminal. Refer to the section that applies to your terminal type.

- DH-485
- RS-232 (DH485)
- RS-232 (DF1)
- RIO
- DH+
- DeviceNet
- ControlNet
- EtherNet/IP
- Modbus


Safety guidelines

Refer to the PanelView Standard Operator Terminals user manual, Publication 2711-UM014B-EN-P, for installation instructions and safety precautions.

If you are running this sample application as a pre-installation desktop setup, the same safety precautions still apply. Make sure that you disconnect power from devices prior to making any communication connections.


DH-485 connections

DH-485 PanelView terminals communicate with external devices through either the DH-485 communications port or DH-485 programming connector. Some DH-485 terminals have an RS-232 port for printing.



RS-232 connections (DH-485 protocol)

RS-232 (DH485) versions of the PanelView terminal are available with one or two RS-232 ports. On terminals with two RS-232 ports, one of the ports is a printer port. The other RS-232 communication port is for connection to an SLC or computer.




Note: Use the same cable to transfer applications to the terminal and to the SLC 5/03, 5/04, 5/05 controller. Change cable connection to controller after downloading.

IMPORTANT

You must configure the Channel 0 Port of the SLC 5/03, 5/04, 5/05 or MicroLogix controller for DH-485 communications using APS, AI500 or RSLogix 500 programming software.


RS-232 connections (DF1 protocol)

DF1 versions of the PanelView terminal have a DF1 (Full Duplex) communications port and an RS-232 file transfer/port. The DF1 port on the PanelView is a 9-pin, male, RS-232 connector.




Remote I/O connections

Remote I/O versions of the PanelView terminal have both an RIO adapter and an RS-232 file transfer/printer port. The RIO adapter allows the terminal to connect to any 1771 Remote I/O link. The PanelView connects to an RIO scanner using cable (Catalog No. 1770-CD, equivalent to Belden 9463).




DH+ connections


DH+ versions of the PanelView terminal have a DH+ Communications Port and an RS-232 file transfer/printer port. Connect the PanelView to a DH+ link using Belden 9463 twin-axial cable (Catalog No. 1770-CD).



DeviceNet connections


DeviceNet versions of the PanelView terminal have a DeviceNet Communications Port and an RS-232 Port for file transfers/printing. Connect the PanelView to a DeviceNet link using DeviceNet cable (Catalog No. 1485C-P1A50, -P1A150, -P1A300). The illustration shows an SLC or PLC controller. Another option would be a ControlLogix controller with a 1756-DNB module.



| DeviceNet Terminal Block | Terminal | Signal | Function | Color |
|---|----------|--------|--------------|-------------|
|  | 1 | COM | Common | Black |
| | 2 | CAN_L | Signal Low | Blue |
| | 3 | SHIELD | Shield | Uninsulated |
| | 4 | CAN_H | Signal High | White |
| | 5 | VDC+ | Power Supply | Red |


ControlNet connections

ControlNet versions of the PanelView terminal have both a ControlNet Communications Port and an RS-232 port for file transfers/printing. Connect the PanelView to a ControlNet link using BNC Coaxial Cable (Catalog No. 1786-RG6).




EtherNet/IP connections

EtherNet/IP versions of the PanelView terminal have both an Ethernet port and an RS-232 port for file transfers/printing. Connect the PanelView to a ControlLogix (with 1756-ENET/B or ENBx module), PLC-5E, or SLC 5/05 controller. The EtherNet/IP network uses a Category 5 shielded and non-shielded twisted-pair cable with RJ45 connectors.



Modbus connections

Modbus versions of the PanelView terminal have both a Modbus Communications Port and an RS-232 File/Transfer Printer Port. The following illustration shows a Modbus PanelView terminal connected to a MicroLogix controller using cable 2711-NC21 or -NC22.



Controller ladder logic

The controller logic programs for running the sample application are already created for you. The files are provided on the PanelBuilder32 installation CD. Refer to Appendix A for a list of these files.

Overview of application

This chapter covers:

- purpose of application
- overview of application screens
- application tags

Purpose of application

The application contains objects that control and monitor the status of a motor. Depending on the communication protocol used, the PanelView terminal reads/writes data to either:

- SLC, MicroLogix, FlexLogix or CompactLogix controller on a DH-485 network
- SLC, PLC-5, or ControlLogix controller on a DH+ network
- SLC, PLC-5 or ControlLogix controller on a Remote I/O network
- SLC, PLC-5, MicroLogix, FlexLogix, CompactLogix, or ControlLogix controller on an RS-232 (DF1) network
- ControlLogix, PLC-5, or SLC controller on a DeviceNet network
- ControlLogix or PLC-5C controller on a ControlNet network (unscheduled)
- ControlLogix controller on a ControlNet network (scheduled)
- ControlLogix, PLC-5E, or SLC 5/05 controller on an EtherNet/IP network
- MicroLogix 1200/1500 Series C on a Modbus network

Chapter 4 give procedures for creating the application on a PanelView 600 keypad terminal.

- If creating the application for a touch screen terminal, touch cell input is automatically enabled and you do not have to assign function keys.
- If creating the application for other size terminals, use the appropriate text sizes.

You can create any of the sample applications for another PanelView terminal size. For instructions on how to do this, see page 45.



All of the sample applications are on the installation CD in the \QuickStart\PV directory.

Application screens

The application contains 3 screens:

- **Motor Status** - contains objects to start or stop a motor, show the on/off status of the motor, and display the current motor speed.
- **Set Motor Speed** - contains a numeric entry object allowing you to enter a maximum speed for the motor.
If the motor speed is changed, the new speed won't take effect until the motor is stopped and started again.
- **Alarm Banner** - global display that opens over the Motor Status or Set Motor Speed screen when an alarm is triggered.


The Motor Status and Set Motor Speed screen each contain a screen button allowing you to navigate between the two screens.

If you want the operator to access the Configuration Mode menu from a touch screen terminal, you should include a Goto Config screen button on the application screen. On keypad only terminals, press the left  and right  arrow keys simultaneously on the terminal's keypad to display the configuration menu.

Motor Control and Status screen

The Motor Status screen appears when you apply power to the terminal. It allows you to:

- start or stop a motor
- view the on/off status of the motor
- view the speed of the motor
- navigate to the Set Motor Speed screen




The following table lists the objects on the Motor Status screen and their functions. Screen headings are created as background text.

| Object | Object Type | Function |
|--------------------------------|---------------------------------------|---|
| Start Motor F1 | Momentary Push Button (Normally Open) | Starts the motor when you press the F1 key or touch the screen object. |
| Stop Motor F2 | Momentary Push Button (Normally Open) | Stops the motor when you press the F2 key or touch the screen object. |
| Motor Running Motor Stopped | Multistate Indicator | Shows the on/off status of the motor. |
| Motor Speed ### | Numeric Data Display | Shows the current motor speed. |
| Motor Speed F3 | Goto screen button | Displays the Set Motor Speed screen when you press the F3 key or touch the screen object. |

Set Motor Speed screen

The Set Motor Speed screen allows you to:

- enter a maximum speed setting for the motor
- navigate to the Motor Status Screen




The following table lists the objects on the Set Motor Speed screen and their functions. The screen heading and object labels are created as background text.

| Object | Object Type | Function |
|---|--------------------|--|
| Enter Maximum Speed: <div>####</div> rpm | Numeric Entry | Opens the numeric scratchpad (when you press the F1 key or touch the screen object) where you enter the maximum motor speed (600 to 1800 RPM). |
| <div>Motor Status F2</div> | Goto Screen Button | Displays the Motor Status screen when you press the F2 key or touch the screen object. |

Alarm Banner

The Alarm Banner is a global display that opens over the Motor Status or Set Motor Speed screen when an alarm is triggered. It displays an alarm message when the motor speed exceeds 1200 rpm and another message when the motor speed exceeds 1500 rpm.



The following table lists the objects on the Alarm Banner and their functions.

| Object | Object Type | Function |
|--|--------------------------|--|
| <div>MOTOR SPEED HIGH!</div> <div>MOTOR SPEED HIGH-HIGH!</div> | Alarm Text | Displays messages when the motor speed reaches 1200 rpm and 1500 rpm. |
| <div>Ack F4</div> | Acknowledge Alarm Button | Acknowledges the alarm in the alarm banner when you press the F4 key or touch the screen object. |

Application tags

The sample application requires only 6 tags. Tags are a group of parameters that define a controller address. Each tag is identified by a unique name.

These are the tags that are used in this application. Notice how the tags are assigned descriptive names. This makes it easier to create and modify an application.

- **Start_Motor** - assigned to the motor start button
- **Stop_Motor** - assigned to the motor stop button
- **Motor_Status_Ind** - assigned to the motor status indicator
- **Motor_Speed** - assigned to the motor speed data display
- **Set_Max_Motor_Speed** - assigned to the data entry display for motor speed
- **Speed_Alarm** - assigned to the trigger for the alarm banner

Tag information is entered using either:

- **Tag Form dialog** - accessed from an object's dialog by clicking the **Edit Tags** button. Allows editing of all tag fields.
- **Tag Editor** - accessed from the **Tools** menu or the System folder in the Application window. The tag editor displays all of the assigned tags within the application and allows editing of most tag fields.

Each application requires slightly different tag information depending on the communication protocol. Chapters 4 and 5 provide the information you need for each terminal type along with instructions for entering tags.


Creating the application

Follow the procedures in this chapter to:

- create the application screens (Motor Status, Set Motor Speed, Alarm Banner)
- select the startup screen for the application
- save the application

Starting PanelBuilder32

Click **Start** on the taskbar, then select **Programs>PanelBuilder32>PanelBuilder32**.




The PanelBuilder32 workspace opens with the startup dialog.

Creating a new application

1. From the startup dialog, select **Create a new application** and click **OK**.




2. In the **Create New Application** dialog, enter a name for your application and select a PanelView terminal (type, protocol and type of operator input)




3. Click **OK** to exit the dialog.

The Application window opens showing the name of the application in the title bar. A blank screen opens with a default name and number - Screen 1.




Renaming and changing the color of Screen 1

1. Select **Screen>Properties** or right-click on Screen 1 in the Screens folder and select **Properties** from the shortcut menu.




2. Type Motor Status in the **Name** field of the dialog
3. In the **Background** box, select White to change the screen background color.
4. Click **OK** to exit the dialog.

The screen's background is now white. The new screen name appears in the title bar of the screen and on the screen icon in the Screens folder.




Creating the Set Motor Speed screen

1. Select **Screen>New** or right-click on the Motor Status screen in the Screens folder and select **New** from the shortcut menu.



2. Enter screen properties as shown above.
3. Click **OK** to exit the dialog.


A blank screen is opened with the screen name and number showing in the title bar. The Application Window also contains an icon for the new screen.




4. Click the Minimize button on the Set Motor Speed screen to reduce the window while you work on the Motor Status screen.

Creating objects on the Motor Status screen

Creating the Start Motor push button




1. Select **Objects>Push Buttons>Momentary**.



2. Position the pointer (+) in the lower left of the screen where you want to draw the button, hold down the left mouse button and drag to size the button.




3. Double-click the object to open its dialog and set the properties as shown below.





Note: You will enter definitions for tags in Chapter 5.


4. Click the **States** tab of the Push Buttons dialog.
- Each row defines text and formatting options for a push button state. Row 0 is state 0, row 1 is state 1. The default text for a 2-state push button is ST 0 and ST 1.




5. Double-click in the Message Text field of each row and change the text as shown below. Also, change the default colors for the object and text.



6. Click **OK** when done to exit dialog. The F1 key shows an icon of the push button indicating the key is assigned to an object.
- If you see an asterisk (*), the object is too small to fit the text. Click on the object and drag a handle until all of the text fits.



Creating the Stop Motor push button




The F1 and F2 keys both have icons showing they are currently assigned to objects.

The Stop Motor push button is created using copy and paste commands.



1. Select (left-click on) the Start Motor button (if not selected).
2. Select **Edit>Copy** or click the **Copy** tool on the toolbar.
3. Select **Edit>Paste** or click the **Paste** tool on the toolbar.
An outline of the button appears.
4. Move the outline to the right of the Start Motor push button and click the left mouse button to paste it on the screen.



5. Double-click the pasted button to open its dialog and set the following properties.

Select F2 →

Push Buttons -- Sample.PBA

Properties | States | Options

Type: Momentary

Write

☒ Single Bit

☐ Value

Data Format:

Initial State: 0

Hold Time: 500 ms

Input

Function Key: F2

☐ Touch Cell

Contacts

☒ Normally Open

☐ Normally Closed

Data Tags

Edit Tag...


Write Tag: Stop_Motor

Indicator Tag:

Handshake Tag:


Replace Start_Motor with Stop_Motor

6. Click the **States** tab of the Push Buttons dialog.



7. Double-click in the Message Text field of each state and replace the text as shown below.


| | |
|---------------------|------------------|
| State 0 | State 1 |
| Stop Motor F2 | Motor Stopped |




Remember, /*R*/ indicates a carriage return.

8. Click **OK** to exit the dialog.

Creating the Motor Speed screen button



1. Select **Objects>Screen Selectors>Goto**.



2. Position the pointer (+) in the lower right area of the screen where you want to draw the button. Hold down the left mouse button and drag to size the button.
3. Select **Format>Toggle Fore/Background** to reverse the object colors.





4. Select **Format>Inner Text** or click the **Inner Text** tool.

The Inner Text toolbar opens showing the default text for the button.

Hint: Click the Down Arrow at the right of the Text box to edit the text in a Text Edit dialog.




5. Replace the default text as shown below. As you replace the text it is also entered in the object.



6. Click anywhere outside the object to exit inner text mode.


The F3 key now shows an icon to show it is assigned to an object.

7. Double-click the Motor Speed screen button.
8. Select the properties as shown below.



9. Click **OK** to exit the dialog.

Creating the Motor Speed display




1. Select **Objects>Numeric Data Display**.
2. Position the pointer (+) above the Motor Speed screen button. Hold down the left mouse button and drag to size the button.
The object is created with ##### characters as a placeholder for the numeric value. Each # represents a digit. The initial field width is 6 digits.



3. Select **Format>Toggle Fore/Background** to reverse the object colors.

4. Double-click the object to opens its dialog. Enter properties as shown below.




5. Click **OK** to exit the dialog.
The object now shows four #### characters as the maximum field width for the numeric value.
6. Select **Objects>Text** to create the label Motor Speed above the object.
7. Position the pointer (+) above the numeric data display, hold down the left mouse button and drag to draw the text box. You are placed in text mode.
8. Enter the text as shown below. As you enter the text it also entered in the object.




9. Click the **Toggle Fore/Background** icon to reverse the text colors.



Creating the Motor Status indicator



1. Select **Objects>Indicator>Multistate**.



2. Position the pointer (+) above the Start and Stop Motor push buttons, hold the left mouse button and drag to size the button.

3. Select **Format>Toggle Fore/Background** to reverse the object colors.

4. Double-click the object to open its dialog and then click the **States** tab.

Each row defines text and formatting options for each indicator state. Row 0 is state 0, row 1 is state 1. The default text for a multistate indicator is ST 0, ST 1, ST2, ST3. Indicators are initially created with 4 states (ST 0 - ST 3).

5. Select rows 2 and 3. (Select row 2, hold down the Shift key and click row 3). Right-click and select **Delete State** from the shortcut menu.

State 0


State 1

| | Message Text | Graphic | Blink | Fill | Object Background | Object Foreground | T |
|---|--------------|---------|--------------------------|------|-------------------|-------------------|------|
| 0 | ST 0 | None | <input type="checkbox"/> | | Blue | White | Blue |
| 1 | ST 1 | None | <input type="checkbox"/> | | Blue | White | Blue |
| 2 | ST 2 | None | <input type="checkbox"/> | | Blue | White | Blue |
| 3 | ST 3 | None | <input type="checkbox"/> | | Blue | White | Blue |
| E | Error | None | <input type="checkbox"/> | | Blue | White | Blue |


Shortcut Menu:

- Cut (Ctrl+X)
- Copy (Ctrl+C)
- Paste (Ctrl+V)
- Insert and Paste (Ctrl+N)
- Append State (Ctrl+A)
- Insert State (Ins)
- Delete State (Del)
- Move State Up (Ctrl+U)
- Move State Down (Ctrl+D)
- Select All (Ctrl+L)
- Embedded Variable
- Use Existing Text...
- New Text ID

6. Double-click in the Message Text field of row 0 and 1 and change the text as shown below.




7. Click the **Properties** tab and set the properties as shown below.



Note: Because **Single Bit** only supports 2 states (State 0 and State 1), you must delete the extra states on the **States** tab before selecting **Single Bit** on the **Properties** tab.

8. Click **OK** to exit the dialog.

Creating the screen title for the Motor Status screen



1. Select **Objects>Text**.
2. Position the pointer (+) at the top of the screen, hold down the left mouse button and drag to draw the text box. You are placed in text mode.
3. Enter the text as shown below. As you enter the text it also entered in the text box.




4. Click the **Toggle Fore/Background** tool to reverse the foreground and background colors of the object.
5. Click the **Text Size** tool and select 8 x 24 from the menu.
6. Deselect the object by clicking anywhere outside the object.

Hint: An asterisk appears (*) if the text box is too small for the text. Select the object and then drag a handle to size the text box until the text fits.


| | |
|------------------|--|
| IMPORTANT | Select Arrange>Bring Dynamic Objects to Front to move control objects to the front of other objects. This ensures that control objects are not covered by static objects such as text. |
|------------------|--|

Creating objects on the Set Motor Speed screen

Creating a numeric entry object for setting the motor speed



1. Open the Set Motor Speed screen (Screen 2) by clicking on the title bar of the minimized screen.
2. Select **Objects>Numeric Entry>Cursor Point**.




3. Position the pointer (+) in the middle of the screen, hold down the left mouse button and drag to draw the object.

The object is created with six ##### characters as a placeholder for the numeric value. Each # represents a digit. The initial field width is 6 digits.



4. Select **Format>Toggle Fore/Background** to reverse the object colors.

- Double-click the object and set the properties as shown below.



- Click **OK** to close the dialog.
The object shows four ##### characters as the maximum field width for the numeric value.
- Select **Objects>Text**.
- Position the pointer (+) above the numeric entry object, hold down the left mouse button and drag to draw the text box. You are placed in text mode.
- Enter the text as shown below. As you enter the text it is also entered in the text box.



- Click the **Toggle Fore/Background** tool to reverse the foreground and background colors of the object.

- Deselect the object by clicking anywhere outside the object.

Hint: An asterisk (*) appears if the text box is too small for the text. Select the object and then drag a handle to size the text box until the text fits.

Creating the Motor Status screen button



The Motor Status screen button is created by copying the Motor Speed screen button from screen 1 and then editing the button properties.

1. Select the Motor Speed screen button on the Motor Status screen. (Click anywhere in the Motor Speed screen to activate the screen.)



2. Select **Edit>Copy** or click the **Copy** tool on the toolbar.

3. Click in the Set Motor Speed screen, or screen 2.



4. Select **Edit>Paste** or click the **Paste** on the toolbar.

An outline of the button appears.


5. Move the object to the lower right of the screen and click the left mouse button to paste it.



6. Click the **Inner Text** tool to edit the text in the button. Replace the current text with the new text as shown below.



7. Double-click the object to open its dialog.



8. Click **OK** to exit the dialog.

Creating the screen title for the Set Motor Speed screen

1. Select **Objects>Text**.
2. Position the pointer (+) at the top of the screen, hold down the left mouse button and drag to draw the text box. You are placed in text mode.
3. Enter the text as shown below. As you enter the text it also entered in the text box.



4. Click the **Toggle Fore/Background** tool to reverse the foreground and background colors of the object.



5. Click the **Text Size** tool and select 8 x 24 from the menu.
6. Deselect the object by clicking anywhere outside the object.

Hint: An asterisk (*) appears if the text box is too small for the text. Select the object and then drag a handle to size the text box until the text fits.

IMPORTANT


Select **Arrange>Bring Dynamic Objects to Front** to move control objects to the front of other objects. This ensures control objects are not covered by static objects such as text.

Creating a Goto Config Screen button

This section applies to touch screen only terminals. If you are creating the sample application for a keypad terminal, skip this section.

To allow an operator access to the touch screen only terminal's configuration mode menu, a Goto Config Screen button is required.

1. Select **Objects>Screen Selectors>Goto Config Screen**.
2. Position the pointer (+) to the left of the screen button on each screen. Hold down the left mouse button and drag to draw the object.
3. Select **Format>Toggle Fore/Background** to reverse the object colors.



Motor Status Screen



Set Motor Speed Screen

Creating the alarm banner and messages



In this section, you will create:

- alarm banner that opens over the current screen when an alarm is triggered. The banner will contain a message display and an Acknowledge button.
- alarm trigger tag defining the address where the controller writes a bit to trigger an alarm.
- alarm messages to appear in the alarm banner when an alarm is triggered

Creating the alarm banner

1. Select **Screen>Create Alarm Banner**.

The Alarm Banner is created in the Screens folder. The default banner appears with a message display and a Clear button.



On color terminals, the background color is red, the foreground color is white. On monochrome terminals, the background is white and the foreground black.

2. Decrease the height of the banner by clicking on the bottom handle and drag up.


3. Deselect the banner by clicking outside the banner.

4. Click on the Clear button and then select **Edit>Cut** or the **Cut** tool.

5. Select **Objects>Alarm Buttons>Acknowledge**.

6. Position the pointer (+) in the banner and left-click to drop the object.

7. Double-click the Ack button to open its dialog. Select the F4 key.



Select F4




8. Click **OK** to exit the dialog.

9. Select **Format>Inner Text** and enter Ack/*R*/F4 in the text box.

Defining an alarm trigger

This section defines the trigger tag. When an alarm condition occurs, a value is sent to the trigger tag address.


1. Double-click the **Alarm Triggers** icon in the Alarms folder.
Or select **Application>Alarm Setup** and select the **Alarm Triggers** tab.



2. Type **Speed_Alarm** in the **Trigger Tag** field.
3. Select **Bit** from the **Trigger Type** field.


Defining alarm messages

1. Select the **Alarm Messages** tab on the Alarms dialog.
Each row defines an alarm message and its attributes.



2. Right-click and select **Append Alarm** from the shortcut menu to add a row.

3. For each row, edit the following attributes shown below:
- Double-click in the Message Text field and type the alarm message.
 - Double-click in the Value/Bit (Bit offset) field and enter the value shown.
 - Click the check box in the Ack field.



4. Click **OK** to exit the Alarms dialog.

Bit triggered alarm messages are defined by a bit offset (Value/Bit field) from the Trigger Tag address. For example, if the Trigger Tag address is defined as B3:1/0, alarm messages can be triggered from addresses B3:1/1 and B3:1/2.

- When the motor speed reaches 1200 rpm, the logic controller sets bit B3:1/2, triggering an alarm condition. The message MOTOR SPEED HIGH! will appear in the alarm banner.

B3:1/0

Trigger Tag Address

+

2

Value/Bit of Alarm Message

=

B3:1/2

Logic Controller Address

- When the motor speed reaches 1500 rpm, the logic controller sets bit B3:1/1, triggering an alarm condition. The message MOTOR SPEED HIGH HIGH! will appear in the alarm banner.

B3:1/0

Trigger Tag Address

+

1

Value/Bit of Alarm Message

=

B3:1/1

Logic Controller Address

Closing the screens


Close each screen by clicking the X in the title bar of the screen. Or select **Screen>Close** to close each screen.



Or select **Windows>Close all Current Application Screens** to close all screens.

Defining the startup screen for the application

1. Select **Application>Settings**.
2. Select the **Power-Up** tab.
3. From the **Startup Screen** list box, select **Motor Status**.




4. Click **OK** to exit the dialog.

Saving the application



1. Select **File>Save** or click the **Save** icon on the toolbar.

The file is saved to a default location using the application name and the .PBA file type.



2. Click the **Save** button to exit and save the application.

File is saved to **Program Files>Allen-Bradley>PanelBuilder32>Applications**.


Hint: The next time you select File>Save the Save As dialog doesn't open. The file is saved to disk with the application name and the .PBA file type.

Converting application for another terminal type

The sample application was created for the PanelView 600 keypad terminal and is available for DH-485, DH+, DF1, Remote I/O, DeviceNet, EtherNet/IP, ControlNet and Modbus protocols. You can convert any one these applications to another terminal size such as PanelView 1000 by following the procedure below.

1. Select **Application>Settings**.
2. Click the **Setup** tab.

3. Select the PanelView terminal for which you want to convert the application.



4. When you click **OK**, the application is converted and validated for any errors.
If the application is converted successfully, the Exceptions window shows the message:
[Application] Conversion Passed - No Errors Found

IMPORTANT

Depending on the terminal size, you may want to reposition and resize objects appropriately. You may also want to adjust the text sizes.

If the terminal uses a different protocol, you can select the **Convert** option on the **Edit Tag** tab of the **Tools>Options** dialog and the tag editor will convert the current tags to the appropriate fields for the new protocol. You still need to update the tag data.

Configuring communications

This chapter shows how to configure network communications for your PanelView terminal and logic controller. Configuration is provided for the following communication protocols:


- **DH-485** - configures a DH-485 PanelView Terminal and an SLC or MicroLogix controller
- **DH+** - configures a DH+ PanelView terminal and a PLC-5, SLC 5/04, or ControlLogix DH+ module.
- **Remote I/O** - configures a Remote I/O terminal and a PLC-5, SLC 5/03, 5/04 or 5/05 controller with a 1747-SN/B scanner or ControlLogix DHRIO module.
- **ControlNet** - configures a ControlNet PanelView terminal and a ControlLogix CNet module or PLC-5 controller using scheduled or unscheduled messaging.
- **DeviceNet** - configures a DeviceNet PanelView terminal to communicate as a slave device to a PLC-5, SLC, or ControlLogix with a DeviceNet module.
- **EtherNet/IP** - configures an EtherNet/IP PanelView terminal to communicate with a ControlLogix controller (with 1756-ENET/B or /ENBx module), PLC-5E or SLC 5/05 on an EtherNet/IP network.
- **DF1**- configures a DF1 PanelView terminal and a PLC-5, SLC 5/03, 5/04, 5/05, MicroLogix, or ControlLogix controller. For a ControlLogix serial port, select PLC-5 controller type.
- **Modbus** - configures a Modbus PanelView terminal and a MicroLogix 1200/1500 Series C.

Refer to the section that is appropriate for your terminal.

Configuring DH-485 communications

This section defines the communication settings for a DH-485 PanelView terminal and logic controller on a DH-485 network.

1. Select **Application>Settings**.
2. Select the **Terminal Setup** tab.
3. Click the **Comms. Setup** button and set the parameters as shown below.
To add a network node, right-click on the **Node Name** field. Enter the **Node Name**, **Node Address** and **Node Type** for the controller you are using.



4. Click **OK** until you exit the **Application Settings** dialog.

Configuring DH+ communications

This section defines the communication settings for a DH+ PanelView terminal and logic controller on a DH+ network.

1. Select **Application>Settings**.

2. Select the **Terminal Setup** tab.


3. Click the **Comms. Setup** button.

4. Set the parameters as shown below.

To add a network node, right-click on the **Node Name** field. Enter the **Node Name**, **Node Address** and **Node Type** of the logic controller you are using.

IMPORTANT

For ControlLogix controller, select a PLC-5 as the Node Type.




5. Click **OK** until you exit the **Application Settings** dialog.

Configuring Remote I/O communications

This section defines the communication settings for a Remote I/O PanelView terminal and logic controller on a Remote I/O network.

1. Select **Application>Settings**.
2. On the **Terminal Setup** tab, click the **Comms. Setup** button. Set the properties as shown.




3. Click **OK** until you exit the **Application Settings** dialog.

Configuring DeviceNet communications

This section defines the communication settings for a DeviceNet PanelView terminal operating as a slave device on a DeviceNet network.

1. Select **Application>Settings**.
2. On the **Terminal Setup** tab, click the **Comms. Setup** button. Set the properties as shown.




3. Click **OK** until you exit the **Application Settings** dialog.

Configuring ControlNet communications

This section defines the communication settings for a ControlNet PanelView terminal and ControlLogix controller on a ControlNet network.

1. Select **Application>Settings**.
2. On the **Terminal Setup** tab, click the **Comms. Setup** button. Set the properties as shown.



1 for Allen-Bradley PLC
 1 1 0 for ControlLogix, where:
 1 refers to the 1784-CNB node number (1 to 99)
 1 refers to the ControlLogix backplane number
 0 refers to ControlLogix slot number
 You must enter a space between the numbers as shown.

3. Click **OK** until you exit the **Application Settings** dialog.

Configuring EtherNet/IP communications

This section defines the communication settings for an EtherNet/IP PanelView terminal and a ControlLogix controller on an Ethernet/IP network.

1. Select **Application>Settings**.
2. On the **Terminal Setup** tab, click the **Comms. Setup** button. Set the properties as shown.

The image shows three overlapping dialog boxes from the Rockwell Automation software:

- Application Settings -- Sample**: The **Terminal Setup** tab is active. The **Terminal Name** is "Sample". The **Selected Terminal** is "2711-K6C20 PV600 Color Key, FRN 4.20-4.xx". The **PanelView** section shows **Type** as "PV600" and **Protocol** as "EtherNet". The **Comms. Setup** button is highlighted.
- Communications Setup - Ethernet**: The **Terminal** section shows "new" and "InterScan Delay" set to "100 ms". The **Ethernet Config** button is highlighted. The **Network Nodes** table is shown below:

| * | Node Name | Node Address | Path | Node Type |
|---|-----------|--------------|------|------------------|
| * | LC_1 | 10.0.0.1 | 1 0 | ControlLogix5000 |
- Ethernet Configuration**: The **DHCP/BootP Enable** checkbox is unchecked. **IP Address** is "10 . 0 . 0 . 2", **Subnet Mask** is "255 . 255 . 255 . 0", and **Gateway Address** is empty. The **DNS Enable** checkbox is unchecked. **DNS Server** is "0 . 0 . 0 . 0" and **Domain Name** is empty. The **Timeouts** section shows **Connection Timeout** as "15000 ms", **Reply Timeout** as "15000 ms", and **Inactivity Timeout** as "10 minutes".

Annotations with arrows point to the following elements:


- "Verify that the catalog number and firmware number matches your hardware." points to the **Selected Terminal** text in the **Application Settings** dialog.
- "Important: LC_1 is entered to match the Node name in the Tag Editor." points to the **Node Name** "LC_1" in the **Communications Setup** table.
- "Enter the Node Address, Path, and Node Type as shown." points to the **Node Address** "10.0.0.1", **Path** "1 0", and **Node Type** "ControlLogix5000" in the **Communications Setup** table.
- "Click the **Ethernet Config** button. Set parameters as shown." points to the **Ethernet Config** button in the **Communications Setup** dialog.

3. Click **OK** until you exit the **Application Settings** dialog.

Configuring DF1 communications

This section defines the communication settings for a DF1 PanelView terminal and a PLC-5 or SLC 5/03, /04, /05 controller through channel 0.

1. Select **Application>Settings**.
2. On the **Terminal Setup** tab, click the **Comms. Setup** button. Set the properties as shown.




3. Click **OK** until you exit the **Application Settings** dialog.

Configuring Modbus Communications

This section defines the communication settings for a Modbus PanelView terminal and a MicroLogix controller.

1. Select **Application>Settings**.
2. On the **Terminal Setup** tab, click the **Comms. Setup** button. Set the properties as shown.



Important:
LC_1 is entered to match the
Node name in the Tag Editor.

Select Modbus as the
Node Type.

Saving the application



Select **File>Save** or click the **Save** tool on the toolbar.

Entering application tags

This chapter shows how to:


- open the tag editor
- enter tags in the worksheet for each communication protocol
- save the tags

Opening the tag editor

To open the tag editor:

- Select **Tools>Tag Editor**.
- Or open the **System** folder in the Application window and double-click on the **Tag Editor** icon.

A blank worksheet opens with the protocol name on its tab. The tag editor has its own menu bar and toolbar that remains active until you close the tag editor.



Description of the application tags

DH-485, DH+, and DF1 application tags

The following application tags are used by the DH-485, DH+, and DF1 applications. Defaults are accepted for fields not shown in table. These tags are also used for EtherNet/IP (to a PLC-5E or SLC) and ControlNet (to a PLC-5C).

| Tag Name | Data Type | Tag Address | Description | Node Name | Initial Value | Min | Max |
|---------------------|------------------|-------------|---------------------------|-----------|---------------|-----|-------|
| Start_Motor | Bit | B3:0/0 | Starts the motor | LC_1 | 0 | 0 | 0 |
| Stop_Motor | Bit | B3:0/1 | Stops the motor | LC_1 | 0 | 0 | 0 |
| Motor_Status_Ind | Bit | B3:0/2 | Shows on/off motor status | LC_1 | 0 | 0 | 0 |
| Motor_Speed | Unsigned Integer | N7:0 | Shows the motor speed | LC_1 | 0 | 0 | 65535 |
| Set_Max_Motor_Speed | Unsigned Integer | N7:1 | Sets the maximum speed | LC_1 | 1800 | 600 | 1800 |
| Speed_Alarm | Bit | B3:1/0 | Triggers alarm messages | LC_1 | 0 | 0 | 0 |

Remote I/O application tags

The following application tags are used by the Remote I/O application. Defaults are accepted for fields not shown in table.

| Tag Name | Data Type | Tag Address | Description | Node Name | Initial Value | Min | Max |
|---------------------|------------------|-------------|---------------------------|-----------|---------------|-----|-------|
| Start_Motor | Bit | I:010/0 | Starts the motor | LC_1 | 0 | 0 | 0 |
| Stop_Motor | Bit | I:010/1 | Stops the motor | LC_1 | 0 | 0 | 0 |
| Motor_Status_Ind | Bit | O:010/0 | Shows on/off motor status | LC_1 | 0 | 0 | 0 |
| Motor_Speed | Unsigned Integer | O:011 | Shows the motor speed | LC_1 | 0 | 0 | 65535 |
| Set_Max_Motor_Speed | Unsigned Integer | I:011 | Sets the maximum speed | LC_1 | 1800 | 600 | 1800 |
| Speed_Alarm | Bit | O:012/0 | Triggers alarm messages | LC_1 | 0 | 0 | 0 |

ControlNet unscheduled application tags

The following application tags are used by the ControlNet application using unscheduled messaging. **Note:** Tags are shown for a ControlLogix application. Defaults are accepted for fields not shown in table.

| Tag Name | Data Type | Tag Address | Description | Node Name | Initial Value | Min | Max |
|---------------------|--------------------|------------------|---------------------------|-----------|---------------|-----|-------|
| Start_Motor | Bit | Motor_Control.00 | Starts the motor | LC_1 | 0 | 0 | 0 |
| Stop_Motor | Bit | Motor_Control.01 | Stops the motor | LC_1 | 0 | 0 | 0 |
| Motor_Status_Ind | Bit | Motor_Control.02 | Shows on/off motor status | LC_1 | 0 | 0 | 0 |
| Motor_Speed | Signed Integer/INT | Motor_Speed[0] | Shows the motor speed | LC_1 | 0 | 0 | 65535 |
| Set_Max_Motor_Speed | Signed Integer/INT | Motor_Speed[1] | Sets the maximum speed | LC_1 | 1800 | 600 | 1800 |
| Speed_Alarm | Bit | Alarms.00 | Triggers alarm messages | LC_1 | 0 | 0 | 0 |

ControlNet scheduled application tags

The following application tags are used by the ControlNet application using scheduled messaging. Defaults are accepted for fields not shown in table.

| Tag Name | Data Type | Tag Address | Description | Node Name | Initial Value | Min | Max |
|---------------------|--------------------|-------------|---------------------------|---------------------------|---------------|-----|-------|
| Start_Motor | Bit | SI0:0/0 | Starts the motor | ControlNet_Scheduled_File | 0 | 0 | 0 |
| Stop_Motor | Bit | SI0:0/1 | Stops the motor | ControlNet_Scheduled_File | 0 | 0 | 0 |
| Motor_Status_Ind | Bit | S00:0/0 | Shows on/off motor status | ControlNet_Scheduled_File | 0 | 0 | 0 |
| Motor_Speed | Signed Integer/INT | S00:1 | Shows the motor speed | ControlNet_Scheduled_File | 0 | 0 | 65535 |
| Set_Max_Motor_Speed | Signed Integer/INT | SI0:1 | Sets the maximum speed | ControlNet_Scheduled_File | 1800 | 600 | 1800 |
| Speed_Alarm | Bit | S00:2/0 | Triggers alarm messages | ControlNet_Scheduled_File | 0 | 0 | 0 |

DeviceNet application tags

The following application tags are used by the DeviceNet application. Defaults are accepted for fields not shown in table.

| Tag Name | Data Type | Tag Address | Description | Node Name | Initial Value | Min | Max |
|---------------------|------------------|-------------|---------------------------|-----------|---------------|-----|-------|
| Start_Motor | Bit | I:00/0 | Starts the motor | LC_1 | 0 | 0 | 0 |
| Stop_Motor | Bit | I:00/1 | Stops the motor | LC_1 | 0 | 0 | 0 |
| Motor_Status_Ind | Bit | O:0/0 | Shows on/off motor status | LC_1 | 0 | 0 | 0 |
| Motor_Speed | Unsigned Integer | O:1 | Shows the motor speed | LC_1 | 0 | 0 | 65535 |
| Set_Max_Motor_Speed | Unsigned Integer | I:1 | Sets the maximum speed | LC_1 | 1800 | 600 | 1800 |
| Speed_Alarm | Bit | O:2/0 | Triggers alarm messages | LC_1 | 0 | 0 | 0 |

EtherNet/IP application tags

The following application tags are used by the ControlLogix controller in the EtherNet/IP application using controller addressing. Defaults are accepted for fields not shown in table.

| Tag Name | Data Type | Tag Address | Description | Node Name | Initial Value | Min | Max |
|---------------------|--------------------|------------------|---------------------------|-----------|---------------|-----|-------|
| Start_Motor | Bit | Motor_Control.00 | Starts the motor | LC_1 | 0 | 0 | 0 |
| Stop_Motor | Bit | Motor_Control.01 | Stops the motor | LC_1 | 0 | 0 | 0 |
| Motor_Status_Ind | Bit | Motor_Control.02 | Shows on/off motor status | LC_1 | 0 | 0 | 0 |
| Motor_Speed | Signed Integer/INT | Motor_Speed[0] | Shows the motor speed | LC_1 | 0 | 0 | 65535 |
| Set_Max_Motor_Speed | Signed Integer/INT | Motor_Speed[1] | Sets the maximum speed | LC_1 | 1800 | 600 | 1800 |
| Speed_Alarm | Bit | Alarms.00 | Triggers alarm messages | LC_1 | 0 | 0 | 0 |

Modbus application tags

The following application tags are used by the Modbus application. Defaults are accepted for fields not shown in table.

| Tag Name | Data Type | Tag Address | Description | Node Name | Initial Value | Type |
|---------------------|----------------------|-------------|---------------------------|-----------|---------------|------------------|
| Start_Motor | Bit | 1 | Starts the motor | LC_1 | 0 | Output Coil |
| Stop_Motor | Bit | 2 | Stops the motor | LC_1 | 0 | Output Coil |
| Motor_Status_Ind | Bit | 3 | Shows on/off motor status | LC_1 | 0 | Output Coil |
| Motor_Speed | Unsigned Integer/INT | 1 | Shows the motor speed | LC_1 | 0 | Holding Register |
| Set_Max_Motor_Speed | Unsigned Integer/INT | 2 | Sets the maximum speed | LC_1 | 1800 | Holding Register |
| Speed_Alarm | Bit | 17 | Triggers alarm messages | LC_1 | 0 | Output Coil |

Entering the application tags

For all communication protocols enter the tags in the worksheet. Each worksheet tab shows the name of the protocol for which you are creating tags. For DeviceNet, make sure you click the **DNet - IO Slave** tab before entering tags. For Ethernet, click the **ENet - Controller Address** tab.

Follow the procedure below to enter each row (DH+ shown, others similar).



1. Select **View>Extended Attributes** or click the **Extended Attributes** tool to display the Initial, Minimum, Maximum, Offset and Scale fields.




2. Select **Edit>Insert Tag** or click the **Insert Tag** tool on the toolbar.


3. Double-click in the **Tag Name** field and type **Start_Motor**.




4. Click on the arrow in the **Data Type** field and select **Bit**.




5. Double-click in the **Address** field and type **B3:0/0**. For Modbus, type **1** in the **Address** field.



6. Double-click in the **Description** field and type **Starts the Motor**.



7. Click on the arrow in the **Node Name** field and select **LC_1**. This node name was entered for the logic controller when you defined communication settings.




The defaults are accepted for the rest of the tag attributes. **However, for the Set_Max_Motor_Speed tag enter 600 in the Minimum field, and 1800 in the Initial Value and Maximum fields. The Minimum value of 600 does not apply to Modbus.**

For a Modbus application, enter **Holding Register** or **Output Coil** in the **Type** field as shown on previous page.


8. Repeat steps 2 - 7 to enter the rest of the tags.

The tag editor should look similar to this when you are done entering your tags.



| | Tag Name | Data Type | Address | Description | Node Name | Initial |
|---|---------------------|------------------|---------|-------------------------|-----------|---------|
| 1 | Motor_Speed | Unsigned Integer | N7:0 | Shows the motor speed | LC_1 | 0 |
| 2 | Motor_Status_Ind | Bit | B3:0/2 | Shows on/off status of | LC_1 | 0 |
| 3 | Set_Max_Motor_Speed | Unsigned Integer | N7:1 | Sets the maximum speed | LC_1 | 1800 |
| 4 | Speed_Alarm | Bit | B3:1/0 | Triggers alarm messages | LC_1 | 0 |
| 5 | Start_Motor | Bit | B3:0/0 | Starts the motor | LC_1 | 0 |
| 6 | Stop_Motor | Bit | B3:0/1 | Stops the motor | LC_1 | 0 |

For a Modbus application, the tag editor should look like this.



| | Tag Name | Data Type | Address | Description | Node Name | Initial Value | Type |
|---|---------------------|------------------|---------|------------------------|-----------|---------------|------------------|
| 1 | Motor_Speed | Unsigned Integer | 1 | Shows the motor speed | LC_1 | 0 | Holding Register |
| 2 | Motor_Status_Ind | Bit | 3 | Shows the on/off motor | LC_1 | 0 | Output Coil |
| 3 | Set_Motor_Max_Speed | Unsigned Integer | 2 | Sets the maximum speed | LC_1 | 1800 | Holding Register |
| 4 | Speed_Alarm | Bit | 17 | Alarm trigger base | LC_1 | 0 | Output Coil |
| 5 | Start_Motor | Bit | 1 | Starts the motor | LC_1 | 0 | Output Coil |
| 6 | Stop_Motor | Bit | 2 | Stops the motor | LC_1 | 0 | Output Coil |

9. Save the tags by selecting **File>Save Project**.
10. Close the tag editor by clicking the **X** in the title bar.



11. Close each screen by clicking the **X** in the title bar of the screen. Or select **Screen>Close** to close each screen.

Saving the application



Select **File>Save** or click the **Save** icon on the toolbar.

Downloading the application

This chapter shows how to:


- validate the application
- download the application using a point-to-point serial connection
- close the application

Checking the application for errors

This section shows you how to validate the application for errors. The application is also validated automatically during the download process.


1. Select **Application>Validate All**. The application is checked for errors.

If the application passes validation, you'll see this dialog.



2. Click **OK**.

If any errors or warnings occur, the Exceptions window opens. Errors must be corrected, before you can download the application. Warnings are optional.



After clearing errors, you can reopen the Exceptions window by double-clicking the Exceptions window in the System folder of the Application window.

To get additional help on validating an application, select **Help>Contents**. Select the **Index** tab and enter the search words **validate application**.

Downloading the application


DH+, Remote I/O, DF1, ControlNet, DeviceNet, EtherNet/IP, Modbus PanelView Terminals

This section shows how to download an application from your computer to a DH+, RIO, ControlNet, DeviceNet, EtherNet/IP or Modbus PanelView terminal using a point-to-point serial connection and PanelBuilder32's DF1 driver.

Check your cable connections as shown in Chapter 1.


1. Select **File>Download**.

The Download File dialog opens. It shows the name of the application and the driver used to download the application.



2. Click **OK**.

The application is validated (checked for errors) and then downloaded to the terminal. The following dialog opens to show the status of the download.



When the download is complete, the terminal resets, verifies and displays the startup screen of the application.

DH485 and RS232 (DH485 protocol) PanelView Terminals

This section shows how to download an application from your computer to a DH485 or RS-232 (DH485 protocol) PanelView terminal using the **RSLinx 1747-PIC Device** driver. RSLinx is installed as part of the PanelBuilder32 installation.


IMPORTANT

The DF1 driver will not be available if any of the serial ports on your computer are configured to use an RSLinx driver.


Check your cable connections as shown in Chapter 1.

1. Configure the RSLinx 1747-PIC driver as described in steps 2 through 5.
2. Select **File>Workstation Setup** and then select **Configure RSLinx Drivers** from the Workstation Setup dialog.

The **Configure Drivers** dialog opens.




3. Select **1747-PIC /AIC+ Device** from the pull-down menu and click **Add New**.
You are prompted to enter a driver name.



4. Click **OK** to save the driver name.


A dialog opens allowing you to enter the configuration of the PIC as shown here:



5. Click **OK** and restart your computer to load the new driver.


6. Select **File>Download**.

The Download File dialog opens. It shows the name of the application. Select **RSlinx 1747-PIC Device** as the driver used to download the application.



7. Click **OK**.

The application is validated (checked for errors) and then downloaded to the terminal. The following dialog opens to show the status of the download.




When the download is complete, the terminal resets, verifies and displays the startup screen of the application.

Close the application and exit PanelBuilder32

1. Select **File>Close**

Or double-click the **X** in the upper corner of the Application Window.




2. Select **File>Exit** to exit PanelBuilder32.

Running the application

This chapter provides some guidance in checking the operation of the application.

Motor Status screen

After receiving the downloaded application, the PanelView terminal displays the Motor Status screen.




To start/stop the motor:

1. Press the [F1] key. On touch screens, touch




Notice how the Start / Stop Motor push button changes each time it is pressed.




2. Stop the motor by pressing [F2] or on touch screens



Notice that the stop button also changes inner text each time it is pressed.




3. Press the Motor Start/Stop buttons and note how the motor status indicator also changes.



Motor Speed screen

Access the Motor Speed Screen by pressing [F3]. On touch screens, touch

Motor Speed F3




To enter a motor speed:


1. Press the [F1] key. On touch screens, touch

Enter Maximum Speed


The numeric entry scratchpad opens.



550 Touch Screen only
Terminal Scratchpad



Keypad and Keypad/Touch Screen
Terminal Scratchpad



900/1000/1400 Touch Screen
Terminal Scratchpad

2. Enter a motor speed between 600 and 1800 on the scratchpad using the numeric entry keys.
On touch screens, touch the numeric keys displayed on the screen.

Note: During data entry, wait until the number you enter appears in the scratchpad before entering the next number.

3. Press Enter (↵) to save the value and close the scratchpad.

4. Press the [F2] key. On touch screens, touch


Motor
Status
F2

Notice the new motor speed displayed on the Status screen.

The new speed will not take effect until the motor is stopped and restarted.

Alarm Banner

Create an alarm condition by entering a motor max speed between 1200 - 1500 as described in the previous section and then starting the motor. An alarm banner is displayed over the current screen.



To acknowledge the alarm, press the [F4] key. On touch screens, touch

Ack
F4

The alarm banner is cleared.

Note: When the motor speed is in the range 1500 -1800 rpm, a different alarm message is displayed.

Application programs

This appendix lists the required ladder logic to run the sample application on the PanelView terminal and contains three sections:

- PanelBuilder32 application programs
- Ladder logic programs
- DeviceNet scanner configurations

PanelBuilder32 application programs

These files are on the PanelBuilder32 installation CD in the QuickStart\PV directory.

PanelBuilder32 Application Files

| File Name | Use with this application: |
|--------------|---|
| CL_DHP.pba | <ul style="list-style-type: none"> ControlLogix Controller with DH+ module (1756-DHRIO) DHRIO module configured for slot 1 Channel 1 of DHRIO set for 57.6K baud |
| CL_rio.pba | <ul style="list-style-type: none"> ControlLogix Controller with RIO Module (1756-DHRIO) DHRIO module in slot 1 Channel 2 of DHRIO set for 57.6K baud |
| CLCNetS.pba | <ul style="list-style-type: none"> ControlLogix with a ControlNet Bridge (1756-CNB) ControlNet Bridge configured for slot 1 Scheduled messaging |
| CLCNetU.pba | <ul style="list-style-type: none"> ControlLogix with a ControlNet Bridge (1756-CNB) ControlNet Bridge configured for slot 1 Unscheduled messaging |
| CL_Enet.pba | <ul style="list-style-type: none"> ControlLogix Controller with 1756-ENET/B module Network addressing Slot 1 |
| PLC_Enet.pba | <ul style="list-style-type: none"> PLC-5E (Ethernet) |
| SLC_Enet.pba | <ul style="list-style-type: none"> SLC 5/05 (Ethernet) |
| DF1.pba | <ul style="list-style-type: none"> Any enhanced PLC-5, SLC-5/03, 5/04, 5/05, Micrologix |
| DNet.pba | <ul style="list-style-type: none"> 1756-DNB configured for slot 1 with ControlLogix controller or 1771-SDN configured for slot 1 with PLC-5 controller or 1747-SDN configured for slot 1 with SLC controller. |
| MLDH485.pba | <ul style="list-style-type: none"> MicroLogix with RS-485 |
| PLC_DHP.pba | <ul style="list-style-type: none"> PLC-5 with Data Highway + |
| PLC_RIO.pba | <ul style="list-style-type: none"> PLC-5 with Remote I/O |
| PLCCNetU.pba | <ul style="list-style-type: none"> PLC-5 with ControlNet Unscheduled messaging |
| SLC_DHP.pba | <ul style="list-style-type: none"> SLC 5/04 with Data Highway + |
| SLC_RIO.pba | <ul style="list-style-type: none"> SLC with Remote I/O Remote I/O module configured for slot 1 |
| SLCDH485.pba | <ul style="list-style-type: none"> 1761-NET-AIC may be required Any SLC Note: SLC 5/04 or 5/05 channel 0 can be configured for DH485 protocol. Configure the PanelBuilder application to match the PanelView catalog number. |
| Modbus.pba | <ul style="list-style-type: none"> MicroLogix 1200/1500 |

Ladder logic programs

These files are provided on the PanelBuilder32 installation CD.

ControlLogix Controller Programs (\QuickStart\CL directory)

| File Name | Use with this Application: | Page: |
|----------------|--|-------|
| cnet_sch.acd | <ul style="list-style-type: none"> ControlLogix in slot 0 ControlLogix 1756-CNB module in slot 1 Scheduled messages | 79 |
| cnet_unsch.acd | <ul style="list-style-type: none"> ControlLogix in slot 0 ControlLogix 1756-CNB module in slot 1 Unscheduled messages | 81 |
| dhp.acd | <ul style="list-style-type: none"> ControlLogix in slot 0 1756-DHRIO module in slot 1 Channel 1 of DHRIO set for 57.6K baud | 83 |
| dnet.acd | <ul style="list-style-type: none"> ControlLogix in slot 0 ControlLogix 1756-DNB module in slot 1 Baud rate set at 125K | 85 |
| rio.acd | <ul style="list-style-type: none"> ControlLogix in slot 0 IP Address is 10.0.0.1 1756-DHRIO module in slot 1 Channel 2 of DHRIO set for 57.6K baud | 87 |
| enet.acd | <ul style="list-style-type: none"> ControlLogix in slot 0 1756-ENET/B module in slot 1 Network Addressing is message type | 89 |

PLC-5 Controller Programs (\QuickStart\PLC directory)

| File Name | Use with this Application: | Page: |
|-------------|---|-------|
| cnet.rsp | <ul style="list-style-type: none"> PLC-5C | 109 |
| dhp_df1.rsp | <ul style="list-style-type: none"> Any enhanced PLC-5 for DF1 Any PLC-5 for DH+ | 111 |
| dnet.rsp | <ul style="list-style-type: none"> Any PLC-5 1771-SDN DeviceNet scanner in slot 1 | 113 |
| rio.rsp | <ul style="list-style-type: none"> Any PLC-5 Remote I/O port | 116 |
| enet.rsp | <ul style="list-style-type: none"> PLC-5E (Ethernet) IP Address is 10.0.0.1 | 118 |


SLC Controller Programs (\QuickStart\SLC directory)


| File Name | For Use with this Application: | Page: |
|------------------|--|--------------|
| dh485.rss | <ul style="list-style-type: none"> Channel 0 must be used on an SLC-5/04 or 5/05 with a 1761-NET-AIC Link Coupler | 95 |
| df1.rss | <ul style="list-style-type: none"> SLC 5/03, 5/04, 5/05 Channel 0 configured for DF1, no-parity, CRC, and no handshaking. Baud rate set at 9600 <p>Important: You may need to convert the ladder logic for the appropriate controller.</p> | 91 |
| dhp.rss | <ul style="list-style-type: none"> SLC 5/04 Channel 1 configured for DH+ at 57.6K baud. | 99 |
| dnet.rss | <ul style="list-style-type: none"> SLC 5/02, 5/03, 5/04, 5/05 1747-SDN DeviceNet scanner in slot 1 Baud rate set at 125K <p>Important: You may need to convert the ladder logic for the appropriate controller.</p> | 101 |
| rio.rss | <ul style="list-style-type: none"> SLC 5/02, 5/03, 5/04, 5/05 1747-SN scanner in slot 1 Baud rate set at 57.6K <p>Important: You may need to convert the ladder logic for the appropriate controller.</p> | 103 |
| enet.rss | <ul style="list-style-type: none"> SLC 5/05E (Ethernet) IP Address is 10.0.0.1 | 105 |

Micrologix Controller Programs (\QuickStart\ML directory)


| File Name | For Use with this Application: | Page: |
|------------------|--|--------------|
| df1.rss | <ul style="list-style-type: none"> MicroLogix 1000 Series C or later <p>Important: You may need to convert the ladder logic for the appropriate controller.</p> | 93 |
| dh485.rss | <ul style="list-style-type: none"> MicroLogix 1000 Series C or later 1761-NET-AIC Link Coupler may be needed Channel 0 must be used on an SLC-5/04 or 5/05 with a 1761-NET-AIC Link Coupler <p>Important: You may need to convert the ladder logic for the appropriate controller.</p> | 97 |
| modbus.rss | <ul style="list-style-type: none"> MicroLogix 1200/1500 <p>Important: You may need to convert the ladder logic for the appropriate controller.</p> | 107 |


cnet_sch.acd





cnet_unsch.acd





QuickStart ControlLogix ladder logic.

The ladder logic is for a ControlLogix in slot 0 and a DHRIO module in slot 1. The Channel 1 of the DHRIO module is DH+ at 57.6 Kbaud. The DHRIO configuration can be changed from the I/O Configuration in RSLogix 5000.

This program simulates a motor/drive being started and stopped from the PanelView. See the Quick Start manual for details.

Motor_Control[0] is B3:0/0 in the PanelView
Motor_Control[1] is B3:0/1 in the PanelView

Motor_Control[0]

Motor_Control[1]

Motor_Feedback

Motor_Feedback

Motor_Control[2]

Motor_Control[2] is B3:0/2 in the PanelView

Indicates when the motor is running or stopped

Allows the operator to change the max motor speed (600 to 1800 rpm)
Motor_Speed[1] is N7:1 in the PanelView

LIM

Limit Test (CIRC)

Low Limit 600

Test Motor_Speed[1]

High Limit 1800

MOV

Move Source Motor_Speed[1]

Dest Simulate_Motor_Speed.PRE

Simulates the motor with a drive incrementing the speed


TON

Timer On Delay


Timer Simulate_Motor_Speed


Preset 1800

Accum 0





dnet.acd







rio.acd







enet.acd







df1.rss





df1.rss (for MicroLogix family)







dh485.rss


QuickStart SLC-5/03, 5/04, 5/05 ladder logic.

The ladder logic is configured for a SLC-5/03 with Channel 1 for DH485 at 19200 baud. The SLC controller selection can be changed under Controller Properties in RSLogix 500.

This program simulates a motor/drive being started and stopped from the PanelView. See the Quick Start manual for details.









dhp.rss

QuickStart SLC-5/04 ladder logic.


The ladder logic is configured for a SLC with Channel 1 for DH+ at 57.6Kbaud. The DH+ configuration can be changed from the Channel Configuration under Project/Controller in RSLogix 500.


This program simulates a motor/drive being started and stopped from the PanelView. See the Quick Start manual for details.





dnet.rss







rio.rss

QuickStart SLC-5/03 ladder logic.


The ladder logic is configured for a SLC with a 1747-SN Remote I/O Scanner in slot 1 at 57.6Kbaud. The 1747-SN configuration can be changed from the I/O Configuration under Project/Controller in RSLogix 500. The controller selection can be changed under Controller Properties.


This program simulates a motor/drive being started and stopped from the PanelView. See the Quick Start manual for details.







enet.rss







modbus.rss (for MicroLogix family)







cnet.rsp







dhp_df1.rsp






dnet.rsp









rio.rsp

QuickStart PLC-5 ladder logic.


The ladder logic is configured for a PLC-5/40 with Channel 1B for Remote I/O at 57.6Kbaud. The PanelView is Rack 1 Groups 0-3. The Remote I/O configuration can be changed from the Channel Configuration under Project/Controller in RSLogix 5.


This program simulates a motor/drive being started and stopped from the PanelView. See the Quick Start manual for details.





enet.rsp





Scanner programs

These files are provided on the PanelBuilder32 installation CD in the (**\QuickStart\DNet directory**).

DeviceNet Applications using RSNetworx for DeviceNet

| File Name | Use with these application files: |
|-------------|---|
| 1747sdn.dnt | <ul style="list-style-type: none">• dnet.rss• dnet.pba |
| 1756dnt.dnt | <ul style="list-style-type: none">• dnet.acd• dnet.pba |
| 1771sdn.dnt | <ul style="list-style-type: none">• dnet.rsp• dnet.pba |

www.rockwellautomation.com

Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444

Europe/Middle East/Africa: Rockwell Automation, Vorstlaan/Boulevard du Souverain 36, 1170 Brussels, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640

Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846

Publication 2711-QS003C-EN-P - March 2002

Supersedes Publication 2711-QS003B-EN-P - May 2001

41061-159-01(3)

Copyright © 2002 Rockwell Automation. All rights reserved. Printed in the U.S.A.