

# SBC 201 Chapter 1 Scope and Applicability — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

## 1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise; an occupied floor is stated to be more than 23 m above the relevant reference level.
- **Deliverable tier:** Project-use matrices in Sections 4–10 (design-check rows, not pasted inventory), plus a coverage summary and unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 1, source file Reference\SBC 201 2024\source\_reference\Chapter\_01 – SCOPE AND APPLICABILITY OF THE GENERAL SAUDI BUILDING CODE.txt.
- **Extraction audit:** Skill extract. Project-use rows follow the chapter-extract row contract (noun-phrase checks, bold SI values, building-language triggers, named exceptions, check-specific actions). Internal inventory: **29** independently checkable numeric records (**27** Verified, **2** Verify source). Unresolved OCR (missing 101.4 plumbing subsection, 109.6 parenthetical refund cap, flattened Table 1-A) is listed in the register and is not a design-release value.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, permit, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from SBC 301–313, SBC 401, SBC 501, SBC 601/602, SBC 701/702, SBC 801, SBC 901, SBC 1001, SBC 1101/1102, SBC 1201, Chapter 9, Chapter 16, Section 1603, Section 3103, NFPA 70, Appendix A or B, commentary examples, bibliography years, or the existing chapter summary. Where Chapter 1 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

### Scope and assumptions

1. Group R-2 and high-rise status are project statements, not independently verified classifications.
2. The exact Riyadh AHJ/permit pathway, Code Compliance Department (CCD) office, project stage and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Automatic sprinkler protection, mixed-use podium, amenity program, storey count and construction type are unconfirmed. Chapter 1 does not branch on NFPA 13 versus 13R.
4. Appendices are not part of the code unless specifically adopted (101.2.1). Appendix A (qualifications) and Appendix B (appeals) are not treated as adopted here.
5. The 101.2 exception that sends detached one- and two-family dwellings and townhouses **not more than three stories** to **SBC 1101/1102** does not reclassify this R-2 high-rise. Section **101.4.9** names those residential volumes as companions; it does not move the tower off SBC 201.
6. A numbered **101.4.5** plumbing charging paragraph is missing from the attached extract (101.4.4 jumps to 101.4.6). Commentary text naming SBC 701/702 is not adopted as a code cell.

## 2. Legends

### Applicability

| Status                | Meaning                                                                                                       |
|-----------------------|---------------------------------------------------------------------------------------------------------------|
| Direct                | Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.                 |
| Conditional           | Governs only when the stated feature, use, mixed-use/podium condition, temporary work or exception exists.    |
| Not typical           | Unrelated occupancy-only rule; omitted from this deliverable unless the gap register already opened that use. |
| External verification | Chapter 1 points to another section/code/standard, or the project/AHJ basis must be confirmed before use.     |

### Source confidence

| Status        | Meaning                                                                                                                                 |
|---------------|-----------------------------------------------------------------------------------------------------------------------------------------|
| Verified      | Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 1 source text or an unambiguous table cell. |
| Verify source | OCR, flattened table, page-split, missing subsection, or parenthetical attachment is unresolved. Not a design-release value.            |

## 3. Project decision and gap register

| Decision / gap               | Current project basis                                                     | Why it controls Chapter 1 application                                                                                                             | Required project action                                                                                              |
|------------------------------|---------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------|
| AHJ / CCD office             | Unconfirmed Riyadh municipality and building official                     | 103–104 name MoM&H CCD as the enforcement agency; permit, inspection and occupancy clocks run through that office                                 | Confirm the permit authority, delegated entity and SBPS pathway before first submittal                               |
| Appendices                   | Not adopted on this extract                                               | 101.2.1: appendices do not apply unless specifically adopted; 103.5.2 points qualifications to Appendix A                                         | AHJ to state whether Appendix A (and B, if used for appeals) is in the adopting law                                  |
| Plumbing companion volume    | 101.4.5 heading/paragraph missing from the extract                        | Electrical, mechanical, energy, fire, existing, green, residential and fuel-gas companions are numbered; plumbing is not                          | Lock the plumbing code from the AHJ-adopted suite; do not copy SBC 701/702 from commentary                           |
| 101.4.9 versus 101.2         | Tower stated as Group R-2 high-rise                                       | 101.4.9 names SBC 1101/1102 for residential buildings; 101.2 keeps this occupancy on SBC 201 unless the three-story dwelling exception applies    | Keep the tower on SBC 201; do not transfer apartments to the villa/townhouse residential codes                       |
| Mixed-use / podium program   | Unconfirmed                                                               | 106.1 live-load posting is commercial/industrial; 107.2.3 occupant-load designation is waived for R-2 but not for other groups on shared drawings | Freeze occupancy by space; show occupant loads on non-R-2 rooms; post live loads only where 106.1 applies            |
| Sprinkler / storeys / height | Occupied floor stated above 23 m; sprinkler basis unconfirmed             | Chapter 1 does not select NFPA 13 versus 13R; 111.2 requires the certificate to record whether a provided sprinkler system is required            | Fire engineer to lock Chapter 9; record the sprinkler basis on the occupancy certificate data                        |
| Temporary structures / uses  | Unconfirmed site compound, sales pavilion or construction-phase occupancy | 108.1 caps the temporary permit at <b>180 days</b> ; 108.2 sends geometry to Section 3103                                                         | If a temporary building or use is planned, time the permit and design it under 3103 — do not import 3103 values here |
| Construction type IV-A/B/C   | Unconfirmed                                                               | 110.3.5 adds a wood-cover connection inspection only for those types                                                                              | Confirm type of construction before scheduling mass-timber connection inspections                                    |
| NOC / permit / occupancy     | SCD NOC and SBPS status unconfirmed                                       | 105 permit, 110 inspections, 111 certificate of occupancy and 112 utilities cannot evidence fire-strategy acceptance                              | Align construction documents, fire strategy, SBPS and SCD comments before occupancy                                  |

4. Scope, editions and conflict rules

| Cite          | Component / check                     | Exact source requirement / value                                                                                                                                                                                                                                                                             | Trigger / condition                                                          | Exceptions / branch                                                                                                                                                                                                                                    | R-2 tower status | Design action                                                                                                | Source confidence |
|---------------|---------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|--------------------------------------------------------------------------------------------------------------|-------------------|
| 101.1–101.1.2 | Official code text                    | These regulations are the General Saudi Building Code, <b>SBC 201</b> . The official version is the English language version, using SI units, published by SBCNC                                                                                                                                             | All work under this code                                                     | None stated                                                                                                                                                                                                                                            | Direct           | Cite SBC 201 English SI text on the code sheet; do not charge the Arabic summary edition as the design text  | Verified          |
| 101.2         | SBC 201 building scope                | Construction, alteration, occupancy, maintenance, removal and demolition of every building or structure and attached appurtenances                                                                                                                                                                           | The R-2 high-rise and its appurtenances                                      | Detached one- and two-family dwellings and townhouses <b>not more than three stories</b> above grade plane with a separate means of egress, and their accessory structures <b>not more than three stories</b> , shall comply with <b>SBC 1101/1102</b> | Direct           | Keep this tower on SBC 201; do not apply the three-story dwelling/townhouse exception to Group R-2 high-rise | Verified          |
| 101.2.1       | Appendix adoption                     | Provisions in the appendices shall not apply unless specifically adopted                                                                                                                                                                                                                                     | Any appendix used as a design or qualification rule                          | None stated                                                                                                                                                                                                                                            | Conditional      | Do not design to Appendix A or B unless the AHJ adopting law includes them                                   | Verified          |
| 102.1         | Conflict hierarchy                    | A specific requirement governs a general requirement. Where different sections specify different materials, methods or other requirements, the <b>most restrictive</b> shall govern                                                                                                                          | Conflicting provisions inside this code                                      | None stated                                                                                                                                                                                                                                            | Direct           | On the code sheet, record the controlling specific section where two Chapter rules overlap                   | Verified          |
| 102.4–102.4.2 | Referenced-standard precedence        | Referenced codes and standards apply to the prescribed extent of each reference. Where this code conflicts with a referenced standard, <b>this code applies</b> . Where a referenced standard covers matter within this code or the Section 101.4 codes, <b>this code or the 101.4 codes take precedence</b> | Companion SBC parts and named standards                                      | None stated                                                                                                                                                                                                                                            | Direct           | Do not let NFPA, ASHRAE or similar referenced text override SBC 201 or the 101.4 suite                       | Verified          |
| 102.6–102.6.1 | Existing and never-occupied buildings | Legal occupancy of a structure existing on the adoption date may continue except as this code, <b>SBC 901</b> or <b>SBC 801</b> requires. A building not previously occupied shall comply with SBC 201 or SBC 1101/1102 for new construction, or with any current permit for that occupancy                  | Existing building, fit-out of a never-occupied shell, or change of occupancy | 102.6.2 continues a previously occupied legal occupancy except as this code, SBC 801 or the building official requires                                                                                                                                 | Conditional      | Treat an unoccupied shell as new construction unless a current permit still covers the fit-out               | Verified          |

5. Companion-code charging

| Cite                                | Component / check                | Exact source requirement / value                                                                                                                                                                                                 | Trigger / condition                                     | Exceptions / branch                                                                                       | R-2 tower status      | Design action                                                                                                       | Source confidence |
|-------------------------------------|----------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------|-----------------------------------------------------------------------------------------------------------|-----------------------|---------------------------------------------------------------------------------------------------------------------|-------------------|
| 101.4.1                             | Structural companion codes       | Chapters <b>16</b> to <b>23</b> address structural requirements and reference <b>SBC 301 through SBC 313</b> as detailed in Table 1-A. SBC 301 applies to structural loading, risk categories and permitted design methodologies | Structural design of the building                       | Table 1-A in this extract is flattened concatenated HTML; titles are not adopted as values                | External verification | Charge structure to Chapters 16–23 and the 301–313 suite; do not import loads, stresses or member sizes here        | Verified          |
| 101.4.2                             | Electrical companion code        | <b>SBC 401</b> applies to electrical wiring from the point of delivery, electrical appliances and related accessories                                                                                                            | Electrical installation from the point of delivery      | None stated                                                                                               | External verification | Name SBC 401 on electrical drawings; do not copy wiring or appliance values from this chapter                       | Verified          |
| 101.4.3                             | Mechanical companion code        | <b>SBC 501</b> applies to installation, alteration, repair and replacement of mechanical systems, including ventilating, heating, cooling, air-conditioning, refrigeration, incinerators and other energy-related systems        | Mechanical systems on the building                      | None stated                                                                                               | External verification | Name SBC 501 on mechanical drawings; do not copy HVAC criteria from this chapter                                    | Verified          |
| 101.4.4                             | Energy companion codes           | <b>SBC 601</b> and <b>SBC 602</b> apply to all matters governing design and construction of buildings for energy efficiency                                                                                                      | Energy-efficiency design and construction               | Chapter 1 does not assign 601 versus 602 to Group R-2                                                     | External verification | Demonstrate energy compliance through SBC 601 and SBC 602; do not adopt envelope or HVAC values here                | Verified          |
| 101.4 (plumbing subsection missing) | Plumbing companion charging      | No numbered plumbing subsection is present between 101.4.4 and 101.4.6 in the attached extract                                                                                                                                   | Plumbing systems on the building                        | Commentary names SBC 701/702; those commentary names are not adopted as code cells                        | External verification | Lock the plumbing volume from the AHJ-adopted suite; do not fill 701/702 criteria from this extract                 | Verify source     |
| 101.4.6                             | Fire-prevention companion code   | <b>SBC 801</b> applies to fire and explosion hazards from structures, processes, premises, materials and devices, and to construction, extension, repair, alteration or removal of fire-suppression, sprinkler and alarm systems | Fire-prevention, occupancy hazards and fire-system work | None stated                                                                                               | External verification | Coordinate SBC 801 with Chapters 9–10; do not import 801 values into this matrix                                    | Verified          |
| 101.4.7                             | Existing-building companion code | <b>SBC 901</b> applies to repair, alteration, change of occupancy, addition and relocation of existing buildings                                                                                                                 | Existing-building work                                  | None stated                                                                                               | Conditional           | Use SBC 901 only for existing-building scopes; keep new-tower work on SBC 201                                       | Verified          |
| 101.4.8                             | Green-building companion code    | <b>SBC 1001</b> applies to design and construction of buildings for green building requirements                                                                                                                                  | Green-building demonstration                            | None stated                                                                                               | External verification | Name SBC 1001 on the sustainability sheet; do not import Mostadam or 1001 credits from this chapter                 | Verified          |
| 101.4.9                             | Residential companion codes      | <b>SBC 1101/1102</b> apply to matters governing design and construction of residential buildings                                                                                                                                 | Residential buildings as scoped by 101.2                | The 101.2 three-story dwelling/townhouse exception is the scope gate, not a blanket transfer of Group R-2 | Direct                | Leave this R-2 high-rise on SBC 201; use 1101/1102 only if a qualifying villa/townhouse actually exists on the plot | Verified          |

| Cite     | Component / check       | Exact source requirement / value                                                                         | Trigger / condition            | Exceptions / branch | R-2 tower status      | Design action                                                                         | Source confidence |
|----------|-------------------------|----------------------------------------------------------------------------------------------------------|--------------------------------|---------------------|-----------------------|---------------------------------------------------------------------------------------|-------------------|
| 101.4.10 | Fuel-gas companion code | <b>SBC 1201</b> applies to gas piping from the point of delivery, gas appliances and related accessories | Fuel-gas piping and appliances | None stated         | External verification | Name SBC 1201 on gas drawings; do not copy pipe or appliance values from this chapter | Verified          |

6. Permits and exemption geometry

| Cite          | Component / check                   | Exact source requirement / value                                                                                                                                                               | Trigger / condition                             | Exceptions / branch                                                                                                                                                                                                                                                                                                                                                                     | R-2 tower status | Design action                                                                                             | Source confidence |
|---------------|-------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|-----------------------------------------------------------------------------------------------------------|-------------------|
| 105.1         | Permit required                     | Owner or authorized agent shall obtain the required permit before construction, alteration, demolition, occupancy change, or regulated electrical, gas, mechanical or plumbing work            | All regulated work on the tower and its systems | Work listed in 105.2 is exempt from permit, but is still not authorized to violate this code or other laws                                                                                                                                                                                                                                                                              | Direct           | Put the permit scope on the drawing index; do not start construction on unexempted work without a permit  | Verified          |
| 105.2 Bldg 1  | Small accessory-structure exemption | Permit not required for one-story detached accessory structures used as tool and storage sheds, playhouses and similar uses, provided floor area is <b>not greater than 11 m<sup>2</sup></b>   | One-story detached shed or similar accessory    | Exemption is not authorization to violate the code                                                                                                                                                                                                                                                                                                                                      | Conditional      | Dimension any site shed; if area exceeds <b>11 m<sup>2</sup></b> , include it on the permit               | Verified          |
| 105.2 Bldg 2  | Fence-height exemption              | Permit not required for fences <b>not over 2.10 meters</b> high                                                                                                                                | Site fences                                     | Exemption is not authorization to violate the code                                                                                                                                                                                                                                                                                                                                      | Conditional      | Permit any fence taller than <b>2.10 m</b>                                                                | Verified          |
| 105.2 Bldg 4  | Retaining-wall exemption            | Permit not required for retaining walls <b>not over 1.20 meters</b> in height measured from the bottom of the footing to the top of the wall                                                   | Site retaining walls                            | Not exempt if supporting a surcharge or impounding Class I, II or IIIA liquids                                                                                                                                                                                                                                                                                                          | Conditional      | Permit walls over <b>1.20 m</b> , surcharge walls and liquid-impounding walls                             | Verified          |
| 105.2 Bldg 5  | Grade-supported tank exemption      | Permit not required for water tanks supported directly on grade if capacity is <b>not greater than 19000 L</b> and height-to-diameter or width ratio is <b>not greater than 2:1</b>            | Grade-supported water tanks                     | Either limit exceeded removes the exemption                                                                                                                                                                                                                                                                                                                                             | Conditional      | Permit tanks over <b>19000 L</b> or slimmer than <b>2:1</b>                                               | Verified          |
| 105.2 Bldg 6  | Sidewalk and driveway exemption     | Permit not required for sidewalks and driveways <b>not more than 750 mm</b> above adjacent grade, not over any basement or story below, and not part of an accessible route                    | Site sidewalks and driveways                    | Accessible routes and decks over a basement/story remain permitted work                                                                                                                                                                                                                                                                                                                 | Conditional      | Permit raised walks over <b>750 mm</b> , walks over a basement, and accessible-route paving               | Verified          |
| 105.2 Bldg 7  | Finish-work exemption               | Permit not required for painting, papering, tiling, carpeting, cabinets, counter tops and similar finish work                                                                                  | Interior finish replacement                     | Cutting structure, changing required egress, or relocating regulated systems is not ordinary finish work (105.2.2)                                                                                                                                                                                                                                                                      | Conditional      | Keep finish-only packages off the structural/egress permit; permit any work that cuts structure or egress | Verified          |
| 105.2 Bldg 13 | Movable-partition exemption         | Permit not required for non-fixed and movable fixtures, cases, racks, counters and partitions <b>not over 1.8 meters</b> in height                                                             | Loose furniture and movable partitions          | Fixed partitions and elements over <b>1.8 m</b> remain permitted work                                                                                                                                                                                                                                                                                                                   | Conditional      | Permit fixed joinery and any movable screen taller than <b>1.8 m</b>                                      | Verified          |
| 105.2 Elec 7  | Low-voltage equipment exemption     | Permit not required for electrical wiring, devices, appliances, apparatus or equipment operating at <b>less than 25 volts</b> and not capable of supplying <b>more than 50 watts</b> of energy | Extra-low-voltage, low-power devices            | Either limit exceeded removes the exemption                                                                                                                                                                                                                                                                                                                                             | Conditional      | Permit any circuit at <b>25 volts</b> or above, or capable of more than <b>50 watts</b>                   | Verified          |
| 105.2 Mech 7  | Small refrigeration exemption       | Permit not required for a self-contained refrigeration system containing <b>4.50 kg or less</b> of refrigerant and actuated by motors of <b>0.75 kW or less</b>                                | Self-contained refrigerators/coolers            | Either limit exceeded removes the exemption                                                                                                                                                                                                                                                                                                                                             | Conditional      | Permit split systems and any unit over <b>4.50 kg</b> refrigerant or <b>0.75 kW</b>                       | Verified          |
| 105.2.2       | Ordinary-repair limit               | Application is not required for ordinary repairs, lamp replacement or connection of approved portable electrical equipment to approved permanently installed receptacles                       | Ordinary maintenance                            | Shall not include cutting away any wall or partition, removing or cutting a structural beam or load-bearing support, removing or changing required means of egress, rearranging parts affecting egress, or adding/altering/replacing/relocating standpipe, water, sewer, drainage, gas, soil, waste, vent, electric wiring or mechanical work affecting public health or general safety | Direct           | Treat structural, egress and regulated-system changes as alterations requiring a permit                   | Verified          |

7. Permit and document clocks

| Cite    | Component / check                | Exact source requirement / value                                                                                                                                  | Trigger / condition                        | Exceptions / branch                                                                                                                        | R-2 tower status | Design action                                                                                                            | Source confidence |
|---------|----------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------|------------------|--------------------------------------------------------------------------------------------------------------------------|-------------------|
| 105.3.2 | Permit-application abandonment   | An application is deemed abandoned <b>180 days</b> after filing unless pursued in good faith or a permit has been issued                                          | Filed permit application awaiting issuance | Building official may grant one or more extensions <b>not exceeding 90 days</b> each, requested in writing with justifiable cause          | Direct           | Diary the <b>180-day</b> filing clock and request any <b>90-day</b> extension in writing before the application lapses   | Verified          |
| 105.5   | Permit commencement and stoppage | A permit becomes invalid unless work commences within <b>180 days</b> after issuance, or if work is suspended or abandoned for <b>180 days</b> after commencement | Issued permit                              | Building official may grant written extensions for periods <b>not more than 180 days</b> each, requested in writing with justifiable cause | Direct           | Plan a start on site within <b>180 days</b> of issuance and avoid a <b>180-day</b> work stop without a written extension | Verified          |

| Cite            | Component / check            | Exact source requirement / value                                                                                                                                                                                                                                                                                                           | Trigger / condition                                   | Exceptions / branch                                                                                    | R-2 tower status | Design action                                                                                                                      | Source confidence |
|-----------------|------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------|--------------------------------------------------------------------------------------------------------|------------------|------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| 107.3.2         | Previous-approval continuity | This code shall not require changes to construction documents, construction or designated occupancy of a structure for which a lawful permit has been issued or otherwise lawfully authorized, and construction of which has been pursued in good faith within <b>180 days</b> after this code's effective date and has not been abandoned | Existing lawful permit spanning a code-edition change | Abandoned work loses the previous-approval protection                                                  | Conditional      | If a prior permit is still live, document good-faith pursuit within <b>180 days</b> of the new code's effective date               | Verified          |
| 107.5           | Approved-document retention  | Building official retains one approved set for <b>not less than 180 days</b> from the date of completion of the permitted work, except records subject to 104.7                                                                                                                                                                            | Completed permitted work                              | Engineered-building records under 104.7 are retained indefinitely; viewing/duplication follows 104.7.1 | Conditional      | Keep the site set until completion; do not rely on municipal copies after the <b>180-day</b> retention window unless 104.7 applies | Verified          |
| 109.6 items 2–3 | Fee-refund cap               | Not more than <b>(80% recommended)</b> percent of the permit fee where work has not been done; not more than <b>(80% recommended)</b> percent of the plan-review fee where the application is withdrawn before review effort                                                                                                               | Unused permit or unused plan-review fee               | Full refund of fees paid in error (item 1)                                                             | Conditional      | Do not treat <b>80%</b> as a locked cap until the published municipal refund schedule is confirmed                                 | Verify source     |
| 109.6           | Refund-application clock     | Building official shall not authorize a fee refund except on written application by the original permittee <b>not later than 180 days</b> after the date of fee payment                                                                                                                                                                    | Any fee-refund request                                | None stated                                                                                            | Conditional      | File any refund request within <b>180 days</b> of payment                                                                          | Verified          |

8. Live-load posting

| Cite  | Component / check             | Exact source requirement / value                                                                                                                                                                                                                                                                                                     | Trigger / condition                                              | Exceptions / branch                                                                                                                                                              | R-2 tower status | Design action                                                                                                                                                                                       | Source confidence |
|-------|-------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| 106.1 | Posted design live load       | In commercial or industrial buildings, each floor or portion designed for live loads <b>exceeding 2.50 kN/m²</b> shall have those design live loads conspicuously posted by the owner or authorized agent in that part of each story in which they apply, using durable signs. It shall be unlawful to remove or deface such notices | Commercial or industrial floors designed above <b>2.50 kN/m²</b> | Typical R-2 dwelling floors are outside the commercial/industrial trigger; podium retail, parking, assembly or industrial portions are inside it if designed above the threshold | Conditional      | Post durable live-load signs in every non-residential portion designed above <b>2.50 kN/m²</b> ; keep dwelling-unit floors off this posting rule unless they meet the commercial/industrial trigger | Verified          |
| 106.2 | Occupancy hold for load signs | A certificate of occupancy required by Section 111 shall not be issued until the floor-load signs required by 106.1 have been installed                                                                                                                                                                                              | Spaces that require 106.1 signs                                  | None stated                                                                                                                                                                      | Conditional      | Photograph installed load signs in the CO close-out pack for every posted floor                                                                                                                     | Verified          |
| 106.3 | Loading restriction           | It shall be unlawful to place, or cause or permit to be placed, on any floor or roof a load greater than is permitted by this code                                                                                                                                                                                                   | All floors and roofs                                             | None stated                                                                                                                                                                      | Direct           | Put the Chapter 16 design live load on the structural notes; do not import the 1607 values into this matrix                                                                                         | Verified          |

9. Construction documents

| Cite    | Component / check             | Exact source requirement / value                                                                                                                                                                                                                                                                                            | Trigger / condition              | Exceptions / branch                                                                                                                                                                                      | R-2 tower status      | Design action                                                                                                                                                                                        | Source confidence |
|---------|-------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| 107.1   | Submittal document sets       | Construction documents, statement of special inspections, calculations, diagrams, geotechnical report and other data shall be submitted in <b>two or more</b> sets with each permit application, prepared by a registered design professional                                                                               | Permit application for the tower | Building official may waive documents not required to be prepared by a registered design professional if review is unnecessary to obtain compliance                                                      | Direct                | Issue at least <b>two</b> coordinated sets and name the registered design professional on the application                                                                                            | Verified          |
| 107.2.1 | Drawing clarity               | Construction documents shall be dimensioned and drawn upon suitable material, of sufficient clarity to indicate location, nature and extent of the work, and show in detail that the work will conform to this code and relevant laws as determined by the building official                                                | All construction documents       | Electronic media permitted where approved by the building official                                                                                                                                       | Direct                | Dimension the work; do not substitute a generic "comply with SBC 201" note for required detail                                                                                                       | Verified          |
| 107.2.2 | Fire-protection shop drawings | Shop drawings for fire-protection systems shall be submitted to indicate conformance to this code and the construction documents, and shall be approved <b>prior to</b> the start of system installation. Shop drawings shall contain all information required by the referenced installation standards in <b>Chapter 9</b> | Fire-protection systems          | Contractor selection may follow the building permit; installation still waits on approved shop drawings                                                                                                  | External verification | List fire-protection packages as deferred submittals; do not import Chapter 9 installation numbers here                                                                                              | Verified          |
| 107.2.3 | Means-of-egress drawings      | Construction documents shall show in sufficient detail the location, construction, size and character of all portions of the means of egress, including the path of the exit discharge to the public way                                                                                                                    | All occupancies                  | In other than Groups <b>R-2</b> , R-3 and I-1, documents shall designate the number of occupants on every floor and in all rooms and spaces. Group R-2 is excepted from that occupant-number designation | Direct                | Draw the complete egress path to the public way. Do not omit occupant loads on non-R-2 rooms in a mixed building; R-2 floors are not required to show designated occupant numbers under this section | Verified          |

| Cite              | Component / check                          | Exact source requirement / value                                                                                                                                                                                                                                                                                                                                                                                                        | Trigger / condition                                                         | Exceptions / branch                                                                                                                                                       | R-2 tower status      | Design action                                                                                                     | Source confidence |
|-------------------|--------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|-------------------------------------------------------------------------------------------------------------------|-------------------|
| 107.2.4           | Exterior-wall envelope documents           | Construction documents shall describe the exterior wall envelope in sufficient detail to determine compliance, including flashing, intersections with dissimilar materials, corners, end details, control joints, roof/eave/parapet intersections, drainage, water-resistive membrane and details around openings, plus manufacturer's installation instructions supporting weather resistance                                          | All buildings                                                               | Where weather resistance is based on tests, describe the tested wall system and test procedure                                                                            | Direct                | Put typical wall sections, opening flashings and WRB continuity on the architectural set                          | Verified          |
| 107.2.5           | Scaled site plan                           | Construction documents shall be accompanied by a site plan showing to scale size and location of new and existing structures, distances from lot lines, established street grades and proposed finished grades, drawn to an accurate boundary-line survey                                                                                                                                                                               | New construction and demolition                                             | Building official may waive or modify the site plan for alteration/repair or where otherwise warranted. Demolition plans shall show work to be removed and work to remain | Direct                | Dimension setbacks, grades and existing-to-remain buildings on the site plan                                      | Verified          |
| 107.2.6           | Structural document content                | Construction documents shall provide the information specified in <b>Section 1603</b>                                                                                                                                                                                                                                                                                                                                                   | Structural design                                                           | None stated                                                                                                                                                               | External verification | Include the 1603 structural criteria on the structural sheets; do not copy Chapter 16 loads into this matrix      | Verified          |
| 107.2.7           | Manufacturer instructions on site          | Manufacturer's installation instructions required by this code shall be available on the job site at the time of inspection                                                                                                                                                                                                                                                                                                             | Products whose listing or code section requires manufacturer instructions   | None stated                                                                                                                                                               | Direct                | Keep listed-product instructions in the site inspection pack                                                      | Verified          |
| 107.2.8           | Braced-wall identification                 | For buildings using braced wall design, and where required by the building official, braced wall lines shall be identified on the construction documents, including bracing methods, location and length of braced wall panels and foundation requirements at top and bottom                                                                                                                                                            | Braced-wall lateral system                                                  | Only where that system is used and the building official requires the identification                                                                                      | Conditional           | If the structure uses braced walls, mark lines, lengths and foundations on the structural plans                   | Verified          |
| 107.3.1           | Stamped construction set                   | When the permit is issued, construction documents shall be approved, in writing or by stamp, as "Reviewed for Code Compliance." One set is retained by the building official; the other set is returned, kept at the site, and open to inspection                                                                                                                                                                                       | Issued permit                                                               | Inspections are against the approved site set, not an unstamped copy                                                                                                      | Direct                | Keep the stamped site set on the job; do not build from an unreviewed revision                                    | Verified          |
| 107.3.3           | Phased foundation permit                   | A permit for foundations or any other part of a building may be issued before whole-building documents are submitted, provided adequate code-complying information has been filed; the holder proceeds at the holder's own risk                                                                                                                                                                                                         | Fast-track / partial permit                                                 | Not a waiver of later whole-building compliance                                                                                                                           | Conditional           | If a foundation-first permit is used, freeze enough structure and load data to support that phase                 | Verified          |
| 107.3.4–107.3.4.1 | Responsible charge and deferred submittals | Where documents must be prepared by a registered design professional, the building official may require a designated registered design professional in responsible charge to review and coordinate submittals, including phased and deferred items. Deferred submittals need prior building-official approval, must be listed on the construction documents, reviewed for general conformance, and must not be installed until approved | Deferred packages (cladding, trusses, stairs, fire protection, and similar) | Installation before building-official approval of the deferred documents is prohibited                                                                                    | Direct                | List every deferred package on the drawing index and hold installation until the stamped deferred set is approved | Verified          |
| 107.4             | Amended construction documents             | Work shall be installed in accordance with the approved construction documents. Changes that are not in compliance shall be resubmitted for approval as an amended set                                                                                                                                                                                                                                                                  | Any field change from the approved set                                      | None stated                                                                                                                                                               | Direct                | Issue an amended set before constructing any non-compliant change                                                 | Verified          |

10. Temporary uses, inspections and occupancy

| Cite  | Component / check               | Exact source requirement / value                                                                                                                                                                                                                                            | Trigger / condition           | Exceptions / branch                                                                  | R-2 tower status      | Design action                                                                                              | Source confidence |
|-------|---------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------|--------------------------------------------------------------------------------------|-----------------------|------------------------------------------------------------------------------------------------------------|-------------------|
| 108.1 | Temporary-permit duration       | Temporary-structure and temporary-use permits shall be limited as to time of service but shall <b>not be permitted for more than 180 days</b> . The building official may grant extensions for demonstrated cause                                                           | Temporary buildings or uses   | Uses intended to last more than <b>180 days</b> are not temporary under this section | Conditional           | Time any sales pavilion, site offices or phased occupancy to <b>180 days</b> , or design them as permanent | Verified          |
| 108.2 | Temporary-structure conformance | Temporary structures and uses shall conform to the structural strength, fire safety, means of egress, light, ventilation and sanitary requirements of this code as necessary to ensure public health, safety and general welfare, and shall comply with <b>Section 3103</b> | Temporary structures and uses | None stated in this section; 3103 values are not in this chapter                     | External verification | Apply 3103 to the temporary building; do not import 3103 area or load figures here                         | Verified          |

| Cite        | Component / check                        | Exact source requirement / value                                                                                                                                                                                                                                                                                                      | Trigger / condition                                                              | Exceptions / branch                                                                                                                                              | R-2 tower status      | Design action                                                                                                                                      | Source confidence |
|-------------|------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|----------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|
| 108.3       | Temporary power                          | Temporary supply and use of power in part of an incomplete electric installation shall comply with temporary lighting, heat or power requirements in <b>NFPA 70</b> (or its equivalent in <b>SBC 401</b> )                                                                                                                            | Construction-phase or incomplete electrical service                              | Temporary permission is not a waiver of NFPA 70 / SBC 401                                                                                                        | External verification | Obtain the temporary-power release; do not import NFPA 70 conductor or GFCI values from this chapter                                               | Verified          |
| 110.3.5     | Mass-timber connection cover             | In Types <b>IV-A</b> , <b>IV-B</b> and <b>IV-C</b> , where connection fire-resistance ratings are provided by wood cover calculated to <b>Section 2304.10.1</b> , inspect the wood cover after it is installed and before any other coverings or finishes                                                                             | Types IV-A/B/C with calculated wood-cover connections                            | None stated                                                                                                                                                      | Conditional           | Hold finishes off mass-timber connections until the cover inspection is signed                                                                     | Verified          |
| 110.3.6     | Gypsum-board inspection                  | Inspect lath, gypsum board and gypsum panel products, interior and exterior, after they are in place and before plastering or taping/finishing of joints and fasteners                                                                                                                                                                | Gypsum used in a fire-resistance-rated assembly or a shear assembly              | Gypsum that is not part of a fire-resistance-rated assembly or a shear assembly is excepted                                                                      | Direct                | Call the gypsum inspection on rated walls and shear walls before tape and joint compound                                                           | Verified          |
| 110.3.7     | Exposed-balcony waterproofing inspection | Where balconies or other elevated walking surfaces have weather-exposed surfaces and structural framing is protected by an impervious moisture barrier, all elements of that barrier system shall not be concealed until inspected and approved                                                                                       | Weather-exposed balconies and elevated walks with an impervious moisture barrier | Exception: special inspections provided in accordance with <b>Section 1705.1.1, Item 3</b>                                                                       | Direct                | Leave balcony membrane, flashings and drainage visible until inspection, unless a 1705.1.1 Item 3 special inspection is in place                   | Verified          |
| 110.3.8     | Firestop concealment hold                | Protection of joints and penetrations in fire-resistance-rated assemblies, smoke barriers and smoke partitions shall not be concealed from view until inspected and approved                                                                                                                                                          | Rated assemblies, smoke barriers and smoke partitions                            | None stated                                                                                                                                                      | Direct                | Hold ceilings and cladding off firestop and joint systems until the inspection is signed                                                           | Verified          |
| 110.3.9     | Energy-efficiency inspection             | Inspections shall be made to determine compliance with <b>Chapter 13</b> and shall include, but not be limited to, envelope insulation R- and U-values, fenestration U-value, duct-system R-value, and HVAC and water-heating equipment efficiency                                                                                    | Energy features required through Chapter 13                                      | Numeric R/U and efficiency values are not published in this chapter                                                                                              | External verification | Schedule envelope and equipment inspections against the locked SBC 601/602 submittal, not against numbers invented here                            | Verified          |
| 110.3.11    | Concealed-services rough inspection      | Rough inspection of plumbing, mechanical, gas and electrical systems shall be made prior to covering or concealment, before fixtures or appliances are set or installed, and prior to framing inspection                                                                                                                              | Concealed MEP/gas/electrical                                                     | Exception: backfilling of ground-source heat-pump loop systems tested in accordance with <b>Section 2105.1 in SBC 1101/1102</b> prior to inspection is permitted | Direct                | Complete MEP rough-in inspection before frame inspection; do not assume the 1101/1102 loop exception applies to this R-2 tower                     | Verified          |
| 110.3.12    | Special-inspection pointer               | For special inspections, see <b>Chapter 17</b>                                                                                                                                                                                                                                                                                        | Work listed in Chapter 17                                                        | None stated                                                                                                                                                      | External verification | Place the special-inspection schedule on the structural set from Chapter 17, not from this chapter                                                 | Verified          |
| 111.1–111.2 | Certificate of occupancy                 | Building shall not be used or occupied, and occupancy classification shall not be changed, until a certificate of occupancy is issued. Certificate shall record use and occupancy per <b>Chapter 3</b> , construction type per <b>Chapter 6</b> , design occupant load, and whether a provided automatic sprinkler system is required | New occupancy or change of occupancy                                             | Certificates are not required for work exempt from permits under 105.2                                                                                           | Direct                | Collect occupancy, construction type, design occupant load and sprinkler-required status for the CO form; do not import Chapter 3 or 6 values here | Verified          |
| 112.1–112.2 | Utility connection release               | No person shall connect a utility, energy, fuel or power source to a building or system regulated by this code for which a permit is required until released by the building official. Temporary connection may be authorized                                                                                                         | Permanent or temporary utility energization                                      | 112.3 authorizes disconnection for emergency or unapproved connections                                                                                           | Direct                | Obtain the building-official utility release before energizing; treat temporary power as a separate 108.3/112.2 approval                           | Verified          |

11. Project-use controls

1. Use **Verified** rows for initial scoping after the row trigger and branch are confirmed.
2. **Verify source** rows (missing 101.4 plumbing subsection; 109.6 items 2–3 parenthetical **80% recommended**) are not design-release values. Confirm the AHJ-adopted plumbing charging section and the published fee-refund ordinance before using those cells. The **180-day** refund-application clock is Verified.
3. Do not import loads, R-values, fire-protection criteria, 3103 temporary-structure geometry, NFPA 70 values, or SBC 701/702 plumbing figures from this chapter, commentary, CS.md or memory.
4. Do not treat **101.4.9** as moving this Group R-2 high-rise onto SBC 1101/1102. The 101.2 three-story dwelling/townhouse exception is the only numbered scope gate in this chapter.
5. Do not treat 105.2 permit exemptions as permission to violate dimensional or system rules elsewhere in the code.
6. Record AHJ, appendix adoption, plumbing volume, mixed-use posting and temporary-permit decisions in the project Golden Thread. This matrix is not evidence of SCD NOC, SBPS approval or stamped compliance.

12. Coverage summary

Internal inventory of the attached Chapter 1 extract (numbered code, exceptions, tables, footnotes; commentary excluded). Row-level records are not published.

- **Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)
- **Total independently checkable numeric records:** 29
- **Verified:** 27

- **Verify source:** 2

Counts by top-level section

| Top-level section | Records |
|-------------------|---------|
| 101               | 2       |
| 102               | 0       |
| 103               | 0       |
| 104               | 0       |
| 105               | 19      |
| 106               | 1       |
| 107               | 3       |
| 108               | 1       |
| 109               | 3       |
| 110               | 0       |
| 111               | 0       |
| 112               | 0       |
| 113               | 0       |
| 114               | 0       |
| 115               | 0       |
| 116               | 0       |
| Table 1-A         | 0       |

No independently checkable numeric cells in Table 1-A (code titles only). 105.2 Building items 3, 8, 10 and 11, Group R-3 pool/awning exemptions, and electrical/gas/mechanical items without published thresholds were inventoried as non-numeric where they carry no independent quantity.

Coverage cross-check against SBC 201 Chapter 1 Scope and Applicability (2024)\_CS.md was topics-only for §§101–102: official English SI text; 101.2 three-story dwelling exception to SBC 1101/1102; appendices not adopted unless specified; companion suite map; conflict/precedence rules; existing-building pointers. The CS.md skips §§103–116. No CS.md value was copied into a matrix cell.

13. Unresolved-source register

| Affected table / clause     | Why unverified                                                                                                                                                 | Control note                                                                                                                                                                                 |
|-----------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 101.4 (plumbing subsection) | Numbered charging jumps from 101.4.4 Energy to 101.4.6 Fire prevention. No 101.4.5 heading or code paragraph is present. SBC 701/702 appear only in commentary | Do not adopt plumbing companion values from commentary. Confirm the AHJ-adopted plumbing charging section before naming a volume on the code sheet                                           |
| 109.6 items 2–3             | Refund cap is written as <b>(80% recommended)</b> percent, not an unambiguous mandatory figure                                                                 | Not a design-release fee. Confirm the published municipal refund schedule. The <b>180-day</b> refund-application clock in the same section is unambiguous and is used in the project-use row |
| Table 1-A                   | Flattened concatenated HTML (CodeTitleSBC 301The Saudi Code...) with no millimetre or capacity cells                                                           | Do not repair titles from memory. Structural charging in project-use follows numbered <b>101.4.1</b> (SBC 301 through 313). No table-cell value is adopted                                   |