

SBC 201 Chapter 10 Means of Egress — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise; an occupied floor is stated to be more than 23 m above the relevant reference level.
- **Deliverable tier:** Completed two-tier document: the approved project-use matrices are retained in Sections 1–20, followed by the exhaustive 645-record Chapter 10 normative numeric appendix.
- **Code/source basis:** SBC 201 (2024), Chapter 10, source file Reference\SBC 201 2024\source_reference\Chapter_10 – MEANS OF EGRESS.txt.
- **Extraction audit:** All 645 appendix records were reconciled against the supplied Chapter 10 source; unresolved OCR is retained as explicit **Verify source** hold points.
- **Model:** GPT-5.6 Sol.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, fire-engineering report, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from an outbound code, standard, commentary example, or the existing chapter summary. Where Chapter 10 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group R-2 and high-rise status are project statements, not independently verified classifications.
2. The exact Riyadh AHJ/permit pathway, project stage, fire-strategy status and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Automatic sprinkler protection is not selected. **NFPA 13 / Section 903.3.1.1** and **NFPA 13R / Section 903.3.1.2** are shown as separate branches wherever Chapter 10 differentiates or jointly recognizes them.
4. Emergency voice/alarm communication system (EVACS) compliance with Section 907.5.2.2 is unconfirmed.
5. Building height, storey count, grade plane, accessible floors and occupied-roof configuration, level(s) of exit discharge, unit type, occupant loads, mixed uses and amenity layouts are unconfirmed.
6. Table 1004.5 Residential, Table 1006.2.1, Tables 1006.3.4(1)/(2), Table 1017.2 and both OCR-labelled Table 1020.2 extracts contain source segmentation or footnote uncertainty. Their affected rows are marked **Verify source** and are not design release values.
7. Accessibility technical geometry cross-referenced to Chapter 11/ICC A117.1, fire-protection systems in Chapter 9, high-rise provisions in Section 403, smokeproof-enclosure systems in Section 909.20, and other outbound standards require separate verification.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, use, occupant load, sprinkler branch or exception exists.
Not typical	Not expected in a conventional R-2 tower, but retain if the feature appears in podium, amenity, roof or mixed-use areas.
External verification	Chapter 10 points to another section/code/standard, or the project/AHJ basis must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against a VERIFIED inventory record and/or unambiguous mandatory Chapter 10 source text.
Verify source	Approved inventory flags OCR/table ambiguity, or a published-source/footnote check is required before design use.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 10 application	Required project action
Sprinkler basis	Unconfirmed: neither NFPA 13 nor NFPA 13R is assumed	Controls capacity reductions, separation, common path, travel-distance table branch, dead ends, accessible-egress exceptions and corridor table branch	Fire engineer and code consultant to lock the Chapter 9 system and record whether Section 903.3.1.1 or 903.3.1.2 applies; verify high-rise permissibility outside Chapter 10
EVACS	Unconfirmed	Reduced stair capacity factor requires both qualifying sprinklers and Section 907.5.2.2 EVACS	Fire alarm designer to confirm EVACS scope and cause/effect; until then retain base capacity factors
Storeys and height	Occupied floor stated above 23 m; exact height, grade plane and storey count unconfirmed	Controls high-rise outbound provisions, accessible-egress elevator trigger, enclosure rating, roof access and stair signs	Issue a signed code datum sheet with grade plane, building height, occupied-floor elevations, basements, mezzanines and storey count
Per-storey occupant load	Unconfirmed	Controls number of exits/accesses to exits and cumulative stair/discharge sizing	Produce a storey-by-storey occupant-load and egress-routing schedule
Per-space occupant load	Unconfirmed	Controls one-door logic, common path, door swing, panic hardware and assembly rules	Produce a room/space load schedule using actual function, net/gross basis and layout
Unit type	Unconfirmed: dwelling units versus sleeping units	Controls Tables 1006.3.4(1)/(2), internal door exceptions and single-exit logic	Classify every R-2 unit type and show the applicable table branch on life-safety plans
Podium and mixed uses	Detailed uses unconfirmed	Shared egress must satisfy the most stringent served occupancy; residential rules cannot be applied to retail, parking, business or assembly by default	Freeze occupancy/use by room and fire area; identify every shared egress component
Amenity assembly	Configuration, fixed seating and occupant load unconfirmed	Triggers Table 1004.5 assembly factors, Section 1030 aisle/seating rules, possible main-exit provisions and occupant-load posting	Classify each lounge, multipurpose room, gym, pool deck, cinema and roof amenity by actual function and seating arrangement
Accessible floors and occupied roof	Unconfirmed	Controls number and components of accessible means of egress and the four-storey elevator trigger	Accessibility consultant to map all required accessible floors/roof and the complete route to a public way
Level of exit discharge	Unconfirmed, including possible multiple discharge levels	Controls elevator trigger datum, stair termination, discharge exceptions, accessible discharge and convergence	Mark each level of exit discharge in section and trace every exit independently to the public way

Decision / gap	Current project basis	Why it controls Chapter 10 application	Required project action
NOC and fire strategy	SCD NOC and stamped fire-strategy status unconfirmed	Authority acceptance, smoke control, active systems, assisted evacuation and high-rise strategy cannot be concluded from Chapter 10 alone	Engage the qualified local/fire consultant; align life-safety drawings, fire strategy, SBPS submission and SCD comments before design freeze

4. General egress baseline

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1003.2	General egress ceiling height	Means of egress ceiling height not less than 2300 mm above finished floor	All egress components	Dwelling/sleeping-unit ceilings, stair headroom, door height, ramp headroom and other listed cases are separately controlled	Direct	Coordinate reflected ceilings, services and signage to preserve the applicable clear height	Verified
1003.3.1	Protruding-object headroom	Minimum headroom 2000 mm over circulation paths; not more than 50% of the egress ceiling area may be reduced	Protrusions below the general ceiling height	Door closers and stops may reduce headroom only to 2000 mm	Direct	Model clear headroom along all walking lines, not only corridor centerlines	Verified
1003.3.1	Low-headroom barrier	Barrier required where clearance is less than 2000 mm ; leading edge 700 mm maximum above floor	Any low-clearance circulation path	No numeric branch stated	Direct	Detail cane-detectable protection below stairs and services	Verified
1003.3.2–1003.3.3	Protruding objects	Post-mounted overhang maximum 100 mm where leading edge is over 700 mm and under 2000 mm ; where post spacing exceeds 300 mm , obstruction bottom is 700 mm maximum or 2000 mm minimum ; horizontal projection maximum 100 mm between 700–2000 mm high	Object projects into a circulation path	Handrail exception permits 115 mm projection; sloping handrail portions between stair/ramp endpoints are excepted as stated	Direct	Audit wall- and post-mounted signs, cabinets and equipment against cane/head zones	Verified
1003.5	Elevation changes	Changes under 300 mm use a sloped surface; slopes over 1:20 (5%) use a 1012 ramp; change 150 mm or less requires handrails or contrasting floor finish	Elevation change in means of egress	Listed nonaccessible exceptions include a single riser or two risers with 325 mm minimum tread and at least one handrail within 750 mm of travel centerline	Direct	Eliminate isolated steps from common egress; document any exact exception	Verified
1003.6	Egress continuity	Path shall not be interrupted; minimum width or required capacity shall not diminish along travel	Entire exit access, exit and exit discharge	Only Chapter 10 permitted projections/components	Direct	Trace the controlling width continuously to the public way	Verified

5. Occupant load and capacity

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1004.2.1	Cumulative load through intervening spaces	Capacity is based on the combined occupant load of interconnected accessory/intervening spaces to each point along the path	Occupants egress through another room/area/space	Do not double-count occupants with independent routes	Direct	Build a cumulative load tree for lobbies, corridors and discharge paths	Verified
1004.2.3	Loads from adjacent stories	Occupant loads from separate stories are not added , except for convergence under 1005.6	Vertical egress sizing by story	Mezzanine loads and convergence follow their own rules	Direct	Size story egress separately, then test convergence	Verified
1004.3	Multiple functions in one area	Calculate each function independently using its applicable occupant-load factor	Mixed-function amenity or podium space	Net areas are removed before applying a gross-area factor to the balance	Conditional	Zone each actual function on the occupant-load plan	Verified
1004.4	Multiple occupancies	Apply means-of-egress rules to each occupancy portion; shared components meet the most stringent requirement of occupancies served	Podium or mixed-use tower	No residential default for shared paths	Conditional	Tag shared corridors, stairs and discharge with all served occupancies	Verified
1004.7	Outdoor areas and occupied roofs	Building official assigns occupant load from anticipated use. Where additional persons use a yard, patio, occupied roof, court or similar area and its egress passes through the building, building egress is based on the sum of building and outdoor-area occupant loads	Outdoor area accessible to and usable by building occupants	The aggregation rule does not apply to outdoor areas associated with an individual Group R-2 dwelling unit; service-only outdoor areas need only one means	Conditional	Include shared roof/terrace amenity loads in the cumulative route; keep private unit balconies/patios on the stated exception branch	Verified
Table 1004.5	Areas without fixed seating	Occupant load is not less than floor area divided by the factor for the function of space	Every non-fixed-seat space	Building official may approve actual load lower than calculated; approval is required	Direct	Record factor, net/gross basis, area and rounded load per space	Verified
Table 1004.5	Residential factor	Residential row exists, but numeric factor and gross/net basis cannot be unambiguously segmented from the OCR table	R-2 dwelling/sleeping areas	No numeric value is adopted in this tier	External verification	Verify published Table 1004.5 before calculating residential loads	Verify source
Table 1004.5	Likely tower support functions	Business 14 m² gross/person ; commercial kitchen 19 m² gross/person ; exercise room 4.6 m² gross/person ; parking garage 19 m² gross/person ; accessory storage/mechanical 28 m² gross/person	Where those actual functions occur	Use actual function, not the overall R-2 group label	Conditional	Apply only to mapped rooms with matching functions	Verified
Table 1004.5	Assembly amenity factors	Standing 0.46 m² net/person ; concentrated chairs only 0.65 m² net/person ; unconcentrated tables/chairs 1.4 m² net/person	Amenity used for assembly without fixed seating	Pools/decks rows remain OCR-unresolved and are not supplied here	Conditional	Test every intended furniture/event layout and use the governing load	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1004.5.1	Increased occupant load	Modified load permitted if all other code requirements use it and density does not exceed 1 person per 0.65 m² of occupiable floor space	Designer/owner proposes higher load	All affected provisions must use modified load	Conditional	Record the approved design load consistently across all disciplines	Verified
1004.6	Fixed seating	Without dividing arms: 1 person per 450 mm of seating length; booths: 1 person per 600 mm measured at backrest	Fixed seating in amenity/assembly areas	Wheelchair and companion spaces each count as one occupant	Conditional	Count seats and continuous benches from the actual seating plan	Verified
1004.8	Concentrated business	Approved actual load, but not less than 1 person per 4.65 m² gross	Call centres, trading floors, data-processing centres and similar dense business uses	Building-official approval required	Conditional	Apply only if such a podium/management use is confirmed	Verified
1005.3.1	Base stair capacity	Stair capacity = served occupant load × 7.6 mm/person	All stairs unless an exception is proven	Assembly seating has separate listed branches	Direct	Retain base factor until sprinkler and EVACS evidence is locked	Verified
1005.3.1 Ex. 1	Reduced stair capacity	5.08 mm/person	Other than H/I-2, and building throughout has Section 903.3.1.1 or 903.3.1.2 sprinklers and Section 907.5.2.2 EVACS	NFPA 13 and NFPA 13R both satisfy the Chapter 10 sprinkler wording; EVACS is additionally mandatory	Conditional	Do not use reduced factor unless both system conditions are documented	Verified
1005.3.2	Base non-stair capacity	Other egress component capacity = served load × 5.08 mm/person	Doors, corridors, ramps and other non-stair components	Reduced-factor Exception 1 is OCR-corrupted	Direct	Use 5.08 mm/person ; do not infer a reduced value	Verified
1005.3.2 Ex. 1	Reduced non-stair capacity	Mandatory OCR is corrupted; numeric factor is not recoverable from approved source	Proposed reduced non-stair factor	No value adopted from commentary or outbound source	External verification	Verify the published clause before any reduction	Verify source
1005.5	Loss of one exit	Loss of any one exit/access shall not leave less than 50% of required capacity or width	More than one exit/access required	Applies to configuration, not only total width	Direct	Run a largest-exit-loss check for every story and converged path	Verified
1005.6	Egress convergence	After convergence from stories above/below, provide the larger of the largest minimum width or the sum of required capacities for the two adjacent stories	Stairs/ramps converge at an intermediate level	Limited to the two adjacent stories described	Conditional	Check podium/ground convergence before fixing lobby width	Verified
1005.7 / 1005.7.1–1005.7.3	Encroachments and projections	Fully opened door reduces required width by maximum 175 mm ; door in any position by maximum one-half ; other trim/decorative projection maximum 40 mm each side ; protruding objects comply with 1003.3	Door, hardware or projection enters required egress width	Surface latch hardware exception requires mounting 850–1200 mm high and stated orientation; door-swing restriction does not apply inside individual R-2 dwelling/sleeping units	Direct	Overlay all door swings and wall projections on net-width plans	Verified

6. Exit counts and loss-of-exit capacity

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1006.2.1	Space-level two-way-out trigger	Provide two exits or exit access doorways from a space where occupant load or common path exceeds Table 1006.2.1	Applied to each room/space	Mechanical penthouse common-path measurement and other listed exceptions	Direct	Check each unit, amenity, plant and tenant space independently	Verified
1006.2.1.1	Large-space exit count	Space load 501–1,000: 3 exits/access doorways; greater than 1,000: 4	Individual space exceeds 500 occupants	Separate from story-level Table 1006.3.3	Conditional	Apply to large podium/amenity spaces if present	Verified
1006.3 / 1006.3.1	Stories and occupied roofs	Number of separate and distinct exits/accesses is based on aggregate load served; where stairs serve multiple stories or a story and occupied roof, use each story or occupied-roof load individually to calculate its required exits/accesses	Every story and occupied roof	Mezzanine and convergence rules remain separate	Direct	Add each occupied roof as its own line in the exit-count schedule	Verified
Table 1006.3.3	Story/occupied-roof exit count	Load 1–500: 2 ; 501–1,000: 3 ; more than 1,000: 4 exits or accesses to exits	Each story and occupied roof	Single-exit permissions under 1006.3.4 are separate exceptions; required count is maintained to exit discharge/public way	Direct	Schedule roof and story counts independently from every space/unit check	Verified
1006.3.4 Item 5	Unit-level one-door logic	An individual single- or multistorey dwelling unit may have a single exit/access if it complies with 1006.2.1 and, outside the unit entrance, access is to at least two approved independent exits , unless the unit exit discharges directly outside at the level of discharge	Individual dwelling unit	This permission does not reduce the required number of exits from the story	Conditional	Show one unit entrance door and two independent story exits as separate checks	Verified
Table 1006.2.1	R-2 one-door space limit	OCR/inventory reads maximum 20 occupants and sprinklered common path 38 m ; unsprinklered branch reads Not Permitted	R-2 room/space with one exit access doorway	Table note recognizes Section 903.3.1.1 or 903.3.1.2; table segmentation requires published-source check	Conditional	Treat as a hold point; verify table before relying on a one-door unit/space	Verify source
Table 1006.3.4(1)	Single-exit R-2 dwelling story	OCR/inventory reads basement through third story above grade: maximum 4 dwelling units and 38 m travel	R-2 consisting of dwelling units	Requires Section 903.3.1.1 or 903.3.1.2 sprinklers and Section 1031 EEROs; fourth story and higher reads Not Permitted	Conditional	High-rise residential floors should retain multiple story exits; verify low podium/residential levels separately	Verify source
Table 1006.3.4(2)	R-2 sleeping-unit story branch	Table is for R-2 sleeping units; inventory rows are flattened and upper stories read single exit Not Permitted from the third story and higher	R-2 consisting of sleeping units	Exact row/occupancy attachment requires published-source check	Conditional	Confirm unit type; do not transpose dwelling-unit limits to sleeping units	Verify source
1005.5	Exit-loss check	Remaining capacity/width after loss of one exit must be at least 50% required	Any floor/space requiring multiple exits	Applies alongside exit-count minimums	Direct	Distribute capacity so one oversized/critical exit does not fail the system	Verified

7. Common path, exit access travel and exit separation

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
Table 1006.2.1	R-2 common path	OCR/inventory reads 38 m with qualifying sprinklers and Not Permitted without	One-door R-2 space branch	Note a recognizes Section 903.3.1.1 or 903.3.1.2; table OCR requires verification	Conditional	Verify published table and measure from the most remote point to choice of two routes	Verify source
Table 1017.2	Group R exit access travel	Flattened OCR row for A/E/F-1/I-1/M/R/S-1 reads “ 60° / 75° ”; limits/footnote markers are unresolved	Total exit access travel for Group R	Sprinkler footnote references Section 903.3.1.1 or 903.3.1.2	External verification	Do not use 60/75 as released design criteria until published table is checked	Verify source
1017.3	Measurement to exit	Where more than one exit is required, measure travel distance to the nearest exit	Multiple exits required	Listed special measurement exceptions	Direct	Show measured travel paths, not straight-line radii	Verified
1007.1.1	Two-exit remoteness — base	Separation at least one-half the maximum overall diagonal of the building/area served	Two exits/access doorways/stairs/ramps required	Straight-line measurement unless corridor method applies	Direct	Dimension the governing diagonal and exit separation on each plan	Verified
1007.1.1	Two-exit remoteness — sprinkler branch	Separation may be at least one-third the maximum overall diagonal	Building throughout sprinklered under 903.3.1.1 or 903.3.1.2	No selection between NFPA 13 and 13R within this Chapter 10 clause	Conditional	Use one-third only after sprinkler basis is formally fixed	Verified
1007.1.1	Interconnected/scissor stairs	Interlocking or scissor stairways count as one exit stairway	Scissor/interlocking core proposed	Does not supply two required exits by itself	Conditional	Do not count two flights in one scissor enclosure as two exits	Verified
1007.1.1	Corridor separation measurement	For stairs/ramps interconnected by a 1-hour corridor complying with 1020, measure along the shortest direct line within the corridor	Rated interconnecting corridor arrangement	Corridor must satisfy the stated protection	Conditional	Identify exact measurement method in fire strategy	Verified
1007.1.2	Three-or-more exits	At least two of three or more required exits/access doorways must satisfy 1007.1.1 remoteness	Story/space requires 3 or 4 exits	Remaining exits still must be arranged to remain available	Conditional	Flag the remote pair in the egress schedule	Verified
1020.5	Dead end — base	Where more than one exit/access doorway is required, dead-end corridor maximum 6 m	Multiple-exit condition	Geometric exception where dead end is less than 2.5 × least corridor width	Direct	Use 6 m unless a listed exception is demonstrated	Verified
1020.5 Ex. 2	Dead end — NFPA 13 branch	Group R-2 dead-end corridor maximum 15 m	Building throughout sprinklered under 903.3.1.1 only	NFPA 13R / 903.3.1.2 is not listed in this exception	Conditional	Keep separate 13 and 13R plan checks; do not give 13R the 15 m allowance	Verified
1017.2.1	Exterior egress balcony increase	Table 1017.2 travel may increase by up to 30 m where the last portion occurs on a 1021-compliant exterior egress balcony	Exterior egress balcony used	Base Table 1017.2 value still requires verification	Conditional	Treat only as a documented alternative after balcony compliance and base limit are verified	Verified

8. Accessible means of egress

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1009.1	Minimum accessible means	Accessible spaces require at least one accessible means of egress	Any required accessible space	Accessible mezzanine and assembly exceptions listed	Direct	Map a continuous accessible egress path to the public way	Verified
1009.1	Multiple accessible means	Where more than one means of egress is required from an accessible space, each accessible portion requires at least two accessible means of egress	1006.2/1006.3 requires multiple means	Assembly ramped/stepped-aisle exception may allow one when common path is accessible and satisfies 1030.8	Direct	Identify the two independent accessible options on every applicable floor	Verified
1009.2	Permitted components	Components include accessible routes, compliant interior/exterior/exit-access stairs, elevators, platform lifts, horizontal exits, ramps, areas of refuge and exterior assisted-rescue areas	Building the complete accessible route	Each component must satisfy its cited section and outbound accessibility scoping	Direct	Create a component-by-component accessible egress diagram	Verified
1009.2.1	Elevator trigger	Where a required accessible floor or occupied roof is four or more stories above or below a level of exit discharge, at least one required accessible means shall be a 1009.4 elevator	Four-storey vertical separation	OCR duplicated wording in one exception; base requirement is clear but inventory remains flagged	Conditional	Reserve an accessible-egress elevator strategy unless an exception is proven	Verify source
1009.2.1 Ex. 1	Elevator exception — horizontal exit	Elevator not required on floors at/above discharge that have a horizontal exit	Building throughout sprinklered under 903.3.1.1 or 903.3.1.2	Does not apply to floors below discharge	Conditional	Demonstrate horizontal-exit refuge, capacity and discharge before using exception	Verify source
1009.2.1 Ex. 2	Elevator exception — ramp	Elevator not required on floors provided with a 1012-compliant ramp	Building throughout sprinklered under 903.3.1.1 or 903.3.1.2	Ramp must serve the applicable levels	Conditional	Apply only to an actual continuous ramp solution	Verify source
1009.3.2	Accessible-egress stair width	Clear width 1200 mm minimum between handrails	Stair used as accessible means of egress	Width not required with 903.3.1.1 or 903.3.1.2 sprinklers, or from refuge area with horizontal exit	Conditional	Check clear width between handrails separately from nominal stair width	Verified
1009.3.3 Ex. 5	R-2 stair area of refuge	Areas of refuge are not required at stairways in Group R-2 occupancies	Stair forms part of an accessible means of egress in R-2	This is only an area-of-refuge exception; it does not remove the accessible-means-of-egress requirement or the accessible route to the stair/elevator	Conditional	Continue to provide the required accessible means, stair access and other applicable communication/elevator components	Verified
1009.6.3	Area-of-refuge wheelchair spaces	One 750 × 1300 mm wheelchair space per 200 occupants or portion served	Area of refuge provided/required	Other protection and communication provisions also apply	Conditional	Lay out spaces without reducing egress width	Verified
1009.7.2–1009.7.4	Exterior assisted-rescue area	Separation 1 hour ; rated wall extends 3000 mm vertically and 3 m horizontally each side, or 1200 mm perpendicular alternative; other sides at least 50% open ; stair 1200 mm clear between handrails	Exterior assisted-rescue option at level of discharge	Rating/width exceptions where throughout sprinklered under 903.3.1.1 or 903.3.1.2	Conditional	Coordinate façade exposure, opening protection and landing geometry	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1009.8	Two-way communication	Provide at each elevator/bank landing on each accessible floor one or more stories above or below discharge	Accessible elevator landings	Areas of refuge, ramps, service/freight/private residence elevators and listed institutional cases have exceptions	Conditional	Include devices, signage, monitoring location and power/interface in fire strategy	Verified

9. Illumination and signs

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1008.2	Illumination while occupied	Means of egress serving a room/space is illuminated whenever occupied	Occupied room or space	Dwelling units and sleeping units in Group R-2 are excepted from this continuous-illumination rule; the exception does not extend to required common egress outside the unit	Direct	Separate in-unit lighting controls from continuously available common egress lighting	Verified
1008.2.1	Normal common-egress illumination	At least 11 lux at walking surface	Required common means of egress outside the excepted R-2 dwelling/sleeping unit	Assembly performance exception is separate	Direct	Put 11-lux minimum on common corridors, exits and discharge criteria	Verified
1008.2.1	Common stair illumination	At least 110 lux at walking surface on exit-access stairs, exit stairs and required landings when in use	Required common stairs outside the excepted R-2 dwelling/sleeping unit	Assembly performance reduction may reach 2.2 lux only with automatic restoration and listed conditions	Direct	Coordinate normal controls so common stairs meet 110 lux when used	Verified
1008.3.2	Emergency-illuminated components	Emergency system automatically illuminates interior exit-access stairs/ramps, interior/exterior exit stairs/ramps, exit passageways, discharge vestibules/areas and exterior exit landings	Building requires two or more exits/accesses	Listed component scope is cumulative	Direct	Include the complete route, not only stairs and exit signs	Verified
1008.3.3 Item 5	Large public-restroom emergency lighting	Public restrooms over 28 m² are automatically illuminated by the emergency electrical system upon power failure	Public restroom area exceeds 28 m²	Other listed emergency-response rooms have no dimensional trigger in this clause	Conditional	Add qualifying public restrooms to emergency-lighting schedules and calculations	Verified
1008.3.4	Emergency duration	Emergency power for at least 90 minutes	Emergency egress lighting	Batteries, unit equipment or on-site generator permitted	Direct	Coordinate 90-minute basis with electrical schedule	Verified
1008.3.5	Initial emergency level	Average at least 11 lux , minimum at any point 1 lux at floor level along path	Emergency power starts	No project-specific reduction	Direct	Verify average and point minimum by calculation	Verified
1008.3.5	End-of-duration level	May decline to average 6 lux , point minimum 0.6 lux at end of duration	At 90-minute endpoint	Applies only at end of emergency-lighting duration	Direct	Include depreciation/end-duration check	Verified
1013.1	Exit-sign spacing	No point in exit-access corridor or exit passageway more than 30 m or listed viewing distance, whichever is less, from visible sign	Direction to exit not readily apparent	Signs not required inside individual R-2 sleeping/dwelling units; one-exit rooms and obvious approved main exterior exits also listed	Direct	Prepare sign visibility/spacing plan outside units	Verified
1013.6.1–1013.6.3	Exit-sign graphics and power	Letters at least 150 mm high with 20 mm strokes; “EXIT” letter width at least 50 mm except I, spacing at least 10 mm ; externally lit face at least 55 lux ; backup at least 90 minutes	Exit/directional sign required	Approved self-powered sign may satisfy stated 90-minute exception	Direct	Coordinate sign schedule and photometrics	Verified
1023.9–1023.9.1	Stair identification sign	Required at each landing when stair/ramp connects more than 3 stories ; bottom at least 1500 mm above landing; sign at least 450 × 300 mm , stair ID 40 mm , floor number 125 mm , other text 25 mm	High-rise interior exit stair/ramp	Tactile sign requirements are separately cross-referenced	Direct	Issue a consistent stair-sign family and location detail	Verified

10. Doors, gates and turnstiles

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1010.1.1	Door clear opening	Capacity-sized and at least 800 mm clear width ; minimum clear height 2000 mm	Required egress door	R-2 internal nonaccessible-unit exceptions exist; Type B user-passage doors remain 800 mm	Direct	Schedule clear opening, not nominal leaf size	Verified
1010.1.1	Swing-door measurement	Measure between door face and stop with door at 90 degrees ; one leaf of a pair without mullion must provide 800 mm clear	Swinging/pair doors	Listed special doors have separate provisions	Direct	Dimension clear width at 90 degrees in door details	Verified
1010.1.2.1	Direction of swing	Door swings in egress direction for room/area load 50 or more , or Group H	Threshold met	Unit entrance below threshold is not automatically required by this clause to swing out	Conditional	Link each door swing to served room load	Verified
1010.1.3	Door operating forces	Push/pull unlatching maximum 67 N ; rotational unlatching maximum 3.15 N-m ; manually operated interior swinging non-fire-rated egress door opening maximum 22 N ; other, sliding, folding and fire-rated doors maximum 133 N to set in motion and 67 N to full-open	Manually operated egress door	Power-operated doors are addressed separately; forces are applied at latch side under 1010.1.3.1	Direct	Put force criteria in hardware specification and commissioning checks	Verified
1010.1.5	Door landing	Landing length in travel direction at least 1100 mm ; fully open door may reduce required dimension by no more than 175 mm	Egress door landing	Within individual R-2 units, landing length need not exceed 900 mm	Direct	Check both open and closed door positions	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1010.1.6	Threshold — base	Sliding doors serving dwelling units maximum 20 mm ; other doors maximum 12.5 mm ; changes over 6 mm bevel no steeper than 1:2 (50%)	Doorway threshold	Exceptions below are narrowly scoped	Direct	Use the base limits for required egress and accessible doors	Verified
1010.1.6 Ex. 1	R-2 exterior threshold	Sliding or side-hinged exterior threshold may be up to 200 mm only where the door is not part of required egress, not part of a Chapter 11 accessible route, and not part of an Accessible, Type A or Type B unit	Group R-2 or R-3 exterior door meeting all three conditions	Failure of any condition returns the door to the base limits	Conditional	Identify the nonrequired, nonaccessible door and unit type before using 200 mm	Verified
1010.1.6 Ex. 2	Type B exterior-side threshold	Where 1010.1.4 Ex. 5 permits a 100 mm exterior level change, exterior-side threshold maximum is 120 mm above deck/patio/balcony for sliding doors and 115 mm for other doors	Exterior door of Type B unit under the cited level-change exception	These are exterior-side measurements; base interior-side limits and beveling still apply	Conditional	Detail both interior and exterior threshold datums	Verified
Unnumbered — commentary indicates 1010.1.7	Doors in series / vestibule	Space between two doors in series is 1200 mm minimum plus the width of a door swinging into the space ; doors swing in the same direction or away from the intervening space	Successive doors/vestibule on an egress path	Horizontal sliding power doors: 1200 mm minimum; R-2/R-3 unit storm/screen doors need not be spaced 1200 mm; doors within R-2/R-3 dwelling units are excepted other than within Type A dwelling units	Conditional	Dimension vestibules beyond the full door swing; apply unit exceptions only at their exact scope	Verify source
1010.2.1	Unlatching	Not more than one motion in one linear/rotational direction to release latching/locking devices	Egress side of doors	Group R unit security devices are a listed exception under 1010.2.4 Item 5	Direct	Coordinate hardware sets for single-action egress	Verified
1010.2.3	Hardware height	Operating devices 850–1200 mm above finished floor	Egress doors/gates	Pool/spa barrier latch exception up to 1350 mm under stated conditions	Direct	Put range in hardware specification	Verified
1010.2.4 Item 5	R-unit security	Group R dwelling/sleeping-unit doors serving load 10 or less may have night latch, dead bolt or security chain if openable inside without key/tool	Individual unit	Does not waive one-motion/safe-egress intent beyond stated permission	Conditional	Confirm unit occupant load and free-egress operation	Verified
1010.2.9	Panic hardware	Group A/E rooms/spaces with load 50 or more require panic/fire-exit hardware; Group H also listed	Assembly amenity or mixed-use trigger	Main-exit and electrical locking exceptions are listed	Conditional	Check amenity and podium doors by actual occupancy/load	Verified
1010.2.11 Item 2	Hardware-released electric lock	Door-mounted release hardware is operable with one hand and complies with 1010.2.1	Door-hardware release electric locking system, except Group H	All listed release and power-loss criteria remain cumulative	Conditional	Coordinate the hardware set and single-hand operation with the electrical lock release	Verified
1010.2.12	Sensor-released lock	Manual release at 1000–1200 mm high and within 1500 mm of secured doors; direct power interruption; unlock at least 30 seconds	Sensor-released electrically locked egress door	Fire alarm, sprinkler/detection and power-loss release conditions also required	Conditional	Coordinate access control with fire alarm and emergency lighting	Verified
1010.2.13 / 1010.2.13.1	Delayed egress	General path maximum one delayed-egress system ; irreversible release within 15 seconds after no more than 3 seconds applied effort; approved delay may be 30 seconds	Delayed-egress locking system serving Group R or another listed occupancy with required sprinkler/detection prerequisite	Institutional two-device exceptions are NOT_TYPICAL and capped at 30 seconds combined	Conditional	Treat delayed egress as a fire-alarm, access-control, emergency-lighting and signage package; obtain approval for any 30-second branch	Verified
1010.2.13.1 Item 6	Delayed-egress sign	Sign above and within 300 mm of exit hardware; PUSH/PULL legend states opening in 15 [30] seconds according to door swing	Delayed-egress door	Group I sign omission is a separate clinical exception	Conditional	Put exact legend, location and approved delay on the door/hardware schedule	Verified
1010.3.1	Revolving door	Breakout aggregate width at least 900 mm ; side-hinged 1010.1 door in same wall within 3000 mm ; revolving door not on accessible route	Revolving entrance proposed	Egress credit limited to 50% and 50 persons per door under 1010.3.1.1	Conditional	Prefer compliant side-hinged egress doors as the dependable route	Verified
1010.5.1	Conventional turnstile	Credit maximum 50 persons and no more than 50% required capacity; device max 990 mm high; clear width 420 mm up to 990 mm high and 550 mm above	Turnstile used for egress credit	Must free-turn on power loss/manual release	Conditional	Keep at least half capacity independent of turnstiles	Verified
1010.5.1.1	Accessible-route turnstile	Clear width at least 900 mm at/below 850 mm high and at least 800 mm between 850–2000 mm ; mechanism is not revolving	Turnstile lies on an accessible route	Accessibility geometry and approach remain separately controlled	Conditional	Provide a compliant nonrevolving accessible lane and dimension both height branches	Verified
1010.5.2	Security access turnstile	Lane minimum 550 mm ; lane under 800 mm credited maximum 50 persons ; lane 800 mm or more sized under Section 1005	Approved supervised 903.3.1.1 sprinklered building and listed release conditions	Requires automatic unobstructed opening on specified events	Conditional	Use only with NFPA 13 branch and coordinated fail-safe release	Verified
1010.5.4	Turnstile companion door	For served load over 300 , side-hinged compliant door within 15 m	Nonportable turnstile	Exception for compliant 1010.5.2 security turnstiles	Conditional	Include companion door in lobby planning if trigger is met	Verified

Door-arrangement numbering hold point: the supplied Chapter 10 text omits the section number before “Door arrangement”; its commentary identifies **1010.1.7**. The mandatory values are retained under the citation **Unnumbered — commentary indicates 1010.1.7**, and the published section number remains a verification hold point.

11. Stairs

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1011.2	Minimum width	Capacity-sized under 1005 and at least 1100 mm	General stair	Stair serving fewer than 50 occupants may be 900 mm ; accessible-egress clear width is separate	Direct	Use the larger of capacity, 1100 mm and accessible-egress requirement	Verified
1011.3	Headroom	At least 2100 mm vertically from nosing line, continuous to one tread beyond bottom riser	General stair	Spiral stair 2000 mm ; limited R-2 in-unit projection exception 120 mm	Direct	Check soffits, landings and underside of flights in section	Verified
1011.5.2	Public/common riser and tread	Riser 100–175 mm ; rectangular tread at least 275 mm	Common/public tower stairs	Assembly stepped aisles and listed special stairs separate	Direct	Apply to exit stairs and common circulation stairs	Verified
1011.5.2 Ex. 3	Inside individual R-2 dwelling	Riser maximum 200 mm ; tread and winder walkline at least 250 mm ; minimum winder depth 150 mm ; solid-riser nosing 20–32 mm where tread below 275 mm	Stair wholly within individual dwelling unit	Not for common/exit stair	Conditional	Label in-unit stairs distinctly so exception is not propagated to core stairs	Verified
1011.5.4	Uniformity	Largest-smallest riser or tread variation maximum 10 mm in a flight	All flights	Listed stepped-aisle and consistent-winder branches	Direct	Add construction tolerance requirement	Verified
1011.6	Landing depth and door	Landing depth equals stair width or 1200 mm , whichever is less; fully open door projects no more than 175 mm ; open door cannot reduce landing below one-half required width	Stair landing	Listed transition/curved landing exceptions	Direct	Overlay door swings on clear landing diagrams	Verified
1011.7.1	Stair walking-surface slope	Maximum 1:48 (2%) in any direction	Treads and landings	Opening-size exceptions for industrial uses	Direct	Coordinate drainage without exceeding cross slope	Verified
1011.8	Maximum flight rise	3600 mm maximum vertical rise between landings	Stair flight	Technical-production spiral exception	Direct	Insert intermediate landing where floor-to-floor geometry requires	Verified
1011.12	Roof stair	In buildings 4 or more stories , one stair extends to roof unless roof slope exceeds 4:12 (33%)	Tower roof	Unoccupied-roof access alternatives listed except where 1011.12.1 requires otherwise	Conditional	Confirm occupied/unoccupied roof and coordinate one core to roof	Verified
1011.12.2	Unoccupied-roof hatch	Hatch permitted at least 1.5 m² , minimum dimension 600 mm	Building without occupied roof	Applies only under stated roof-access exception	Conditional	Coordinate hatch, ladder/device and roof safety	Verified
1011.13	Roof-edge guard near hatch	Guard roof hatch/access or roof edge where opening is within 3000 mm of roof edge	Roof access near edge	Guard must satisfy 1015	Conditional	Keep hatch farther from edge or detail compliant guard	Verified

12. Ramps

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1012.2	Means-of-egress ramp slope	Maximum 1:12 (8.3%)	Ramp forms part of means of egress	Other pedestrian ramps may be 1:8 (12.5%) , but accessible route may be more restrictive outbound	Conditional	Use 1:12 for egress/accessible planning unless verified otherwise	Verified
1012.3	Ramp cross slope	Maximum 1:48 (2%)	All ramps	No numeric branch stated	Conditional	Coordinate drainage falls	Verified
1012.4	Rise per run	Maximum 750 mm	Each ramp run	No numeric branch stated	Conditional	Set landing frequency from rise	Verified
1012.5.1	Ramp clear width	At least 900 mm between handrails/projections and sized for capacity	Egress ramp	Accessible route and served load may require more	Conditional	Check clear width after handrails	Verified
1012.5.2	Ramp headroom	At least 2000 mm over runs and intermediate landings	Egress ramp	No stated numeric exception	Conditional	Coordinate structure/services in section	Verified
1012.6.3–1012.6.4	Ramp landings	Length at least 1500 mm ; direction-change landing 1500 × 1500 mm	Ramp landing	Nonaccessible R-2 individual units may use 900 mm landing / 900 × 900 mm turn; nonaccessible ramp length need not exceed 1200 mm	Conditional	Apply accessibility/unit classification before selecting exception	Verified
1012.8	Ramp handrails	Both sides where rise exceeds 150 mm	Ramp run	No general numeric exception in record	Conditional	Detail continuous handrails and extensions	Verified
1012.10.1–1012.10.2	Edge protection	Curb at least 100 mm , or qualifying barrier; extended floor/ground at least 300 mm beyond inside face of handrail	Ramp/landing edge protection required	Listed flared-side/adjoining-run/minor-drop exceptions	Conditional	Select and detail one compliant edge-protection method	Verified

13. Handrails and guards

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1014.2	Handrail height	Uniform 850–950 mm above stair nosings or ramp surface	Required handrails	Alternating tread/ship ladder 750–850 mm ; fitting transitions listed	Direct	Dimension from correct datum, not finished landing	Verified
1014.3.1	Type I graspability	Circular outside diameter 32–50 mm ; noncircular perimeter 100–160 mm , max cross-section 60 mm , min 25 mm	Type I handrail	Edge radius at least 0.25 mm	Direct	Put profile limits in metalwork/joinery details	Verified
1014.6	Extensions	Ramp extensions 300 mm horizontally beyond top/bottom; stair top 300 mm , bottom slopes one tread depth	Handrails not continuous between runs/flights	Nonaccessible dwelling-unit and assembly-aisle exceptions	Direct	Resolve extensions against doors and circulation	Verified
1014.7	Wall clearance	At least 38 mm clear between handrail and wall/surface	Wall-mounted handrail	No numeric branch stated	Direct	Coordinate brackets and finishes	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1014.8	Projection	Handrail projections into required aisle/stair/ramp width maximum 115 mm each side; accessible ramp clear between rails at least 900 mm	Handrails project into egress width	Intermediate-pair rule applies where gap over 150 mm	Direct	Calculate capacity on net clear width	Verified
1014.9	Intermediate handrails	All portions of stair minimum width/required capacity within 750 mm of a handrail	Wide stair	No stated numeric exception	Conditional	Add intermediate rails to wide stairs	Verified
1015.2	Guard trigger	Guard open-sided walking surfaces where drop exceeds 750 mm at a point within 900 mm horizontally of edge	Mezzanine, balcony, stair, ramp, landing, roof edge	Listed stage/loading/service exceptions	Direct	Survey every edge and adjacent level	Verified
1015.3	General guard height	At least 1100 mm	Required guards	R-2 in-unit stair guards may be 850 mm ; top-as-handrail 850–950 mm ; low-rise in-unit 900 mm exception does not describe this high-rise tower generally	Direct	Use 1100 mm for common areas and document any in-unit exception	Verified
1015.4	Guard openings	General guard rejects 100 mm sphere; in R-2 unit open stair, 110 mm sphere; triangular stair opening 150 mm	Required guard	Other listed industrial/assembly branches	Direct	Specify opening limits by location	Verified
1015.6–1015.7	Roof service/access guards	Guards where service component or hatch is within 3000 mm / 3 m of edge and edge drop exceeds 750 mm ; service guard extends 750 mm beyond component/hatch	Roof equipment/access near edge	Fall-arrest/restraint anchorage exception under stated standard	Conditional	Coordinate roof plant zones, access path and fall protection	Verified
1015.8	R-2 operable-window trigger	In Group R-2/R-3 buildings including dwelling units, comply with one of four controls where bottom of clear operable opening is less than 900 mm above interior floor and exterior drop is more than 1800 mm to grade/surface below	Both sill/drop conditions occur	Raising bottom of clear opening to at least 900 mm avoids this trigger; an EERO must also satisfy 1031	Direct	Audit every operable residential window against interior sill and exterior drop	Verified
1015.8 Items 1–3	Window fall-prevention branches	(1) Where top of sill is more than 23 m above exterior grade/surface, provide ASTM F2006 device; or (2) largest open position rejects a 100 mm-diameter sphere ; or (3) provide ASTM F2090 fall-prevention device	Triggered R-2/R-3 operable window	ASTM F2006 branch is expressly tied to the more-than-23 m top-of-sill condition; select one listed branch	Direct	Coordinate façade hardware and identify any window also serving as EERO	Verified
1015.8 Item 4 / 1015.8.1	Window opening-control device	Opening-control device complies with ASTM F2090 and, after release for full opening, does not reduce net clear opening below Section 1031.3.1	Triggered window uses opening-control-device branch	Section 1031.3.1 criterion matters where the window is an EERO	Conditional	Obtain listed device data and verify released EERO clear area where applicable	Verified

14. Corridors, aisles and exterior egress balconies

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1016.2	Intervening spaces	Exit access cannot pass through a lockable room; dwelling/sleeping-area egress cannot lead through another sleeping area, toilet or bathroom; egress generally cannot pass through kitchens/storage/closets	Exit route passes through another space	Kitchen serving adjoining rooms in same dwelling/sleeping unit is a listed exception	Direct	Trace unit and shared routes against room locking and use	Verified
1016.2	Elevator lobby route	If two or more exits are required, at least one required exit must be accessible without travel through the enclosed elevator lobby required by Section 3006	Enclosed elevator lobby lies on exit access	Lobby protection need not extend to exit unless another section requires direct access	Conditional	Preserve one independent route around lobby	Verified
1016.2.1	Multiple tenants/units	Each tenant space, dwelling unit and sleeping unit gets access to required exits without passing through adjacent tenant/unit	More than one tenant/unit on floor	Smaller-tenant exception is less than 10% of larger adjoining space and has other conditions	Direct	Keep residential units independently connected to common egress	Verified
1018.3 / 1018.5	Nonassembly aisles	Nonpublic aisle serving fewer than 50 and not required accessible may be 700 mm	B/M or other nonassembly work/stock aisle	Public/accessible aisle must satisfy applicable width/capacity	Conditional	Apply only to genuinely nonpublic support aisles	Verified
Table 1020.2	R corridor rating	For Group R corridor serving more than 10 , OCR reads unsprinklered Not Permitted and sprinklered “0.5/1 hours” ; rating/footnote attachment unresolved	Common R corridor	Table recognizes 903.3.1.1 or 903.3.1.2 where allowed; in-unit R corridor rating exception exists	External verification	Obtain published table/footnote before selecting corridor rating	Verify source
Table 1020.2	Corridor width	OCR table contains 1100 mm general and 900 mm small-load/within-unit values, but row attachment is unresolved	Corridor width selection	Capacity under Section 1005 can govern above table minimum	External verification	Verify published table before issue; provisionally coordinate common corridor no narrower than capacity and verified minimum	Verify source
1020.5	R-2 dead ends	Base 6 m ; 15 m only with throughout 903.3.1.1 sprinklers	Multiple exits/access required	NFPA 13R not named for 15 m exception; 2.5:1 geometric exception also listed	Direct	Maintain separate NFPA 13 and 13R checks	Verified
1021.3	Balcony openness	Long side at least 50% open , distributed to minimize smoke/toxic-gas accumulation	Exterior egress balcony	Wall separation and opening protection also apply	Conditional	Demonstrate permanent openness, not operable glazing	Verified
1021.4	Balcony location	Fire separation distance at least 3000 mm from lot line, other building portions and same-lot buildings unless protected as stated	Exterior egress balcony	Section 705 protection branch	Conditional	Coordinate façade returns and adjacent masses	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1017.2.1	Balcony travel increase	Up to 30 m additional travel only where last portion to exit is on compliant exterior egress balcony	Travel-distance strategy uses balcony	Base travel-distance table remains a verification hold point	Conditional	Do not bank increase before published Table 1017.2 check	Verified

15. Interior exit stairs/ramps, exit passageways and horizontal exits

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1023.1	Exit enclosure continuity	Interior exit stair/ramp enclosed and leads directly outside or extends outside through 1024 exit passageway; used only for egress and circulation	Interior exit stair/ramp	Limited discharge alternatives under 1028.2	Direct	Keep storage, plant and non-egress uses out of enclosure	Verified
1023.2	Enclosure rating	2 hours where connecting 4 stories or more ; 1 hour where fewer; basements count, mezzanines do not	Interior exit enclosure	Rating not less than penetrated floor and need not exceed 2 hours; listed special exceptions	Direct	Tower core should be coordinated to 2-hour branch, subject to full code review	Verified
1023.4	Openings	Openings limited to required exit access and egress; elevators shall not open into interior exit stairways/ramps	Exit enclosure	Unprotected exterior openings handled separately	Direct	Eliminate service-room and elevator openings into stairs	Verified
1023.7	Exposed exterior wall	At angle below 180° , building wall within 3000 mm requires at least 1 hour ; protection extends to 3000 mm above top landing/roof line; openings at least 3/4 hour	Stair exterior wall exposed by building return	Applies to affected exposure zone	Conditional	Check façade returns around discharge and roof	Verified
1023.10 / 1023.9.1 Items 4–6	Elevator-lobby identification	At an interior-exit-stair landing where two or more doors lead to the floor , any door directly accessing an enclosed elevator lobby is marked “ Elevator Lobby ” on or directly adjacent to the door; lettering/numbers at least 25 mm , nonglare and contrasting	Two-or-more-door stair landing with direct enclosed-lobby door	If the building/sign is subject to Section 1025, use the same material required by 1025.4; R-2 alone is not a listed 1025.1 group	Conditional	Add the lobby-door sign to stair-core door/sign schedules without importing Section 403 elevator assumptions	Verified
1024.2	Exit-passageway width	Capacity-sized; minimum 1100 mm , or 900 mm when serving fewer than 50 occupants	Exit passageway used	Permitted encroachments under 1005.7	Conditional	Size for cumulative stair load, not only local floor	Verified
1024.3	Exit-passageway rating	At least 1 hour and not less than connected stair/ramp requirement	Exit passageway extends protected exit	Connected 2-hour tower stair therefore controls at not less than that rating	Conditional	Match passageway protection to connected enclosure	Verified
1026.1	Horizontal-exit share	Cannot be sole exit; with multiple exits, no more than one-half total number or width/capacity may be horizontal exits	Horizontal exit proposed	I-2/I-3 exceptions not typical for R-2	Conditional	Retain independent vertical/outdoor exits for remaining required share	Verified
1026.2	Horizontal-exit separation	Minimum 2-hour separation, extending vertically unless floors are at least 2 hours with no unprotected openings	Horizontal exit proposed	Pedestrian-walkway exception only under stated conditions	Conditional	Align barrier continuity through tower/podium	Verified
1026.4.1	Refuge capacity	Net 0.28 m²/person accommodated	Horizontal-exit refuge area	Separate from 1009 wheelchair-space geometry	Conditional	Calculate both total refuge area and accessible spaces	Verified
1026.4.2	Refuge exit	At least one refuge-area exit leads directly outside or to interior exit stair/ramp	Horizontal-exit refuge	Listed adjoining-compartment exception	Conditional	Show onward route without return through fire-origin compartment	Verified

16. Exit discharge and egress courts

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1028.1 / 1028.5	Discharge destination	Exits discharge directly outside; exit discharge provides direct, unobstructed access to public way	Every exit	Limited 1028.2 discharge-through-area/vestibule/horizontal-exit branches	Direct	Trace every stair/exit independently to public way	Verified
1028.2 Ex. 1	Discharge through level area	No more than 50% of number and width/capacity of interior exit stairs/ramps may egress through discharge-level areas	Lobby/atrium discharge proposed	Requires visible unobstructed exterior door and separation below; egress path is sprinkler-protected, and portions with access to it are either sprinklered throughout under 903.3.1.1 or 903.3.1.2 or separated as an interior-exit enclosure	Conditional	Keep at least half direct and document the NFPA 13 or NFPA 13R discharge-lobby protection branch	Verified
1028.2 Ex. 1.4	Stair termination separation	Exit-access stair/ramp termination and interior-exit discharge door separated by at least 9 m or one-fourth building diagonal, whichever is less	Both terminate at same discharge level	Straight-line measurement	Conditional	Dimension conflict separation in lobby plan	Verified
1028.2 Ex. 2	Vestibule discharge	No more than 50% of number and width/capacity may discharge through vestibule	Vestibule alternative	Depth from exterior max 3000 mm , length max 9 m ; protected and used only for egress	Conditional	Detail enclosure, dimensions and direct outside door	Verified
1028.2	Combined exceptions	Combined use of area and vestibule exceptions cannot exceed 50% of required exits and width/capacity	Both exceptions used	Aggregate cap, not 50% each	Conditional	Include combined schedule	Verified
1028.5	Safe dispersal	If public-way access cannot be provided: at least 0.46 m²/person , on same lot at least 15 m from building, permanently maintained/identified, with safe unobstructed path	Safe-dispersal alternative	Only when direct public-way access cannot be provided	Conditional	Coordinate site/fire-appliance/landscape plans and capacity	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1029.2	Egress-court width/headroom	Capacity-sized; minimum 1100 mm ; unobstructed to 2.1 m high	Egress court forms discharge	R-3/U 900 mm exception does not apply to R-2 tower	Conditional	Protect net width from gates, planting and services	Verified
1029.3	Narrow egress court	Where court is under 3000 mm wide, walls at least 1 hour for 3000 mm above court floor; openings at least 3/4 hour	Narrow court	Exceptions for load under 10 and R-3, not general R-2	Conditional	Coordinate wall/opening ratings along court	Verified

17. Assembly amenity conditions

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
Table 1004.5	Unfixed amenity seating/load	Standing 0.46 m² net/person ; chairs only 0.65 m² net/person ; tables/chairs 1.4 m² net/person	Assembly amenity without fixed seats	Select by actual configuration; pool/deck factors unresolved	Conditional	Calculate each operating/event layout	Verified
1004.9	Occupant-load posting	Every assembly room/space posts approved load conspicuously near main exit/access doorway in permanent, maintained form	Space is assembly occupancy	Intended configurations must be represented	Conditional	Add placard to signage schedule	Verified
1030.2	Main exit over 300	If assembly load is greater than 300 and a main exit is provided, main exit accommodates at least one-half load and at least total capacity leading to it	Large assembly amenity	If no well-defined main exit/multiple main exits, perimeter distribution may provide 100% capacity	Conditional	Test ballroom/cinema/club layouts if load crosses 300	Verified
1030.2	Group A frontage	Group A main exit fronts a street or at least 3000 mm unoccupied space adjoining street/public way	Building/space classified Group A and main exit used	Occupancy classification is outbound from Chapter 10	Conditional	Confirm whether amenity is Group A and coordinate frontage	Verified
1030.3	Other exits over 300	In addition to main exit, each level with load over 300 gets additional egress capacity for at least one-half total load served, complying with 1007.1	Large assembly with main exit	Distributed-main-exit alternative separately addressed	Conditional	Provide remote additional exits and capacity split	Verified
1030.5	Balcony/gallery	Seating capacity 50 or more requires at least two means of egress , one from each side	Interior assembly balcony/gallery/press box	Under 50 follows other applicable rules	Conditional	Avoid single-ended amenity mezzanine seating at trigger	Verified
1030.8	Assembly common path	Base maximum 9 m from seat to choice of two routes; area serving fewer than 50 may use 23 m	Assembly seating	Smoke-protected/open-air branch 15 m	Conditional	Measure from worst seat under every furniture plan	Verified
1030.9.1	Assembly aisle widths	Stepped, seating both sides 1200 mm ; one side 900 mm ; level/ramped both sides 1100 mm ; one side 900 mm	Assembly seating aisle	Listed reductions to 900/750/600 mm depend on seat count, accessibility and handrail arrangement	Conditional	Size from served seats and accessible route	Verified
1030.13.1	Seating at tables datum	Required clear width measured to line 480 mm from and parallel to table/counter edge	Loose seating at tables/counters	Fixed-seat measurement from back of seat	Conditional	Draw chair occupancy envelope in egress plans	Verified
1030.13.1.1	Table aisle access-way	At least 300 mm plus 12.5 mm per additional 300 mm/fraction beyond 3600 mm length	Seating at tables/counters	Portion not over 1800 mm serving max 4 persons excepted	Conditional	Check deep banquettes and private dining layouts	Verified
1030.13.1.2	Table access travel	Maximum 9 m from any seat to choice of two or more separate-exit paths	Seating at tables	No numeric branch stated	Conditional	Test farthest chair, not table edge	Verified
1030.14.1	Ramped assembly aisle	Over 1:20 (5%) is a ramped aisle; accessible route max 1:12 (8%) ; other ramped aisle max 1:8 (12.5%)	Sloped amenity seating aisle	Cross slope max 1:48 (2%)	Conditional	Coordinate sightlines with accessible slope	Verified
1030.14.2	Stepped assembly aisle	Slope over 1:8 (12.5%) uses full-width risers/treads; tread at least 275 mm ; riser generally 100–200 mm	Stepped seating aisle	Sightline exception permits riser to 225 mm with stated marking/tolerance controls	Conditional	Use dedicated stepped-aisle detail, not ordinary stair detail	Verified
1030.16	Assembly aisle handrails	Ramped aisle over 1:15 (6.7%) and stepped aisle require handrails; wide one-sided stepped aisle 1850 mm or more requires two; one rail within 750 mm	Assembly aisles	Listed seating/guard and extension exceptions	Conditional	Coordinate mid-aisle rails with seat access	Verified

18. Emergency escape and rescue openings

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1031.2 / Table 1006.3.4	R-2 scope	Group R-2 is subject to 1031.2 only when located in a story with one exit or access to one exit as permitted by Tables 1006.3.4(1)/(2)	Project relies on a permitted single-exit R-2 story	General multiexit R-2 floors are not independently brought into 1031.2 by the R-2 listing	Conditional	Keep EEROs within the complete, source-verified single-exit package	Verified
1031.2	Location rule by listed occupancy	Within the listed occupancy scope, basements and sleeping rooms below the fourth story above grade plane require at least one EERO; each basement sleeping room requires one and adjoining basement areas do not	R-3/R-4 generally; R-2 only within the single-exit scope above	Opening leads directly to public way or a yard/court opening to public way; listed exceptions follow	Conditional	Do not apply the general R-3/R-4 trigger to ordinary multiexit R-2 tower floors	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1031.2 Ex. 5	Sprinklered basement sleeping rooms	In an individual R-2/R-3 dwelling or sleeping unit, basement sleeping-room EEROs may be omitted where building is throughout sprinklered under 903.3.1.1, .1.2 or .1.3 and basement has either one means of egress plus one EERO , or two means of egress	R-3 generally; R-2 only where 1031.2 already applies through the permitted single-exit-story scope	Exception changes basement sleeping-room distribution; it does not expand 1031.2 to general multiexit R-2	Conditional	Confirm the parent 1031.2 scope before using Exception 5	Verified
1031.3.1	Net clear area	Minimum 0.53 m² ; grade-floor opening minimum 0.46 m²	EERO required	Grade-floor exception only	Conditional	Schedule net clear area in open position	Verified
1031.3.2	Minimum dimensions	Clear height at least 600 mm and clear width at least 500 mm	EERO required	Both dimensions apply alongside area	Conditional	Verify proprietary window free opening, not frame size	Verified
1031.3.3	Sill height	Bottom of clear opening maximum 1100 mm above floor	EERO required	No numeric branch stated	Conditional	Coordinate furniture and façade module	Verified
1031.5.1	Area well	Minimum horizontal area 0.84 m² , projection and width at least 900 mm	EERO opens into area well	Ladder/steps may encroach maximum 150 mm	Conditional	Coordinate structure, drainage and usable clear opening	Verified
1031.5.2	Deep well ladder/steps	Well deeper than 1100 mm requires permanently fixed ladder or steps	Deep area well	Must not obstruct opening operation	Conditional	Detail access and opening swing together	Verified
1031.5.2.1–.2	Well ladder/step geometry	Ladder inside width at least 300 mm , projection at least 75 mm , vertical spacing max 450 mm ; steps inside width at least 350 mm , tread over 125 mm , riser max 450 mm	Ladder/steps provided	Use the applicable device branch	Conditional	Include complete dimensional detail	Verified

19. High-rise and outbound dependencies

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1023.12	Smokeproof enclosure dependency	“Where required by Section 403.5.4, 405.7.2 or 412.2.2.1,” interior exit stairs/ramps are smokeproof enclosures under 909.20	High-rise statement points toward 403.5.4 review	Chapter 10 does not fully define the high-rise trigger, exceptions or 909.20 system	External verification	Verify Section 403 applicability/exceptions and engineer the 909.20 system; do not claim Chapter 10 alone proves smokeproof stairs	Verified
1009.2.1 / 1009.4	Accessible-egress elevator	Four-or-more-storey trigger is in Chapter 10; elevator must comply with 1009.4	Required accessible floor/roof at trigger	1009.4 then cross-references elevator systems/standby power and other requirements	External verification	Coordinate accessibility, vertical transport, fire alarm and fire strategy	Verified
Section 403 / Ch. 30	High-rise/fire-service/occupant elevators	Chapter 10 commentary/cross-references identify high-rise elevator interfaces, but Chapter 10 does not fully define Section 403 elevator triggers or values	High-rise tower	Requirements and exceptions lie outside Chapter 10	External verification	Do not claim high-rise elevator quantities/features from this matrix; verify Sections 403, 3007 and 3008 as applicable	Verified
1025.1	Luminous egress path markings	Listed high-rise groups are A, B, E, I-1, M and R-1	High-rise building in a listed group	R-2 is not included in the listed groups ; mixed-use listed occupancy portions may still require analysis	Not typical	Do not impose Section 1025 solely because the tower is R-2 high-rise; review any listed podium/mixed use separately	Verified
1005.3.1 Ex. 1	Reduced stair factor systems	5.08 mm/person only with 903.3.1.1 or .1.2 sprinklers plus 907.5.2.2 EVACS	Capacity reduction proposed	High-rise sprinkler/EVACS requirements themselves are outside this clause	External verification	Keep 7.6 mm/person until fire engineer confirms both systems and AHJ acceptance	Verified
Table 1017.2	Travel-distance dependency	Group R row OCR reads “ 60° / 75° ”, unresolved	Travel design	Published table/footnotes and sprinkler basis need verification	External verification	Resolve before schematic egress freeze	Verify source
Table 1020.2	Corridor dependency	Group R sprinklered rating OCR reads “ 0.5/1 hours ”, unresolved	Common R corridor serving load over 10	Published table and footnote attachment required	External verification	Do not release partition rating from this extract	Verify source
1002.1–1002.2	Operations and plans	Means of egress maintenance and required fire-safety/evacuation plans are directed to SBC 801	Occupancy/operation	Chapter 10 does not define the full operational plan	External verification	Integrate assisted evacuation, phased strategy and management procedures into approved fire strategy/SBC 801 plan	Verified
Chapter 11 / ICC A117.1	Accessibility geometry	Chapter 10 establishes accessible-egress scoping but cross-references technical accessibility requirements	Accessible routes, doors, signs, ramps and communication	Exact technical geometry outside the Chapter 10 source-only matrix	External verification	Complete separate SBC accessibility review	Verified
Chapters 7 and 9 / SBC 501	Passive and active fire protection	Chapter 10 relies on fire barriers, opening protectives, sprinklers, alarm and smoke-control provisions elsewhere	All protected egress systems	Ratings and system design are not fully specified by Chapter 10 alone	External verification	Align architectural egress matrix with fire engineer’s code basis and SCD NOC package	Verified
SCD / SBPS	Authority acceptance	No Chapter 10 value constitutes authority approval	Riyadh permit/NOC pathway	AHJ identity, submission stage and comments unconfirmed	External verification	Qualified local consultant to confirm authority pathway and close decision register before issue for approval	Verified

20. Project-use controls

1. Use the **Verified** rows for initial dimensional coordination only after the row trigger and branch are confirmed.
2. Treat every **Verify source** row as a design hold point; no affected value is to be placed in issued-for-approval drawings without a published-source check.
3. Maintain separate NFPA 13 and NFPA 13R life-safety diagrams until the fire strategy selects one. In particular, the Section 1020.5 **15 m** R-2 dead-end allowance is NFPA 13 only.
4. Calculate occupant load by actual room function, then test in sequence: room/space exit-access doors, story exits, remoteness, capacity, loss of one exit, travel/common path, accessible egress, discharge and public-way continuity.
5. Record all fire-strategy and authority decisions in the project Golden Thread; this matrix is not evidence of SCD NOC or stamped compliance.

Appendix A. Complete Chapter 10 normative numeric inventory

A.1 Scope and use control

This appendix reproduces every approved normative numeric inventory record exactly once as a structured design-audit row. Record IDs are stable and sequential in approved inventory order. Appended-table records are explicitly labelled in the Section / table column.

Commentary-only numeric examples were deliberately excluded from the normative matrix and are not for design use.

A **Verify source** row is a design hold point. Where its extracted values are empty, the appendix states **No value adopted — OCR/source verification required** and retains the raw ambiguity in the mandatory requirement and notes without inference.

A.2 Coverage summary

- **Total approved records:** 645
- **Verified:** 557
- **Verify source:** 88
- **Numeric records in Sections 1001 and 1002:** 0 (no appendix record rows)

Counts by top-level section (approved report)

Top-level section	Records
1001	0
1002	0
1003	15
1004	47
1005	11
1006	49
1007	7
1008	12
1009	15
1010	116
1011	55
1012	17
1013	10
1014	18
1015	24
1016	5
1017	16
1018	7
1019	1
1020	21
1021	3
1022	1
1023	14
1024	6
1025	20
1026	8
1027	10
1028	7
1029	5
1030	109
1031	16

Appended-table coverage (approved report)

Appended table	Records	Verify source records
Table 1004.5	38	6
Table 1006.2.1	14	14
Table 1006.3.3	3	0
Table 1006.3.4(1)	1	1

Appended table	Records	Verify source records
Table 1006.3.4(2)	8	8
Table 1010.3.1(1)	5	0
Table 1010.3.1(2)	12	12
Table 1017.2	11	11
Table 1020.2 — corridor rating	7	7
Table 1020.2 — minimum width	7	7
Table 1030.6.2	5	0
Table 1030.13.2.1	8	8

A.3 Unresolved-source register

The following list is exhaustive for the 88 **Verify source** records. Counts are record counts, not distinct numeric values.

Affected table / clause	Verify source records	Inventory source page(s)	Control note
Table 1004.5	6	1177	Flattened table; unresolved rows have empty values.
Section 1005.3.2	1	1010–1011	Exception 1 is severely repeated/corrupted; no reduced factor inferred.
Table 1006.2.1	14	1178	Flattened table; recoverable row cells were cleaned, but superscript footnote attachments require verification.
Section 1006.2.2.2	1	1015–1016	Page-split continuation retained; published-source verification required.
Table 1006.3.4(1)	1	1179	Flattened single-exit table row requires published-source verification.
Table 1006.3.4(2)	8	1179	Flattened single-exit table rows require published-source verification.
Section 1008.2.2	1	1025	Mandatory OCR begins with a grammatical fragment; scope cannot be silently reconstructed.
Section 1009.2.1	1	1030	Duplicated wording in Exception 2; retained as Verify source.
Unnumbered — commentary indicates 1010.1.7	3	1049	Mandatory door-arrangement text and values are clear, but the supplied source omits the section number.
Table 1010.3.1(2)	12	1180	Concatenated diameter/speed cells require published-source verification.
Section 1011.2	1	1073–1074	Exception 3 crosses pages; joined text requires published-source verification.
Table 1017.2	11	1180	Damaged header, substituted footnote marks and duplicate I-1 row; raw OCR retained.
Table 1020.2 — corridor rating	7	1181	Duplicate OCR table number; Group R 0.5/1 rating remains unresolved and unselected.
Table 1020.2 — minimum width	7	1181	Duplicate OCR table number; row and footnote attachment require verification.
Section 1025.2.6.1	1	1139–1140	Inventory flags OCR/source ambiguity; verify the published clause.
Section 1025.4	1	1140	Mandatory OCR contains corrupted luminance units “micil-candelas”/“mili-candelas”; raw text and values are retained without silent correction.
Section 1027.6	1	1145–1146	Exception item 8 crosses pages; joined text requires published-source verification.
Table 1030.13.2.1	8	1182	Concatenated row cells; seat counts retained pending verification.
Section 1030.17.3	1	1170	Inventory flags OCR/source ambiguity; verify the published clause.
Section 1030.17.4	2	1171	Inventory flags OCR/source ambiguity; verify the published clause.

A.4 Complete normative numeric record matrix

A.4.1003 — Section 1003 (15 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0001	Section 1003.2	Ceiling height	The means of egress shall have a ceiling height of not less than 2300 mm above the finished floor.	Sl: 2300 mm	min	Per Section 1003.2 (Ceiling height).	Exceptions: 1. Sloped ceilings in accordance with Section 1208.2. 2. Ceilings of dwelling units and sleeping units within residential occupancies in accordance with Section 1208.2. 3. Allowable projections in accordance with Section 1003.3. 4. Stair headroom in accordance with Section 1011.3. 5. Door height in accordance with Section 1010.1.1. 6. Ramp headroom in accordance with Section 1012.5.2. 7. The clear height of floor levels in vehicular and pedestrian traffic areas of public and private parking garages in accordance with Section 406.2.2. 8. Areas above and below mezzanine floors in accordance with Section 505.2.	DIRECT	1000	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0002	Section 1003.3.1	Door closer and stop headroom	Door closers and stops shall not reduce headroom to less than 2000 mm.	Sl: 2000 mm	min	Exception to Section 1003.3.1 for door closers and stops.	None stated in inventory	DIRECT	1000	Verified
CH10-0003	Section 1003.3.1	Headroom	Protruding objects are permitted to extend below the minimum ceiling height required by Section 1003.2 where a minimum headroom of 2000 mm is provided over any circulation paths, including walks, corridors, aisles and passageways.	Sl: 2000 mm	min	All means-of-egress circulation paths.	Door closers and stops shall not reduce headroom to less than 2000 mm.	DIRECT	1000	Verified
CH10-0004	Section 1003.3.1	Low-headroom barrier leading edge	The leading edge of such a barrier shall be located 700 mm maximum above the finished floor.	Sl: 700 mm	max	Barrier required by Section 1003.3.1 at low-headroom circulation paths.	None stated in inventory	DIRECT	1000	Verified
CH10-0005	Section 1003.3.1	Low-headroom barrier trigger	A barrier shall be provided where the vertical clearance above a circulation path is less than 2000 mm high above the finished floor.	Sl: 2000 mm	trigger	Circulation paths with vertical clearance below 2000 mm.	None stated in inventory	DIRECT	1000	Verified
CH10-0006	Section 1003.3.1	Reduced ceiling area	Not more than 50 percent of the ceiling area of a means of egress shall be reduced in height by protruding objects.	Sl: 50 percent	max	Means-of-egress ceilings affected by protruding objects.	None stated in inventory	DIRECT	1000	Verified
CH10-0007	Section 1003.3.2	Post-mounted objects	A free-standing object mounted on a post or pylon shall not overhang that post or pylon more than 100 mm where the lowest point of the leading edge is more than 700 mm and less than 2000 mm above the finished floor.	Sl: 100 mm; 700 mm; 2000 mm	mixed	Per Section 1003.3.2 (Post-mounted objects).	Exception: These requirements shall not apply to sloping portions of handrails between the top and bottom riser of stairs and above the ramp run.	DIRECT	1001	Verified
CH10-0008	Section 1003.3.2	Post-mounted objects	Where a sign or other obstruction is mounted between posts or pylons and the clear distance between the posts or pylons is greater than 300 mm, the lowest edge of such sign or obstruction shall be 700 mm maximum or 2000 mm minimum above the finished floor or ground.	Sl: 300 mm; 700 mm; 2000 mm	mixed	Per Section 1003.3.2 (Post-mounted objects).	Exception: These requirements shall not apply to sloping portions of handrails between the top and bottom riser of stairs and above the ramp run.	DIRECT	1001	Verified
CH10-0009	Section 1003.3.3	Horizontal projections	Exception: Handrails are permitted to protrude 115 mm from the wall or guard.	Sl: 115 mm	trigger	Per Section 1003.3.3 (Horizontal projections).	Exception: Handrails are permitted to protrude 115 mm from the wall or guard.	CONDITIONAL	1001	Verified
CH10-0010	Section 1003.3.3	Horizontal projections	Objects with leading edges more than 700 mm and not more than 2000 mm above the finished floor shall not project horizontally more than 100 mm into the circulation path.	Sl: 700 mm; 2000 mm; 100 mm	mixed	Per Section 1003.3.3 (Horizontal projections).	Exception: Handrails are permitted to protrude 115 mm from the wall or guard.	DIRECT	1001	Verified
CH10-0011	Section 1003.5	Elevation change	Exception item 2. A stair with a single riser or with two risers and a tread is permitted at locations not required to be accessible by Chapter 11 where the risers and treads comply with Section 1011.5, the minimum depth of the tread is 325 mm and not less than one handrail complying with Section 1014 is provided within 750 mm of the centerline of the normal path of egress travel on the stair.	Sl: single riser; two risers; 325 mm; 750 mm	min	Per Section 1003.5 (Elevation change).	Exceptions: 1. Steps at exterior doors complying with Section 1010.1.4. 2. A stair with a single riser or with two risers and a tread is permitted at locations not required to be accessible by Chapter 11 where the risers and treads comply with Section 1011.5, the minimum depth of the tread is 325 mm and not less than one handrail complying with Section 1014 is provided within 750 mm of the centerline of the normal path of egress travel on the stair. 3. A step is permitted in aisles serving seating that has a difference in elevation less than 300 mm at locations not required to be accessible by Chapter 11, provided that the risers and treads comply with Section 1030.14 and the aisle is provided with a handrail complying with Section 1030.16. Throughout a story in a Group I-2 occupancy, any change in elevation in portions of the means of egress that serve non-ambulatory persons shall be by means of a ramp or sloped walkway.	CONDITIONAL	1002	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0012	Section 1003.5	Elevation change	Exception item 3. A step is permitted in aisles serving seating that has a difference in elevation less than 300 mm at locations not required to be accessible by Chapter 11, provided that the risers and treads comply with Section 1030.14 and the aisle is provided with a handrail complying with Section 1030.16. Throughout a story in a Group I-2 occupancy, any change in elevation in portions of the means of egress that serve non-ambulatory persons shall be by means of a ramp or sloped walkway.	Sl: 300 mm	trigger	Per Section 1003.5 (Elevation change).	Exceptions: 1. Steps at exterior doors complying with Section 1010.1.4. 2. A stair with a single riser or with two risers and a tread is permitted at locations not required to be accessible by Chapter 11 where the risers and treads comply with Section 1011.5, the minimum depth of the tread is 325 mm and not less than one handrail complying with Section 1014 is provided within 750 mm of the centerline of the normal path of egress travel on the stair. 3. A step is permitted in aisles serving seating that has a difference in elevation less than 300 mm at locations not required to be accessible by Chapter 11, provided that the risers and treads comply with Section 1030.14 and the aisle is provided with a handrail complying with Section 1030.16. Throughout a story in a Group I-2 occupancy, any change in elevation in portions of the means of egress that serve non-ambulatory persons shall be by means of a ramp or sloped walkway.	NOT_TYPICAL	1002	Verified
CH10-0013	Section 1003.5	Elevation change	Where changes in elevation of less than 300 mm exist in the means of egress, sloped surfaces shall be used.	Sl: 300 mm	trigger	Per Section 1003.5 (Elevation change).	Exceptions: 1. Steps at exterior doors complying with Section 1010.1.4. 2. A stair with a single riser or with two risers and a tread is permitted at locations not required to be accessible by Chapter 11 where the risers and treads comply with Section 1011.5, the minimum depth of the tread is 325 mm and not less than one handrail complying with Section 1014 is provided within 750 mm of the centerline of the normal path of egress travel on the stair. 3. A step is permitted in aisles serving seating that has a difference in elevation less than 300 mm at locations not required to be accessible by Chapter 11, provided that the risers and treads comply with Section 1030.14 and the aisle is provided with a handrail complying with Section 1030.16. Throughout a story in a Group I-2 occupancy, any change in elevation in portions of the means of egress that serve non-ambulatory persons shall be by means of a ramp or sloped walkway.	DIRECT	1002	Verified
CH10-0014	Section 1003.5	Elevation change	Where the difference in elevation is 150 mm or less, the ramp shall be equipped with either handrails or floor finish materials that contrast with adjacent floor finish materials.	Sl: 150 mm	trigger	Per Section 1003.5 (Elevation change).	Exceptions: 1. Steps at exterior doors complying with Section 1010.1.4. 2. A stair with a single riser or with two risers and a tread is permitted at locations not required to be accessible by Chapter 11 where the risers and treads comply with Section 1011.5, the minimum depth of the tread is 325 mm and not less than one handrail complying with Section 1014 is provided within 750 mm of the centerline of the normal path of egress travel on the stair. 3. A step is permitted in aisles serving seating that has a difference in elevation less than 300 mm at locations not required to be accessible by Chapter 11, provided that the risers and treads comply with Section 1030.14 and the aisle is provided with a handrail complying with Section 1030.16. Throughout a story in a Group I-2 occupancy, any change in elevation in portions of the means of egress that serve non-ambulatory persons shall be by means of a ramp or sloped walkway.	DIRECT	1002	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0015	Section 1003.5	Elevation change	Where the slope is greater than one unit vertical in 20 units horizontal (5-percent slope), ramps complying with Section 1012 shall be used.	Sl: one unit vertical in 20 units horizontal; 5-percent	trigger	Per Section 1003.5 (Elevation change).	Exceptions: 1. Steps at exterior doors complying with Section 1010.1.4. 2. A stair with a single riser or with two risers and a tread is permitted at locations not required to be accessible by Chapter 11 where the risers and treads comply with Section 1011.5, the minimum depth of the tread is 325 mm and not less than one handrail complying with Section 1014 is provided within 750 mm of the centerline of the normal path of egress travel on the stair. 3. A step is permitted in aisles serving seating that has a difference in elevation less than 300 mm at locations not required to be accessible by Chapter 11, provided that the risers and treads comply with Section 1030.14 and the aisle is provided with a handrail complying with Section 1030.16. Throughout a story in a Group I-2 occupancy, any change in elevation in portions of the means of egress that serve non-ambulatory persons shall be by means of a ramp or sloped walkway.	DIRECT	1002	Verified

A.4.1004 — Section 1004 (47 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0016	Section 1004.2.1	Intervening spaces or accessory areas	Where occupants egress from one or more rooms, areas or spaces through others, the design occupant load shall be the combined occupant load of interconnected accessory or intervening spaces. Design of egress path capacity shall be based on the cumulative portion of occupant loads of all rooms, areas or spaces to that point along the path of egress travel.	Sl: one or more rooms, areas or spaces	formula	Occupants egressing through interconnected accessory or intervening spaces.	None stated in inventory	DIRECT	1004	Verified
CH10-0017	Section 1004.4	Multiple occupancies	Where a building contains two or more occupancies, the means of egress requirements shall apply to each portion of the building based on the occupancy of that space. Where two or more occupancies utilize portions of the same means of egress system, those egress components shall meet the more stringent requirements of all occupancies that are served.	Sl: two or more occupancies	trigger	Mixed occupancies and shared means-of-egress components.	None stated in inventory	CONDITIONAL	1004	Verified
CH10-0018	Section 1004.5	Areas without fixed seating	The number of occupants shall be computed at the rate of one occupant per unit of area as prescribed in Table 1004.5.	Sl: one occupant	trigger	Per Section 1004.5 (Areas without fixed seating).	None stated in inventory	DIRECT	1005	Verified
CH10-0019	Table 1004.5 (appended-table row); Section 1004.5	Bowling-center occupant load	For bowling centers, allow 5 persons for each lane including 4.6 m of runway, and use 0.65 m² net per occupant for additional areas.	Sl: 5 persons; 4.6 m; 0.65 m²	formula	Bowling centers	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0020	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Accessory storage areas and mechanical equipment rooms, use a maximum floor area allowance of 28 m² gross per occupant.	Sl: 28 m²	formula	Accessory storage areas and mechanical equipment rooms	None stated in inventory	CONDITIONAL	1177	Verified
CH10-0021	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Agricultural buildings, use a maximum floor area allowance of 28 m² gross per occupant.	Sl: 28 m²	formula	Agricultural buildings	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0022	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Aircraft hangars, use a maximum floor area allowance of 46 m² gross per occupant.	Sl: 46 m²	formula	Aircraft hangars	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0023	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Airport terminal baggage claim, use a maximum floor area allowance of 1.9 m² gross per occupant.	Sl: 1.9 m²	formula	Airport terminal baggage claim	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0024	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Airport terminal baggage handling, use a maximum floor area allowance of 28 m² gross per occupant.	Sl: 28 m²	formula	Airport terminal baggage handling	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0025	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Airport terminal concourse, use a maximum floor area allowance of 9 m² gross per occupant.	Sl: 9 m²	formula	Airport terminal concourse	None stated in inventory	NOT_TYPICAL	1177	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0026	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Airport terminal waiting areas, use a maximum floor area allowance of 1.4 m² gross per occupant.	Sl: 1.4 m²	formula	Airport terminal waiting areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0027	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Assembly exhibit galleries and museums, use a maximum floor area allowance of 2.8 m² net per occupant.	Sl: 2.8 m²	formula	Assembly exhibit galleries and museums	None stated in inventory	CONDITIONAL	1177	Verified
CH10-0028	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Assembly gaming floors, use a maximum floor area allowance of 1 m² gross per occupant.	Sl: 1 m²	formula	Assembly gaming floors	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0029	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Assembly standing space, use a maximum floor area allowance of 0.46 m² net per occupant.	Sl: 0.46 m²	formula	Assembly standing space	None stated in inventory	CONDITIONAL	1177	Verified
CH10-0030	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Assembly without fixed seats, concentrated chairs only, use a maximum floor area allowance of 0.65 m² net per occupant.	Sl: 0.65 m²	formula	Assembly without fixed seats, concentrated chairs only	None stated in inventory	CONDITIONAL	1177	Verified
CH10-0031	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Assembly without fixed seats, unconcentrated tables and chairs, use a maximum floor area allowance of 1.4 m² net per occupant.	Sl: 1.4 m²	formula	Assembly without fixed seats, unconcentrated tables and chairs	None stated in inventory	CONDITIONAL	1177	Verified
CH10-0032	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Business areas, use a maximum floor area allowance of 14 m² gross per occupant.	Sl: 14 m²	formula	Business areas	None stated in inventory	CONDITIONAL	1177	Verified
CH10-0033	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Commercial kitchens, use a maximum floor area allowance of 19 m² gross per occupant.	Sl: 19 m²	formula	Commercial kitchens	None stated in inventory	CONDITIONAL	1177	Verified
CH10-0034	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Courtrooms other than fixed seating areas, use a maximum floor area allowance of 3.7 m² net per occupant.	Sl: 3.7 m²	formula	Courtrooms other than fixed seating areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0035	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Day care, use a maximum floor area allowance of 3.3 m² net per occupant.	Sl: 3.3 m²	formula	Day care	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0036	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Dormitories, use a maximum floor area allowance of 4.6 m² gross per occupant.	Sl: 4.6 m²	formula	Dormitories	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0037	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Educational classroom areas, use a maximum floor area allowance of 1.9 m² net per occupant.	Sl: 1.9 m²	formula	Educational classroom areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0038	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Educational shops and other vocational room areas, use a maximum floor area allowance of 4.6 m² net per occupant.	Sl: 4.6 m²	formula	Educational shops and other vocational room areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0039	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Exercise rooms, use a maximum floor area allowance of 4.6 m² gross per occupant.	Sl: 4.6 m²	formula	Exercise rooms	None stated in inventory	CONDITIONAL	1177	Verified
CH10-0040	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For H-5 fabrication and manufacturing areas, use a maximum floor area allowance of 19 m² gross per occupant.	Sl: 19 m²	formula	H-5 fabrication and manufacturing areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0041	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Industrial areas, use a maximum floor area allowance of 9 m² gross per occupant.	Sl: 9 m²	formula	Industrial areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0042	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Institutional inpatient treatment areas, use a maximum floor area allowance of 22 m² gross per occupant.	Sl: 22 m²	formula	Institutional inpatient treatment areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0043	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Institutional outpatient areas, use a maximum floor area allowance of 9 m² gross per occupant.	Sl: 9 m²	formula	Institutional outpatient areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0044	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Institutional sleeping areas, use a maximum floor area allowance of 11 m² gross per occupant.	Sl: 11 m²	formula	Institutional sleeping areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0045	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Library reading rooms, use a maximum floor area allowance of 4.6 m² net per occupant.	Sl: 4.6 m²	formula	Library reading rooms	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0046	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Library stack areas, use a maximum floor area allowance of 9 m² gross per occupant.	Sl: 9 m²	formula	Library stack areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0047	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Mercantile areas on other floors, use a maximum floor area allowance of 5.6 m² gross per occupant.	Sl: 5.6 m²	formula	Mercantile areas on other floors	None stated in inventory	NOT_TYPICAL	1177	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0048	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Mercantile basement and grade floor areas, use a maximum floor area allowance of 2.8 m² gross per occupant.	Sl: 2.8 m²	formula	Mercantile basement and grade floor areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0049	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Mercantile storage, stock and shipping areas, use a maximum floor area allowance of 28 m² gross per occupant.	Sl: 28 m²	formula	Mercantile storage, stock and shipping areas	None stated in inventory	NOT_TYPICAL	1177	Verified
CH10-0050	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	For Parking garages, use a maximum floor area allowance of 19 m² gross per occupant.	Sl: 19 m²	formula	Parking garages	None stated in inventory	CONDITIONAL	1177	Verified
CH10-0051	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	The source contains the Decks row, but its numeric factor and gross/net basis cannot be unambiguously segmented from the concatenated OCR table.	No value adopted — OCR/source verification required	trigger	Decks	None stated in inventory	EXTERNAL_VERIFY	1177	Verify source
CH10-0052	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	The source contains the Residential row, but its numeric factor and gross/net basis cannot be unambiguously segmented from the concatenated OCR table.	No value adopted — OCR/source verification required	trigger	Residential	None stated in inventory	EXTERNAL_VERIFY	1177	Verify source
CH10-0053	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	The source contains the Rink and pool areas row, but its numeric factor and gross/net basis cannot be unambiguously segmented from the concatenated OCR table.	No value adopted — OCR/source verification required	trigger	Rink and pool areas	None stated in inventory	EXTERNAL_VERIFY	1177	Verify source
CH10-0054	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	The source contains the Skating rinks and swimming pools row, but its numeric factor and gross/net basis cannot be unambiguously segmented from the concatenated OCR table.	No value adopted — OCR/source verification required	trigger	Skating rinks and swimming pools	None stated in inventory	EXTERNAL_VERIFY	1177	Verify source
CH10-0055	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	The source contains the Stages and platforms row, but its numeric factor and gross/net basis cannot be unambiguously segmented from the concatenated OCR table.	No value adopted — OCR/source verification required	trigger	Stages and platforms	None stated in inventory	EXTERNAL_VERIFY	1177	Verify source
CH10-0056	Table 1004.5 (appended-table row); Section 1004.5	Occupant load factor	The source contains the Warehouses row, but its numeric factor and gross/net basis cannot be unambiguously segmented from the concatenated OCR table.	No value adopted — OCR/source verification required	trigger	Warehouses	None stated in inventory	NOT_TYPICAL	1177	Verify source
CH10-0057	Section 1004.5.1	Increased occupant load	The occupant load permitted in any building, or portion thereof, is permitted to be increased from that number established for the occupancies in Table 1004.5, provided that all other requirements of the code are met based on such modified number and the occupant load does not exceed one occupant per 0.65 m² of occupiable floor space.	Sl: one occupant; 0.65 m²	max	Per Section 1004.5.1 (Increased occupant load).	None stated in inventory	DIRECT	1007	Verified
CH10-0058	Section 1004.6	Fixed seating	For areas having fixed seating without dividing arms, the occupant load shall be not less than the number of seats based on one person for each 450 mm of seating length.	Sl: one person; 450 mm	formula	Per Section 1004.6 (Fixed seating).	None stated in inventory	CONDITIONAL	1007	Verified
CH10-0059	Section 1004.6	Fixed seating	The occupant load of seating booths shall be based on one person for each 600 mm of booth seat length measured at the backrest of the seating booth.	Sl: one person; 600 mm	trigger	Per Section 1004.6 (Fixed seating).	None stated in inventory	CONDITIONAL	1007	Verified
CH10-0060	Section 1004.6	Fixed seating	The occupant load of wheelchair spaces and the associated companion seat shall be based on one occupant for each wheelchair space and one occupant for the associated companion seat provided in accordance with Section 1109.2.3.	Sl: one occupant	trigger	Per Section 1004.6 (Fixed seating).	None stated in inventory	CONDITIONAL	1007	Verified
CH10-0061	Section 1004.7	Outdoor areas	Exception item 1. Outdoor areas used exclusively for service of the building need only have one means of egress.	Sl: one means of egress	trigger	Per Section 1004.7 (Outdoor areas).	Exceptions: 1. Outdoor areas used exclusively for service of the building need only have one means of egress. 2. Both outdoor areas associated with Group R-3 and individual dwelling units of Group R-2.	CONDITIONAL	1007	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0062	Section 1004.8	Concentrated business use areas The occupant load factor for concentrated business use shall be applied to telephone call centers, trading floors, electronic data processing centers and similar business use areas with a higher density of occupants than would normally be expected in a typical business occupancy environment	Where approved by the building official, the occupant load for concentrated business use areas shall be the actual occupant load, but not less than one occupant per 4.65 square meter gross of occupiable floor space.	Sl: one occupant; 4.65 m²	min	Per Section 1004.8 (Concentrated business use areas The occupant load factor for concentrated business use shall be applied to telephone call centers, trading floors, electronic data processing centers and similar business use areas with a higher density of occupants than would normally be expected in a typical business occupancy environment).	None stated in inventory	CONDITIONAL	1008	Verified

A.4.1005 — Section 1005 (11 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0063	Section 1005.3.1	Stairways	Exception item 1. For other than Group H and I-2 occupancies, the capacity, in millimeters, of means of egress stairways shall be calculated by multiplying the occupant load served by such stairways by a means of egress capacity factor of 5.08 mm per occupant in buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2 and an emergency voice/ alarm communication system in accordance with Section 907.5.2.2.	Sl: 5.08 mm per occupant	formula	Per Section 1005.3.1 (Stairways).	Exceptions: 1. For other than Group H and I-2 occupancies, the capacity, in millimeters, of means of egress stairways shall be calculated by multiplying the occupant load served by such stairways by a means of egress capacity factor of 5.08 mm per occupant in buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2 and an emergency voice/ alarm communication system in accordance with Section 907.5.2.2. 2. Facilities with smoke-protected assembly seating shall be permitted to use the capacity factors in Table 1030.6.2 indicated for stepped aisles for exit access or exit stairways where the entire path for means of egress from the seating to the exit discharge is open to the outdoors. 3. Facilities with open-air assembly seating shall be permitted to the capacity factors in Section 1030.6.3 indicated for stepped aisles for exit access or exit stairways where the entire path for means of egress from the seating to the exit discharge is open to the outdoors.	CONDITIONAL	1009	Verified
CH10-0064	Section 1005.3.1	Stairways	The capacity, in millimeters, of means of egress stairways shall be calculated by multiplying the occupant load served by such stairways by a means of egress capacity factor of 7.6 mm per occupant.	Sl: 7.6 mm per occupant	formula	Per Section 1005.3.1 (Stairways).	Exceptions: 1. For other than Group H and I-2 occupancies, the capacity, in millimeters, of means of egress stairways shall be calculated by multiplying the occupant load served by such stairways by a means of egress capacity factor of 5.08 mm per occupant in buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2 and an emergency voice/ alarm communication system in accordance with Section 907.5.2.2. 2. Facilities with smoke-protected assembly seating shall be permitted to use the capacity factors in Table 1030.6.2 indicated for stepped aisles for exit access or exit stairways where the entire path for means of egress from the seating to the exit discharge is open to the outdoors. 3. Facilities with open-air assembly seating shall be permitted to the capacity factors in Section 1030.6.3 indicated for stepped aisles for exit access or exit stairways where the entire path for means of egress from the seating to the exit discharge is open to the outdoors.	DIRECT	1009	Verified
CH10-0065	Section 1005.3.2	Other egress component capacity — corrupted Exception 1	Exception 1 begins with a reduced-capacity calculation for occupancies other than Groups H and I-2, but the mandatory OCR text is corrupted by repeated phrases and the numeric capacity factor is not recoverable from this source.	No value adopted — OCR/source verification required	formula	Other-than-Group-H and I-2 occupancies; exact exception conditions and factor require the published source.	Exception 1 is represented by a separate VERIFY_SOURCE record because its OCR text is corrupted.	CONDITIONAL	1010–1011	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0066	Section 1005.3.2	Other egress components	The capacity, in millimeters, of means of egress components other than stairways shall be calculated by multiplying the occupant load served by such component by a means of egress capacity factor of 5.08 mm per occupant.	Sl: 5.08 mm per occupant	formula	Per Section 1005.3.2 (Other egress components).	Exception 1 is represented by a separate VERIFY_SOURCE record because its OCR text is corrupted.	DIRECT	1010	Verified
CH10-0067	Section 1005.5	Distribution of minimum width and required capacity	Where more than one exit, or access to more than one exit, is required, the means of egress shall be configured such that the loss of any one exit, or access to one exit, shall not reduce the available capacity or width to less than 50 percent of the required capacity or width.	Sl: one exit; 50 percent	min	Per Section 1005.5 (Distribution of minimum width and required capacity).	None stated in inventory	DIRECT	1012	Verified
CH10-0068	Section 1005.6	Egress convergence	Where the means of egress from stories above and below converge at an intermediate level, the capacity of the means of egress from the point of convergence shall be not less than the largest minimum width or the sum of the required capacities for the stairways or ramps serving the two adjacent stories, whichever is larger.	Sl: two adjacent stories	formula	Per Section 1005.6 (Egress convergence).	None stated in inventory	DIRECT	1012	Verified
CH10-0069	Section 1005.7.1	Doors	Doors in any position shall not reduce the required width by more than one-half.	Sl: one-half	formula	Per Section 1005.7.1 (Doors).	Exceptions: 1. Surface-mounted latch release hardware shall be exempt from inclusion in the 175 mm encroachment where both of the following conditions exist: 1.1. The hardware is mounted to the side of the door facing away from the adjacent wall where the door is in the open position. 1.2. The hardware is mounted not less than 850 mm nor more than 1200 mm above the finished floor. 2. The restrictions on door swing shall not apply to doors within individual dwelling units and sleeping units of Group R-2 occupancies and dwelling units of Group R-3 occupancies.	DIRECT	1012	Verified
CH10-0070	Section 1005.7.1	Doors	Doors, when fully opened, shall not reduce the required width by more than 175 mm.	Sl: 175 mm	min	Per Section 1005.7.1 (Doors).	Exceptions: 1. Surface-mounted latch release hardware shall be exempt from inclusion in the 175 mm encroachment where both of the following conditions exist: 1.1. The hardware is mounted to the side of the door facing away from the adjacent wall where the door is in the open position. 1.2. The hardware is mounted not less than 850 mm nor more than 1200 mm above the finished floor. 2. The restrictions on door swing shall not apply to doors within individual dwelling units and sleeping units of Group R-2 occupancies and dwelling units of Group R-3 occupancies.	DIRECT	1012	Verified
CH10-0071	Section 1005.7.1	Doors	Exception item 1. Surface-mounted latch release hardware shall be exempt from inclusion in the 175 mm encroachment where both of the following conditions exist:	Sl: 175 mm	trigger	Per Section 1005.7.1 (Doors).	Exceptions: 1. Surface-mounted latch release hardware shall be exempt from inclusion in the 175 mm encroachment where both of the following conditions exist: 1.1. The hardware is mounted to the side of the door facing away from the adjacent wall where the door is in the open position. 1.2. The hardware is mounted not less than 850 mm nor more than 1200 mm above the finished floor. 2. The restrictions on door swing shall not apply to doors within individual dwelling units and sleeping units of Group R-2 occupancies and dwelling units of Group R-3 occupancies.	CONDITIONAL	1012	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0072	Section 1005.7.1	Doors	Exception item 1.2. The hardware is mounted not less than 850 mm nor more than 1200 mm above the finished floor.	Sl: 850 mm; 1200 mm	range	Per Section 1005.7.1 (Doors).	Exceptions: 1. Surface-mounted latch release hardware shall be exempt from inclusion in the 175 mm encroachment where both of the following conditions exist: 1.1. The hardware is mounted to the side of the door facing away from the adjacent wall where the door is in the open position. 1.2. The hardware is mounted not less than 850 mm nor more than 1200 mm above the finished floor. 2. The restrictions on door swing shall not apply to doors within individual dwelling units and sleeping units of Group R-2 occupancies and dwelling units of Group R-3 occupancies.	CONDITIONAL	1012	Verified
CH10-0073	Section 1005.7.2	Other projections	Other nonstructural projections such as trim and similar decorative features shall be permitted to project into the required width not more than 40 mm on each side.	Sl: 40 mm	max	Per Section 1005.7.2 (Other projections).	Exception: Projections are permitted in corridors within Group I-2 Condition 1 in accordance with Section 407.4.3.	DIRECT	1013	Verified

A.4.1006 — Section 1006 (49 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0074	Section 1006.2.1	Egress based on occupant load and common path of egress travel distance	Two exits or exit access doorways from any space shall be provided where the design occupant load or the common path of egress travel distance exceeds the values listed in Table 1006.2.1.	Sl: Two exits	trigger	Per Section 1006.2.1 (Egress based on occupant load and common path of egress travel distance).	## Exceptions: 1. The number of exits from foyers, lobbies, vestibules or similar spaces need not be based on cumulative occupant loads for areas discharging through such spaces, but the capacity of the exits from such spaces shall be based on applicable cumulative occupant loads. 2. Care suites in Group I-2 occupancies complying with Section 407.4. 3. Unoccupied mechanical rooms and penthouses are not required to comply with the common path of egress travel distance measurement.	DIRECT	1014	Verified
CH10-0075	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row A, C, M and U, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 49 occupants; maximum common path of egress travel is 23 m without sprinklers where OL ≤ 30, 23 m without sprinklers where OL > 30, and 23 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 49 occupants; without sprinkler, OL ≤ 30: 23 m; without sprinkler, OL > 30: 23 m; with sprinkler: 23 m	max	Occupancy A, C, M and U	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. For a room or space used for assembly purposes having fixed seating, see Section 1030.8.	CONDITIONAL	1178	Verify source
CH10-0076	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row B, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 49 occupants; maximum common path of egress travel is 30 m without sprinklers where OL ≤ 30, 23 m without sprinklers where OL > 30, and 30 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 49 occupants; without sprinkler, OL ≤ 30: 30 m; without sprinkler, OL > 30: 23 m; with sprinkler: 30 m	max	Occupancy B	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2.	NOT_TYPICAL	1178	Verify source
CH10-0077	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row F, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 49 occupants; maximum common path of egress travel is 23 m without sprinklers where OL ≤ 30, 23 m without sprinklers where OL > 30, and 30 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 49 occupants; without sprinkler, OL ≤ 30: 23 m; without sprinkler, OL > 30: 23 m; with sprinkler: 30 m	max	Occupancy F	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2.	NOT_TYPICAL	1178	Verify source
CH10-0078	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row H-1, H-2 and H-3, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 3 occupants; maximum common path of egress travel is NP without sprinklers where OL ≤ 30, NP without sprinklers where OL > 30, and 7.5 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 3 occupants; without sprinkler, OL ≤ 30: NP; without sprinkler, OL > 30: NP; with sprinkler: 7.5 m	max	Occupancy H-1, H-2 and H-3	NP = Not Permitted. b. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.2.	NOT_TYPICAL	1178	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0079	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row H-4 and H-5, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 10 occupants; maximum common path of egress travel is NP without sprinklers where OL ≤ 30, NP without sprinklers where OL > 30, and 23 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 10 occupants; without sprinkler, OL ≤ 30: NP; without sprinkler, OL > 30: NP; with sprinkler: 23 m	max	Occupancy H-4 and H-5	NP = Not Permitted. b. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.2.	NOT_TYPICAL	1178	Verify source
CH10-0080	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row I-1, I-2 and I-4, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 10 occupants; maximum common path of egress travel is NP without sprinklers where OL ≤ 30, NP without sprinklers where OL > 30, and 23 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 10 occupants; without sprinkler, OL ≤ 30: NP; without sprinkler, OL > 30: NP; with sprinkler: 23 m	max	Occupancy I-1, I-2 and I-4	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. d. For the travel distance limitations in Group I-2, see Section 407.4.	NOT_TYPICAL	1178	Verify source
CH10-0081	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row I-3, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 10 occupants; maximum common path of egress travel is NP without sprinklers where OL ≤ 30, NP without sprinklers where OL > 30, and 30 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 10 occupants; without sprinkler, OL ≤ 30: NP; without sprinkler, OL > 30: NP; with sprinkler: 30 m	max	Occupancy I-3	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2.	NOT_TYPICAL	1178	Verify source
CH10-0082	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row R-1, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 10 occupants; maximum common path of egress travel is NP without sprinklers where OL ≤ 30, NP without sprinklers where OL > 30, and 23 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 10 occupants; without sprinkler, OL ≤ 30: NP; without sprinkler, OL > 30: NP; with sprinkler: 23 m	max	Occupancy R-1	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2.	NOT_TYPICAL	1178	Verify source
CH10-0083	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row R-2, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 20 occupants; maximum common path of egress travel is NP without sprinklers where OL ≤ 30, NP without sprinklers where OL > 30, and 38 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 20 occupants; without sprinkler, OL ≤ 30: NP; without sprinkler, OL > 30: NP; with sprinkler: 38 m	max	Occupancy R-2	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2.	EXTERNAL_VERIFY	1178	Verify source
CH10-0084	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row R-3, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 20 occupants; maximum common path of egress travel is NP without sprinklers where OL ≤ 30, NP without sprinklers where OL > 30, and 38 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 20 occupants; without sprinkler, OL ≤ 30: NP; without sprinkler, OL > 30: NP; with sprinkler: 38 m	max	Occupancy R-3	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. e. The common path of egress travel distance shall only apply in a Group R-3 occupancy located in a mixed occupancy building or within a Group R-3 or R-4 congregate living facility. g. For the travel distance limitations in Group R-3 and R-4 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3, see Section 1006.2.2.6.	NOT_TYPICAL	1178	Verify source
CH10-0085	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row R-4, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 20 occupants; maximum common path of egress travel is NP without sprinklers where OL ≤ 30, NP without sprinklers where OL > 30, and 38 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 20 occupants; without sprinkler, OL ≤ 30: NP; without sprinkler, OL > 30: NP; with sprinkler: 38 m	max	Occupancy R-4	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. e. The common path of egress travel distance shall only apply in a Group R-3 occupancy located in a mixed occupancy building or within a Group R-3 or R-4 congregate living facility. g. For the travel distance limitations in Group R-3 and R-4 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3, see Section 1006.2.2.6.	NOT_TYPICAL	1178	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0086	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row S, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 29 occupants; maximum common path of egress travel is 30 m without sprinklers where OL ≤ 30, 23 m without sprinklers where OL > 30, and 30 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 29 occupants; without sprinkler, OL ≤ 30: 30 m; without sprinkler, OL > 30: 23 m; with sprinkler: 30 m	max	Occupancy S	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. f. The length of common path of egress travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	CONDITIONAL	1178	Verify source
CH10-0087	Table 1006.2.1 (appended-table row); Section 1006.2.1	One-exit space limits	For the raw OCR occupancy row U, Table 1006.2.1 permits one exit or exit access doorway up to a maximum occupant load of 49 occupants; maximum common path of egress travel is 30 m without sprinklers where OL ≤ 30, 23 m without sprinklers where OL > 30, and 23 m with sprinklers.	Sl: one exit or exit access doorway; maximum occupant load: 49 occupants; without sprinkler, OL ≤ 30: 30 m; without sprinkler, OL > 30: 23 m; with sprinkler: 23 m	max	Occupancy U	NP = Not Permitted. a. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2.	NOT_TYPICAL	1178	Verify source
CH10-0088	Table 1006.2.1 (appended-table row); Section 1006.2.1	Open-parking common path	For Group S-2 open parking garages, common path of egress travel shall be not more than 30 m.	Sl: 30 m	max	Group S-2 open parking garage; table footnote f	f. The length of common path of egress travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	CONDITIONAL	1178	Verify source
CH10-0089	Section 1006.2.1.1	Three or more exits or exit access doorways	Four exits or exit access doorways shall be provided from any space with an occupant load greater than 1,000.	Sl: Four exits; occupant load greater than 1,000	trigger	Per Section 1006.2.1.1 (Three or more exits or exit access doorways).	None stated in inventory	DIRECT	1015	Verified
CH10-0090	Section 1006.2.1.1	Three or more exits or exit access doorways	Three exits or exit access doorways shall be provided from any space with an occupant load of 501 to 1,000.	Sl: Three exits; occupant load of 501; 1,000 occupants	trigger	Per Section 1006.2.1.1 (Three or more exits or exit access doorways).	None stated in inventory	DIRECT	1015	Verified
CH10-0091	Section 1006.2.2.1	Boiler, incinerator and furnace rooms	Exit access doorways shall be separated by a horizontal distance equal to one-half the length of the maximum overall diagonal dimension of the room.	Sl: one-half	formula	Per Section 1006.2.2.1 (Boiler, incinerator and furnace rooms).	None stated in inventory	CONDITIONAL	1015	Verified
CH10-0092	Section 1006.2.2.1	Boiler, incinerator and furnace rooms	Two exit access doorways are required in boiler, incinerator and furnace rooms where the area is over 45 m² and any fuel-fired equipment exceeds 422,000 kJ input capacity.	Sl: Two exit; 45 m²; 422,000 kJ	trigger	Per Section 1006.2.2.1 (Boiler, incinerator and furnace rooms).	None stated in inventory	CONDITIONAL	1015	Verified
CH10-0093	Section 1006.2.2.1	Boiler, incinerator and furnace rooms	Where two exit access doorways are required, one is permitted to be a fixed ladder or an alternating tread device.	Sl: two exit	trigger	Per Section 1006.2.2.1 (Boiler, incinerator and furnace rooms).	None stated in inventory	CONDITIONAL	1015	Verified
CH10-0094	Section 1006.2.2.2	Alternative second doorway component	Where two exit access doorways are required, one such doorway is permitted to be served by a fixed ladder or an alternating tread device.	Sl: two exit access doorways; one doorway	trigger	Refrigeration machinery rooms requiring two exit access doorways.	None stated in inventory	CONDITIONAL	1015–1016	Verify source
CH10-0095	Section 1006.2.2.2	Exit doorway separation	Exit access doorways shall be separated by a horizontal distance equal to one-half the maximum horizontal dimension of the room.	Sl: one-half	formula	Refrigeration machinery rooms requiring two exit access doorways.	None stated in inventory	CONDITIONAL	1016	Verified
CH10-0096	Section 1006.2.2.2	Machinery room travel distance	All portions of machinery rooms shall be within 45 m of an exit or exit access doorway.	Sl: 45 m	trigger	Refrigeration machinery rooms.	None stated in inventory	CONDITIONAL	1016	Verified
CH10-0097	Section 1006.2.2.2	Refrigeration machinery room exits	Machinery rooms larger than 100 m² shall have not less than two exits or exit access doorways.	Sl: 100 m²; two exits	min	Refrigeration machinery rooms larger than 100 m².	None stated in inventory	CONDITIONAL	1015	Verified
CH10-0098	Section 1006.2.2.3	Refrigerated rooms or spaces	Exit access travel distance shall be determined as specified in Section 1017.1, but all portions of a refrigerated room or space shall be within 45 m of an exit or exit access doorway where such rooms are not protected by an approved automatic sprinkler system.	Sl: 45 m	trigger	Per Section 1006.2.2.3 (Refrigerated rooms or spaces).	Exception: Where using refrigerants in quantities limited to the amounts based on the volume set forth in SBC 501.	CONDITIONAL	1016	Verified
CH10-0099	Section 1006.2.2.3	Refrigerated rooms or spaces	Rooms or spaces having a floor area larger than 100 m², containing a refrigerant evaporator and maintained at a temperature below 20°C, shall have access to not less than two exits or exit access doorways.	Sl: 100 m²; 20°C; two exits	min	Per Section 1006.2.2.3 (Refrigerated rooms or spaces).	Exception: Where using refrigerants in quantities limited to the amounts based on the volume set forth in SBC 501.	CONDITIONAL	1016	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0100	Section 1006.2.2.4	Electrical rooms	The location and number of exit or exit access doorways shall be provided for electrical rooms in accordance with Section 110.26 of NFPA 70 (or its equivalent in SBC 401) for electrical equipment rated 1000 V or less, and Section 110.33 of NFPA 70 (or its equivalent in SBC 401) for electrical equipment rated over 1000 V.	Sl: 1000 V	trigger	Per Section 1006.2.2.4 (Electrical rooms).	None stated in inventory	CONDITIONAL	1016	Verified
CH10-0101	Section 1006.2.2.6	Groups R-3 and R-4	Where Group R-3 occupancies are permitted by Section 903.2.8 to be protected by an automatic sprinkler system installed in accordance with Section 903.3.1.3, the exit access travel distance for Group R-3 shall be not more than 38 m.	Sl: 38 m	max	Per Section 1006.2.2.6 (Groups R-3 and R-4).	None stated in inventory	NOT_TYPICAL	1016	Verified
CH10-0102	Section 1006.2.2.6	Groups R-3 and R-4	Where Group R-4 occupancies are permitted by Section 903.2.8 to be protected by an automatic sprinkler system installed in accordance with Section 903.3.1.3, the exit access travel distance for Group R-4 shall be not more than 23 m.	Sl: 23 m	max	Per Section 1006.2.2.6 (Groups R-3 and R-4).	None stated in inventory	NOT_TYPICAL	1016	Verified
CH10-0103	Section 1006.3.1	Occupant load	Where stairways serve more than one story, or more than one story and an occupied roof, only the occupant load of each story or occupied roof, considered individually, shall be used when calculating the required number of exits or access to exits serving that story.	Sl: more than one story; one story and an occupied roof	formula	Stairways serving multiple stories or a story and occupied roof.	None stated in inventory	DIRECT	1017	Verified
CH10-0104	Section 1006.3.2	Path of egress travel	The path of egress travel to an exit shall not pass through more than one adjacent story.	Sl: more than one adjacent story	max	General path-of-egress limit before listed exceptions.	None stated in inventory	DIRECT	1017	Verified
CH10-0105	Section 1006.3.2	Path of egress travel	Exception: The path of egress travel to an exit shall be permitted to pass through more than one adjacent story in any of the following: 1. In Group R-1, R-2 or R-3 occupancies, exit access stairways and ramps connecting four stories or less serving and contained within an individual dwelling unit, sleeping unit or live/work unit.	Sl: four stories	trigger	Per Section 1006.3.2 (Path of egress travel).	Exception: The path of egress travel to an exit shall be permitted to pass through more than one adjacent story in any of the following: 1. In Group R-1, R-2 or R-3 occupancies, exit access stairways and ramps connecting four stories or less serving and contained within an individual dwelling unit, sleeping unit or live/work unit. 2. Exit access stairways serving and contained within a Group R-3 congregate residence or a Group R-4 facility. 3. Exit access stairways and ramps within an atrium comply with the provisions of Section 404. 4. Exit access stairways and ramps in open parking garages that serve only the parking garage. 5. Exit access stairways and ramps serving open-air assembly seating complying with the exit access travel distance requirements of Section 1029.7. 6. Exit access stairways and ramps between the balcony, gallery or press box and the main assembly floor in occupancies such as theaters, auditoriums and sports facilities. 7. Exterior exit access stairways and ramps between occupied roofs.	CONDITIONAL	1017	Verified
CH10-0106	Table 1006.3.3 (appended-table row); Section 1006.3.3	Minimum exits per story	A story with 1 to 500 occupants requires a minimum of 2 exits or accesses to exits.	Sl: 1 to 500 occupants; 2 exits	min	Each story and occupied roof	None stated in inventory	DIRECT	1178	Verified
CH10-0107	Table 1006.3.3 (appended-table row); Section 1006.3.3	Minimum exits per story	A story with 501 to 1,000 occupants requires a minimum of 3 exits or accesses to exits.	Sl: 501 to 1,000 occupants; 3 exits	min	Each story and occupied roof	None stated in inventory	DIRECT	1178	Verified
CH10-0108	Table 1006.3.3 (appended-table row); Section 1006.3.3	Minimum exits per story	A story with more than 1,000 occupants requires a minimum of 4 exits or accesses to exits.	Sl: 1,000 occupants; 4 exits	min	Each story and occupied roof	None stated in inventory	DIRECT	1178	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0109	Section 1006.3.4	Single exits	Item 2 Rooms, areas and spaces complying with Section 1006.2.1 with exits that discharge directly to the exterior at the level of exit discharge, are permitted to have one exit or access to a single exit.	Sl: one exit; single exit	trigger	Per Section 1006.3.4 (Single exits).	1 The occupant load, number of dwelling units and exit access travel distance do not exceed the values in Table 1006.3.4(1) or Table 1006.3.4(2). 2 Rooms, areas and spaces complying with Section 1006.2.1 with exits that discharge directly to the exterior at the level of exit discharge, are permitted to have one exit or access to a single exit. 3 Parking garages where vehicles are mechanically parked shall be permitted to have one exit or access to a single exit. 4 Group R-3 and R-4 occupancies shall be permitted to have one exit or access to a single exit. 5 Individual single-story or multistory dwelling units shall be permitted to have a single exit or access to a single exit from the dwelling unit provided that both of the following criteria are met: 5.1 The dwelling unit complies with Section 1006.2.1 as a space with one means of egress. 5.2 Either the exit from the dwelling unit discharges directly to the exterior at the level of exit discharge, or the exit access outside the dwelling unit's entrance door provides access to not less than two approved independent exits.	CONDITIONAL	1018	Verified
CH10-0110	Section 1006.3.4	Single exits	Item 3 Parking garages where vehicles are mechanically parked shall be permitted to have one exit or access to a single exit.	Sl: one exit; single exit	trigger	Per Section 1006.3.4 (Single exits).	1 The occupant load, number of dwelling units and exit access travel distance do not exceed the values in Table 1006.3.4(1) or Table 1006.3.4(2). 2 Rooms, areas and spaces complying with Section 1006.2.1 with exits that discharge directly to the exterior at the level of exit discharge, are permitted to have one exit or access to a single exit. 3 Parking garages where vehicles are mechanically parked shall be permitted to have one exit or access to a single exit. 4 Group R-3 and R-4 occupancies shall be permitted to have one exit or access to a single exit. 5 Individual single-story or multistory dwelling units shall be permitted to have a single exit or access to a single exit from the dwelling unit provided that both of the following criteria are met: 5.1 The dwelling unit complies with Section 1006.2.1 as a space with one means of egress. 5.2 Either the exit from the dwelling unit discharges directly to the exterior at the level of exit discharge, or the exit access outside the dwelling unit's entrance door provides access to not less than two approved independent exits.	CONDITIONAL	1018	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0111	Section 1006.3.4	Single exits	Item 4 Group R-3 and R-4 occupancies shall be permitted to have one exit or access to a single exit.	Sl: one exit; single exit	trigger	Per Section 1006.3.4 (Single exits).	1 The occupant load, number of dwelling units and exit access travel distance do not exceed the values in Table 1006.3.4(1) or Table 1006.3.4(2). 2 Rooms, areas and spaces complying with Section 1006.2.1 with exits that discharge directly to the exterior at the level of exit discharge, are permitted to have one exit or access to a single exit. 3 Parking garages where vehicles are mechanically parked shall be permitted to have one exit or access to a single exit. 4 Group R-3 and R-4 occupancies shall be permitted to have one exit or access to a single exit. 5 Individual single-story or multistory dwelling units shall be permitted to have a single exit or access to a single exit from the dwelling unit provided that both of the following criteria are met: 5.1 The dwelling unit complies with Section 1006.2.1 as a space with one means of egress. 5.2 Either the exit from the dwelling unit discharges directly to the exterior at the level of exit discharge, or the exit access outside the dwelling unit's entrance door provides access to not less than two approved independent exits.	NOT_TYPICAL	1018	Verified
CH10-0112	Section 1006.3.4	Single exits	Item 5.1 The dwelling unit complies with Section 1006.2.1 as a space with one means of egress.	Sl: one means of egress	trigger	Per Section 1006.3.4 (Single exits).	1 The occupant load, number of dwelling units and exit access travel distance do not exceed the values in Table 1006.3.4(1) or Table 1006.3.4(2). 2 Rooms, areas and spaces complying with Section 1006.2.1 with exits that discharge directly to the exterior at the level of exit discharge, are permitted to have one exit or access to a single exit. 3 Parking garages where vehicles are mechanically parked shall be permitted to have one exit or access to a single exit. 4 Group R-3 and R-4 occupancies shall be permitted to have one exit or access to a single exit. 5 Individual single-story or multistory dwelling units shall be permitted to have a single exit or access to a single exit from the dwelling unit provided that both of the following criteria are met: 5.1 The dwelling unit complies with Section 1006.2.1 as a space with one means of egress. 5.2 Either the exit from the dwelling unit discharges directly to the exterior at the level of exit discharge, or the exit access outside the dwelling unit's entrance door provides access to not less than two approved independent exits.	CONDITIONAL	1018	Verified
CH10-0113	Section 1006.3.4.1	Mixed occupancies	Where one exit, or exit access stairway or ramp providing access to exits at other stories, is permitted to serve individual stories, mixed occupancies shall be permitted to be served by single exits provided that each individual occupancy complies with the applicable requirements of Table 1006.3.4(1) or 1006.3.4(2) for that occupancy.	Sl: one exit; single exits	trigger	Per Section 1006.3.4.1 (Mixed occupancies).	None stated in inventory	CONDITIONAL	1021	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0114	Table 1006.3.4(1) (appended-table row); Section 1006.3.4(1)	Single-exit R-2 dwelling stories	For an R-2 basement, first, second or third story above grade plane, a single exit is limited to 4 dwelling units and a maximum exit access travel distance of 38 m.	Sl: third story; single exit; 4 dwelling units; 38 m	max	R-2 dwelling units; building sprinklered throughout under Sections 903.3.1.1 or 903.3.1.2 and provided with Section 1031 emergency escape and rescue openings	Fourth story above grade plane and higher: single exit Not Permitted. NP = Not Permitted. NA = Not Applicable. a. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1031. b. This table is used for R-2 occupancies consisting of dwelling units. For R-2 occupancies consisting of sleeping units, use Table 1006.3.4(2).	EXTERNAL_VERIFY	1179	Verify source
CH10-0115	Table 1006.3.4(2) (appended-table row); Section 1006.3.4(2)	Open-parking single-exit travel	For Group S-2 open parking garages, exit access travel distance shall be not more than 30 m.	Sl: 30 m	max	Table footnote d	NP = Not Permitted. NA = Not Applicable. a. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1031. b. Group B, F and S occupancies in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 shall have a maximum exit access travel distance of 30 meters. c. This table is used for R-2 occupancies consisting of sleeping units. For R-2 occupancies consisting of dwelling units, use Table 1006.3.4(1). d. The length of exit access travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	NOT_TYPICAL	1179	Verify source
CH10-0116	Table 1006.3.4(2) (appended-table row); Section 1006.3.4(2)	Single-exit story limits	A single exit is limited to 10 occupants and a maximum exit access travel distance of 23 m.	Sl: single exit; 10 occupants; 23 m	max	First story above or below grade plane; H-4, H-5, I, R-1 or R-2 sleeping units	NP = Not Permitted. NA = Not Applicable. a. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1031. b. Group B, F and S occupancies in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 shall have a maximum exit access travel distance of 30 meters. c. This table is used for R-2 occupancies consisting of sleeping units. For R-2 occupancies consisting of dwelling units, use Table 1006.3.4(1). d. The length of exit access travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	EXTERNAL_VERIFY	1179	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0117	Table 1006.3.4(2) (appended-table row); Section 1006.3.4(2)	Single-exit story limits	A single exit is limited to 29 occupants and a maximum exit access travel distance of 23 m.	Sl: single exit; 29 occupants; 23 m	max	First story above or below grade plane; S	NP = Not Permitted. NA = Not Applicable. a. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1031. b. Group B, F and S occupancies in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 shall have a maximum exit access travel distance of 30 meters. c. This table is used for R-2 occupancies consisting of sleeping units. For R-2 occupancies consisting of dwelling units, use Table 1006.3.4(1). d. The length of exit access travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	NOT_TYPICAL	1179	Verify source
CH10-0118	Table 1006.3.4(2) (appended-table row); Section 1006.3.4(2)	Single-exit story limits	A single exit is limited to 29 occupants and a maximum exit access travel distance of 23 m.	Sl: single exit; 29 occupants; 23 m	max	Second story above grade plane; B, F, M or S	NP = Not Permitted. NA = Not Applicable. a. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1031. b. Group B, F and S occupancies in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 shall have a maximum exit access travel distance of 30 meters. c. This table is used for R-2 occupancies consisting of sleeping units. For R-2 occupancies consisting of dwelling units, use Table 1006.3.4(1). d. The length of exit access travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	NOT_TYPICAL	1179	Verify source
CH10-0119	Table 1006.3.4(2) (appended-table row); Section 1006.3.4(2)	Single-exit story limits	A single exit is limited to 3 occupants and a maximum exit access travel distance of 7.5 m.	Sl: single exit; 3 occupants; 7.5 m	max	First story above or below grade plane; H-2 or H-3	NP = Not Permitted. NA = Not Applicable. a. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1031. b. Group B, F and S occupancies in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 shall have a maximum exit access travel distance of 30 meters. c. This table is used for R-2 occupancies consisting of sleeping units. For R-2 occupancies consisting of dwelling units, use Table 1006.3.4(1). d. The length of exit access travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	NOT_TYPICAL	1179	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0120	Table 1006.3.4(2) (appended-table row); Section 1006.3.4(2)	Single-exit story limits	A single exit is limited to 49 occupants and a maximum exit access travel distance of 23 m.	Sl: single exit; 49 occupants; 23 m	max	First story above or below grade plane; A, B, E, F, M or U	NP = Not Permitted. NA = Not Applicable. a. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1031. b. Group B, F and S occupancies in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 shall have a maximum exit access travel distance of 30 meters. c. This table is used for R-2 occupancies consisting of sleeping units. For R-2 occupancies consisting of dwelling units, use Table 1006.3.4(1). d. The length of exit access travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	NOT_TYPICAL	1179	Verify source
CH10-0121	Table 1006.3.4(2) (appended-table row); Section 1006.3.4(2)	Sprinklered B/F/S single-exit travel	Group B, F and S occupancies in buildings sprinklered throughout under Section 903.3.1.1 have a maximum exit access travel distance of 30 m.	Sl: 30 m	max	Table footnote b	NP = Not Permitted. NA = Not Applicable. a. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1031. b. Group B, F and S occupancies in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 shall have a maximum exit access travel distance of 30 meters. c. This table is used for R-2 occupancies consisting of sleeping units. For R-2 occupancies consisting of dwelling units, use Table 1006.3.4(1). d. The length of exit access travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	NOT_TYPICAL	1179	Verify source
CH10-0122	Table 1006.3.4(2) (appended-table row); Section 1006.3.4(2)	Upper-story single exits	At the third story above grade plane and higher, a single exit is Not Permitted.	Sl: third story; single exit	trigger	All occupancies in this table	NP = Not Permitted. NA = Not Applicable. a. Buildings classified as Group R-2 equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 and provided with emergency escape and rescue openings in accordance with Section 1031. b. Group B, F and S occupancies in buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 shall have a maximum exit access travel distance of 30 meters. c. This table is used for R-2 occupancies consisting of sleeping units. For R-2 occupancies consisting of dwelling units, use Table 1006.3.4(1). d. The length of exit access travel distance in a Group S-2 open parking garage shall be not more than 30 meters.	EXTERNAL_VERIFY	1179	Verify source

A.4.1007 — Section 1007 (7 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0123	Section 1007.1.1	Interconnected stair corridor measurement	Where interior exit stairways or ramps are interconnected by a 1-hour fire-resistance-rated corridor conforming to Section 1020, the required exit separation shall be measured along the shortest direct line of travel within the corridor.	Sl: 1-hour	trigger	Exception 1: interior exit stairways or ramps interconnected by a compliant corridor.	None stated in inventory	CONDITIONAL	1022	Verified
CH10-0124	Section 1007.1.1	Interlocking and scissor stair count	Interlocking or scissor stairways shall be counted as one exit stairway.	Sl: one exit	trigger	Interlocking or scissor stairways.	None stated in inventory	CONDITIONAL	1022	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0125	Section 1007.1.1	Sprinklered exit separation	Where a building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2, the separation distance shall be not less than one-third of the length of the maximum overall diagonal dimension of the area served.	Sl: one-third	formula	Exception 2: buildings sprinklered throughout under Section 903.3.1.1 or 903.3.1.2.	None stated in inventory	CONDITIONAL	1022	Verified
CH10-0126	Section 1007.1.1	Two-exit separation	Where two exits, exit access doorways, exit access stairways or ramps, or any combination thereof, are required from any portion of the exit access, they shall be placed a distance apart equal to not less than one-half of the length of the maximum overall diagonal dimension of the building or area to be served measured in a straight line between them.	Sl: two exits; one-half	formula	Exit access portions requiring two exits or exit access components.	None stated in inventory	DIRECT	1022	Verified
CH10-0127	Section 1007.1.2	Three or more exits or exit access doorways	Where access to three or more exits is required, not less than two exit or exit access doorways shall be arranged in accordance with the provisions of Section 1007.1.1.	Sl: three or more exits; two exit	min	Per Section 1007.1.2 (Three or more exits or exit access doorways).	None stated in inventory	DIRECT	1023	Verified
CH10-0128	Section 1007.1.3	Remoteness of exit access stairways or ramps	Where two exit access stairways or ramps provide the required means of egress to exits at another story, the required separation distance shall be maintained for all portions of such exit access stairways or ramps.	Sl: two exit	trigger	Per Section 1007.1.3 (Remoteness of exit access stairways or ramps).	None stated in inventory	DIRECT	1023	Verified
CH10-0129	Section 1007.1.3.1	Three or more exit access stairways or ramps	Where more than two exit access stairways or ramps provide the required means of egress, not less than two shall be arranged in accordance with Section 1007.1.3.	Sl: two exit	min	Per Section 1007.1.3.1 (Three or more exit access stairways or ramps).	None stated in inventory	DIRECT	1024	Verified

A.4.1008 — Section 1008 (12 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0130	Section 1008.2.1	Illumination level under normal power	Along exit access stairways, exit stairways and at their required landings, the illumination level shall not be less than 110 lux at the walking surface when the stairway is in use.	Sl: 110 lux	min	Per Section 1008.2.1 (Illumination level under normal power).	Exception: For auditoriums, theaters, concert or opera halls and similar assembly occupancies, the illumination at the walking surface is permitted to be reduced during performances by one of the following methods provided that the required illumination is automatically restored upon activation of a premises' fire alarm system: 1. Externally illuminated walking surfaces shall be permitted to be illuminated to not less than 2.2 lux. 2. Steps, landings and the sides of ramps shall be permitted to be marked with self-luminous materials in accordance with Sections 1025.2.1, 1025.2.2 and 1025.2.4 by systems listed in accordance with UL 1994.	DIRECT	1024	Verified
CH10-0131	Section 1008.2.1	Illumination level under normal power	Exception item 1. Externally illuminated walking surfaces shall be permitted to be illuminated to not less than 2.2 lux.	Sl: 2.2 lux	min	Per Section 1008.2.1 (Illumination level under normal power).	Exception: For auditoriums, theaters, concert or opera halls and similar assembly occupancies, the illumination at the walking surface is permitted to be reduced during performances by one of the following methods provided that the required illumination is automatically restored upon activation of a premises' fire alarm system: 1. Externally illuminated walking surfaces shall be permitted to be illuminated to not less than 2.2 lux. 2. Steps, landings and the sides of ramps shall be permitted to be marked with self-luminous materials in accordance with Sections 1025.2.1, 1025.2.2 and 1025.2.4 by systems listed in accordance with UL 1994.	CONDITIONAL	1024	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0132	Section 1008.2.1	Illumination level under normal power	The means of egress illumination level shall be not less than 11 lux at the walking surface.	Sl: 11 lux	min	Per Section 1008.2.1 (Illumination level under normal power).	Exception: For auditoriums, theaters, concert or opera halls and similar assembly occupancies, the illumination at the walking surface is permitted to be reduced during performances by one of the following methods provided that the required illumination is automatically restored upon activation of a premises' fire alarm system: 1. Externally illuminated walking surfaces shall be permitted to be illuminated to not less than 2.2 lux. 2. Steps, landings and the sides of ramps shall be permitted to be marked with self-luminous materials in accordance with Sections 1025.2.1, 1025.2.2 and 1025.2.4 by systems listed in accordance with UL 1994.	DIRECT	1024	Verified
CH10-0133	Section 1008.2.2	Group I-2	occupancies where two or more exits are required, on the exterior landings required by Section1010.1.5, means of egress illumination levels for the exit discharge shall be provided such that failure of a single lamp in a luminaire shall not reduce the illumination level on that landing to less than 11 lux.	Sl: two or more exits; 11 lux	min	Per Section 1008.2.2 (Group I-2).	None stated in inventory	NOT_TYPICAL	1025	Verify source
CH10-0134	Section 1008.2.3	Exit discharge Illumination shall be provided along the path of travel for the exit discharge from each exit to the public way	Exception item 2. A dispersal area shall be illuminated to a level not less than 11 lux at the walking surface.	Sl: 11 lux	min	Per Section 1008.2.3 (Exit discharge Illumination shall be provided along the path of travel for the exit discharge from each exit to the public way).	Exception: Illumination shall not be required where the path of the exit discharge meets both of the following requirements: 1. The path of exit discharge is illuminated from the exit to a safe dispersal area complying with Section 1028.5. 2. A dispersal area shall be illuminated to a level not less than 11 lux at the walking surface.	CONDITIONAL	1025	Verified
CH10-0135	Section 1008.3.1	General	In the event of power supply failure in rooms and spaces that require two or more exits or access to exits, an emergency electrical system shall automatically illuminate all of the following areas:	Sl: two or more exits	trigger	Per Section 1008.3.1 (General).	1 Aisles. 2 Corridors. 3 Exit access stairways and ramps.	DIRECT	1025	Verified
CH10-0136	Section 1008.3.2	Buildings	In the event of power supply failure in buildings that require two or more exits or access to exits, an emergency electrical system shall automatically illuminate all of the following areas:	Sl: two or more exits	trigger	Per Section 1008.3.2 (Buildings).	1 Interior exit access stairways and ramps. 2 Interior and exterior exit stairways and ramps. 3 Exit passageways. 4 Vestibules and areas on the level of discharge used for exit discharge in accordance with Section 1028.2. 5 Exterior landings as required by Section 1010.1.5 for exit doorways that lead directly to the exit discharge.	DIRECT	1026	Verified
CH10-0137	Section 1008.3.3	Emergency lighting in large public restrooms	Item 5 Public restrooms with an area greater than 28 m² shall be automatically illuminated by the emergency electrical system upon power supply failure.	Sl: area greater than 28 m²	trigger	Public restrooms; Section 1008.3.3 Item 5.	None stated in inventory	CONDITIONAL	1026	Verified
CH10-0138	Section 1008.3.4	Duration	The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator.	Sl: 90 minutes	min	Per Section 1008.3.4 (Duration).	None stated in inventory	DIRECT	1026	Verified
CH10-0139	Section 1008.3.5	Illumination level under emergency power	Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 11 lux and a minimum at any point of 1 lux measured along the path of egress at floor level.	Sl: 11 lux; 1 lux	min	Per Section 1008.3.5 (Illumination level under emergency power).	None stated in inventory	DIRECT	1026	Verified
CH10-0140	Section 1008.3.5	Illumination level under emergency power	Illumination levels shall be permitted to decline to 6 lux average and a minimum at any point of 0.6 lux at the end of the emergency lighting time duration.	Sl: 6 lux; 0.6 lux	min	Per Section 1008.3.5 (Illumination level under emergency power).	None stated in inventory	DIRECT	1026	Verified
CH10-0141	Section 1008.3.5	Illumination level under emergency power	In Group I-2 occupancies, failure of a single lamp in a luminaire shall not reduce the illumination level to less than 2.2 lux.	Sl: 2.2 lux	min	Per Section 1008.3.5 (Illumination level under emergency power).	None stated in inventory	NOT_TYPICAL	1026	Verified

A.4.1009 — Section 1009 (15 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0142	Section 1009.1	Accessible means of egress required	Accessible spaces shall be provided with not less than one accessible means of egress.	Sl: one accessible means of egress	min	Per Section 1009.1 (Accessible means of egress required).	## Exceptions: 1. One accessible means of egress is required from an accessible mezzanine level in accordance with Section 1009.3, 1009.4 or 1009.5. 2. In assembly areas with ramped aisles or stepped aisles, one accessible means of egress is permitted where the common path of egress travel is accessible and meets the requirements in Section 1030.8.	DIRECT	1027	Verified
CH10-0143	Section 1009.1	Accessible means of egress required	Exception item 1. One accessible means of egress is required from an accessible mezzanine level in accordance with Section 1009.3, 1009.4 or 1009.5. 2. In assembly areas with ramped aisles or stepped aisles, one accessible means of egress is permitted where the common path of egress travel is accessible and meets the requirements in Section 1030.8.	Sl: One accessible means of egress; one accessible means of egress	trigger	Per Section 1009.1 (Accessible means of egress required).	## Exceptions: 1. One accessible means of egress is required from an accessible mezzanine level in accordance with Section 1009.3, 1009.4 or 1009.5. 2. In assembly areas with ramped aisles or stepped aisles, one accessible means of egress is permitted where the common path of egress travel is accessible and meets the requirements in Section 1030.8.	CONDITIONAL	1027	Verified
CH10-0144	Section 1009.1	Accessible means of egress required	Where more than one means of egress is required by Section 1006.2 or 1006.3 from any accessible space, each accessible portion of the space shall be served by not less than two accessible means of egress.	Sl: one means of egress; two accessible means of egress	min	Per Section 1009.1 (Accessible means of egress required).	## Exceptions: 1. One accessible means of egress is required from an accessible mezzanine level in accordance with Section 1009.3, 1009.4 or 1009.5. 2. In assembly areas with ramped aisles or stepped aisles, one accessible means of egress is permitted where the common path of egress travel is accessible and meets the requirements in Section 1030.8.	DIRECT	1027	Verified
CH10-0145	Section 1009.2.1	Elevators required	In buildings where a required accessible floor or occupied roof is four or more stories above or below a level of exit discharge, not less than one required accessible means of egress shall be an elevator complying with Section 1009.4.	Sl: four or more stories; one required accessible means of egress	min	Per Section 1009.2.1 (Elevators required).	1. In buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, the elevator shall not be required on floors provided with a horizontal exit and located at or above the levels of exit discharge. 2. In buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, the elevator shall not be required on floors provided with a ramp conforming to Section 1012.	CONDITIONAL	1030	Verify source
CH10-0146	Section 1009.3.2	Stairway width	Exception item 1. The clear width of 1200 mm between handrails is not required in buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.	Sl: 1200 mm	trigger	Per Section 1009.3.2 (Stairway width).	Exceptions: 1. The clear width of 1200 mm between handrails is not required in buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2. 2. The clear width of 1200 mm between handrails is not required for stairways accessed from a refuge area in conjunction with a horizontal exit.	CONDITIONAL	1031	Verified
CH10-0147	Section 1009.3.2	Stairway width	Exception item 2. The clear width of 1200 mm between handrails is not required for stairways accessed from a refuge area in conjunction with a horizontal exit.	Sl: 1200 mm	trigger	Per Section 1009.3.2 (Stairway width).	Exceptions: 1. The clear width of 1200 mm between handrails is not required in buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2. 2. The clear width of 1200 mm between handrails is not required for stairways accessed from a refuge area in conjunction with a horizontal exit.	CONDITIONAL	1031	Verified
CH10-0148	Section 1009.3.2	Stairway width	Stairways shall have a clear width of 1200 mm minimum between handrails.	Sl: 1200 mm	min	Per Section 1009.3.2 (Stairway width).	Exceptions: 1. The clear width of 1200 mm between handrails is not required in buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2. 2. The clear width of 1200 mm between handrails is not required for stairways accessed from a refuge area in conjunction with a horizontal exit.	DIRECT	1031	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0149	Section 1009.6.3	Size	Each area of refuge shall be sized to accommodate one wheelchair space of 750 mm by 1300 mm for each 200 occupants or portion thereof, based on the occupant load of the area of refuge and areas served by the area of refuge.	Sl: 750 mm; 1300 mm; 200 occupants	trigger	Per Section 1009.6.3 (Size).	None stated in inventory	CONDITIONAL	1036	Verified
CH10-0150	Section 1009.7.2	Separation	Exterior walls separating the exterior area of assisted rescue from the interior of the building shall have a minimum fire-resistance rating of 1 hour, rated for exposure to fire from the inside.	Sl: 1 hour	min	Per Section 1009.7.2 (Separation).	Exception: The fire-resistance rating and opening protectives are not required in the exterior wall where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.	CONDITIONAL	1038	Verified
CH10-0151	Section 1009.7.2	Separation	The fire-resistance-rated construction shall extend vertically from the ground to a point not less than 3000 mm above the floor level of the area for assisted rescue or to the roof line, whichever is lower.	Sl: 3000 mm	min	Per Section 1009.7.2 (Separation).	Exception: The fire-resistance rating and opening protectives are not required in the exterior wall where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.	CONDITIONAL	1038	Verified
CH10-0152	Section 1009.7.2	Separation	The fire-resistance-rated exterior wall construction shall extend horizontally not less than 3 m beyond the landing on either side of the landing or equivalent fire-resistance-rated construction is permitted to extend out perpendicular to the exterior wall not less than 1200 mm on the side of the landing.	Sl: 3 m; 1200 mm	min	Per Section 1009.7.2 (Separation).	Exception: The fire-resistance rating and opening protectives are not required in the exterior wall where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.	CONDITIONAL	1038	Verified
CH10-0153	Section 1009.7.3	Openness	The sides other than the separation walls shall be not less than 50 percent open, and the open area shall be distributed so as to minimize the accumulation of smoke or toxic gases.	Sl: 50 percent	min	Per Section 1009.7.3 (Openness).	None stated in inventory	CONDITIONAL	1039	Verified
CH10-0154	Section 1009.7.4	Stairways	Exception: The minimum clear width of 1200 mm between handrails is not required at stairways serving buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.	Sl: 1200 mm	trigger	Per Section 1009.7.4 (Stairways).	Exception: The minimum clear width of 1200 mm between handrails is not required at stairways serving buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.	CONDITIONAL	1039	Verified
CH10-0155	Section 1009.7.4	Stairways	Stairways that are part of the means of egress for the exterior area for assisted rescue shall provide a minimum clear width of 1200 mm between handrails.	Sl: 1200 mm	min	Per Section 1009.7.4 (Stairways).	Exception: The minimum clear width of 1200 mm between handrails is not required at stairways serving buildings equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2.	CONDITIONAL	1039	Verified
CH10-0156	Section 1009.8	Two-way communication	A two-way communication system complying with Sections 1009.8.1 and 1009.8.2 shall be provided at the landing serving each elevator or bank of elevators on each accessible floor that is one or more stories above or below the level of exit discharge.	Sl: one or more stories	trigger	Per Section 1009.8 (Two-way communication).	Exceptions: 1. Two-way communication systems are not required at the landing serving each elevator or bank of elevators where the two-way communication system is provided within areas of refuge in accordance with Section 1009.6.5. 2. Two-way communication systems are not required on floors provided with ramps conforming to the provisions of Section 1012. 3. Two-way communication systems are not required at the landings serving only service elevators that are not designated as part of the accessible means of egress or serve as part of the required accessible route into a facility. 4. Two-way communication systems are not required at the landings serving only freight elevators. 5. Two-way communication systems are not required at the landing serving a private residence elevator. 6. Two-way communication systems are not required in Group I-2 or I-3 facilities.	CONDITIONAL	1039	Verified

A.4.1010 — Section 1010 (116 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0157	Section 1010.1.1	Door clear opening height	The minimum clear opening height of doors shall be 2000 mm.	Sl: 2000 mm	min	Means-of-egress doors.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	DIRECT	1042	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0158	Section 1010.1.1	Door clear opening width	The required capacity of each door opening shall be sufficient for the occupant load thereof and shall provide a minimum clear opening width of 800 mm.	Sl: 800 mm	min	Means-of-egress door openings.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	DIRECT	1042	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0159	Section 1010.1.1	Door size Exception 10	Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal.	Sl: 100 m²; 1500 mm	max	Exception 10: walk-in freezer and cooler doors below the stated area.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	CONDITIONAL	1043	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0160	Section 1010.1.1	Door size Exception 11	Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	Sl: 500 mm	min	Exception 11: specified nonaccessible single-user compartment and stall doors.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	CONDITIONAL	1043	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0161	Section 1010.1.1	Door size Exception 2	In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm.	Sl: 700 mm	min	Exception 2: nonaccessible Group I-3 resident sleeping-unit doors.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	NOT_TYPICAL	1042	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0162	Section 1010.1.1	Door size Exception 3	Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width.	Sl: 1.0 m²	mixed	Exception 3: storage closets below the stated area.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	CONDITIONAL	1042	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0163	Section 1010.1.1	Door size Exception 6	Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm.	Sl: 2000 mm	min	Exception 6: door openings within dwelling or sleeping units.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	DIRECT	1042	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0164	Section 1010.1.1	Door size Exception 7	In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm.	Sl: 1900 mm	min	Exception 7: specified nonaccessible dwelling/sleeping-unit exterior doors.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	DIRECT	1042	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0165	Section 1010.1.1	Door size Exception 9	Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm.	Sl: 800 mm	min	Exception 9: Type B unit doors intended for user passage.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	DIRECT	1043	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0166	Section 1010.1.1	Group I-2 bed-movement door width	In Group I-2, means-of-egress doors used for movement of beds shall provide a minimum clear opening width of 1000 mm.	Sl: 1000 mm	min	Group I-2 bed-movement doors.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	NOT_TYPICAL	1042	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0167	Section 1010.1.1	Swinging-door clear width measurement	The clear opening width of doorways with swinging doors shall be measured between the face of the door and the stop, with the door open 90 degrees.	Sl: 90 degrees	trigger	Swinging doors.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	DIRECT	1042	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0168	Section 1010.1.1	Two-leaf door clear width	Where a door opening includes two door leaves without a mullion, one leaf shall provide a minimum clear opening width of 800 mm.	Sl: two door leaves; one qualifying leaf; 800 mm	mixed	Door openings required to provide 800 mm minimum clear width and having two leaves without a mullion.	1. In Group R-2 and R-3 dwelling and sleeping units that are not required to be an Accessible unit, Type A unit or Type B unit, the minimum width shall not apply to door openings that are not part of the required means of egress. 2. In Group I-3, door openings to resident sleeping units that are not required to be an Accessible unit shall have a minimum clear opening width of 700 mm. 3. Door openings to storage closets less than 1.0 m² in area shall not be limited by the minimum clear opening width. 4. The maximum width of door leaves in revolving doors that comply with Section 1010.3.1 shall not be limited. 5. The maximum width of door leaves in power-operated doors that comply with Section 1010.3.2 shall not be limited. 6. Door openings within a dwelling unit or sleeping unit shall have a minimum clear opening height of 2000 mm. 7. In dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, exterior door openings, other than the required exit door, shall have a minimum clear opening height of 1900 mm. 8. In Groups I-1, R-2, R-3 and R-4 occupancies, in dwelling and sleeping units that are not required to be Accessible, Type A or Type B units, the minimum clear opening widths shall not apply to interior egress doors. 9. Door openings required to be accessible within Type B units intended for user passage shall have a minimum clear opening width of 800 mm. 10. Doors to walk-in freezers and coolers less than 100 m² in area shall have a maximum width of 1500 mm nominal. 11. Doors serving nonaccessible single-user shower or sauna compartments, toilet stalls or dressing, fitting or changing rooms shall have a minimum clear opening width of 500 mm.	DIRECT	1042	Verified
CH10-0169	Section 1010.1.1.1	Projections into clear opening	Exception: Door closers, overhead door stops, power door operators, and electromagnetic door locks shall be permitted to be 2000 mm minimum above the floor.	Sl: 2000 mm	min	Per Section 1010.1.1.1 (Projections into clear opening).	Exception: Door closers, overhead door stops, power door operators, and electromagnetic door locks shall be permitted to be 2000 mm minimum above the floor.	CONDITIONAL	1044	Verified
CH10-0170	Section 1010.1.1.1	Projections into clear opening	Projections into the clear opening width between 850 mm and 2000 mm above the floor or ground shall not exceed 100 mm.	Sl: 850 mm; 2000 mm; 100 mm	max	Per Section 1010.1.1.1 (Projections into clear opening).	Exception: Door closers, overhead door stops, power door operators, and electromagnetic door locks shall be permitted to be 2000 mm minimum above the floor.	DIRECT	1044	Verified
CH10-0171	Section 1010.1.1.1	Projections into clear opening	There shall not be projections into the required clear opening width lower than 850 mm above the floor or ground.	Sl: 850 mm	min	Per Section 1010.1.1.1 (Projections into clear opening).	Exception: Door closers, overhead door stops, power door operators, and electromagnetic door locks shall be permitted to be 2000 mm minimum above the floor.	DIRECT	1044	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0172	Section 1010.1.2	Egress door types	Exception item 1. Private garages, office areas, factory and storage areas with an occupant load of 10 or less.	Sl: occupant load of 10	trigger	Per Section 1010.1.2 (Egress door types).	Exceptions: 1. Private garages, office areas, factory and storage areas with an occupant load of 10 or less. 2. Group I-3 occupancies used as a place of detention. 3. Critical or intensive care patient rooms within suites of health care facilities. 4. Doors within or serving a single dwelling unit in Groups R-2 and R-3. 5. In other than Group H occupancies, revolving doors complying with Section 1010.3.1. 6. In other than Group H occupancies, special purpose horizontal sliding, accordion or folding door assemblies complying with Section 1010.3.3. 7. Power-operated doors in accordance with Section 1010.3.2. 8. Doors serving a bathroom within an individual sleeping unit in Group R-1. 9. In other than Group H occupancies, manually operated horizontal sliding doors are permitted in a means of egress from spaces with an occupant load of 10 or less.	CONDITIONAL	1045	Verified
CH10-0173	Section 1010.1.2	Egress door types	Exception item 9. In other than Group H occupancies, manually operated horizontal sliding doors are permitted in a means of egress from spaces with an occupant load of 10 or less.	Sl: occupant load of 10	trigger	Per Section 1010.1.2 (Egress door types).	Exceptions: 1. Private garages, office areas, factory and storage areas with an occupant load of 10 or less. 2. Group I-3 occupancies used as a place of detention. 3. Critical or intensive care patient rooms within suites of health care facilities. 4. Doors within or serving a single dwelling unit in Groups R-2 and R-3. 5. In other than Group H occupancies, revolving doors complying with Section 1010.3.1. 6. In other than Group H occupancies, special purpose horizontal sliding, accordion or folding door assemblies complying with Section 1010.3.3. 7. Power-operated doors in accordance with Section 1010.3.2. 8. Doors serving a bathroom within an individual sleeping unit in Group R-1. 9. In other than Group H occupancies, manually operated horizontal sliding doors are permitted in a means of egress from spaces with an occupant load of 10 or less.	CONDITIONAL	1045	Verified
CH10-0174	Section 1010.1.2.1	Direction of swing	Side-hinged swinging doors, pivoted doors and balanced doors shall swing in the direction of egress travel where serving a room or area containing an occupant load of 50 or more persons or a Group H occupancy.	Sl: occupant load of 50	trigger	Per Section 1010.1.2.1 (Direction of swing).	None stated in inventory	DIRECT	1046	Verified
CH10-0175	Section 1010.1.3	Forces to unlatch and open doors	Item 1 For interior swinging egress doors that are manually operated, other than doors required to be fire rated, the force for pushing or pulling open the door shall not exceed 22 N.	Sl: 22 N	max	Per Section 1010.1.3 (Forces to unlatch and open doors).	1 Where door hardware operates by push or pull, the operational force to unlatch the door shall not exceed 67 N. 2 Where door hardware operates by rotation, the operational force to unlatch the door shall not exceed 3.15 N-m. 1 For interior swinging egress doors that are manually operated, other than doors required to be fire rated, the force for pushing or pulling open the door shall not exceed 22 N. 2 For other swinging doors, sliding doors or folding doors, and doors required to be fire rated, the door shall require not more than a 133 N force to be set in motion and shall move to a full-open position when subjected to not more than a 67 N force.	DIRECT	1046	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0176	Section 1010.1.3	Forces to unlatch and open doors	Item 1 Where door hardware operates by push or pull, the operational force to unlatch the door shall not exceed 67 N.	Sl: 67 N	max	Per Section 1010.1.3 (Forces to unlatch and open doors).	1 Where door hardware operates by push or pull, the operational force to unlatch the door shall not exceed 67 N. 2 Where door hardware operates by rotation, the operational force to unlatch the door shall not exceed 3.15 N-m. 1 For interior swinging egress doors that are manually operated, other than doors required to be fire rated, the force for pushing or pulling open the door shall not exceed 22 N. 2 For other swinging doors, sliding doors or folding doors, and doors required to be fire rated, the door shall require not more than a 133 N force to be set in motion and shall move to a full-open position when subjected to not more than a 67 N force.	DIRECT	1046	Verified
CH10-0177	Section 1010.1.3	Forces to unlatch and open doors	Item 2 For other swinging doors, sliding doors or folding doors, and doors required to be fire rated, the door shall require not more than a 133 N force to be set in motion and shall move to a full-open position when subjected to not more than a 67 N force.	Sl: 133 N; 67 N	max	Per Section 1010.1.3 (Forces to unlatch and open doors).	1 Where door hardware operates by push or pull, the operational force to unlatch the door shall not exceed 67 N. 2 Where door hardware operates by rotation, the operational force to unlatch the door shall not exceed 3.15 N-m. 1 For interior swinging egress doors that are manually operated, other than doors required to be fire rated, the force for pushing or pulling open the door shall not exceed 22 N. 2 For other swinging doors, sliding doors or folding doors, and doors required to be fire rated, the door shall require not more than a 133 N force to be set in motion and shall move to a full-open position when subjected to not more than a 67 N force.	CONDITIONAL	1046	Verified
CH10-0178	Section 1010.1.3	Forces to unlatch and open doors	Item 2 Where door hardware operates by rotation, the operational force to unlatch the door shall not exceed 3.15 N-m.	Sl: 3.15 N-m	max	Per Section 1010.1.3 (Forces to unlatch and open doors).	1 Where door hardware operates by push or pull, the operational force to unlatch the door shall not exceed 67 N. 2 Where door hardware operates by rotation, the operational force to unlatch the door shall not exceed 3.15 N-m. 1 For interior swinging egress doors that are manually operated, other than doors required to be fire rated, the force for pushing or pulling open the door shall not exceed 22 N. 2 For other swinging doors, sliding doors or folding doors, and doors required to be fire rated, the door shall require not more than a 133 N force to be set in motion and shall move to a full-open position when subjected to not more than a 67 N force.	DIRECT	1046	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0179	Section 1010.1.4	Floor elevation	Exception item 2. At exterior doors serving Groups F, H, R-2 and S and where such doors are not part of an accessible route, the landing at an exterior door shall not be more than 175 mm below the landing on the egress side of the door, provided the door, other than an exterior storm or screen door, does not swing over the landing.	Sl: 175 mm	max	Per Section 1010.1.4 (Floor elevation).	## Exceptions: 1. At doors serving individual dwelling units or sleeping units in Groups R-2 and R-3 a door is permitted to open at the top step of an interior flight of stairs, provided the door does not swing over the top step. 2. At exterior doors serving Groups F, H, R-2 and S and where such doors are not part of an accessible route, the landing at an exterior door shall not be more than 175 mm below the landing on the egress side of the door, provided the door, other than an exterior storm or screen door, does not swing over the landing. 3. At exterior doors serving Group U and individual dwelling units and sleeping units in Groups R-2 and R-3, and where such units are not required to be Accessible units, Type A units or Type B units, the landing at an exterior doorway shall be not more than 200 mm below the landing on the egress side of the door. Such doors, including storm or screen doors, shall be permitted to swing over either landing. 4. Variations in elevation due to differences in finish materials, but not more than 12.5 mm. 5. Exterior decks, patios or balconies that are part of Type B dwelling units or sleeping units, that have impervious surfaces and that are not more than 100 mm below the finished floor level of the adjacent interior space of the dwelling unit or sleeping unit. 6. Doors serving equipment spaces not required to be accessible in accordance with Section 1103.2.9 and serving an occupant load of five or less shall be permitted to have a landing on one side to be not more than 175 mm above or below the landing on the egress side of the door.	CONDITIONAL	1047	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0180	Section 1010.1.4	Floor elevation	Exception item 3. At exterior doors serving Group U and individual dwelling units and sleeping units in Groups R-2 and R-3, and where such units are not required to be Accessible units, Type A units or Type B units, the landing at an exterior doorway shall be not more than 200 mm below the landing on the egress side of the door. Such doors, including storm or screen doors, shall be permitted to swing over either landing.	Sl: 200 mm	max	Per Section 1010.1.4 (Floor elevation).	## Exceptions: 1. At doors serving individual dwelling units or sleeping units in Groups R-2 and R-3 a door is permitted to open at the top step of an interior flight of stairs, provided the door does not swing over the top step. 2. At exterior doors serving Groups F, H, R-2 and S and where such doors are not part of an accessible route, the landing at an exterior door shall not be more than 175 mm below the landing on the egress side of the door, provided the door, other than an exterior storm or screen door, does not swing over the landing. 3. At exterior doors serving Group U and individual dwelling units and sleeping units in Groups R-2 and R-3, and where such units are not required to be Accessible units, Type A units or Type B units, the landing at an exterior doorway shall be not more than 200 mm below the landing on the egress side of the door. Such doors, including storm or screen doors, shall be permitted to swing over either landing. 4. Variations in elevation due to differences in finish materials, but not more than 12.5 mm. 5. Exterior decks, patios or balconies that are part of Type B dwelling units or sleeping units, that have impervious surfaces and that are not more than 100 mm below the finished floor level of the adjacent interior space of the dwelling unit or sleeping unit. 6. Doors serving equipment spaces not required to be accessible in accordance with Section 1103.2.9 and serving an occupant load of five or less shall be permitted to have a landing on one side to be not more than 175 mm above or below the landing on the egress side of the door.	CONDITIONAL	1047	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0181	Section 1010.1.4	Floor elevation	Exception item 4. Variations in elevation due to differences in finish materials, but not more than 12.5 mm.	Sl: 12.5 mm	max	Per Section 1010.1.4 (Floor elevation).	## Exceptions: 1. At doors serving individual dwelling units or sleeping units in Groups R-2 and R-3 a door is permitted to open at the top step of an interior flight of stairs, provided the door does not swing over the top step. 2. At exterior doors serving Groups F, H, R-2 and S and where such doors are not part of an accessible route, the landing at an exterior door shall not be more than 175 mm below the landing on the egress side of the door, provided the door, other than an exterior storm or screen door, does not swing over the landing. 3. At exterior doors serving Group U and individual dwelling units and sleeping units in Groups R-2 and R-3, and where such units are not required to be Accessible units, Type A units or Type B units, the landing at an exterior doorway shall be not more than 200 mm below the landing on the egress side of the door. Such doors, including storm or screen doors, shall be permitted to swing over either landing. 4. Variations in elevation due to differences in finish materials, but not more than 12.5 mm. 5. Exterior decks, patios or balconies that are part of Type B dwelling units or sleeping units, that have impervious surfaces and that are not more than 100 mm below the finished floor level of the adjacent interior space of the dwelling unit or sleeping unit. 6. Doors serving equipment spaces not required to be accessible in accordance with Section 1103.2.9 and serving an occupant load of five or less shall be permitted to have a landing on one side to be not more than 175 mm above or below the landing on the egress side of the door.	CONDITIONAL	1047	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0182	Section 1010.1.4	Floor elevation	Exception item 5. Exterior decks, patios or balconies that are part of Type B dwelling units or sleeping units, that have impervious surfaces and that are not more than 100 mm below the finished floor level of the adjacent interior space of the dwelling unit or sleeping unit.	Sl: 100 mm	max	Per Section 1010.1.4 (Floor elevation).	## Exceptions: 1. At doors serving individual dwelling units or sleeping units in Groups R-2 and R-3 a door is permitted to open at the top step of an interior flight of stairs, provided the door does not swing over the top step. 2. At exterior doors serving Groups F, H, R-2 and S and where such doors are not part of an accessible route, the landing at an exterior door shall not be more than 175 mm below the landing on the egress side of the door, provided the door, other than an exterior storm or screen door, does not swing over the landing. 3. At exterior doors serving Group U and individual dwelling units and sleeping units in Groups R-2 and R-3, and where such units are not required to be Accessible units, Type A units or Type B units, the landing at an exterior doorway shall be not more than 200 mm below the landing on the egress side of the door. Such doors, including storm or screen doors, shall be permitted to swing over either landing. 4. Variations in elevation due to differences in finish materials, but not more than 12.5 mm. 5. Exterior decks, patios or balconies that are part of Type B dwelling units or sleeping units, that have impervious surfaces and that are not more than 100 mm below the finished floor level of the adjacent interior space of the dwelling unit or sleeping unit. 6. Doors serving equipment spaces not required to be accessible in accordance with Section 1103.2.9 and serving an occupant load of five or less shall be permitted to have a landing on one side to be not more than 175 mm above or below the landing on the egress side of the door.	CONDITIONAL	1047	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0183	Section 1010.1.4	Floor elevation	Exception item 6. Doors serving equipment spaces not required to be accessible in accordance with Section 1103.2.9 and serving an occupant load of five or less shall be permitted to have a landing on one side to be not more than 175 mm above or below the landing on the egress side of the door.	Sl: one side; 175 mm	max	Per Section 1010.1.4 (Floor elevation).	## Exceptions: 1. At doors serving individual dwelling units or sleeping units in Groups R-2 and R-3 a door is permitted to open at the top step of an interior flight of stairs, provided the door does not swing over the top step. 2. At exterior doors serving Groups F, H, R-2 and S and where such doors are not part of an accessible route, the landing at an exterior door shall not be more than 175 mm below the landing on the egress side of the door, provided the door, other than an exterior storm or screen door, does not swing over the landing. 3. At exterior doors serving Group U and individual dwelling units and sleeping units in Groups R-2 and R-3, and where such units are not required to be Accessible units, Type A units or Type B units, the landing at an exterior doorway shall be not more than 200 mm below the landing on the egress side of the door. Such doors, including storm or screen doors, shall be permitted to swing over either landing. 4. Variations in elevation due to differences in finish materials, but not more than 12.5 mm. 5. Exterior decks, patios or balconies that are part of Type B dwelling units or sleeping units, that have impervious surfaces and that are not more than 100 mm below the finished floor level of the adjacent interior space of the dwelling unit or sleeping unit. 6. Doors serving equipment spaces not required to be accessible in accordance with Section 1103.2.9 and serving an occupant load of five or less shall be permitted to have a landing on one side to be not more than 175 mm above or below the landing on the egress side of the door.	CONDITIONAL	1047	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0184	Section 1010.1.4	Floor elevation	Landings shall be level except for exterior landings, which are permitted to have a slope not to exceed 0.25-unit vertical in 12 units horizontal (2-percent slope).	Sl: 0.25-unit vertical in 12 units horizontal; 2-percent	trigger	Per Section 1010.1.4 (Floor elevation).	## Exceptions: 1. At doors serving individual dwelling units or sleeping units in Groups R-2 and R-3 a door is permitted to open at the top step of an interior flight of stairs, provided the door does not swing over the top step. 2. At exterior doors serving Groups F, H, R-2 and S and where such doors are not part of an accessible route, the landing at an exterior door shall not be more than 175 mm below the landing on the egress side of the door, provided the door, other than an exterior storm or screen door, does not swing over the landing. 3. At exterior doors serving Group U and individual dwelling units and sleeping units in Groups R-2 and R-3, and where such units are not required to be Accessible units, Type A units or Type B units, the landing at an exterior doorway shall be not more than 200 mm below the landing on the egress side of the door. Such doors, including storm or screen doors, shall be permitted to swing over either landing. 4. Variations in elevation due to differences in finish materials, but not more than 12.5 mm. 5. Exterior decks, patios or balconies that are part of Type B dwelling units or sleeping units, that have impervious surfaces and that are not more than 100 mm below the finished floor level of the adjacent interior space of the dwelling unit or sleeping unit. 6. Doors serving equipment spaces not required to be accessible in accordance with Section 1103.2.9 and serving an occupant load of five or less shall be permitted to have a landing on one side to be not more than 175 mm above or below the landing on the egress side of the door.	DIRECT	1047	Verified
CH10-0185	Section 1010.1.5	Landings at doors	Doors in the fully open position shall not reduce a required dimension by more than 175 mm.	Sl: 175 mm	min	Per Section 1010.1.5 (Landings at doors).	Exception: Landing length in the direction of travel in Groups R-3 and U and within individual units of Group R-2 need not exceed 900 mm.	DIRECT	1048	Verified
CH10-0186	Section 1010.1.5	Landings at doors	Exception: Landing length in the direction of travel in Groups R-3 and U and within individual units of Group R-2 need not exceed 900 mm.	Sl: 900 mm	max	Per Section 1010.1.5 (Landings at doors).	Exception: Landing length in the direction of travel in Groups R-3 and U and within individual units of Group R-2 need not exceed 900 mm.	CONDITIONAL	1048	Verified
CH10-0187	Section 1010.1.5	Landings at doors	Landings shall have a length measured in the direction of travel of not less than 1100 mm.	Sl: 1100 mm	min	Per Section 1010.1.5 (Landings at doors).	Exception: Landing length in the direction of travel in Groups R-3 and U and within individual units of Group R-2 need not exceed 900 mm.	DIRECT	1048	Verified
CH10-0188	Section 1010.1.5	Landings at doors	Where a landing serves an occupant load of 50 or more, doors in any position shall not reduce the landing to less than one-half its required width.	Sl: occupant load of 50; one-half	formula	Per Section 1010.1.5 (Landings at doors).	Exception: Landing length in the direction of travel in Groups R-3 and U and within individual units of Group R-2 need not exceed 900 mm.	DIRECT	1048	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0189	Section 1010.1.6	Thresholds	Exception item 1. In occupancy Group R-2 or R-3, threshold heights for sliding and side-hinged exterior doors shall be permitted to be up to 200 mm in height if all of the following apply:	Sl: 200 mm	max	Per Section 1010.1.6 (Thresholds).	Exceptions: 1. In occupancy Group R-2 or R-3, threshold heights for sliding and side-hinged exterior doors shall be permitted to be up to 200 mm in height if all of the following apply: 1.1. The door is not part of the required means of egress. 1.2. The door is not part of an accessible route as required by Chapter 11. 1.3. The door is not part of an Accessible unit, Type A unit or Type B unit. 2. In Type B units, where Exception 5 to Section 1010.1.4 permits a 100 mm elevation change at the door, the threshold height on the exterior side of the door shall not exceed 120 mm in height above the exterior deck, patio or balcony for sliding doors or 115 mm above the exterior deck, patio or balcony for other doors.	CONDITIONAL	1048	Verified
CH10-0190	Section 1010.1.6	Thresholds	Exception item 2. In Type B units, where Exception 5 to Section 1010.1.4 permits a 100 mm elevation change at the door, the threshold height on the exterior side of the door shall not exceed 120 mm in height above the exterior deck, patio or balcony for sliding doors or 115 mm above the exterior deck, patio or balcony for other doors.	Sl: 100 mm; 120 mm; 115 mm	max	Per Section 1010.1.6 (Thresholds).	Exceptions: 1. In occupancy Group R-2 or R-3, threshold heights for sliding and side-hinged exterior doors shall be permitted to be up to 200 mm in height if all of the following apply: 1.1. The door is not part of the required means of egress. 1.2. The door is not part of an accessible route as required by Chapter 11. 1.3. The door is not part of an Accessible unit, Type A unit or Type B unit. 2. In Type B units, where Exception 5 to Section 1010.1.4 permits a 100 mm elevation change at the door, the threshold height on the exterior side of the door shall not exceed 120 mm in height above the exterior deck, patio or balcony for sliding doors or 115 mm above the exterior deck, patio or balcony for other doors.	CONDITIONAL	1048	Verified
CH10-0191	Section 1010.1.6	Thresholds	Raised thresholds and floor level changes greater than 6 mm at doorways shall be beveled with a slope not greater than one unit vertical in two units horizontal (50-percent slope).	Sl: 6 mm; 50-percent; one unit vertical in two units horizontal	mixed	Per Section 1010.1.6 (Thresholds).	Exceptions: 1. In occupancy Group R-2 or R-3, threshold heights for sliding and side-hinged exterior doors shall be permitted to be up to 200 mm in height if all of the following apply: 1.1. The door is not part of the required means of egress. 1.2. The door is not part of an accessible route as required by Chapter 11. 1.3. The door is not part of an Accessible unit, Type A unit or Type B unit. 2. In Type B units, where Exception 5 to Section 1010.1.4 permits a 100 mm elevation change at the door, the threshold height on the exterior side of the door shall not exceed 120 mm in height above the exterior deck, patio or balcony for sliding doors or 115 mm above the exterior deck, patio or balcony for other doors.	DIRECT	1048	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0192	Section 1010.1.6	Thresholds	Thresholds at doorways shall not exceed 20 mm in height above the finished floor or landing for sliding doors serving dwelling units or 12.5 mm above the finished floor or landing for other doors.	Sl: 20 mm; 12.5 mm	max	Per Section 1010.1.6 (Thresholds).	Exceptions: 1. In occupancy Group R-2 or R-3, threshold heights for sliding and side-hinged exterior doors shall be permitted to be up to 200 mm in height if all of the following apply: 1.1. The door is not part of the required means of egress. 1.2. The door is not part of an accessible route as required by Chapter 11. 1.3. The door is not part of an Accessible unit, Type A unit or Type B unit. 2. In Type B units, where Exception 5 to Section 1010.1.4 permits a 100 mm elevation change at the door, the threshold height on the exterior side of the door shall not exceed 120 mm in height above the exterior deck, patio or balcony for sliding doors or 115 mm above the exterior deck, patio or balcony for other doors.	DIRECT	1048	Verified
CH10-0193	Section Unnumbered — commentary indicates 1010.1.7	Door arrangement	Space between two doors in a series shall be 1200 mm minimum plus the width of a door swinging into the space.	Sl: 1200 mm; width of door swinging into the space; two doors	min	Two doors in series.	None stated in inventory	CONDITIONAL	1049	Verify source
CH10-0194	Section Unnumbered — commentary indicates 1010.1.7	Door arrangement — horizontal sliding power doors	Exception 1. The minimum distance between horizontal sliding power-operated doors in a series shall be 1200 mm.	Sl: 1200 mm	min	Horizontal sliding power-operated doors in series.	None stated in inventory	CONDITIONAL	1049	Verify source
CH10-0195	Section Unnumbered — commentary indicates 1010.1.7	Door arrangement — dwelling-unit storm and screen doors	Exception 2. Storm and screen doors serving individual dwelling units in Groups R-2 and R-3 need not be spaced 1200 mm from the other door.	Sl: 1200 mm spacing exception	exception	Storm and screen doors serving individual Group R-2 and R-3 dwelling units.	None stated in inventory	CONDITIONAL	1049	Verify source
CH10-0196	Section 1010.2.1	Unlatching	The unlatching of any door or leaf for egress shall require not more than one motion in a single linear or rotational direction to release all latching and all locking devices.	Sl: one motion	max	Per Section 1010.2.1 (Unlatching).	Exceptions: 1. Places of detention or restraint. 2. Where manually operated bolt locks are permitted by Section 1010.2.5. 3. Doors with automatic flush bolts as permitted by Section 1010.2.4, Item 4. 4. Doors from individual dwelling units and sleeping units of Group R occupancies as permitted by Section 1010.2.4, Item 5.	CONDITIONAL	1050	Verified
CH10-0197	Section 1010.2.3	Hardware height	Door handles, pulls, latches, locks and other operating devices shall be installed 850 mm minimum and 1200 mm maximum above the finished floor.	Sl: 850 mm; 1200 mm	range	Per Section 1010.2.3 (Hardware height).	Exception: Access doors or gates in barrier walls and fences protecting pools, spas and hot tubs shall be permitted to have operable parts of the release of latch on self-latching devices at 1350 mm maximum above the finished floor or ground, provided that the self-latching devices are not also self-locking devices operated by means of a key, electronic opener or integral combination lock.	CONDITIONAL	1051	Verified
CH10-0198	Section 1010.2.3	Hardware height	Exception: Access doors or gates in barrier walls and fences protecting pools, spas and hot tubs shall be permitted to have operable parts of the release of latch on self-latching devices at 1350 mm maximum above the finished floor or ground, provided that the self-latching devices are not also self-locking devices operated by means of a key, electronic opener or integral combination lock.	Sl: 1350 mm	max	Per Section 1010.2.3 (Hardware height).	Exception: Access doors or gates in barrier walls and fences protecting pools, spas and hot tubs shall be permitted to have operable parts of the release of latch on self-latching devices at 1350 mm maximum above the finished floor or ground, provided that the self-latching devices are not also self-locking devices operated by means of a key, electronic opener or integral combination lock.	CONDITIONAL	1051	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0199	Section 1010.2.4	Locks and latches	Item 3 In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M and S the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided:	Sl: occupant load of 300	trigger	Per Section 1010.2.4 (Locks and latches).	1 Places of detention or restraint. 2 In Group I-1, Condition 2 and Group I-2 occupancies where the clinical needs of persons receiving care require containment or where persons receiving care pose a security threat, provided that all clinical staff can readily unlock doors at all times, and all such locks are keyed to keys carried by all clinical staff at all times or all clinical staff have the codes or other means necessary to operate the locks at all times. 3 In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M and S the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided: 3.1 The locking device is readily distinguishable as locked. 3.2 A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED. The sign shall be in letters 25 mm high on a contrasting background. 3.3 The use of the key-operated locking device is revokable by the building official for due cause. 4 Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts does not have a doorknob or surface-mounted hardware. 5 Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt or security chain, provided such devices are openable from the inside without the use of a key or tool. 6 Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures. 7 Doors serving roofs not intended to be occupied shall be permitted to be locked preventing entry to the building from the roof. 8 Other than egress courts, where occupants must egress from an exterior space through the building for means of egress, exit access doors shall be permitted to be equipped with an approved locking device where installed and operated in accordance with all of the following: 8.1 The maximum occupant load shall be posted where required by Section 1004.9. Such signage shall be permanently affixed inside the building and shall be posted in a conspicuous space near all the exit access doorways. 8.2 A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side. 8.3 The egress door locking device is readily distinguishable as locked and shall be a key-operated locking device. 8.4 A clear window or glazed door opening, not less than 0.46 m (²) in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area. 8.5 A readily visible, durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating, "THIS DOOR TO REMAIN UNLOCKED	CONDITIONAL	1052	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
							WHEN THE OUTDOOR AREA IS OCCUPIED." The letters on the sign shall be not less than 25 mm high on a contrasting background. 8.6 The occupant load of the occupied exterior area shall not exceed 300 occupants in accordance with Section 1004. 9 Locking devices are permitted on doors to balconies, decks or other exterior spaces serving individual dwelling or sleeping units. 10 Locking devices are permitted on doors to balconies, decks or other exterior spaces of (23 \, m^{2}) or less serving a private office space.			

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0200	Section 1010.2.4	Locks and latches	Item 3.2 A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED. The sign shall be in letters 25 mm high on a contrasting background.	Sl: 25 mm	trigger	Per Section 1010.2.4 (Locks and latches).	1 Places of detention or restraint. 2 In Group I-1, Condition 2 and Group I-2 occupancies where the clinical needs of persons receiving care require containment or where persons receiving care pose a security threat, provided that all clinical staff can readily unlock doors at all times, and all such locks are keyed to keys carried by all clinical staff at all times or all clinical staff have the codes or other means necessary to operate the locks at all times. 3 In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M and S the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided: 3.1 The locking device is readily distinguishable as locked. 3.2 A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED. The sign shall be in letters 25 mm high on a contrasting background. 3.3 The use of the key-operated locking device is revokable by the building official for due cause. 4 Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts does not have a doorknob or surface-mounted hardware. 5 Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt or security chain, provided such devices are openable from the inside without the use of a key or tool. 6 Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures. 7 Doors serving roofs not intended to be occupied shall be permitted to be locked preventing entry to the building from the roof. 8 Other than egress courts, where occupants must egress from an exterior space through the building for means of egress, exit access doors shall be permitted to be equipped with an approved locking device where installed and operated in accordance with all of the following: 8.1 The maximum occupant load shall be posted where required by Section 1004.9. Such signage shall be permanently affixed inside the building and shall be posted in a conspicuous space near all the exit access doorways. 8.2 A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side. 8.3 The egress door locking device is readily distinguishable as locked and shall be a key-operated locking device. 8.4 A clear window or glazed door opening, not less than 0.46 m (¹ / ₂) in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area. 8.5 A readily visible, durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating, "THIS DOOR TO REMAIN UNLOCKED	CONDITIONAL	1052	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
							WHEN THE OUTDOOR AREA IS OCCUPIED." The letters on the sign shall be not less than 25 mm high on a contrasting background. 8.6 The occupant load of the occupied exterior area shall not exceed 300 occupants in accordance with Section 1004. 9 Locking devices are permitted on doors to balconies, decks or other exterior spaces serving individual dwelling or sleeping units. 10 Locking devices are permitted on doors to balconies, decks or other exterior spaces of (23 \, m^{2}) or less serving a private office space.			

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0201	Section 1010.2.4	Locks and latches	Item 5 Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt or security chain, provided such devices are openable from the inside without the use of a key or tool.	Sl: occupant load of 10	trigger	Per Section 1010.2.4 (Locks and latches).	1 Places of detention or restraint. 2 In Group I-1, Condition 2 and Group I-2 occupancies where the clinical needs of persons receiving care require containment or where persons receiving care pose a security threat, provided that all clinical staff can readily unlock doors at all times, and all such locks are keyed to keys carried by all clinical staff at all times or all clinical staff have the codes or other means necessary to operate the locks at all times. 3 In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M and S the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided: 3.1 The locking device is readily distinguishable as locked. 3.2 A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED. The sign shall be in letters 25 mm high on a contrasting background. 3.3 The use of the key-operated locking device is revokable by the building official for due cause. 4 Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts does not have a doorknob or surface-mounted hardware. 5 Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt or security chain, provided such devices are openable from the inside without the use of a key or tool. 6 Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures. 7 Doors serving roofs not intended to be occupied shall be permitted to be locked preventing entry to the building from the roof. 8 Other than egress courts, where occupants must egress from an exterior space through the building for means of egress, exit access doors shall be permitted to be equipped with an approved locking device where installed and operated in accordance with all of the following: 8.1 The maximum occupant load shall be posted where required by Section 1004.9. Such signage shall be permanently affixed inside the building and shall be posted in a conspicuous space near all the exit access doorways. 8.2 A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side. 8.3 The egress door locking device is readily distinguishable as locked and shall be a key-operated locking device. 8.4 A clear window or glazed door opening, not less than 0.46 m (¹ / ₂) in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area. 8.5 A readily visible, durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating, "THIS DOOR TO REMAIN UNLOCKED	CONDITIONAL	1052	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
							WHEN THE OUTDOOR AREA IS OCCUPIED." The letters on the sign shall be not less than 25 mm high on a contrasting background. 8.6 The occupant load of the occupied exterior area shall not exceed 300 occupants in accordance with Section 1004. 9 Locking devices are permitted on doors to balconies, decks or other exterior spaces serving individual dwelling or sleeping units. 10 Locking devices are permitted on doors to balconies, decks or other exterior spaces of (23 \, m^{2}) or less serving a private office space.			

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0202	Section 1010.2.4	Locks and latches	Item 8.2 A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side.	Sl: one required exit	min	Per Section 1010.2.4 (Locks and latches).	1 Places of detention or restraint. 2 In Group I-1, Condition 2 and Group I-2 occupancies where the clinical needs of persons receiving care require containment or where persons receiving care pose a security threat, provided that all clinical staff can readily unlock doors at all times, and all such locks are keyed to keys carried by all clinical staff at all times or all clinical staff have the codes or other means necessary to operate the locks at all times. 3 In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M and S the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided: 3.1 The locking device is readily distinguishable as locked. 3.2 A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED. The sign shall be in letters 25 mm high on a contrasting background. 3.3 The use of the key-operated locking device is revokable by the building official for due cause. 4 Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts does not have a doorknob or surface-mounted hardware. 5 Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt or security chain, provided such devices are openable from the inside without the use of a key or tool. 6 Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures. 7 Doors serving roofs not intended to be occupied shall be permitted to be locked preventing entry to the building from the roof. 8 Other than egress courts, where occupants must egress from an exterior space through the building for means of egress, exit access doors shall be permitted to be equipped with an approved locking device where installed and operated in accordance with all of the following: 8.1 The maximum occupant load shall be posted where required by Section 1004.9. Such signage shall be permanently affixed inside the building and shall be posted in a conspicuous space near all the exit access doorways. 8.2 A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side. 8.3 The egress door locking device is readily distinguishable as locked and shall be a key-operated locking device. 8.4 A clear window or glazed door opening, not less than 0.46 m (²) in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area. 8.5 A readily visible, durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating, "THIS DOOR TO REMAIN UNLOCKED	CONDITIONAL	1052	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
							WHEN THE OUTDOOR AREA IS OCCUPIED." The letters on the sign shall be not less than 25 mm high on a contrasting background. 8.6 The occupant load of the occupied exterior area shall not exceed 300 occupants in accordance with Section 1004. 9 Locking devices are permitted on doors to balconies, decks or other exterior spaces serving individual dwelling or sleeping units. 10 Locking devices are permitted on doors to balconies, decks or other exterior spaces of (23 \, m^{2}) or less serving a private office space.			

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0203	Section 1010.2.4	Locks and latches	Item 8.4 A clear window or glazed door opening, not less than 0.46 m (^{2}) in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area.	Sl: 0.46 m²	min	Per Section 1010.2.4 (Locks and latches).	1 Places of detention or restraint. 2 In Group I-1, Condition 2 and Group I-2 occupancies where the clinical needs of persons receiving care require containment or where persons receiving care pose a security threat, provided that all clinical staff can readily unlock doors at all times, and all such locks are keyed to keys carried by all clinical staff at all times or all clinical staff have the codes or other means necessary to operate the locks at all times. 3 In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M and S the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided: 3.1 The locking device is readily distinguishable as locked. 3.2 A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED. The sign shall be in letters 25 mm high on a contrasting background. 3.3 The use of the key-operated locking device is revokable by the building official for due cause. 4 Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts does not have a doorknob or surface-mounted hardware. 5 Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt or security chain, provided such devices are openable from the inside without the use of a key or tool. 6 Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures. 7 Doors serving roofs not intended to be occupied shall be permitted to be locked preventing entry to the building from the roof. 8 Other than egress courts, where occupants must egress from an exterior space through the building for means of egress, exit access doors shall be permitted to be equipped with an approved locking device where installed and operated in accordance with all of the following: 8.1 The maximum occupant load shall be posted where required by Section 1004.9. Such signage shall be permanently affixed inside the building and shall be posted in a conspicuous space near all the exit access doorways. 8.2 A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side. 8.3 The egress door locking device is readily distinguishable as locked and shall be a key-operated locking device. 8.4 A clear window or glazed door opening, not less than 0.46 m (^{2}) in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area. 8.5 A readily visible, durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating, "THIS DOOR TO REMAIN UNLOCKED	CONDITIONAL	1052	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
							WHEN THE OUTDOOR AREA IS OCCUPIED." The letters on the sign shall be not less than 25 mm high on a contrasting background. 8.6 The occupant load of the occupied exterior area shall not exceed 300 occupants in accordance with Section 1004. 9 Locking devices are permitted on doors to balconies, decks or other exterior spaces serving individual dwelling or sleeping units. 10 Locking devices are permitted on doors to balconies, decks or other exterior spaces of (23 \, m^{2}) or less serving a private office space.			

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0204	Section 1010.2.4	Locks and latches	Item 8.5 A readily visible, durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating, "THIS DOOR TO REMAIN UNLOCKED WHEN THE OUTDOOR AREA IS OCCUPIED." The letters on the sign shall be not less than 25 mm high on a contrasting background.	Sl: 25 mm	min	Per Section 1010.2.4 (Locks and latches).	1 Places of detention or restraint. 2 In Group I-1, Condition 2 and Group I-2 occupancies where the clinical needs of persons receiving care require containment or where persons receiving care pose a security threat, provided that all clinical staff can readily unlock doors at all times, and all such locks are keyed to keys carried by all clinical staff at all times or all clinical staff have the codes or other means necessary to operate the locks at all times. 3 In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M and S the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided: 3.1 The locking device is readily distinguishable as locked. 3.2 A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED. The sign shall be in letters 25 mm high on a contrasting background. 3.3 The use of the key-operated locking device is revokable by the building official for due cause. 4 Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts does not have a doorknob or surface-mounted hardware. 5 Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt or security chain, provided such devices are openable from the inside without the use of a key or tool. 6 Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures. 7 Doors serving roofs not intended to be occupied shall be permitted to be locked preventing entry to the building from the roof. 8 Other than egress courts, where occupants must egress from an exterior space through the building for means of egress, exit access doors shall be permitted to be equipped with an approved locking device where installed and operated in accordance with all of the following: 8.1 The maximum occupant load shall be posted where required by Section 1004.9. Such signage shall be permanently affixed inside the building and shall be posted in a conspicuous space near all the exit access doorways. 8.2 A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side. 8.3 The egress door locking device is readily distinguishable as locked and shall be a key-operated locking device. 8.4 A clear window or glazed door opening, not less than 0.46 m ([^]2) in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area. 8.5 A readily visible, durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating, "THIS DOOR TO REMAIN UNLOCKED	CONDITIONAL	1052	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
							WHEN THE OUTDOOR AREA IS OCCUPIED." The letters on the sign shall be not less than 25 mm high on a contrasting background. 8.6 The occupant load of the occupied exterior area shall not exceed 300 occupants in accordance with Section 1004. 9 Locking devices are permitted on doors to balconies, decks or other exterior spaces serving individual dwelling or sleeping units. 10 Locking devices are permitted on doors to balconies, decks or other exterior spaces of (23 \, m^{2}) or less serving a private office space.			

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0205	Section 1010.2.4	Locks and latches	Item 8.6 The occupant load of the occupied exterior area shall not exceed 300 occupants in accordance with Section 1004.	Sl: 300 occupants	max	Per Section 1010.2.4 (Locks and latches).	1 Places of detention or restraint. 2 In Group I-1, Condition 2 and Group I-2 occupancies where the clinical needs of persons receiving care require containment or where persons receiving care pose a security threat, provided that all clinical staff can readily unlock doors at all times, and all such locks are keyed to keys carried by all clinical staff at all times or all clinical staff have the codes or other means necessary to operate the locks at all times. 3 In buildings in occupancy Group A having an occupant load of 300 or less, Groups B, F, M and S the main door or doors are permitted to be equipped with key-operated locking devices from the egress side provided: 3.1 The locking device is readily distinguishable as locked. 3.2 A readily visible durable sign is posted on the egress side on or adjacent to the door stating: THIS DOOR TO REMAIN UNLOCKED WHEN THIS SPACE IS OCCUPIED. The sign shall be in letters 25 mm high on a contrasting background. 3.3 The use of the key-operated locking device is revokable by the building official for due cause. 4 Where egress doors are used in pairs, approved automatic flush bolts shall be permitted to be used, provided that the door leaf having the automatic flush bolts does not have a doorknob or surface-mounted hardware. 5 Doors from individual dwelling or sleeping units of Group R occupancies having an occupant load of 10 or less are permitted to be equipped with a night latch, dead bolt or security chain, provided such devices are openable from the inside without the use of a key or tool. 6 Fire doors after the minimum elevated temperature has disabled the unlatching mechanism in accordance with listed fire door test procedures. 7 Doors serving roofs not intended to be occupied shall be permitted to be locked preventing entry to the building from the roof. 8 Other than egress courts, where occupants must egress from an exterior space through the building for means of egress, exit access doors shall be permitted to be equipped with an approved locking device where installed and operated in accordance with all of the following: 8.1 The maximum occupant load shall be posted where required by Section 1004.9. Such signage shall be permanently affixed inside the building and shall be posted in a conspicuous space near all the exit access doorways. 8.2 A weatherproof telephone or two-way communication system installed in accordance with Sections 1009.8.1 and 1009.8.2 shall be located adjacent to not less than one required exit access door on the exterior side. 8.3 The egress door locking device is readily distinguishable as locked and shall be a key-operated locking device. 8.4 A clear window or glazed door opening, not less than 0.46 m (²) in area, shall be provided at each exit access door to determine if there are occupants using the outdoor area. 8.5 A readily visible, durable sign shall be posted on the interior side on or adjacent to each locked required exit access door serving the exterior area stating, "THIS DOOR TO REMAIN UNLOCKED	CONDITIONAL	1052	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
							WHEN THE OUTDOOR AREA IS OCCUPIED." The letters on the sign shall be not less than 25 mm high on a contrasting background. 8.6 The occupant load of the occupied exterior area shall not exceed 300 occupants in accordance with Section 1004. 9 Locking devices are permitted on doors to balconies, decks or other exterior spaces serving individual dwelling or sleeping units. 10 Locking devices are permitted on doors to balconies, decks or other exterior spaces of (23 \, m^{2}) or less serving a private office space.			
CH10-0206	Section 1010.2.5	Bolt locks	Exception item 3. Where a pair of doors serves an occupant load of less than 50 persons in a Group B, F or S occupancy, manually operated edge-or surface-mounted bolts are permitted on the inactive leaf. The inactive leaf shall not contain doorknobs, panic bars or similar operating hardware.	Sl: 50 persons	max	Per Section 1010.2.5 (Bolt locks).	## Exceptions: 1. On doors not required for egress in individual dwelling units or sleeping units. 2. Where a pair of doors serves a storage or equipment room, manually operated edge-or surface-mounted bolts are permitted on the inactive leaf. 3. Where a pair of doors serves an occupant load of less than 50 persons in a Group B, F or S occupancy, manually operated edge-or surface-mounted bolts are permitted on the inactive leaf. The inactive leaf shall not contain doorknobs, panic bars or similar operating hardware. 4. Where a pair of doors serves a Group B, F or S occupancy, manually operated edge-	CONDITIONAL	1053	Verified
CH10-0207	Section 1010.2.9	Panic and fire exit hardware	Swinging doors serving a Group H occupancy and swinging doors serving rooms or spaces with an occupant load of 50 or more in a Group A or E occupancy shall not be provided with a latch or lock other than panic hardware or fire exit hardware.	Sl: occupant load of 50	min	Per Section 1010.2.9 (Panic and fire exit hardware).	Exceptions: 1. A main exit of a Group A occupancy shall be permitted to have locking devices in accordance with Section 1010.2.4, Item 3. 2. Doors provided with panic hardware or fire exit hardware and serving a Group A or E occupancy shall be permitted to be electrically locked in accordance with Section 1010.2.11 or 1010.2.12. 3. Exit access doors serving occupied exterior areas shall be permitted to be locked in accordance with Section 1010.2.4, Item 8. 4. Courtrooms shall be permitted to be locked in accordance with Section 1010.2.13, Item 3.	CONDITIONAL	1056	Verified
CH10-0208	Section 1010.2.9.1	Refrigeration machinery room	Refrigeration machinery rooms larger than 100 m (^{2}) shall have not less than two exit or exit access doorways that swing in the direction of egress travel and shall be equipped with panic hardware or fire exit hardware.	Sl: 100 m²; two exit	min	Per Section 1010.2.9.1 (Refrigeration machinery room).	None stated in inventory	CONDITIONAL	1057	Verified
CH10-0209	Section 1010.2.9.2	Rooms with electrical equipment	Rooms containing electrical equipment rated 800 amperes or more that contain overcurrent devices, switching devices or control devices and where the exit or exit access door is less than 7.5 m from the equipment working space as required by NFPA 70 (or its equivalent in SBC 401), such doors shall not be provided with a latch or lock other than panic hardware or fire exit hardware.	Sl: 7.5 m; 800 amperes	mixed	Per Section 1010.2.9.2 (Rooms with electrical equipment).	None stated in inventory	CONDITIONAL	1057	Verified
CH10-0210	Section 1010.2.9.3	Installation	Item 3 The actuating portion of the releasing device shall extend not less than one-half of the door leaf width.	Sl: one-half	formula	Per Section 1010.2.9.3 (Installation).	1 Panic hardware shall be listed in accordance with UL 305. 2 Fire exit hardware shall be listed in accordance with UL 10C and UL 305. 3 The actuating portion of the releasing device shall extend not less than one-half of the door leaf width. 4 The maximum unlatching force shall not exceed 67 N.	DIRECT	1057	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0211	Section 1010.2.9.3	Installation	Item 4 The maximum unlatching force shall not exceed 67 N.	Sl: 67 N	max	Per Section 1010.2.9.3 (Installation).	1 Panic hardware shall be listed in accordance with UL 305. 2 Fire exit hardware shall be listed in accordance with UL 10C and UL 305. 3 The actuating portion of the releasing device shall extend not less than one-half of the door leaf width. 4 The maximum unlatching force shall not exceed 67 N.	DIRECT	1057	Verified
CH10-0212	Section 1010.2.9.4	Balanced doors	If balanced doors are used and panic hardware is required, the panic hardware shall be the push-pad type and the pad shall not extend more than one-half the width of the door measured from the latch side.	Sl: one-half	formula	Per Section 1010.2.9.4 (Balanced doors).	None stated in inventory	CONDITIONAL	1059	Verified
CH10-0213	Section 1010.2.11	Door-hardware release of electrically locked egress doors	Item 2 The door hardware shall be capable of being operated with one hand and shall comply with Section 1010.2.1.	Sl: one hand	max	Door-hardware release electric locking system; any occupancy except Group H.	None stated in inventory	CONDITIONAL	1059	Verified
CH10-0214	Section 1010.2.12	Sensor release of electrically locked egress doors	Item 4 The doors shall be arranged to unlock from a manual unlocking device located 1000 mm to 1200 mm vertically above the floor and within 1500 mm of the secured doors. Ready access shall be provided to the manual unlocking device and the device shall be clearly identified by a sign that reads "PUSH TO EXIT." When operated, the manual unlocking device shall result in direct interruption of power to the electric lock—independent of other electronics—and the electric lock shall remain unlocked for not less than 30 seconds.	Sl: 1000 mm; 1200 mm; 1500 mm; 30 seconds	mixed	Per Section 1010.2.12 (Sensor release of electrically locked egress doors).	1 The sensor shall be installed on the egress side, arranged to detect an occupant approaching the doors, and shall cause the electric locking system to unlock. 2 The electric locks shall be arranged to unlock by a signal from or loss of power to the sensor. 3 Loss of power to the lock or locking system shall automatically unlock the electric locks. 4 The doors shall be arranged to unlock from a manual unlocking device located 1000 mm to 1200 mm vertically above the floor and within 1500 mm of the secured doors. Ready access shall be provided to the manual unlocking device and the device shall be clearly identified by a sign that reads "PUSH TO EXIT." When operated, the manual unlocking device shall result in direct interruption of power to the electric lock—independent of other electronics—and the electric lock shall remain unlocked for not less than 30 seconds. 5 Activation of the building fire alarm system, where provided, shall automatically unlock the electric lock. The electric lock shall remain unlocked until the fire alarm system has been reset. 6 Activation of the building automatic sprinkler system or fire detection system, where provided, shall automatically unlock the electric lock. The electric lock shall remain unlocked until the fire alarm system has been reset. 7 Emergency lighting shall be provided on the egress side of the door. 8 The door locking system units shall be listed in accordance with UL 294.	CONDITIONAL	1060	Verified
CH10-0215	Section 1010.2.13	Delayed egress — Group E classroom limit	Item 2 Delayed egress locking systems are permitted for Group E classrooms with an occupant load of less than 50 where the Section 1010.2.13 system prerequisites are satisfied.	Sl: occupant load less than 50	max	Group E classrooms using delayed egress.	None stated in inventory	NOT_TYPICAL	1062	Verified
CH10-0216	Section 1010.2.13.1	Delayed egress — release timing	Item 4 An attempt to egress shall initiate an irreversible process allowing egress in not more than 15 seconds when physical effort is applied to the egress-side door hardware for not more than 3 seconds.	Sl: 15 seconds; 3 seconds	max	Delayed egress locking system.	None stated in inventory	CONDITIONAL	1063	Verified
CH10-0217	Section 1010.2.13.1	Delayed egress — approved extended delay	Exception to Item 4. Where approved, a delay of not more than 30 seconds is permitted on a delayed egress door.	Sl: 30 seconds	max	Approved delayed egress door.	None stated in inventory	CONDITIONAL	1063	Verified
CH10-0218	Section 1010.2.13.1	Delayed egress — number of systems	Item 5 The egress path from any point shall not pass through more than one delayed egress locking system.	Sl: one delayed egress locking system	max	General delayed egress path.	None stated in inventory	CONDITIONAL	1063	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0219	Section 1010.2.13.1	Delayed egress — institutional exception 1	Exception 1 to Item 5. In Group I-1 Condition 2, Group I-2 or I-3 occupancies, the egress path shall pass through not more than two delayed egress locking systems, with a combined delay not exceeding 30 seconds.	Sl: two delayed egress locking systems; combined delay 30 seconds	max	Group I-1 Condition 2, Group I-2 or I-3.	None stated in inventory	NOT_TYPICAL	1063	Verified
CH10-0220	Section 1010.2.13.1	Delayed egress — institutional exception 2	Exception 2 to Item 5. In Group I-1 Condition 1 or Group I-4 occupancies, the egress path shall pass through not more than two delayed egress locking systems, with a combined delay not exceeding 30 seconds, where the building is sprinklered throughout under Section 903.3.1.1.	Sl: two delayed egress locking systems; combined delay 30 seconds	max	Group I-1 Condition 1 or Group I-4; Section 903.3.1.1 sprinklers throughout.	None stated in inventory	NOT_TYPICAL	1063	Verified
CH10-0221	Section 1010.2.13.1	Delayed egress — sign location	Item 6 A sign shall be provided on the door above and within 300 mm of the door exit hardware.	Sl: within 300 mm	max	Delayed egress door sign.	None stated in inventory	CONDITIONAL	1063	Verified
CH10-0222	Section 1010.2.13.1	Delayed egress — push-door sign	Item 6.1 For doors swinging in the direction of egress, the sign shall read: PUSH UNTIL ALARM SOUNDS. DOOR CAN BE OPENED IN 15 [30] SECONDS.	Sl: 15 seconds; 30 seconds	instruction	Delayed egress door swinging in direction of egress.	None stated in inventory	CONDITIONAL	1063	Verified
CH10-0223	Section 1010.2.13.1	Delayed egress — pull-door sign	Item 6.2 For doors swinging opposite the direction of egress, the sign shall read: PULL UNTIL ALARM SOUNDS. DOOR CAN BE OPENED IN 15 [30] SECONDS.	Sl: 15 seconds; 30 seconds	instruction	Delayed egress door swinging opposite direction of egress.	None stated in inventory	CONDITIONAL	1063	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0224	Section 1010.2.14	Controlled egress doors in Groups I-1 and I-2	Exception item 4 A building occupant shall not be required to pass through more than one door equipped with a controlled egress locking system before entering an exit.	Sl: one door	max	Per Section 1010.2.14 (Controlled egress doors in Groups I-1 and I-2).	1 The door locks shall unlock on actuation of the automatic sprinkler system or automatic smoke detection system. 2 The door locks shall unlock on loss of power controlling the lock or lock mechanism. 3 The door locking system shall be installed to have the capability of being unlocked by a switch located at the fire command center, a nursing station or other approved location. The switch shall directly break power to the lock. 4 A building occupant shall not be required to pass through more than one door equipped with a controlled egress locking system before entering an exit. 5 The procedures for unlocking the doors shall be described and approved as part of the emergency planning and preparedness required by Chapter 4 of SBC 801. 6 All clinical staff shall have the keys, codes or other means necessary to operate the locking systems. 7 Emergency lighting shall be provided at the door. 8 The door locking system units shall be listed in accordance with UL 294. Exceptions: 1. Items 1 through 4 shall not apply to doors to areas occupied by persons who, because of clinical needs, require restraint or containment as part of the function of a psychiatric or cognitive treatment area. 2. Items 1 through 4 shall not apply to doors to areas where a listed egress control system is utilized to reduce the risk of child abduction from nursery and obstetric areas of a Group I-2 hospital. These provisions are intended to address the special safety needs for wards, units or areas in assisted living facilities, nursing homes and hospitals where egress may need to be controlled for the safety of the occupants or where specialized protective measures are needed for patients. "Controlled egress" means that the ability of occupants, such as patients or residents, to leave a space is controlled by others, such as staff. The areas where controlled egress may be permitted include psychiatric areas, dementia units, Alzheimer's units, maternity units and newborn nurseries. building officials may also permit these provisions in other areas such as emergency departments or pediatric areas where the safety and security of the occupants are of primary concern. In all situations, there must be a balance between maintaining a safe and secure environment and providing for emergency egress.	NOT_TYPICAL	1065	Verified
CH10-0225	Section 1010.2.15	Correctional-facility locking arrangements	Doors with correctional-facility egress control devices shall unlock manually and by not less than one of the three listed means.	Sl: not less than one listed unlocking means; three listed means	min	Correctional and detention facilities.	None stated in inventory	NOT_TYPICAL	1066	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0226	Section 1010.3.1	Revolving doors	Item 2 Each revolving door shall be capable of breakout in accordance with BHMA A156.27 and shall provide an aggregate width of not less than 900 mm.	Sl: 900 mm	min	Per Section 1010.3.1 (Revolving doors).	1 Revolving doors shall comply with BHMA A156.27 and shall be installed in accordance with the manufacturer's instructions. 2 Each revolving door shall be capable of breakout in accordance with BHMA A156.27 and shall provide an aggregate width of not less than 900 mm. 3 A revolving door shall not be located within 3000 mm of the foot or top of stairways or escalators. A dispersal area shall be provided between the stairways or escalators and the revolving doors. 4 The revolutions per minute (rpm) for a revolving door shall not exceed the maximum rpm as specified in BHMA A156.27. Manual revolving doors shall comply with Table 1010.3.1(1). Automatic or power-operated revolving doors shall comply with Table 1010.3.1(2). 5 An emergency stop switch shall be provided near each entry point of power or automatic operated revolving doors within 1200 mm of the door and between 850 mm and 1200 mm above the floor. The activation area of the emergency stop switch button shall be not less than 25 mm in diameter and shall be red. 6 Each revolving door shall have a side-hinged swinging door that complies with Section 1010.1 in the same wall and within 3000 mm of the revolving door. 7 Revolving doors shall not be part of an accessible route required by Section 1009 and Chapter 11.	CONDITIONAL	1066	Verified
CH10-0227	Section 1010.3.1	Revolving doors	Item 3 A revolving door shall not be located within 3000 mm of the foot or top of stairways or escalators. A dispersal area shall be provided between the stairways or escalators and the revolving doors.	Sl: 3000 mm	min	Per Section 1010.3.1 (Revolving doors).	1 Revolving doors shall comply with BHMA A156.27 and shall be installed in accordance with the manufacturer's instructions. 2 Each revolving door shall be capable of breakout in accordance with BHMA A156.27 and shall provide an aggregate width of not less than 900 mm. 3 A revolving door shall not be located within 3000 mm of the foot or top of stairways or escalators. A dispersal area shall be provided between the stairways or escalators and the revolving doors. 4 The revolutions per minute (rpm) for a revolving door shall not exceed the maximum rpm as specified in BHMA A156.27. Manual revolving doors shall comply with Table 1010.3.1(1). Automatic or power-operated revolving doors shall comply with Table 1010.3.1(2). 5 An emergency stop switch shall be provided near each entry point of power or automatic operated revolving doors within 1200 mm of the door and between 850 mm and 1200 mm above the floor. The activation area of the emergency stop switch button shall be not less than 25 mm in diameter and shall be red. 6 Each revolving door shall have a side-hinged swinging door that complies with Section 1010.1 in the same wall and within 3000 mm of the revolving door. 7 Revolving doors shall not be part of an accessible route required by Section 1009 and Chapter 11.	CONDITIONAL	1066	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0228	Section 1010.3.1	Revolving doors	Item 5 An emergency stop switch shall be provided near each entry point of power or automatic operated revolving doors within 1200 mm of the door and between 850 mm and 1200 mm above the floor. The activation area of the emergency stop switch button shall be not less than 25 mm in diameter and shall be red.	Sl: 1200 mm; 850 mm; 25 mm	mixed	Per Section 1010.3.1 (Revolving doors).	1 Revolving doors shall comply with BHMA A156.27 and shall be installed in accordance with the manufacturer's instructions. 2 Each revolving door shall be capable of breakout in accordance with BHMA A156.27 and shall provide an aggregate width of not less than 900 mm. 3 A revolving door shall not be located within 3000 mm of the foot or top of stairways or escalators. A dispersal area shall be provided between the stairways or escalators and the revolving doors. 4 The revolutions per minute (rpm) for a revolving door shall not exceed the maximum rpm as specified in BHMA A156.27. Manual revolving doors shall comply with Table 1010.3.1(1). Automatic or power-operated revolving doors shall comply with Table 1010.3.1(2). 5 An emergency stop switch shall be provided near each entry point of power or automatic operated revolving doors within 1200 mm of the door and between 850 mm and 1200 mm above the floor. The activation area of the emergency stop switch button shall be not less than 25 mm in diameter and shall be red. 6 Each revolving door shall have a side-hinged swinging door that complies with Section 1010.1 in the same wall and within 3000 mm of the revolving door. 7 Revolving doors shall not be part of an accessible route required by Section 1009 and Chapter 11.	CONDITIONAL	1066	Verified
CH10-0229	Section 1010.3.1	Revolving doors	Item 6 Each revolving door shall have a side-hinged swinging door that complies with Section 1010.1 in the same wall and within 3000 mm of the revolving door.	Sl: 3000 mm	trigger	Per Section 1010.3.1 (Revolving doors).	1 Revolving doors shall comply with BHMA A156.27 and shall be installed in accordance with the manufacturer's instructions. 2 Each revolving door shall be capable of breakout in accordance with BHMA A156.27 and shall provide an aggregate width of not less than 900 mm. 3 A revolving door shall not be located within 3000 mm of the foot or top of stairways or escalators. A dispersal area shall be provided between the stairways or escalators and the revolving doors. 4 The revolutions per minute (rpm) for a revolving door shall not exceed the maximum rpm as specified in BHMA A156.27. Manual revolving doors shall comply with Table 1010.3.1(1). Automatic or power-operated revolving doors shall comply with Table 1010.3.1(2). 5 An emergency stop switch shall be provided near each entry point of power or automatic operated revolving doors within 1200 mm of the door and between 850 mm and 1200 mm above the floor. The activation area of the emergency stop switch button shall be not less than 25 mm in diameter and shall be red. 6 Each revolving door shall have a side-hinged swinging door that complies with Section 1010.1 in the same wall and within 3000 mm of the revolving door. 7 Revolving doors shall not be part of an accessible route required by Section 1009 and Chapter 11.	CONDITIONAL	1066	Verified
CH10-0230	Section 1010.3.1.1	Egress component	Item 1 Revolving doors shall not be given credit for more than 50 percent of the minimum width or required capacity.	Sl: 50 percent	min	Per Section 1010.3.1.1 (Egress component).	1 Revolving doors shall not be given credit for more than 50 percent of the minimum width or required capacity. 2 Each revolving door shall be credited with a capacity based on not more than a 50-person occupant load. 3 Each revolving door shall provide for egress in accordance with BHMA A156.27 with a breakout force of not more than 578 N.	CONDITIONAL	1068	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0231	Section 1010.3.1.1	Egress component	Item 2 Each revolving door shall be credited with a capacity based on not more than a 50-person occupant load.	Sl: 50-person occupant load	max	Per Section 1010.3.1.1 (Egress component).	1 Revolving doors shall not be given credit for more than 50 percent of the minimum width or required capacity. 2 Each revolving door shall be credited with a capacity based on not more than a 50-person occupant load. 3 Each revolving door shall provide for egress in accordance with BHMA A156.27 with a breakout force of not more than 578 N.	CONDITIONAL	1068	Verified
CH10-0232	Section 1010.3.1.1	Egress component	Item 3 Each revolving door shall provide for egress in accordance with BHMA A156.27 with a breakout force of not more than 578 N.	Sl: 578 N	max	Per Section 1010.3.1.1 (Egress component).	1 Revolving doors shall not be given credit for more than 50 percent of the minimum width or required capacity. 2 Each revolving door shall be credited with a capacity based on not more than a 50-person occupant load. 3 Each revolving door shall provide for egress in accordance with BHMA A156.27 with a breakout force of not more than 578 N.	CONDITIONAL	1068	Verified
CH10-0233	Table 1010.3.1(1) (appended-table row); Section 1010.3.1(1)	Manual revolving-door speed	A manual revolving door with maximum nominal diameter 1.8 m has maximum allowable speed 12 rpm.	Sl: 1.8 m; 12 rpm	max	Manual revolving doors	None stated in inventory	CONDITIONAL	1179	Verified
CH10-0234	Table 1010.3.1(1) (appended-table row); Section 1010.3.1(1)	Manual revolving-door speed	A manual revolving door with maximum nominal diameter 2.1 m has maximum allowable speed 11 rpm.	Sl: 2.1 m; 11 rpm	max	Manual revolving doors	None stated in inventory	CONDITIONAL	1179	Verified
CH10-0235	Table 1010.3.1(1) (appended-table row); Section 1010.3.1(1)	Manual revolving-door speed	A manual revolving door with maximum nominal diameter 2.4 m has maximum allowable speed 10 rpm.	Sl: 2.4 m; 10 rpm	max	Manual revolving doors	None stated in inventory	CONDITIONAL	1179	Verified
CH10-0236	Table 1010.3.1(1) (appended-table row); Section 1010.3.1(1)	Manual revolving-door speed	A manual revolving door with maximum nominal diameter 2.7 m has maximum allowable speed 9 rpm.	Sl: 2.7 m; 9 rpm	max	Manual revolving doors	None stated in inventory	CONDITIONAL	1179	Verified
CH10-0237	Table 1010.3.1(1) (appended-table row); Section 1010.3.1(1)	Manual revolving-door speed	A manual revolving door with maximum nominal diameter 3 m has maximum allowable speed 8 rpm.	Sl: 3 m; 8 rpm	max	Manual revolving doors	None stated in inventory	CONDITIONAL	1179	Verified
CH10-0238	Section 1010.3.1.2	Other than egress component	Exception item 3 There is an actuation of a smoke detection system that is installed in accordance with Section 907 to provide coverage in areas within the building that are within 23 m of the revolving doors.	Sl: 23 m	trigger	Per Section 1010.3.1.2 (Other than egress component).	Exception: A breakout force in excess of 800 N is permitted if the breakout force is reduced to not more than 578 N when not less than one of the following conditions is satisfied: 1 There is a power failure or power is removed to the device holding the door wings in position. 2 There is an actuation of the automatic sprinkler system where such system is provided. 3 There is an actuation of a smoke detection system that is installed in accordance with Section 907 to provide coverage in areas within the building that are within 23 m of the revolving doors. 4 There is an actuation of a manual control switch, in an approved location and clearly identified, that reduces the breakout force to not more than 578 N.	CONDITIONAL	1068	Verified
CH10-0239	Section 1010.3.1.2	Other than egress component	Exception item 4 There is an actuation of a manual control switch, in an approved location and clearly identified, that reduces the breakout force to not more than 578 N.	Sl: 578 N	max	Per Section 1010.3.1.2 (Other than egress component).	Exception: A breakout force in excess of 800 N is permitted if the breakout force is reduced to not more than 578 N when not less than one of the following conditions is satisfied: 1 There is a power failure or power is removed to the device holding the door wings in position. 2 There is an actuation of the automatic sprinkler system where such system is provided. 3 There is an actuation of a smoke detection system that is installed in accordance with Section 907 to provide coverage in areas within the building that are within 23 m of the revolving doors. 4 There is an actuation of a manual control switch, in an approved location and clearly identified, that reduces the breakout force to not more than 578 N.	CONDITIONAL	1068	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0240	Section 1010.3.1.2	Other than egress component	Exception: A breakout force in excess of 800 N is permitted if the breakout force is reduced to not more than 578 N when not less than one of the following conditions is satisfied:	Sl: 800 N; 578 N	mixed	Per Section 1010.3.1.2 (Other than egress component).	Exception: A breakout force in excess of 800 N is permitted if the breakout force is reduced to not more than 578 N when not less than one of the following conditions is satisfied: 1 There is a power failure or power is removed to the device holding the door wings in position. 2 There is an actuation of the automatic sprinkler system where such system is provided. 3 There is an actuation of a smoke detection system that is installed in accordance with Section 907 to provide coverage in areas within the building that are within 23 m of the revolving doors. 4 There is an actuation of a manual control switch, in an approved location and clearly identified, that reduces the breakout force to not more than 578 N.	CONDITIONAL	1068	Verified
CH10-0241	Section 1010.3.1.2	Other than egress component	The breakout force of a revolving door not used as a component of a means of egress shall not be more than 800 N.	Sl: 800 N	max	Per Section 1010.3.1.2 (Other than egress component).	Exception: A breakout force in excess of 800 N is permitted if the breakout force is reduced to not more than 578 N when not less than one of the following conditions is satisfied: 1 There is a power failure or power is removed to the device holding the door wings in position. 2 There is an actuation of the automatic sprinkler system where such system is provided. 3 There is an actuation of a smoke detection system that is installed in accordance with Section 907 to provide coverage in areas within the building that are within 23 m of the revolving doors. 4 There is an actuation of a manual control switch, in an approved location and clearly identified, that reduces the breakout force to not more than 578 N.	CONDITIONAL	1068	Verified
CH10-0242	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 2.4 m has maximum allowable speed 7.2 rpm.	Sl: 2.4 m; 7.2 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0243	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 2.7 m has maximum allowable speed 6.4 rpm.	Sl: 2.7 m; 6.4 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0244	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 3 m has maximum allowable speed 5.7 rpm.	Sl: 3 m; 5.7 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0245	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 3.4 m has maximum allowable speed 5.2 rpm.	Sl: 3.4 m; 5.2 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0246	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 3.7 m has maximum allowable speed 4.8 rpm.	Sl: 3.7 m; 4.8 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0247	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 3.8 m has maximum allowable speed 4.6 rpm.	Sl: 3.8 m; 4.6 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0248	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 4.3 m has maximum allowable speed 4.1 rpm.	Sl: 4.3 m; 4.1 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0249	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 4.9 m has maximum allowable speed 3.6 rpm.	Sl: 4.9 m; 3.6 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0250	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 5.2 m has maximum allowable speed 3.4 rpm.	Sl: 5.2 m; 3.4 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0251	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 5.5 m has maximum allowable speed 3.2 rpm.	Sl: 5.5 m; 3.2 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0252	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 6.1 m has maximum allowable speed 2.9 rpm.	Sl: 6.1 m; 2.9 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0253	Table 1010.3.1(2) (appended-table row); Section 1010.3.1(2)	Power-operated revolving-door speed	An automatic or power-operated revolving door with maximum nominal diameter 7.3 m has maximum allowable speed 2.4 rpm.	Sl: 7.3 m; 2.4 rpm	max	Automatic or power-operated revolving doors	None stated in inventory	CONDITIONAL	1180	Verify source
CH10-0254	Section 1010.3.2	Power-operated doors	Exception item 3. For a biparting door in the emergency breakout mode, a door leaf located within a multiple-leaf opening shall be exempt from the minimum 800 mm single-leaf requirement of Section 1010.1.1, provided a minimum 800 mm clear opening is provided when the two biparting leaves meeting in the center are broken out.	Sl: 800 mm	min	Per Section 1010.3.2 (Power-operated doors).	## Exceptions: 1. Occupancies in Group I-3. 2. Special purpose horizontal sliding, accordion or folding doors complying with Section 1010.3.3. 3. For a biparting door in the emergency breakout mode, a door leaf located within a multiple-leaf opening shall be exempt from the minimum 800 mm single-leaf requirement of Section 1010.1.1, provided a minimum 800 mm clear opening is provided when the two biparting leaves meeting in the center are broken out.	CONDITIONAL	1068	Verified
CH10-0255	Section 1010.3.2	Power-operated doors	The forces required to open these doors manually shall not exceed those specified in Section 1010.1.3, except that the force to set the door in motion shall not exceed 220 N.	Sl: 220 N	max	Per Section 1010.3.2 (Power-operated doors).	## Exceptions: 1. Occupancies in Group I-3. 2. Special purpose horizontal sliding, accordion or folding doors complying with Section 1010.3.3. 3. For a biparting door in the emergency breakout mode, a door leaf located within a multiple-leaf opening shall be exempt from the minimum 800 mm single-leaf requirement of Section 1010.1.1, provided a minimum 800 mm clear opening is provided when the two biparting leaves meeting in the center are broken out.	CONDITIONAL	1068	Verified
CH10-0256	Section 1010.3.3	Special purpose horizontal sliding, accordion or folding doors	Item 3 The force required to operate the door shall not exceed 133 N to set the door in motion and 67 N to close the door or open it to the minimum required width.	Sl: 133 N; 67 N	max	Per Section 1010.3.3 (Special purpose horizontal sliding, accordion or folding doors).	1 The doors shall be power operated and shall be capable of being operated manually in the event of power failure. 2 The doors shall be openable by a simple method without special knowledge or effort from the egress side or sides. 3 The force required to operate the door shall not exceed 133 N to set the door in motion and 67 N to close the door or open it to the minimum required width. 4 The door shall be openable with a force not to exceed 67 N when a force of 1100 N is applied perpendicular to the door adjacent to the operating device. 5 The door assembly shall comply with the applicable fire protection rating and, where rated, shall be self-closing or automatic closing by smoke detection in accordance with Section 716.2.6.6, shall be installed in accordance with NFPA 80 and shall comply with Section 716. 6 The door assembly shall have an integrated standby power supply. 7 The door assembly power supply shall be electrically supervised. 8 The door shall open to the minimum required width within 10 seconds after activation of the operating device.	CONDITIONAL	1070	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0257	Section 1010.3.3	Special purpose horizontal sliding, accordion or folding doors	Item 4 The door shall be openable with a force not to exceed 67 N when a force of 1100 N is applied perpendicular to the door adjacent to the operating device.	Sl: 67 N; 1100 N	trigger	Per Section 1010.3.3 (Special purpose horizontal sliding, accordion or folding doors).	1 The doors shall be power operated and shall be capable of being operated manually in the event of power failure. 2 The doors shall be openable by a simple method without special knowledge or effort from the egress side or sides. 3 The force required to operate the door shall not exceed 133 N to set the door in motion and 67 N to close the door or open it to the minimum required width. 4 The door shall be openable with a force not to exceed 67 N when a force of 1100 N is applied perpendicular to the door adjacent to the operating device. 5 The door assembly shall comply with the applicable fire protection rating and, where rated, shall be self-closing or automatic closing by smoke detection in accordance with Section 716.2.6.6, shall be installed in accordance with NFPA 80 and shall comply with Section 716. 6 The door assembly shall have an integrated standby power supply. 7 The door assembly power supply shall be electrically supervised. 8 The door shall open to the minimum required width within 10 seconds after activation of the operating device.	CONDITIONAL	1070	Verified
CH10-0258	Section 1010.3.4	Security grilles	Where two or more exits or access to exits are required, not more than one-half of the exits or exit access doorways shall be equipped with horizontal sliding or vertical security grilles.	Sl: two or more exits; one-half	formula	Per Section 1010.3.4 (Security grilles).	None stated in inventory	CONDITIONAL	1070	Verified
CH10-0259	Section 1010.4	Gates	Exception: Horizontal sliding or swinging gates exceeding the 1200 mm maximum leaf width limitation are permitted in fences and walls surrounding a stadium.	Sl: 1200 mm	max	Per Section 1010.4 (Gates).	Exception: Horizontal sliding or swinging gates exceeding the 1200 mm maximum leaf width limitation are permitted in fences and walls surrounding a stadium.	CONDITIONAL	1071	Verified
CH10-0260	Section 1010.4.1	Stadiums	Panic hardware is not required on gates surrounding stadiums where such gates are under constant immediate supervision while the public is present, and where safe dispersal areas based on 0.28 m ² per occupant are located between the fence and enclosed space.	Sl: 0.28 m ² per occupant	formula	Per Section 1010.4.1 (Stadiums).	None stated in inventory	CONDITIONAL	1071	Verified
CH10-0261	Section 1010.4.1	Stadiums	Such required safe dispersal areas shall not be located less than 15 m from the enclosed space.	Sl: 15 m	min	Per Section 1010.4.1 (Stadiums).	None stated in inventory	CONDITIONAL	1071	Verified
CH10-0262	Section 1010.5	Turnstile direction restriction	Turnstiles or similar devices that restrict travel to one direction shall not obstruct any required means of egress except where permitted by Sections 1010.5.1, 1010.5.3 and 1010.5.4.	Sl: one direction	restriction	Turnstile or similar device on a required means of egress.	None stated in inventory	CONDITIONAL	1071	Verified
CH10-0263	Section 1010.5.1	Capacity Each turnstile or similar device shall be credited with a capacity based on not more than a 50-person occupant load where all of the following provisions are met:	Capacity Each turnstile or similar device shall be credited with a capacity based on not more than a 50-person occupant load where all of the following provisions are met:	Sl: 50-person occupant load	max	Per Section 1010.5.1 (Capacity Each turnstile or similar device shall be credited with a capacity based on not more than a 50-person occupant load where all of the following provisions are met:).	1 Each device shall turn free in the direction of egress travel when primary power is lost and on the manual release by an employee in the area. 2 Such devices are not given credit for more than 50 percent of the required egress capacity or width. 3 Each device is not more than 990 mm high. 4 Each device has not less than 420 mm clear width at and below a height of 990 mm and not less than 550 mm clear width at heights above 990 mm.	CONDITIONAL	1071	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0264	Section 1010.5.1	Capacity Each turnstile or similar device shall be credited with a capacity based on not more than a 50-person occupant load where all of the following provisions are met:	Item 2 Such devices are not given credit for more than 50 percent of the required egress capacity or width.	Sl: 50 percent	trigger	Per Section 1010.5.1 (Capacity Each turnstile or similar device shall be credited with a capacity based on not more than a 50-person occupant load where all of the following provisions are met:).	1 Each device shall turn free in the direction of egress travel when primary power is lost and on the manual release by an employee in the area. 2 Such devices are not given credit for more than 50 percent of the required egress capacity or width. 3 Each device is not more than 990 mm high. 4 Each device has not less than 420 mm clear width at and below a height of 990 mm and not less than 550 mm clear width at heights above 990 mm.	CONDITIONAL	1071	Verified
CH10-0265	Section 1010.5.1	Capacity Each turnstile or similar device shall be credited with a capacity based on not more than a 50-person occupant load where all of the following provisions are met:	Item 3 Each device is not more than 990 mm high.	Sl: 990 mm	max	Per Section 1010.5.1 (Capacity Each turnstile or similar device shall be credited with a capacity based on not more than a 50-person occupant load where all of the following provisions are met:).	1 Each device shall turn free in the direction of egress travel when primary power is lost and on the manual release by an employee in the area. 2 Such devices are not given credit for more than 50 percent of the required egress capacity or width. 3 Each device is not more than 990 mm high. 4 Each device has not less than 420 mm clear width at and below a height of 990 mm and not less than 550 mm clear width at heights above 990 mm.	CONDITIONAL	1071	Verified
CH10-0266	Section 1010.5.1	Capacity Each turnstile or similar device shall be credited with a capacity based on not more than a 50-person occupant load where all of the following provisions are met:	Item 4 Each device has not less than 420 mm clear width at and below a height of 990 mm and not less than 550 mm clear width at heights above 990 mm.	Sl: 420 mm; 990 mm; 550 mm	mixed	Per Section 1010.5.1 (Capacity Each turnstile or similar device shall be credited with a capacity based on not more than a 50-person occupant load where all of the following provisions are met:).	1 Each device shall turn free in the direction of egress travel when primary power is lost and on the manual release by an employee in the area. 2 Such devices are not given credit for more than 50 percent of the required egress capacity or width. 3 Each device is not more than 990 mm high. 4 Each device has not less than 420 mm clear width at and below a height of 990 mm and not less than 550 mm clear width at heights above 990 mm.	CONDITIONAL	1071	Verified
CH10-0267	Section 1010.5.1.1	Accessible-turnstile clear width	Where part of an accessible route, turnstiles shall have not less than 900 mm clear width at and below a height of 850 mm, not less than 800 mm clear width between 850 mm and 2000 mm, and a mechanism other than a revolving device.	Sl: 900 mm clear width; 850 mm height; 800 mm clear width; 2000 mm height	mixed	Turnstile located as part of an accessible route.	None stated in inventory	CONDITIONAL	1071	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0268	Section 1010.5.2	Security access turnstiles	Exception item 2 Each security access turnstile lane configuration has a minimum clear passage width of 550 mm.	Sl: 550 mm	min	Per Section 1010.5.2 (Security access turnstiles).	1 The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 903.3.1.1. 2 Each security access turnstile lane configuration has a minimum clear passage width of 550 mm. 3 Any security access turnstile lane configuration providing a clear passage width of less than 800 mm shall be credited with a maximum egress capacity of 50 persons. 4 Any security access turnstile lane configuration providing a clear passage width of 800 mm or more shall be credited with a maximum egress capacity as calculated in accordance with Section 1005. 5 Each secured physical barrier shall automatically retract or swing to an unobstructed open position in the direction of egress, under each of the following conditions: 5.1 Upon loss of power to the turnstile or any part of the access control system that secures the physical barrier. 5.2 Upon actuation of a clearly identified manual release device with ready access that results in direct interruption of power to each secured physical barrier, after which such barriers remain in the open position for not less than 30 seconds. The manual release device shall be positioned at one of the following locations: 5.2.1 On the egress side of each security access turnstile lane. 5.2.2 At an approved location where it can be actuated by an employee assigned to the area at all times that the building is occupied. 5.3 Upon actuation of the building fire alarm system, if provided, after which the physical barrier remains in the open position until the fire alarm system is manually reset. Exception: Actuation of a manual fire alarm box.	CONDITIONAL	1072	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0269	Section 1010.5.2	Security access turnstiles	Exception item 3 Any security access turnstile lane configuration providing a clear passage width of less than 800 mm shall be credited with a maximum egress capacity of 50 persons.	Sl: 800 mm; 50 persons	max	Per Section 1010.5.2 (Security access turnstiles).	1 The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 903.3.1.1. 2 Each security access turnstile lane configuration has a minimum clear passage width of 550 mm. 3 Any security access turnstile lane configuration providing a clear passage width of less than 800 mm shall be credited with a maximum egress capacity of 50 persons. 4 Any security access turnstile lane configuration providing a clear passage width of 800 mm or more shall be credited with a maximum egress capacity as calculated in accordance with Section 1005. 5 Each secured physical barrier shall automatically retract or swing to an unobstructed open position in the direction of egress, under each of the following conditions: 5.1 Upon loss of power to the turnstile or any part of the access control system that secures the physical barrier. 5.2 Upon actuation of a clearly identified manual release device with ready access that results in direct interruption of power to each secured physical barrier, after which such barriers remain in the open position for not less than 30 seconds. The manual release device shall be positioned at one of the following locations: 5.2.1 On the egress side of each security access turnstile lane. 5.2.2 At an approved location where it can be actuated by an employee assigned to the area at all times that the building is occupied. 5.3 Upon actuation of the building fire alarm system, if provided, after which the physical barrier remains in the open position until the fire alarm system is manually reset. Exception: Actuation of a manual fire alarm box.	CONDITIONAL	1072	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0270	Section 1010.5.2	Security access turnstiles	Exception item 4 Any security access turnstile lane configuration providing a clear passage width of 800 mm or more shall be credited with a maximum egress capacity as calculated in accordance with Section 1005.	Sl: 800 mm	max	Per Section 1010.5.2 (Security access turnstiles).	1 The building is protected throughout by an approved, supervised automatic sprinkler system in accordance with Section 903.3.1.1. 2 Each security access turnstile lane configuration has a minimum clear passage width of 550 mm. 3 Any security access turnstile lane configuration providing a clear passage width of less than 800 mm shall be credited with a maximum egress capacity of 50 persons. 4 Any security access turnstile lane configuration providing a clear passage width of 800 mm or more shall be credited with a maximum egress capacity as calculated in accordance with Section 1005. 5 Each secured physical barrier shall automatically retract or swing to an unobstructed open position in the direction of egress, under each of the following conditions: 5.1 Upon loss of power to the turnstile or any part of the access control system that secures the physical barrier. 5.2 Upon actuation of a clearly identified manual release device with ready access that results in direct interruption of power to each secured physical barrier, after which such barriers remain in the open position for not less than 30 seconds. The manual release device shall be positioned at one of the following locations: 5.2.1 On the egress side of each security access turnstile lane. 5.2.2 At an approved location where it can be actuated by an employee assigned to the area at all times that the building is occupied. 5.3 Upon actuation of the building fire alarm system, if provided, after which the physical barrier remains in the open position until the fire alarm system is manually reset. Exception: Actuation of a manual fire alarm box.	CONDITIONAL	1072	Verified
CH10-0271	Section 1010.5.3	High turnstile	Turnstiles more than 990 mm high shall meet the requirements for revolving doors or the requirements of Section 1010.5.2 for security access turnstiles.	Sl: 990 mm	trigger	Per Section 1010.5.3 (High turnstile).	None stated in inventory	CONDITIONAL	1072	Verified
CH10-0272	Section 1010.5.4	Additional door	Where serving an occupant load greater than 300, each turnstile that is not portable shall have a side-hinged swinging door that conforms to Section 1010.1 within 15 m.	Sl: occupant load greater than 300; 15 m	trigger	Per Section 1010.5.4 (Additional door).	Exception: A side-hinged swinging door is not required at security access turnstiles that comply with Section 1010.5.2.	CONDITIONAL	1072	Verified

A.4.1011 — Section 1011 (55 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0273	Section 1011.2	Stairway lift clear passage width	Exception item 3. Where an incline platform lift or stairway chairlift is installed on stairways serving occupancies in Group R-3, or within dwelling units in occupancies in Group R-2, a clear passage width not less than 500 mm shall be provided. Where the seat and platform can be folded when not in use, the distance shall be measured from the folded position.	Sl: 500 mm	min	Exception 3: Group R-3 stairways and stairways within Group R-2 dwelling units having an incline platform lift or stairway chairlift.	1. Stairways serving an occupant load of less than 50 shall have a width of not less than 900 mm. 2. Spiral stairways as provided for in Section 1011.10. Where an incline platform lift or stairway chairlift is installed on stairways serving occupancies in Group R-3, or within dwelling units in occupancies in Group R-2, a clear passage width not less than 500 mm shall be provided. Where the seat and platform can be folded when not in use, the distance shall be measured from the folded position.	CONDITIONAL	1073–1074	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0274	Section 1011.2	Width and capacity	Exception item 1. Stairways serving an occupant load of less than 50 shall have a width of not less than 900 mm.	Sl: 900 mm; 50 occupants	mixed	Per Section 1011.2 (Width and capacity).	1. Stairways serving an occupant load of less than 50 shall have a width of not less than 900 mm. 2. Spiral stairways as provided for in Section 1011.10. Where an incline platform lift or stairway chairlift is installed on stairways serving occupancies in Group R-3, or within dwelling units in occupancies in Group R-2, a clear passage width not less than 500 mm shall be provided. Where the seat and platform can be folded when not in use, the distance shall be measured from the folded position.	CONDITIONAL	1073	Verified
CH10-0275	Section 1011.2	Width and capacity	The required capacity of stairways shall be determined as specified in Section 1005.1, but the minimum width shall be not less than 1100 mm.	Sl: 1100 mm	min	Per Section 1011.2 (Width and capacity).	1. Stairways serving an occupant load of less than 50 shall have a width of not less than 900 mm. 2. Spiral stairways as provided for in Section 1011.10. Where an incline platform lift or stairway chairlift is installed on stairways serving occupancies in Group R-3, or within dwelling units in occupancies in Group R-2, a clear passage width not less than 500 mm shall be provided. Where the seat and platform can be folded when not in use, the distance shall be measured from the folded position.	DIRECT	1073	Verified
CH10-0276	Section 1011.3	Headroom	Exception item 1. Spiral stairways complying with Section 1011.10 are permitted a 2000 mm headroom clearance.	Sl: 2000 mm	trigger	Per Section 1011.3 (Headroom).	## Exceptions: 1. Spiral stairways complying with Section 1011.10 are permitted a 2000 mm headroom clearance. 2. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; where the nosings of treads at the side of a flight extend under the edge of a floor opening through which the stair passes, the floor opening shall be allowed to project horizontally into the required headroom not more than 120 mm.	CONDITIONAL	1074	Verified
CH10-0277	Section 1011.3	Headroom	Exception item 2. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; where the nosings of treads at the side of a flight extend under the edge of a floor opening through which the stair passes, the floor opening shall be allowed to project horizontally into the required headroom not more than 120 mm.	Sl: 120 mm	max	Per Section 1011.3 (Headroom).	## Exceptions: 1. Spiral stairways complying with Section 1011.10 are permitted a 2000 mm headroom clearance. 2. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; where the nosings of treads at the side of a flight extend under the edge of a floor opening through which the stair passes, the floor opening shall be allowed to project horizontally into the required headroom not more than 120 mm.	CONDITIONAL	1074	Verified
CH10-0278	Section 1011.3	Headroom	Stairways shall have a headroom clearance of not less than 2100 mm measured vertically from a line connecting the edge of the nosings.	Sl: 2100 mm	min	Per Section 1011.3 (Headroom).	## Exceptions: 1. Spiral stairways complying with Section 1011.10 are permitted a 2000 mm headroom clearance. 2. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; where the nosings of treads at the side of a flight extend under the edge of a floor opening through which the stair passes, the floor opening shall be allowed to project horizontally into the required headroom not more than 120 mm.	DIRECT	1074	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0279	Section 1011.3	Headroom	Such headroom shall be continuous above the stairway to the point where the line intersects the landing below, one tread depth beyond the bottom riser.	Sl: one tread	trigger	Per Section 1011.3 (Headroom).	## Exceptions: 1. Spiral stairways complying with Section 1011.10 are permitted a 2000 mm headroom clearance. 2. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; where the nosings of treads at the side of a flight extend under the edge of a floor opening through which the stair passes, the floor opening shall be allowed to project horizontally into the required headroom not more than 120 mm.	DIRECT	1074	Verified
CH10-0280	Section 1011.4	Walkline	The 300 mm dimension shall be measured from the widest point of the clear stair width at the walking surface of the winder.	Sl: 300 mm	trigger	Per Section 1011.4 (Walkline).	None stated in inventory	DIRECT	1075	Verified
CH10-0281	Section 1011.4	Walkline	The walkline across winder treads shall be concentric to the direction of travel through the turn and located 300 mm from the side where the winders are narrower.	Sl: 300 mm	trigger	Per Section 1011.4 (Walkline).	None stated in inventory	DIRECT	1075	Verified
CH10-0282	Section 1011.5.2	Riser height and tread depth	Exception item 3. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; the maximum riser height shall be 200 mm; the minimum tread depth shall be 250 mm; the minimum winder tread depth at the walkline shall be 250 mm; and the minimum winder tread depth shall be 150 mm. A nosing projection not less than 20 mm but not more than 32 mm shall be provided on stairways with solid risers where the tread depth is less than 275 mm.	Sl: 200 mm; 250 mm; 150 mm; 20 mm; 32 mm; 275 mm	mixed	Per Section 1011.5.2 (Riser height and tread depth).	Exceptions: 1. Spiral stairways in accordance with Section 1011.10. 2. Stairways connecting stepped aisles to cross aisles or concourses shall be permitted to use the riser/tread dimension in Section 1030.14.2. 3. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; the maximum riser height shall be 200 mm; the minimum tread depth shall be 250 mm; the minimum winder tread depth at the walkline shall be 250 mm; and the minimum winder tread depth shall be 150 mm. A nosing projection not less than 20 mm but not more than 32 mm shall be provided on stairways with solid risers where the tread depth is less than 275 mm. 4. See Section 503.1 of SBC 901 for the replacement of existing stairways. 5. In Group I-3 facilities, stairways providing access to guard towers, observation stations and control rooms, not more than 23 m² in area, shall be permitted to have a maximum riser height of 200 mm and a minimum tread depth of 225 mm.	CONDITIONAL	1076	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0283	Section 1011.5.2	Riser height and tread depth	Exception item 5. In Group I-3 facilities, stairways providing access to guard towers, observation stations and control rooms, not more than 23 m² in area, shall be permitted to have a maximum riser height of 200 mm and a minimum tread depth of 225 mm.	Sl: 23 m²; 200 mm; 225 mm	mixed	Per Section 1011.5.2 (Riser height and tread depth).	Exceptions: 1. Spiral stairways in accordance with Section 1011.10. 2. Stairways connecting stepped aisles to cross aisles or concourses shall be permitted to use the riser/tread dimension in Section 1030.14.2. 3. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; the maximum riser height shall be 200 mm; the minimum tread depth shall be 250 mm; the minimum winder tread depth at the walkline shall be 250 mm; and the minimum winder tread depth shall be 150 mm. A nosing projection not less than 20 mm but not more than 32 mm shall be provided on stairways with solid risers where the tread depth is less than 275 mm. 4. See Section 503.1 of SBC 901 for the replacement of existing stairways. 5. In Group I-3 facilities, stairways providing access to guard towers, observation stations and control rooms, not more than 23 m² in area, shall be permitted to have a maximum riser height of 200 mm and a minimum tread depth of 225 mm.	NOT_TYPICAL	1076	Verified
CH10-0284	Section 1011.5.2	Riser height and tread depth	Rectangular tread depths shall be 275 mm minimum measured horizontally between the vertical planes of the foremost projection of adjacent treads and at a right angle to the tread's nosing.	Sl: 275 mm	min	Per Section 1011.5.2 (Riser height and tread depth).	Exceptions: 1. Spiral stairways in accordance with Section 1011.10. 2. Stairways connecting stepped aisles to cross aisles or concourses shall be permitted to use the riser/tread dimension in Section 1030.14.2. 3. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; the maximum riser height shall be 200 mm; the minimum tread depth shall be 250 mm; the minimum winder tread depth at the walkline shall be 250 mm; and the minimum winder tread depth shall be 150 mm. A nosing projection not less than 20 mm but not more than 32 mm shall be provided on stairways with solid risers where the tread depth is less than 275 mm. 4. See Section 503.1 of SBC 901 for the replacement of existing stairways. 5. In Group I-3 facilities, stairways providing access to guard towers, observation stations and control rooms, not more than 23 m² in area, shall be permitted to have a maximum riser height of 200 mm and a minimum tread depth of 225 mm.	DIRECT	1076	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0285	Section 1011.5.2	Riser height and tread depth	Stair riser heights shall be 175 mm maximum and 100 mm minimum.	Sl: 175 mm; 100 mm	range	Per Section 1011.5.2 (Riser height and tread depth).	Exceptions: 1. Spiral stairways in accordance with Section 1011.10. 2. Stairways connecting stepped aisles to cross aisles or concourses shall be permitted to use the riser/tread dimension in Section 1030.14.2. 3. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; the maximum riser height shall be 200 mm; the minimum tread depth shall be 250 mm; the minimum winder tread depth at the walkline shall be 250 mm; and the minimum winder tread depth shall be 150 mm. A nosing projection not less than 20 mm but not more than 32 mm shall be provided on stairways with solid risers where the tread depth is less than 275 mm. 4. See Section 503.1 of SBC 901 for the replacement of existing stairways. 5. In Group I-3 facilities, stairways providing access to guard towers, observation stations and control rooms, not more than 23 m² in area, shall be permitted to have a maximum riser height of 200 mm and a minimum tread depth of 225 mm.	DIRECT	1076	Verified
CH10-0286	Section 1011.5.2	Riser height and tread depth	Wider treads shall have a minimum tread depth of 275 mm between the vertical planes of the foremost projection of adjacent treads at the intersections with the walkline and a minimum tread depth of 250 mm within the clear width of the stair.	Sl: 275 mm; 250 mm	min	Per Section 1011.5.2 (Riser height and tread depth).	Exceptions: 1. Spiral stairways in accordance with Section 1011.10. 2. Stairways connecting stepped aisles to cross aisles or concourses shall be permitted to use the riser/tread dimension in Section 1030.14.2. 3. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are accessory to a Group R-3 occupancy or accessory to individual dwelling units in Group R-2 occupancies; the maximum riser height shall be 200 mm; the minimum tread depth shall be 250 mm; the minimum winder tread depth at the walkline shall be 250 mm; and the minimum winder tread depth shall be 150 mm. A nosing projection not less than 20 mm but not more than 32 mm shall be provided on stairways with solid risers where the tread depth is less than 275 mm. 4. See Section 503.1 of SBC 901 for the replacement of existing stairways. 5. In Group I-3 facilities, stairways providing access to guard towers, observation stations and control rooms, not more than 23 m² in area, shall be permitted to have a maximum riser height of 200 mm and a minimum tread depth of 225 mm.	DIRECT	1076	Verified
CH10-0287	Section 1011.5.4	Dimensional uniformity	The greatest winder tread depth at the walkline within any flight of stairs shall not exceed the smallest by more than 10 mm.	Sl: 10 mm	max	Per Section 1011.5.4 (Dimensional uniformity).	## Exceptions: 1. Stairways connecting stepped aisles to cross aisles or concourses shall be permitted to comply with the dimensional non-uniformity in Section 1030.14.2. 2. Consistently shaped winders, complying with Section 1011.5, differing from rectangular treads in the same flight of stairs. 3. Non-uniform riser dimension complying with Section 1011.5.4.1.	DIRECT	1078	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0288	Section 1011.5.4	Dimensional uniformity	The tolerance between the largest and smallest riser height or between the largest and smallest tread depth shall not exceed 10 mm in any flight of stairs.	Sl: 10 mm	max	Per Section 1011.5.4 (Dimensional uniformity).	## Exceptions: 1. Stairways connecting stepped aisles to cross aisles or concourses shall be permitted to comply with the dimensional non-uniformity in Section 1030.14.2. 2. Consistently shaped winders, complying with Section 1011.5, differing from rectangular treads in the same flight of stairs. 3. Non-uniform riser dimension complying with Section 1011.5.4.1.	DIRECT	1078	Verified
CH10-0289	Section 1011.5.4.1	Nonuniform height risers	Marking stripes shall have a width of not less than 25 mm but not more than 50 mm.	Sl: 25 mm; 50 mm	range	Per Section 1011.5.4.1 (Nonuniform height risers).	None stated in inventory	DIRECT	1078	Verified
CH10-0290	Section 1011.5.4.1	Nonuniform height risers	Where the bottom or top riser adjoins a sloping public way, walkway or driveway having an established grade and serving as a landing, the bottom or top riser is permitted to be reduced along the slope to less than 100 mm in height, with the variation in height of the bottom or top riser not to exceed one unit vertical in 12 units horizontal (8-percent slope) of stair width.	Sl: 100 mm; one unit vertical in 12 units horizontal; 8-percent	trigger	Per Section 1011.5.4.1 (Nonuniform height risers).	None stated in inventory	DIRECT	1078	Verified
CH10-0291	Section 1011.5.5	Nosing curvature or bevel	Nosing shall have a curvature or bevel of not less than 2 mm but not more than 15 mm from the foremost projection of the tread.	Sl: 2 mm; 15 mm	range	Stair nosings.	None stated in inventory	DIRECT	1079	Verified
CH10-0292	Section 1011.5.5	Riser profile	Risers shall be solid and vertical or sloped under the tread above from the underside of the nosing above at an angle not more than 30 degrees from the vertical.	Sl: 30 degrees	max	Stair risers.	None stated in inventory	DIRECT	1079	Verified
CH10-0293	Section 1011.5.5.1	Nosing projection size	The leading edge (nosing) of treads shall project not more than 32 mm beyond the tread below.	Sl: 32 mm	max	Per Section 1011.5.5.1 (Nosing projection size).	None stated in inventory	DIRECT	1079	Verified
CH10-0294	Section 1011.5.5.3	Solid risers	Item 1. Solid risers are not required for stairways that are not required to comply with Section 1009.3, provided that the opening between treads does not permit the passage of a sphere with a diameter of 100 mm.	Sl: 100 mm	trigger	Per Section 1011.5.5.3 (Solid risers).	1. Solid risers are not required for stairways that are not required to comply with Section 1009.3, provided that the opening between treads does not permit the passage of a sphere with a diameter of 100 mm. 2. Solid risers are not required for occupancies in Group I-3 or in Group F, H and S occupancies other than areas accessible to the public. The size of the opening in the riser is not restricted. 3. Solid risers are not required for spiral stairways constructed in accordance with Section 1011.10.	DIRECT	1079	Verified
CH10-0295	Section 1011.6	Stairway landings	Doors opening onto a landing shall not reduce the landing to less than one-half the required width.	Sl: one-half	formula	Per Section 1011.6 (Stairway landings).	Exception: 1. Where stairways connect stepped aisles to cross aisles or concourses, stairway landings are not required at the transition between stairways and stepped aisles constructed in accordance with Section 1030. 2. Where curved stairways of constant radius have intermediate landings, the landing depth shall be measured horizontally between the intersection of the walkline of the lower flight at the landing nosing and the intersection of the walkline of the upper flight at the nosing of the lowest tread of the upper flight. 3. Where a landing turns 90 degrees or more, the minimum landing depth in accordance with this section shall not be required where the landing provided is not less than that described by an arc with a radius equal to the width of the flight served.	DIRECT	1080	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0296	Section 1011.6	Stairway landings	Every landing shall have a minimum depth, measured parallel to the direction of travel, equal to the width of the stairway or 1200 mm, whichever is less.	Sl: 1200 mm	min	Per Section 1011.6 (Stairway landings).	Exception: 1. Where stairways connect stepped aisles to cross aisles or concourses, stairway landings are not required at the transition between stairways and stepped aisles constructed in accordance with Section 1030. 2. Where curved stairways of constant radius have intermediate landings, the landing depth shall be measured horizontally between the intersection of the walkline of the lower flight at the landing nosing and the intersection of the walkline of the upper flight at the nosing of the lowest tread of the upper flight. 3. Where a landing turns 90 degrees or more, the minimum landing depth in accordance with this section shall not be required where the landing provided is not less than that described by an arc with a radius equal to the width of the flight served.	DIRECT	1080	Verified
CH10-0297	Section 1011.6	Stairway landings	Exception item 3. Where a landing turns 90 degrees or more, the minimum landing depth in accordance with this section shall not be required where the landing provided is not less than that described by an arc with a radius equal to the width of the flight served.	Sl: 90 degrees	mixed	Per Section 1011.6 (Stairway landings).	Exception: 1. Where stairways connect stepped aisles to cross aisles or concourses, stairway landings are not required at the transition between stairways and stepped aisles constructed in accordance with Section 1030. 2. Where curved stairways of constant radius have intermediate landings, the landing depth shall be measured horizontally between the intersection of the walkline of the lower flight at the landing nosing and the intersection of the walkline of the upper flight at the nosing of the lowest tread of the upper flight. 3. Where a landing turns 90 degrees or more, the minimum landing depth in accordance with this section shall not be required where the landing provided is not less than that described by an arc with a radius equal to the width of the flight served.	CONDITIONAL	1080	Verified
CH10-0298	Section 1011.6	Stairway landings	When fully open, the door shall not project more than 175 mm into the required width of a landing.	Sl: 175 mm	max	Per Section 1011.6 (Stairway landings).	Exception: 1. Where stairways connect stepped aisles to cross aisles or concourses, stairway landings are not required at the transition between stairways and stepped aisles constructed in accordance with Section 1030. 2. Where curved stairways of constant radius have intermediate landings, the landing depth shall be measured horizontally between the intersection of the walkline of the lower flight at the landing nosing and the intersection of the walkline of the upper flight at the nosing of the lowest tread of the upper flight. 3. Where a landing turns 90 degrees or more, the minimum landing depth in accordance with this section shall not be required where the landing provided is not less than that described by an arc with a radius equal to the width of the flight served.	DIRECT	1080	Verified
CH10-0299	Section 1011.7.1	Stairway walking surface	Exception item 1. Openings in stair walking surfaces shall be a size that does not permit the passage of 12.5 mm sphere. Elongated openings shall be placed so that the long dimension is perpendicular to the direction of travel. 2. In Group F, H and S occupancies, other than areas of parking structures accessible to the public, openings in treads and landings shall not be prohibited provided a sphere with a diameter of 30 mm cannot pass through the opening.	Sl: 12.5 mm; 30 mm	max	Per Section 1011.7.1 (Stairway walking surface).	Exceptions: 1. Openings in stair walking surfaces shall be a size that does not permit the passage of 12.5 mm sphere. Elongated openings shall be placed so that the long dimension is perpendicular to the direction of travel. 2. In Group F, H and S occupancies, other than areas of parking structures accessible to the public, openings in treads and landings shall not be prohibited provided a sphere with a diameter of 30 mm cannot pass through the opening.	CONDITIONAL	1081	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0300	Section 1011.7.1	Stairway walking surface	The walking surface of treads and landings of a stairway shall not be sloped steeper than one unit vertical in 48 units horizontal (2-percent slope) in any direction.	Sl: one unit vertical in 48 units horizontal; 2-percent	max	Per Section 1011.7.1 (Stairway walking surface).	Exceptions: 1. Openings in stair walking surfaces shall be a size that does not permit the passage of 12.5 mm sphere. Elongated openings shall be placed so that the long dimension is perpendicular to the direction of travel. 2. In Group F, H and S occupancies, other than areas of parking structures accessible to the public, openings in treads and landings shall not be prohibited provided a sphere with a diameter of 30 mm cannot pass through the opening.	DIRECT	1081	Verified
CH10-0301	Section 1011.7.3	Enclosures under interior stairways	Exception: Spaces under stairways serving and contained within a single residential dwelling unit in Group R-2 or R-3 shall be permitted to be protected on the enclosed side with 12.5 mm gypsum board.	Sl: 12.5 mm	trigger	Per Section 1011.7.3 (Enclosures under interior stairways).	Exception: Spaces under stairways serving and contained within a single residential dwelling unit in Group R-2 or R-3 shall be permitted to be protected on the enclosed side with 12.5 mm gypsum board.	CONDITIONAL	1082	Verified
CH10-0302	Section 1011.7.3	Enclosures under interior stairways	The walls and soffits within enclosed usable spaces under enclosed and unenclosed stairways shall be protected by 1-hour fire-resistance-rated construction or the fire-resistance rating of the stairway enclosure, whichever is greater.	Sl: 1-hour	trigger	Per Section 1011.7.3 (Enclosures under interior stairways).	Exception: Spaces under stairways serving and contained within a single residential dwelling unit in Group R-2 or R-3 shall be permitted to be protected on the enclosed side with 12.5 mm gypsum board.	DIRECT	1082	Verified
CH10-0303	Section 1011.7.4	Enclosures under exterior stairways	There shall not be enclosed usable space under exterior exit stairways unless the space is completely enclosed in 1-hour fire-resistance-rated construction.	Sl: 1-hour	min	Per Section 1011.7.4 (Enclosures under exterior stairways).	None stated in inventory	DIRECT	1082	Verified
CH10-0304	Section 1011.8	Vertical rise	A flight of stairs shall not have a vertical rise greater than 3600 mm between floor levels or landings.	Sl: 3600 mm	max	Per Section 1011.8 (Vertical rise).	Exception: Spiral stairways used as a means of egress from technical production areas.	DIRECT	1082	Verified
CH10-0305	Section 1011.9	Curved stairways	Curved stairways with winder treads shall have treads and risers in accordance with Section 1011.5 and the smallest radius shall be not less than twice the minimum width or required capacity of the stairway.	Sl: twice	min	Per Section 1011.9 (Curved stairways).	Exception: The radius restriction shall not apply to curved stairways in Group R-3 and within individual dwelling units in Group R-2.	CONDITIONAL	1082	Verified
CH10-0306	Section 1011.10	Spiral stairways	A spiral stairway shall have a 170 mm minimum clear tread depth at a point 300 mm from the narrow edge.	Sl: 170 mm; 300 mm	min	Per Section 1011.10 (Spiral stairways).	None stated in inventory	CONDITIONAL	1082	Verified
CH10-0307	Section 1011.10	Spiral stairways	Spiral stairways are permitted to be used as a component in the means of egress only within dwelling units or from a space not more than ($23 \sqrt{m^2}$) in area and serving not more than five occupants, or from technical production areas in accordance with Section 410.5.	Sl: 23 m^2 ; five occupants	max	Per Section 1011.10 (Spiral stairways).	None stated in inventory	CONDITIONAL	1082	Verified
CH10-0308	Section 1011.10	Spiral stairways	The minimum stairway clear width at and below the handrail shall be 650 mm.	Sl: 650 mm	min	Per Section 1011.10 (Spiral stairways).	None stated in inventory	CONDITIONAL	1082	Verified
CH10-0309	Section 1011.10	Spiral stairways	The risers shall be sufficient to provide a headroom of 2000 mm minimum, but riser height shall not be more than 240 mm.	Sl: 2000 mm; 240 mm	mixed	Per Section 1011.10 (Spiral stairways).	None stated in inventory	CONDITIONAL	1082	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0310	Section 1011.11	Handrails	Exception item 1. Flights of stairways within dwelling units and flights of spiral stairways are permitted to have a handrail on one side only.	St: one side	trigger	Per Section 1011.11 (Handrails).	## Exceptions: 1. Flights of stairways within dwelling units and flights of spiral stairways are permitted to have a handrail on one side only. 2. Decks, patios and walkways that have a single change in elevation where the landing depth on each side of the change of elevation is greater than what is required for a landing do not require handrails. 3. In Group R-3 occupancies, a change in elevation consisting of a single riser at an entrance or egress door does not require handrails. 4. Changes in room elevations of three or fewer risers within dwelling units and sleeping units in Group R-2 and R-3 do not require handrails. 5. Where a platform lift is in a stationary position and the floor of the platform lift serves as the upper landing of a stairway, handrails shall not be required on the stairway, provided that all of the following criteria are met: 5.1. The stairway contains not more than two risers. 5.2. A handhold, positioned horizontally or vertically, is located on one side of the stairway adjacent to the top landing. 5.3. The handhold is located not less than 850 mm and not more than 1050 mm above the bottom landing of the stairway. 5.4. The handhold gripping surface complies with Section 1014.3, and is not less than 115 mm in length.	CONDITIONAL	1083	Verified
CH10-0311	Section 1011.11	Handrails	Exception item 5.1. The stairway contains not more than two risers.	St: two risers	max	Per Section 1011.11 (Handrails).	## Exceptions: 1. Flights of stairways within dwelling units and flights of spiral stairways are permitted to have a handrail on one side only. 2. Decks, patios and walkways that have a single change in elevation where the landing depth on each side of the change of elevation is greater than what is required for a landing do not require handrails. 3. In Group R-3 occupancies, a change in elevation consisting of a single riser at an entrance or egress door does not require handrails. 4. Changes in room elevations of three or fewer risers within dwelling units and sleeping units in Group R-2 and R-3 do not require handrails. 5. Where a platform lift is in a stationary position and the floor of the platform lift serves as the upper landing of a stairway, handrails shall not be required on the stairway, provided that all of the following criteria are met: 5.1. The stairway contains not more than two risers. 5.2. A handhold, positioned horizontally or vertically, is located on one side of the stairway adjacent to the top landing. 5.3. The handhold is located not less than 850 mm and not more than 1050 mm above the bottom landing of the stairway. 5.4. The handhold gripping surface complies with Section 1014.3, and is not less than 115 mm in length.	CONDITIONAL	1083	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0312	Section 1011.11	Handrails	Exception item 5.2. A handhold, positioned horizontally or vertically, is located on one side of the stairway adjacent to the top landing.	St: one side	trigger	Per Section 1011.11 (Handrails).	## Exceptions: 1. Flights of stairways within dwelling units and flights of spiral stairways are permitted to have a handrail on one side only. 2. Decks, patios and walkways that have a single change in elevation where the landing depth on each side of the change of elevation is greater than what is required for a landing do not require handrails. 3. In Group R-3 occupancies, a change in elevation consisting of a single riser at an entrance or egress door does not require handrails. 4. Changes in room elevations of three or fewer risers within dwelling units and sleeping units in Group R-2 and R-3 do not require handrails. 5. Where a platform lift is in a stationary position and the floor of the platform lift serves as the upper landing of a stairway, handrails shall not be required on the stairway, provided that all of the following criteria are met: 5.1. The stairway contains not more than two risers. 5.2. A handhold, positioned horizontally or vertically, is located on one side of the stairway adjacent to the top landing. 5.3. The handhold is located not less than 850 mm and not more than 1050 mm above the bottom landing of the stairway. 5.4. The handhold gripping surface complies with Section 1014.3, and is not less than 115 mm in length.	CONDITIONAL	1083	Verified
CH10-0313	Section 1011.11	Handrails	Exception item 5.3. The handhold is located not less than 850 mm and not more than 1050 mm above the bottom landing of the stairway.	St: 850 mm; 1050 mm	range	Per Section 1011.11 (Handrails).	## Exceptions: 1. Flights of stairways within dwelling units and flights of spiral stairways are permitted to have a handrail on one side only. 2. Decks, patios and walkways that have a single change in elevation where the landing depth on each side of the change of elevation is greater than what is required for a landing do not require handrails. 3. In Group R-3 occupancies, a change in elevation consisting of a single riser at an entrance or egress door does not require handrails. 4. Changes in room elevations of three or fewer risers within dwelling units and sleeping units in Group R-2 and R-3 do not require handrails. 5. Where a platform lift is in a stationary position and the floor of the platform lift serves as the upper landing of a stairway, handrails shall not be required on the stairway, provided that all of the following criteria are met: 5.1. The stairway contains not more than two risers. 5.2. A handhold, positioned horizontally or vertically, is located on one side of the stairway adjacent to the top landing. 5.3. The handhold is located not less than 850 mm and not more than 1050 mm above the bottom landing of the stairway. 5.4. The handhold gripping surface complies with Section 1014.3, and is not less than 115 mm in length.	CONDITIONAL	1083	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0314	Section 1011.11	Handrails	Exception item 5.4. The handhold gripping surface complies with Section 1014.3, and is not less than 115 mm in length.	Sl: 115 mm	min	Per Section 1011.11 (Handrails).	## Exceptions: 1. Flights of stairways within dwelling units and flights of spiral stairways are permitted to have a handrail on one side only. 2. Decks, patios and walkways that have a single change in elevation where the landing depth on each side of the change of elevation is greater than what is required for a landing do not require handrails. 3. In Group R-3 occupancies, a change in elevation consisting of a single riser at an entrance or egress door does not require handrails. 4. Changes in room elevations of three or fewer risers within dwelling units and sleeping units in Group R-2 and R-3 do not require handrails. 5. Where a platform lift is in a stationary position and the floor of the platform lift serves as the upper landing of a stairway, handrails shall not be required on the stairway, provided that all of the following criteria are met: 5.1. The stairway contains not more than two risers. 5.2. A handhold, positioned horizontally or vertically, is located on one side of the stairway adjacent to the top landing. 5.3. The handhold is located not less than 850 mm and not more than 1050 mm above the bottom landing of the stairway. 5.4. The handhold gripping surface complies with Section 1014.3, and is not less than 115 mm in length.	CONDITIONAL	1083	Verified
CH10-0315	Section 1011.12	Stairway to roof	In buildings four or more stories above grade plane, one stairway shall extend to the roof surface unless the roof has a slope steeper than four units vertical in 12 units horizontal (33-percent slope).	Sl: four or more stories; one stairway; 33-percent; four units vertical in 12 units horizontal	trigger	Per Section 1011.12 (Stairway to roof).	Exception: Other than where required by Section 1011.12.1, in buildings without an occupied roof access to the roof from the top story shall be permitted to be by an alternating tread device, a ship's ladder or a permanent ladder.	CONDITIONAL	1084	Verified
CH10-0316	Section 1011.12.2	Roof access	Exception: In buildings without an occupied roof, access to the roof shall be permitted to be a roof hatch or trap door not less than 1.5 m (^{2}) in area and having a minimum dimension of 600 mm.	Sl: 1.5 m²; 600 mm	min	Per Section 1011.12.2 (Roof access).	Exception: In buildings without an occupied roof, access to the roof shall be permitted to be a roof hatch or trap door not less than 1.5 m (^{2}) in area and having a minimum dimension of 600 mm.	CONDITIONAL	1085	Verified
CH10-0317	Section 1011.13	Guards	Where the roof hatch opening providing the required access is located within 3000 mm of the roof edge, such roof access or roof edge shall be protected by guards installed in accordance with Section 1015.	Sl: 3000 mm	trigger	Per Section 1011.13 (Guards).	None stated in inventory	CONDITIONAL	1085	Verified
CH10-0318	Section 1011.14	Alternating tread devices	Alternating tread devices are limited to an element of a means of egress in buildings of Groups F, H and S from a mezzanine not more than (23 \, m^{2}) in area and that serves not more than five occupants: in buildings of Group I-3 from a guard tower, observation station or control room not more than (23 \, m^{2}) in area and for access to unoccupied roofs.	Sl: 23 m²; five occupants	max	Per Section 1011.14 (Alternating tread devices).	None stated in inventory	NOT_TYPICAL	1085	Verified
CH10-0319	Section 1011.14	Alternating tread devices	Alternating tread devices used as a means of egress shall not have a rise greater than 6000 mm between floor levels or landings.	Sl: 6000 mm	max	Per Section 1011.14 (Alternating tread devices).	None stated in inventory	CONDITIONAL	1085	Verified
CH10-0320	Section 1011.14.2	Treads of alternating tread devices	Alternating tread devices shall have a minimum tread depth of 125 mm, a minimum projected tread depth of 215 mm, a minimum tread width of 175 mm and a maximum riser height of 240 mm.	Sl: 125 mm; 215 mm; 175 mm; 240 mm	mixed	Per Section 1011.14.2 (Treads of alternating tread devices).	Exception: Alternating tread devices used as an element of a means of egress in buildings from a mezzanine area not more than (23 \, m^{2}) in area that serves not more than five occupants shall have a minimum tread depth of (75 \, mm) with a minimum projected tread depth of (265 \, mm) . The rise to the next alternating tread surface shall not exceed (200 \, mm) .	CONDITIONAL	1086	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0321	Section 1011.14.2	Treads of alternating tread devices	Exception: Alternating tread devices used as an element of a means of egress in buildings from a mezzanine area not more than ($23 \sqrt{m^2}$) in area that serves not more than five occupants shall have a minimum tread depth of ($75 \sqrt{mm}$) with a minimum projected tread depth of ($265 \sqrt{mm}$) . The rise to the next alternating tread surface shall not exceed ($200 \sqrt{mm}$) .	Sl: 23 m²; five occupants; 75 mm; 265 mm; 200 mm	mixed	Per Section 1011.14.2 (Treads of alternating tread devices).	Exception: Alternating tread devices used as an element of a means of egress in buildings from a mezzanine area not more than ($23 \sqrt{m^2}$) in area that serves not more than five occupants shall have a minimum tread depth of ($75 \sqrt{mm}$) with a minimum projected tread depth of ($265 \sqrt{mm}$) . The rise to the next alternating tread surface shall not exceed ($200 \sqrt{mm}$) .	CONDITIONAL	1086	Verified
CH10-0322	Section 1011.14.2	Treads of alternating tread devices	The riser height and tread depth provided shall result in an angle of ascent from the horizontal of between 50 and 70 degrees.	Sl: 70 degrees; 50 degrees	range	Per Section 1011.14.2 (Treads of alternating tread devices).	Exception: Alternating tread devices used as an element of a means of egress in buildings from a mezzanine area not more than ($23 \sqrt{m^2}$) in area that serves not more than five occupants shall have a minimum tread depth of ($75 \sqrt{mm}$) with a minimum projected tread depth of ($265 \sqrt{mm}$) . The rise to the next alternating tread surface shall not exceed ($200 \sqrt{mm}$) .	CONDITIONAL	1086	Verified
CH10-0323	Section 1011.15	Ship's ladders	Ship's ladders are permitted to be used in Group I-3 as a component of a means of egress to and from control rooms or elevated facility observation stations not more than 23 m² with not more than three occupants and for access to unoccupied roofs.	Sl: 23 m²; three occupants	max	Per Section 1011.15 (Ship's ladders).	None stated in inventory	NOT_TYPICAL	1086	Verified
CH10-0324	Section 1011.15	Ship's ladders	The minimum clear width at and below the handrails shall be 500 mm.	Sl: 500 mm	min	Per Section 1011.15 (Ship's ladders).	None stated in inventory	CONDITIONAL	1086	Verified
CH10-0325	Section 1011.15.2	Treads of ship's ladders	Ship's ladders shall have a minimum tread depth of 125 mm.	Sl: 125 mm	min	Per Section 1011.15.2 (Treads of ship's ladders).	None stated in inventory	CONDITIONAL	1086	Verified
CH10-0326	Section 1011.15.2	Treads of ship's ladders	The maximum riser height shall be 240 mm.	Sl: 240 mm	max	Per Section 1011.15.2 (Treads of ship's ladders).	None stated in inventory	CONDITIONAL	1086	Verified
CH10-0327	Section 1011.15.2	Treads of ship's ladders	The tread shall be projected such that the total of the tread depth plus the nosing projection is not less than 215 mm.	Sl: 215 mm	formula	Per Section 1011.15.2 (Treads of ship's ladders).	None stated in inventory	CONDITIONAL	1086	Verified

A.4.1012 — Section 1012 (17 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0328	Section 1012.2	Slope	Ramps used as part of a means of egress shall have a running slope not steeper than 1 unit vertical in 12 units horizontal (8.3-percent slope).	Sl: 1 unit vertical in 12 units horizontal; 8.3-percent	trigger	Per Section 1012.2 (Slope).	None stated in inventory	CONDITIONAL	1088	Verified
CH10-0329	Section 1012.2	Slope	The slope of other pedestrian ramps shall not be steeper than 1 unit vertical in 8 units horizontal (12.5-percent slope).	Sl: 1 unit vertical in 8 units horizontal; 12.5-percent	max	Per Section 1012.2 (Slope).	None stated in inventory	CONDITIONAL	1088	Verified
CH10-0330	Section 1012.3	Cross slope	The slope measured perpendicular to the direction of travel of a ramp shall not be steeper than one unit vertical in 48 units horizontal (2-percent slope).	Sl: one unit vertical in 48 units horizontal; 2-percent	max	Per Section 1012.3 (Cross slope).	None stated in inventory	CONDITIONAL	1088	Verified
CH10-0331	Section 1012.4	Vertical rise	The rise for any ramp run shall be 750 mm maximum.	Sl: 750 mm	max	Per Section 1012.4 (Vertical rise).	None stated in inventory	CONDITIONAL	1088	Verified
CH10-0332	Section 1012.5.1	Width and capacity	The clear width of a ramp between handrails, if provided, or other permissible projections shall be 900 mm minimum.	Sl: 900 mm	min	Per Section 1012.5.1 (Width and capacity).	None stated in inventory	CONDITIONAL	1088	Verified
CH10-0333	Section 1012.5.2	Headroom	The minimum headroom in all parts of the means of egress ramp shall be not less than 2000 mm above the finished floor of the ramp run and any intermediate landings.	Sl: 2000 mm	min	Per Section 1012.5.2 (Headroom).	None stated in inventory	CONDITIONAL	1088	Verified
CH10-0334	Section 1012.5.3	Restrictions	Doors opening onto a landing shall not reduce the clear width to less than 1100 mm.	Sl: 1100 mm	min	Per Section 1012.5.3 (Restrictions).	None stated in inventory	CONDITIONAL	1088	Verified
CH10-0335	Section 1012.6.1	Slope	Landings shall have a slope not steeper than one unit vertical in 48 units horizontal (2-percent slope) in any direction.	Sl: one unit vertical in 48 units horizontal; 2-percent	trigger	Per Section 1012.6.1 (Slope).	None stated in inventory	CONDITIONAL	1089	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0336	Section 1012.6.3	Length	Exception item 1. In Group R-2 and R-3 individual dwelling and sleeping units that are not required to be Accessible units, Type A units or Type B units in accordance with Section 1108, landings are permitted to be 900 mm minimum. 2. Where the ramp is not a part of an accessible route, the length of the landing shall not be required to be more than 1200 mm in the direction of travel.	Sl: 900 mm; 1200 mm	mixed	Per Section 1012.6.3 (Length).	Exceptions: 1. In Group R-2 and R-3 individual dwelling and sleeping units that are not required to be Accessible units, Type A units or Type B units in accordance with Section 1108, landings are permitted to be 900 mm minimum. 2. Where the ramp is not a part of an accessible route, the length of the landing shall not be required to be more than 1200 mm in the direction of travel.	CONDITIONAL	1089	Verified
CH10-0337	Section 1012.6.3	Length	The landing length shall be 1500 mm minimum.	Sl: 1500 mm	min	Per Section 1012.6.3 (Length).	Exceptions: 1. In Group R-2 and R-3 individual dwelling and sleeping units that are not required to be Accessible units, Type A units or Type B units in accordance with Section 1108, landings are permitted to be 900 mm minimum. 2. Where the ramp is not a part of an accessible route, the length of the landing shall not be required to be more than 1200 mm in the direction of travel.	CONDITIONAL	1089	Verified
CH10-0338	Section 1012.6.4	Change in direction	Exception: In Group R-2 and R-3 individual dwelling or sleeping units that are not required to be Accessible units, Type A units or Type B units in accordance with Section 1108, landings are permitted to be 900 mm by 900 mm minimum.	Sl: 900 mm	min	Per Section 1012.6.4 (Change in direction).	Exception: In Group R-2 and R-3 individual dwelling or sleeping units that are not required to be Accessible units, Type A units or Type B units in accordance with Section 1108, landings are permitted to be 900 mm by 900 mm minimum.	CONDITIONAL	1089	Verified
CH10-0339	Section 1012.6.4	Change in direction	Where changes in direction of travel occur at landings provided between ramp runs, the landing shall be 1500 mm by 1500 mm minimum.	Sl: 1500 mm	min	Per Section 1012.6.4 (Change in direction).	Exception: In Group R-2 and R-3 individual dwelling or sleeping units that are not required to be Accessible units, Type A units or Type B units in accordance with Section 1108, landings are permitted to be 900 mm by 900 mm minimum.	CONDITIONAL	1089	Verified
CH10-0340	Section 1012.8	Handrails	Ramps with a rise greater than 150 mm shall have handrails on both sides.	Sl: 150 mm	trigger	Per Section 1012.8 (Handrails).	None stated in inventory	CONDITIONAL	1090	Verified
CH10-0341	Section 1012.10	Edge protection	Exception item 3. Edge protection is not required on the sides of ramp landings having a vertical drop off of not more than 12.5 mm within 250 mm horizontally of the required landing area.	Sl: 12.5 mm; 250 mm	max	Per Section 1012.10 (Edge protection).	Exceptions: 1. Edge protection is not required on ramps that are not required to have handrails, provided they have flared sides that comply with the ICC A117.1 curb ramp provisions. 2. Edge protection is not required on the sides of ramp landings serving an adjoining ramp run or stairway. 3. Edge protection is not required on the sides of ramp landings having a vertical drop off of not more than 12.5 mm within 250 mm horizontally of the required landing area.	CONDITIONAL	1090	Verified
CH10-0342	Section 1012.10.1	Curb, rail, wall or barrier	A curb shall be not less than 100 mm in height.	Sl: 100 mm	min	Per Section 1012.10.1 (Curb, rail, wall or barrier).	None stated in inventory	CONDITIONAL	1091	Verified
CH10-0343	Section 1012.10.1	Curb, rail, wall or barrier	Barriers shall be constructed so that the barrier prevents the passage of a 100 mm diameter sphere, where any portion of the sphere is within 100 mm of the floor or ground surface.	Sl: 100 mm	trigger	Per Section 1012.10.1 (Curb, rail, wall or barrier).	None stated in inventory	CONDITIONAL	1091	Verified
CH10-0344	Section 1012.10.2	Extended floor or ground surface	The floor or ground surface of the ramp run, or landing shall extend 300 mm minimum beyond the inside face of a handrail complying with Section 1014.	Sl: 300 mm	min	Per Section 1012.10.2 (Extended floor or ground surface).	None stated in inventory	CONDITIONAL	1091	Verified

A.4.1013 — Section 1013 (10 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0345	Section 1013.1	Where required	Exception item 1. Exit signs are not required in rooms or areas that require only one exit or exit access.	Sl: one exit	trigger	Per Section 1013.1 (Where required).	Exceptions: 1. Exit signs are not required in rooms or areas that require only one exit or exit access. 2. Main exterior exit doors or gates that are obviously and clearly identifiable as exits need not have exit signs where approved by the building official. 3. Exit signs are not required in occupancies in Group U and individual sleeping units or dwelling units in Group R-1, R-2 or R-3. 4. Exit signs are not required in dayrooms, sleeping rooms or dormitories in occupancies in Group I-3. 5. In occupancies in Groups A-4 and A-5, exit signs are not required on the seating side of vomitories or openings into seating areas where exit signs are provided in the concourse that are readily apparent from the vomitories. Egress lighting is provided to identify each vomitory or opening within the seating area in an emergency.	CONDITIONAL	1091	Verified
CH10-0346	Section 1013.1	Where required	Exit sign placement shall be such that no point in an exit access corridor or exit passageway is more than 30 m or the listed viewing distance for the sign, whichever is less, from the nearest visible exit sign.	Sl: 30 m	trigger	Per Section 1013.1 (Where required).	Exceptions: 1. Exit signs are not required in rooms or areas that require only one exit or exit access. 2. Main exterior exit doors or gates that are obviously and clearly identifiable as exits need not have exit signs where approved by the building official. 3. Exit signs are not required in occupancies in Group U and individual sleeping units or dwelling units in Group R-1, R-2 or R-3. 4. Exit signs are not required in dayrooms, sleeping rooms or dormitories in occupancies in Group I-3. 5. In occupancies in Groups A-4 and A-5, exit signs are not required on the seating side of vomitories or openings into seating areas where exit signs are provided in the concourse that are readily apparent from the vomitories. Egress lighting is provided to identify each vomitory or opening within the seating area in an emergency.	DIRECT	1091	Verified
CH10-0347	Section 1013.2	Floor-level exit signs in Group R-1	The bottom of the sign shall be not less than 250 mm nor more than 450 mm above the floor level.	Sl: 250 mm; 450 mm	range	Per Section 1013.2 (Floor-level exit signs in Group R-1).	None stated in inventory	NOT_TYPICAL	1092	Verified
CH10-0348	Section 1013.2	Floor-level exit signs in Group R-1	Where mounted on the wall, the edge of the sign shall be within 100 mm of the door frame on the latch side.	Sl: 100 mm	trigger	Per Section 1013.2 (Floor-level exit signs in Group R-1).	None stated in inventory	NOT_TYPICAL	1092	Verified
CH10-0349	Section 1013.6.1	Graphics	Every exit sign and directional exit sign shall have plainly legible letters not less than 150 mm high with the principal strokes of the letters not less than 20 mm wide.	Sl: 150 mm; 20 mm	min	Per Section 1013.6.1 (Graphics).	None stated in inventory	DIRECT	1094	Verified
CH10-0350	Section 1013.6.1	Graphics	The word "EXIT" shall have letters having a width not less than 50 mm wide, except the letter "I," and the minimum spacing between letters shall be not less than 10 mm.	Sl: 50 mm; 10 mm	min	Per Section 1013.6.1 (Graphics).	None stated in inventory	DIRECT	1094	Verified
CH10-0351	Section 1013.6.2	Exit sign illumination	The face of an exit sign illuminated from an external source shall have an intensity of not less than 55 lux.	Sl: 55 lux	min	Per Section 1013.6.2 (Exit sign illumination).	None stated in inventory	DIRECT	1094	Verified
CH10-0352	Section 1013.6.3	Power source	Exception: Approved exit sign illumination types that provide continuous illumination independent of external power sources for a duration of not less than 90 minutes, in case of primary power loss, are not required to be connected to an emergency electrical system.	Sl: 90 minutes	min	Per Section 1013.6.3 (Power source).	Exception: Approved exit sign illumination types that provide continuous illumination independent of external power sources for a duration of not less than 90 minutes, in case of primary power loss, are not required to be connected to an emergency electrical system.	CONDITIONAL	1094	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0353	Section 1013.6.3	Power source	Group I-2 Condition 2 exit sign illumination shall not be provided by unit equipment batteries only.	Sl: 2 exit	trigger	Per Section 1013.6.3 (Power source).	Exception: Approved exit sign illumination types that provide continuous illumination independent of external power sources for a duration of not less than 90 minutes, in case of primary power loss, are not required to be connected to an emergency electrical system.	NOT_TYPICAL	1094	Verified
CH10-0354	Section 1013.6.3	Power source	To ensure continued illumination for a duration of not less than 90 minutes in case of primary power loss, the sign illumination means shall be connected to an emergency power system provided from storage batteries, unit equipment or an on-site generator.	Sl: 90 minutes	min	Per Section 1013.6.3 (Power source).	Exception: Approved exit sign illumination types that provide continuous illumination independent of external power sources for a duration of not less than 90 minutes, in case of primary power loss, are not required to be connected to an emergency electrical system.	DIRECT	1094	Verified

A.4.1014 — Section 1014 (18 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0355	Section 1014.2	Height	Handrail height of alternating tread devices and ship's ladders, measured above tread nosings, shall be uniform, not less than 750 mm and not more than 850 mm.	Sl: 750 mm; 850 mm	range	Per Section 1014.2 (Height).	Exceptions: 1. Where handrail fittings or bendings are used to provide continuous transition between flights, the fittings or bendings shall be permitted to exceed the maximum height. 2. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are associated with a Group R-3 occupancy or associated with individual dwelling units in Group R-2 occupancies; where handrail fittings or bendings are used to provide continuous transition between flights, transition at winder treads, transition from handrail to guard, or where used at the start of a flight, the handrail height at the fittings or bendings shall be permitted to exceed the maximum height. 3. Handrails on top of a guard where permitted along stepped aisles and ramped aisles in accordance with Section 1030.16.	CONDITIONAL	1095	Verified
CH10-0356	Section 1014.2	Height	Handrail height, measured above stair tread nosings, or finish surface of ramp slope, shall be uniform, not less than 850 mm and not more than 950 mm.	Sl: 850 mm; 950 mm	range	Per Section 1014.2 (Height).	Exceptions: 1. Where handrail fittings or bendings are used to provide continuous transition between flights, the fittings or bendings shall be permitted to exceed the maximum height. 2. In Group R-3 occupancies; within dwelling units in Group R-2 occupancies; and in Group U occupancies that are associated with a Group R-3 occupancy or associated with individual dwelling units in Group R-2 occupancies; where handrail fittings or bendings are used to provide continuous transition between flights, transition at winder treads, transition from handrail to guard, or where used at the start of a flight, the handrail height at the fittings or bendings shall be permitted to exceed the maximum height. 3. Handrails on top of a guard where permitted along stepped aisles and ramped aisles in accordance with Section 1030.16.	DIRECT	1095	Verified
CH10-0357	Section 1014.3.1	Type I	Edges shall have a minimum radius of 0.25 mm.	Sl: 0.25 mm	min	Per Section 1014.3.1 (Type I).	None stated in inventory	DIRECT	1096	Verified
CH10-0358	Section 1014.3.1	Type I	Handrails with a circular cross section shall have an outside diameter of not less than 32 mm and not greater than 50 mm.	Sl: 32 mm; 50 mm	range	Per Section 1014.3.1 (Type I).	None stated in inventory	DIRECT	1096	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0359	Section 1014.3.1	Type I	Where the handrail is not circular, it shall have a perimeter dimension of not less than 100 mm and not greater than 160 mm with a maximum cross-sectional dimension of 60 mm and minimum cross-sectional dimension of 25 mm.	Sl: 100 mm; 160 mm; 60 mm; 25 mm	range	Per Section 1014.3.1 (Type I).	None stated in inventory	DIRECT	1096	Verified
CH10-0360	Section 1014.3.2	Type II	Edges shall have a minimum radius of 0.25 mm.	Sl: 0.25 mm	min	Per Section 1014.3.2 (Type II).	None stated in inventory	DIRECT	1097	Verified
CH10-0361	Section 1014.3.2	Type II	Handrails with a perimeter greater than 160 mm shall provide a graspable finger recess area on both sides of the profile.	Sl: 160 mm	trigger	Per Section 1014.3.2 (Type II).	None stated in inventory	DIRECT	1097	Verified
CH10-0362	Section 1014.3.2	Type II	The finger recess shall begin within a distance of 20 mm measured vertically from the tallest portion of the profile and achieve a depth of not less than 8 mm within 22 mm below the widest portion of the profile.	Sl: 20 mm; 8 mm; 22 mm	min	Per Section 1014.3.2 (Type II).	None stated in inventory	DIRECT	1097	Verified
CH10-0363	Section 1014.3.2	Type II	The width of the handrail above the recess shall be not less than 32 mm to not greater than 70 mm.	Sl: 32 mm; 70 mm	range	Per Section 1014.3.2 (Type II).	None stated in inventory	DIRECT	1097	Verified
CH10-0364	Section 1014.3.2	Type II	This required depth shall continue for not less than 10 mm to a level that is not less than 45 mm below the tallest portion of the profile.	Sl: 10 mm; 45 mm	min	Per Section 1014.3.2 (Type II).	None stated in inventory	DIRECT	1097	Verified
CH10-0365	Section 1014.4	Continuity	Exception item 3. Handrail brackets or balusters attached to the bottom surface of the handrail that do not project horizontally beyond the sides of the handrail within 38 mm of the bottom of the handrail shall not be considered obstructions. For each 12.5 mm of additional handrail perimeter dimension above 100 mm, the vertical clearance dimension of 38 mm shall be permitted to be reduced by 3 mm.	Sl: 38 mm; 12.5 mm; 100 mm; 3 mm	mixed	Per Section 1014.4 (Continuity).	Exceptions: 1. Handrails within dwelling units are permitted to be interrupted by a newel post at a turn or landing. 2. Within a dwelling unit, the use of a volute, turnout, starting easing or starting newel is allowed over the lowest tread. 3. Handrail brackets or balusters attached to the bottom surface of the handrail that do not project horizontally beyond the sides of the handrail within 38 mm of the bottom of the handrail shall not be considered obstructions. For each 12.5 mm of additional handrail perimeter dimension above 100 mm, the vertical clearance dimension of 38 mm shall be permitted to be reduced by 3 mm. 4. Where handrails are provided along walking surfaces with slopes not steeper than 1.20, the bottoms of the handrail gripping surfaces shall be permitted to be obstructed along their entire length where they are integral to crash rails or bumper guards. 5. Handrails serving stepped aisles or ramped aisles are permitted to be discontinuous in accordance with Section 1030.16.1.	CONDITIONAL	1097	Verified
CH10-0366	Section 1014.6	Handrail extensions	At ramps where handrails are not continuous between runs, the handrails shall extend horizontally above the landing 300 mm minimum beyond the top and bottom of ramp runs.	Sl: 300 mm	min	Per Section 1014.6 (Handrail extensions).	Exceptions: 1. Handrails within a dwelling unit that is not required to be accessible need extend only from the top riser to the bottom riser. 2. Handrails serving aisles in rooms or spaces used for assembly purposes are permitted to comply with the handrail extensions in accordance with Section 1030.16. 3. Handrails for alternating tread devices and ship's ladders are permitted to terminate at a location vertically above the top and bottom risers. Handrails for alternating tread devices are not required to be continuous between flights or to extend beyond the top or bottom risers.	DIRECT	1098	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0367	Section 1014.6	Handrail extensions	Where handrails are not continuous between flights, the handrails shall extend horizontally not less than 300 mm beyond the top riser and continue to slope for the depth of one tread beyond the bottom riser.	Sl: 300 mm; one tread	min	Per Section 1014.6 (Handrail extensions).	Exceptions: 1. Handrails within a dwelling unit that is not required to be accessible need extend only from the top riser to the bottom riser. 2. Handrails serving aisles in rooms or spaces used for assembly purposes are permitted to comply with the handrail extensions in accordance with Section 1030.16. 3. Handrails for alternating tread devices and ship's ladders are permitted to terminate at a location vertically above the top and bottom risers. Handrails for alternating tread devices are not required to be continuous between flights or to extend beyond the top or bottom risers.	DIRECT	1098	Verified
CH10-0368	Section 1014.7	Clearance	Clear space between a handrail and a wall or other surface shall be not less than 38 mm.	Sl: 38 mm	min	Per Section 1014.7 (Clearance).	None stated in inventory	DIRECT	1099	Verified
CH10-0369	Section 1014.8	Projections	On ramps and on ramped aisles that are part of an accessible route, the clear width between handrails shall be 900 mm minimum.	Sl: 900 mm	min	Per Section 1014.8 (Projections).	None stated in inventory	CONDITIONAL	1099	Verified
CH10-0370	Section 1014.8	Projections	Projections into the required width of aisles, stairways and ramps at each side shall not exceed 115 mm at or below the handrail height.	Sl: 115 mm	max	Per Section 1014.8 (Projections).	None stated in inventory	DIRECT	1099	Verified
CH10-0371	Section 1014.8	Projections	Where a pair of intermediate handrails are provided within the stairway width without a walking surface between the pair of intermediate handrails and the distance between the pair of intermediate handrails is greater than 150 mm, the available egress width shall be reduced by the distance between the closest edges of each such intermediate pair of handrails that is greater than 150 mm.	Sl: 150 mm	trigger	Per Section 1014.8 (Projections).	None stated in inventory	DIRECT	1099	Verified
CH10-0372	Section 1014.9	Intermediate handrails	Stairways shall have intermediate handrails located in such a manner that all portions of the stairway minimum width or required capacity are within 750 mm of a handrail.	Sl: 750 mm	min	Per Section 1014.9 (Intermediate handrails).	None stated in inventory	DIRECT	1099	Verified

A.4.1015 — Section 1015 (24 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0373	Section 1015.1	General	Operable windows with sills located more than 1800 mm above finished grade or other surface below shall comply with Section 1015.8.	Sl: 1800 mm	trigger	Per Section 1015.1 (General).	None stated in inventory	DIRECT	1100	Verified
CH10-0374	Section 1015.2	Where required	Guards shall be located along open-sided walking surfaces, including mezzanines, equipment platforms, aisles, stairs, ramps and landings that are located more than 750 mm measured vertically to the floor or grade below at any point within 900 mm horizontally to the edge of the open side.	Sl: 750 mm; 900 mm	trigger	Per Section 1015.2 (Where required).	Exception: Guards are not required for the following locations: 1. On the loading side of loading docks or piers. 2. On the audience side of stages and raised platforms, including stairs leading up to the stage and raised platforms. 3. On raised stage and platform floor areas, such as runways, ramps and side stages used for entertainment or presentations. 4. At vertical openings in the performance area of stages and platforms. 5. At elevated walking surfaces appurtenant to stages and platforms for access to and utilization of special lighting or equipment. 6. Along vehicle service pits not accessible to the public. 7. In assembly seating areas at cross aisles in accordance with Section 1030.17.2. 8. On the loading side of station platforms on fixed guideway transit or passenger rail systems.	CONDITIONAL	1100	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0375	Section 1015.3	Height	Exception item 1. For occupancies in Group R-3 not more than three stories above grade in height and within individual dwelling units in occupancies in Group R-2 not more than three stories above grade in height with separate means of egress, required guards shall be not less than 900 mm in height measured vertically above the adjacent walking surfaces.	Sl: three stories; 900 mm	range	Per Section 1015.3 (Height).	1 From the adjacent walking surfaces. 2 On stairways and stepped aisles, from the line connecting the leading edges of the tread nosings. 3 On ramps and ramped aisles, from the ramp surface at the guard. Exceptions: 1. For occupancies in Group R-3 not more than three stories above grade in height and within individual dwelling units in occupancies in Group R-2 not more than three stories above grade in height with separate means of egress, required guards shall be not less than 900 mm in height measured vertically above the adjacent walking surfaces. 2. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, guards on the open sides of stairs shall have a height not less than 850 mm measured vertically from a line connecting the leading edges of the treads. 3. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, where the top of the guard also serves as a handrail on the open sides of stairs, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads. 4. The guard height in assembly seating areas shall comply with Section 1030.17 as applicable. 5. Along alternating tread devices and ship's ladders, guards where the top rail also serves as a handrail shall have height not less than 750 mm and not more than 850 mm, measured vertically from the leading edge of the device tread nosing. 6. In Group F occupancies where exit access stairways serve fewer than three stories and such stairways are not open to the public, and where the top of the guard also serves as a handrail, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads.	CONDITIONAL	1101	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0376	Section 1015.3	Height	Exception item 2. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, guards on the open sides of stairs shall have a height not less than 850 mm measured vertically from a line connecting the leading edges of the treads.	Sl: 850 mm	min	Per Section 1015.3 (Height).	1 From the adjacent walking surfaces. 2 On stairways and stepped aisles, from the line connecting the leading edges of the tread nosings. 3 On ramps and ramped aisles, from the ramp surface at the guard. Exceptions: 1. For occupancies in Group R-3 not more than three stories above grade in height and within individual dwelling units in occupancies in Group R-2 not more than three stories above grade in height with separate means of egress, required guards shall be not less than 900 mm in height measured vertically above the adjacent walking surfaces. 2. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, guards on the open sides of stairs shall have a height not less than 850 mm measured vertically from a line connecting the leading edges of the treads. 3. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, where the top of the guard also serves as a handrail on the open sides of stairs, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads. 4. The guard height in assembly seating areas shall comply with Section 1030.17 as applicable. 5. Along alternating tread devices and ship's ladders, guards where the top rail also serves as a handrail shall have height not less than 750 mm and not more than 850 mm, measured vertically from the leading edge of the device tread nosing. 6. In Group F occupancies where exit access stairways serve fewer than three stories and such stairways are not open to the public, and where the top of the guard also serves as a handrail, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads.	CONDITIONAL	1101	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0377	Section 1015.3	Height	Exception item 3. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, where the top of the guard also serves as a handrail on the open sides of stairs, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads.	Sl: 850 mm; 950 mm	range	Per Section 1015.3 (Height).	1 From the adjacent walking surfaces. 2 On stairways and stepped aisles, from the line connecting the leading edges of the tread nosings. 3 On ramps and ramped aisles, from the ramp surface at the guard. Exceptions: 1. For occupancies in Group R-3 not more than three stories above grade in height and within individual dwelling units in occupancies in Group R-2 not more than three stories above grade in height with separate means of egress, required guards shall be not less than 900 mm in height measured vertically above the adjacent walking surfaces. 2. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, guards on the open sides of stairs shall have a height not less than 850 mm measured vertically from a line connecting the leading edges of the treads. 3. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, where the top of the guard also serves as a handrail on the open sides of stairs, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads. 4. The guard height in assembly seating areas shall comply with Section 1030.17 as applicable. 5. Along alternating tread devices and ship's ladders, guards where the top rail also serves as a handrail shall have height not less than 750 mm and not more than 850 mm, measured vertically from the leading edge of the device tread nosing. 6. In Group F occupancies where exit access stairways serve fewer than three stories and such stairways are not open to the public, and where the top of the guard also serves as a handrail, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads.	CONDITIONAL	1101	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0378	Section 1015.3	Height	Exception item 5. Along alternating tread devices and ship's ladders, guards where the top rail also serves as a handrail shall have height not less than 750 mm and not more than 850 mm, measured vertically from the leading edge of the device tread nosing.	Sl: 750 mm; 850 mm	range	Per Section 1015.3 (Height).	1 From the adjacent walking surfaces. 2 On stairways and stepped aisles, from the line connecting the leading edges of the tread nosings. 3 On ramps and ramped aisles, from the ramp surface at the guard. Exceptions: 1. For occupancies in Group R-3 not more than three stories above grade in height and within individual dwelling units in occupancies in Group R-2 not more than three stories above grade in height with separate means of egress, required guards shall be not less than 900 mm in height measured vertically above the adjacent walking surfaces. 2. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, guards on the open sides of stairs shall have a height not less than 850 mm measured vertically from a line connecting the leading edges of the treads. 3. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, where the top of the guard also serves as a handrail on the open sides of stairs, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads. 4. The guard height in assembly seating areas shall comply with Section 1030.17 as applicable. 5. Along alternating tread devices and ship's ladders, guards where the top rail also serves as a handrail shall have height not less than 750 mm and not more than 850 mm, measured vertically from the leading edge of the device tread nosing. 6. In Group F occupancies where exit access stairways serve fewer than three stories and such stairways are not open to the public, and where the top of the guard also serves as a handrail, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads.	CONDITIONAL	1101	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0379	Section 1015.3	Height	Exception item 6. In Group F occupancies where exit access stairways serve fewer than three stories and such stairways are not open to the public, and where the top of the guard also serves as a handrail, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads.	Sl: three stories; 850 mm; 950 mm	range	Per Section 1015.3 (Height).	1 From the adjacent walking surfaces. 2 On stairways and stepped aisles, from the line connecting the leading edges of the tread nosings. 3 On ramps and ramped aisles, from the ramp surface at the guard. Exceptions: 1. For occupancies in Group R-3 not more than three stories above grade in height and within individual dwelling units in occupancies in Group R-2 not more than three stories above grade in height with separate means of egress, required guards shall be not less than 900 mm in height measured vertically above the adjacent walking surfaces. 2. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, guards on the open sides of stairs shall have a height not less than 850 mm measured vertically from a line connecting the leading edges of the treads. 3. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, where the top of the guard also serves as a handrail on the open sides of stairs, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads. 4. The guard height in assembly seating areas shall comply with Section 1030.17 as applicable. 5. Along alternating tread devices and ship's ladders, guards where the top rail also serves as a handrail shall have height not less than 750 mm and not more than 850 mm, measured vertically from the leading edge of the device tread nosing. 6. In Group F occupancies where exit access stairways serve fewer than three stories and such stairways are not open to the public, and where the top of the guard also serves as a handrail, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads.	NOT_TYPICAL	1101	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0380	Section 1015.3	Height	Required guards shall be not less than 1100 mm high, measured vertically as follows:	Sl: 1100 mm	min	Per Section 1015.3 (Height).	1 From the adjacent walking surfaces. 2 On stairways and stepped aisles, from the line connecting the leading edges of the tread nosings. 3 On ramps and ramped aisles, from the ramp surface at the guard. Exceptions: 1. For occupancies in Group R-3 not more than three stories above grade in height and within individual dwelling units in occupancies in Group R-2 not more than three stories above grade in height with separate means of egress, required guards shall be not less than 900 mm in height measured vertically above the adjacent walking surfaces. 2. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, guards on the open sides of stairs shall have a height not less than 850 mm measured vertically from a line connecting the leading edges of the treads. 3. For occupancies in Group R-3, and within individual dwelling units in occupancies in Group R-2, where the top of the guard also serves as a handrail on the open sides of stairs, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads. 4. The guard height in assembly seating areas shall comply with Section 1030.17 as applicable. 5. Along alternating tread devices and ship's ladders, guards where the top rail also serves as a handrail shall have height not less than 750 mm and not more than 850 mm, measured vertically from the leading edge of the device tread nosing. 6. In Group F occupancies where exit access stairways serve fewer than three stories and such stairways are not open to the public, and where the top of the guard also serves as a handrail, the top of the guard shall be not less than 850 mm and not more than 950 mm measured vertically from a line connecting the leading edges of the treads.	DIRECT	1101	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0381	Section 1015.4	Opening limitations	Exception item 1. From a height of 900 mm to 1100 mm, guards shall not have openings that allow passage of a sphere 110 mm in diameter.	Sl: 900 mm; 1100 mm; 110 mm	mixed	Per Section 1015.4 (Opening limitations).	Exceptions: 1. From a height of 900 mm to 1100 mm, guards shall not have openings that allow passage of a sphere 110 mm in diameter. 2. The triangular openings at the open sides of a stair, formed by the riser, tread and bottom rail shall not allow passage of a sphere 150 mm in diameter. 3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for alternating tread devices and ship's ladders, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 5. In assembly seating areas, guards required at the end of aisles in accordance with Section 1030.17.4 shall not have openings that allow passage of a sphere 100 mm in diameter up to a height of 650 mm. From a height of 650 mm to 1100 mm above the adjacent walking surfaces, guards shall not have openings that allow passage of a sphere 200 mm in diameter. 6. Within individual dwelling units and sleeping units in Group R-2 and R-3 occupancies, guards on the open sides of stairs shall not have openings that allow passage of a sphere 110 mm in diameter.	CONDITIONAL	1102	Verified
CH10-0382	Section 1015.4	Opening limitations	Exception item 2. The triangular openings at the open sides of a stair, formed by the riser, tread and bottom rail shall not allow passage of a sphere 150 mm in diameter.	Sl: 150 mm	max	Per Section 1015.4 (Opening limitations).	Exceptions: 1. From a height of 900 mm to 1100 mm, guards shall not have openings that allow passage of a sphere 110 mm in diameter. 2. The triangular openings at the open sides of a stair, formed by the riser, tread and bottom rail shall not allow passage of a sphere 150 mm in diameter. 3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for alternating tread devices and ship's ladders, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 5. In assembly seating areas, guards required at the end of aisles in accordance with Section 1030.17.4 shall not have openings that allow passage of a sphere 100 mm in diameter up to a height of 650 mm. From a height of 650 mm to 1100 mm above the adjacent walking surfaces, guards shall not have openings that allow passage of a sphere 200 mm in diameter. 6. Within individual dwelling units and sleeping units in Group R-2 and R-3 occupancies, guards on the open sides of stairs shall not have openings that allow passage of a sphere 110 mm in diameter.	CONDITIONAL	1102	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0383	Section 1015.4	Opening limitations	Exception item 3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, guards shall not have openings that allow passage of a sphere 525 mm in diameter.	Sl: 525 mm	max	Per Section 1015.4 (Opening limitations).	Exceptions: 1. From a height of 900 mm to 1100 mm, guards shall not have openings that allow passage of a sphere 110 mm in diameter. 2. The triangular openings at the open sides of a stair, formed by the riser, tread and bottom rail shall not allow passage of a sphere 150 mm in diameter. 3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for alternating tread devices and ship's ladders, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 5. In assembly seating areas, guards required at the end of aisles in accordance with Section 1030.17.4 shall not have openings that allow passage of a sphere 100 mm in diameter up to a height of 650 mm. From a height of 650 mm to 1100 mm above the adjacent walking surfaces, guards shall not have openings that allow passage of a sphere 200 mm in diameter. 6. Within individual dwelling units and sleeping units in Group R-2 and R-3 occupancies, guards on the open sides of stairs shall not have openings that allow passage of a sphere 110 mm in diameter.	CONDITIONAL	1102	Verified
CH10-0384	Section 1015.4	Opening limitations	Exception item 4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for alternating tread devices and ship's ladders, guards shall not have openings that allow passage of a sphere 525 mm in diameter.	Sl: 525 mm	max	Per Section 1015.4 (Opening limitations).	Exceptions: 1. From a height of 900 mm to 1100 mm, guards shall not have openings that allow passage of a sphere 110 mm in diameter. 2. The triangular openings at the open sides of a stair, formed by the riser, tread and bottom rail shall not allow passage of a sphere 150 mm in diameter. 3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for alternating tread devices and ship's ladders, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 5. In assembly seating areas, guards required at the end of aisles in accordance with Section 1030.17.4 shall not have openings that allow passage of a sphere 100 mm in diameter up to a height of 650 mm. From a height of 650 mm to 1100 mm above the adjacent walking surfaces, guards shall not have openings that allow passage of a sphere 200 mm in diameter. 6. Within individual dwelling units and sleeping units in Group R-2 and R-3 occupancies, guards on the open sides of stairs shall not have openings that allow passage of a sphere 110 mm in diameter.	NOT_TYPICAL	1102	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0385	Section 1015.4	Opening limitations	Exception item 5. In assembly seating areas, guards required at the end of aisles in accordance with Section 1030.17.4 shall not have openings that allow passage of a sphere 100 mm in diameter up to a height of 650 mm. From a height of 650 mm to 1100 mm above the adjacent walking surfaces, guards shall not have openings that allow passage of a sphere 200 mm in diameter.	Sl: 100 mm; 650 mm; 1100 mm; 200 mm	mixed	Per Section 1015.4 (Opening limitations).	Exceptions: 1. From a height of 900 mm to 1100 mm, guards shall not have openings that allow passage of a sphere 110 mm in diameter. 2. The triangular openings at the open sides of a stair, formed by the riser, tread and bottom rail shall not allow passage of a sphere 150 mm in diameter. 3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for alternating tread devices and ship's ladders, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 5. In assembly seating areas, guards required at the end of aisles in accordance with Section 1030.17.4 shall not have openings that allow passage of a sphere 100 mm in diameter up to a height of 650 mm. From a height of 650 mm to 1100 mm above the adjacent walking surfaces, guards shall not have openings that allow passage of a sphere 200 mm in diameter. 6. Within individual dwelling units and sleeping units in Group R-2 and R-3 occupancies, guards on the open sides of stairs shall not have openings that allow passage of a sphere 110 mm in diameter.	CONDITIONAL	1102	Verified
CH10-0386	Section 1015.4	Opening limitations	Exception item 6. Within individual dwelling units and sleeping units in Group R-2 and R-3 occupancies, guards on the open sides of stairs shall not have openings that allow passage of a sphere 110 mm in diameter.	Sl: 110 mm	max	Per Section 1015.4 (Opening limitations).	Exceptions: 1. From a height of 900 mm to 1100 mm, guards shall not have openings that allow passage of a sphere 110 mm in diameter. 2. The triangular openings at the open sides of a stair, formed by the riser, tread and bottom rail shall not allow passage of a sphere 150 mm in diameter. 3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for alternating tread devices and ship's ladders, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 5. In assembly seating areas, guards required at the end of aisles in accordance with Section 1030.17.4 shall not have openings that allow passage of a sphere 100 mm in diameter up to a height of 650 mm. From a height of 650 mm to 1100 mm above the adjacent walking surfaces, guards shall not have openings that allow passage of a sphere 200 mm in diameter. 6. Within individual dwelling units and sleeping units in Group R-2 and R-3 occupancies, guards on the open sides of stairs shall not have openings that allow passage of a sphere 110 mm in diameter.	CONDITIONAL	1102	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0387	Section 1015.4	Opening limitations	Required guards shall not have openings that allow passage of a sphere 100 mm in diameter from the walking surface to the required guard height.	Sl: 100 mm	max	Per Section 1015.4 (Opening limitations).	Exceptions: 1. From a height of 900 mm to 1100 mm, guards shall not have openings that allow passage of a sphere 110 mm in diameter. 2. The triangular openings at the open sides of a stair, formed by the riser, tread and bottom rail shall not allow passage of a sphere 150 mm in diameter. 3. At elevated walking surfaces for access to and use of electrical, mechanical or plumbing systems or equipment, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 4. In areas that are not open to the public within occupancies in Group I-3, F, H or S, and for alternating tread devices and ship's ladders, guards shall not have openings that allow passage of a sphere 525 mm in diameter. 5. In assembly seating areas, guards required at the end of aisles in accordance with Section 1030.17.4 shall not have openings that allow passage of a sphere 100 mm in diameter up to a height of 650 mm. From a height of 650 mm to 1100 mm above the adjacent walking surfaces, guards shall not have openings that allow passage of a sphere 200 mm in diameter. 6. Within individual dwelling units and sleeping units in Group R-2 and R-3 occupancies, guards on the open sides of stairs shall not have openings that allow passage of a sphere 110 mm in diameter.	DIRECT	1102	Verified
CH10-0388	Section 1015.5	Screen porches	Porches and decks that are enclosed with insect screening shall be provided with guards where the walking surface is located more than 750 mm above the floor or grade below.	Sl: 750 mm	trigger	Per Section 1015.5 (Screen porches).	None stated in inventory	DIRECT	1103	Verified
CH10-0389	Section 1015.6	Mechanical equipment, systems and devices	Guards shall be provided where various components that require service are located within 3000 mm of a roof edge or open side of a walking surface and such edge or open side is located more than 750 mm above the floor, roof or grade below.	Sl: 3000 mm; 750 mm	trigger	Per Section 1015.6 (Mechanical equipment, systems and devices).	Exception: Guards are not required where fall arrest/restraint anchorage connector devices that comply with ANSI/ASSE Z 359.1 are installed.	CONDITIONAL	1103	Verified
CH10-0390	Section 1015.6	Mechanical equipment, systems and devices	The guard shall be constructed so as to prevent the passage of a sphere 525 mm in diameter.	Sl: 525 mm	trigger	Per Section 1015.6 (Mechanical equipment, systems and devices).	Exception: Guards are not required where fall arrest/restraint anchorage connector devices that comply with ANSI/ASSE Z 359.1 are installed.	DIRECT	1103	Verified
CH10-0391	Section 1015.6	Mechanical equipment, systems and devices	The guard shall extend not less than 750 mm beyond each end of such components.	Sl: 750 mm	min	Per Section 1015.6 (Mechanical equipment, systems and devices).	Exception: Guards are not required where fall arrest/restraint anchorage connector devices that comply with ANSI/ASSE Z 359.1 are installed.	DIRECT	1103	Verified
CH10-0392	Section 1015.7	Roof access	Guards shall be provided where the roof hatch opening is located within 3 m of a roof edge or open side of a walking surface and such edge or open side is located more than 750 mm above the floor, roof or grade below.	Sl: 3 m; 750 mm	trigger	Per Section 1015.7 (Roof access).	Exception: Guards are not required where fall arrest/restraint anchorage connector devices that comply with ANSI/ASSE Z 359.1 are installed	CONDITIONAL	1103	Verified
CH10-0393	Section 1015.7	Roof access	The guard shall be constructed so as to prevent the passage of a sphere 525 mm in diameter.	Sl: 525 mm	trigger	Per Section 1015.7 (Roof access).	Exception: Guards are not required where fall arrest/restraint anchorage connector devices that comply with ANSI/ASSE Z 359.1 are installed	CONDITIONAL	1103	Verified
CH10-0394	Section 1015.7	Roof access	The guard shall extend not less than 750 mm beyond each end of the hatch parallel to the roof edge.	Sl: 750 mm	min	Per Section 1015.7 (Roof access).	Exception: Guards are not required where fall arrest/restraint anchorage connector devices that comply with ANSI/ASSE Z 359.1 are installed	CONDITIONAL	1103	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0395	Section 1015.8	Window openings	Windows in Group R-2 and R-3 buildings including dwelling units, where the bottom of the clear opening of an operable window is located less than 900 mm above the finished floor and more than 1800 mm above the finished grade or other surface below on the exterior of the building, shall comply with one of the following: 1 Operable windows where the top of the sill of the opening is located more than 23 m above the finished grade or other surface below and that are provided with window fall prevention devices that comply with ASTM F2006.	Sl: 900 mm; 1800 mm; 23 m	mixed	Per Section 1015.8 (Window openings).	None stated in inventory	DIRECT	1103	Verified
CH10-0396	Section 1015.8	Window openings — Item 2 sphere limit	2 Operable windows where the openings will not allow a 100 mm-diameter sphere to pass through the opening when the window is in its largest opened position.	Sl: 100 mm	max	Operable Group R-2 or R-3 window subject to Section 1015.8 using Item 2.	None stated in inventory	DIRECT	1103	Verified

A.4.1016 — Section 1016 (5 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0397	Section 1016.2	Egress through intervening spaces	Exception item 1 Exit access through an enclosed elevator lobby is permitted. Where access to two or more exits or exit access doorways is required in Section 1006.2.1, access to not less than one of the required exits shall be provided without travel through the enclosed elevator lobbies required by Section 3006. Where the path of exit access travel passes through an enclosed elevator lobby, the level of protection required for the enclosed elevator lobby is not required to be extended to the exit unless direct access to an exit is required by other sections of this code.	Sl: one required exit; two or more exits	mixed	Per Section 1016.2 (Egress through intervening spaces).	1 Exit access through an enclosed elevator lobby is permitted. Where access to two or more exits or exit access doorways is required in Section 1006.2.1, access to not less than one of the required exits shall be provided without travel through the enclosed elevator lobbies required by Section 3006. Where the path of exit access travel passes through an enclosed elevator lobby, the level of protection required for the enclosed elevator lobby is not required to be extended to the exit unless direct access to an exit is required by other sections of this code. 2 Egress from a room or space shall not pass through adjoining or intervening rooms or areas, except where such adjoining rooms or areas and the area served are accessory to one or the other, are not a Group H occupancy and provide a discernible path of egress travel to an exit. Exception: Means of egress are not prohibited through adjoining or intervening rooms or spaces in a Group H, S or F occupancy where the adjoining or intervening rooms or spaces are the same or a lesser hazard occupancy group. 3 An exit access shall not pass through a room that can be locked to prevent egress. 4 Means of egress from dwelling units or sleeping areas shall not lead through other sleeping areas, toilet rooms or bathrooms. 5 Egress shall not pass through kitchens, storage rooms, closets or spaces used for similar purposes. Exceptions: 1. Means of egress are not prohibited through a kitchen area serving adjoining rooms constituting part of the same dwelling unit or sleeping unit. 2. Means of egress are not prohibited through stockrooms in Group M occupancies where all of the following are met: 2.1. The stock is of the same hazard classification as that found in the main retail area. 2.2. Not more than 50 percent of the exit access is through the stockroom. 2.3. The stockroom is not subject to locking from the egress side. 2.4. There is a demarcated, minimum 1100 mm-wide aisle defined by full- or partial-height fixed walls or similar construction that will maintain the required width and lead directly from the retail area to the exit without obstructions.	CONDITIONAL	1105	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0398	Section 1016.2	Egress through intervening spaces	Exception item 2.2. Not more than 50 percent of the exit access is through the stockroom.	Sl: 50 percent	max	Per Section 1016.2 (Egress through intervening spaces).	1 Exit access through an enclosed elevator lobby is permitted. Where access to two or more exits or exit access doorways is required in Section 1006.2.1, access to not less than one of the required exits shall be provided without travel through the enclosed elevator lobbies required by Section 3006. Where the path of exit access travel passes through an enclosed elevator lobby, the level of protection required for the enclosed elevator lobby is not required to be extended to the exit unless direct access to an exit is required by other sections of this code. 2 Egress from a room or space shall not pass through adjoining or intervening rooms or areas, except where such adjoining rooms or areas and the area served are accessory to one or the other, are not a Group H occupancy and provide a discernible path of egress travel to an exit. Exception: Means of egress are not prohibited through adjoining or intervening rooms or spaces in a Group H, S or F occupancy where the adjoining or intervening rooms or spaces are the same or a lesser hazard occupancy group. 3 An exit access shall not pass through a room that can be locked to prevent egress. 4 Means of egress from dwelling units or sleeping areas shall not lead through other sleeping areas, toilet rooms or bathrooms. 5 Egress shall not pass through kitchens, storage rooms, closets or spaces used for similar purposes. Exceptions: 1. Means of egress are not prohibited through a kitchen area serving adjoining rooms constituting part of the same dwelling unit or sleeping unit. 2. Means of egress are not prohibited through stockrooms in Group M occupancies where all of the following are met: 2.1. The stock is of the same hazard classification as that found in the main retail area. 2.2. Not more than 50 percent of the exit access is through the stockroom. 2.3. The stockroom is not subject to locking from the egress side. 2.4. There is a demarcated, minimum 1100 mm-wide aisle defined by full- or partial-height fixed walls or similar construction that will maintain the required width and lead directly from the retail area to the exit without obstructions.	CONDITIONAL	1105	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0399	Section 1016.2	Egress through intervening spaces	Exception item 2.4. There is a demarcated, minimum 1100 mm-wide aisle defined by full- or partial-height fixed walls or similar construction that will maintain the required width and lead directly from the retail area to the exit without obstructions.	Sl: 1100 mm	min	Per Section 1016.2 (Egress through intervening spaces).	1 Exit access through an enclosed elevator lobby is permitted. Where access to two or more exits or exit access doorways is required in Section 1006.2.1, access to not less than one of the required exits shall be provided without travel through the enclosed elevator lobbies required by Section 3006. Where the path of exit access travel passes through an enclosed elevator lobby, the level of protection required for the enclosed elevator lobby is not required to be extended to the exit unless direct access to an exit is required by other sections of this code. 2 Egress from a room or space shall not pass through adjoining or intervening rooms or areas, except where such adjoining rooms or areas and the area served are accessory to one or the other, are not a Group H occupancy and provide a discernible path of egress travel to an exit. Exception: Means of egress are not prohibited through adjoining or intervening rooms or spaces in a Group H, S or F occupancy where the adjoining or intervening rooms or spaces are the same or a lesser hazard occupancy group. 3 An exit access shall not pass through a room that can be locked to prevent egress. 4 Means of egress from dwelling units or sleeping areas shall not lead through other sleeping areas, toilet rooms or bathrooms. 5 Egress shall not pass through kitchens, storage rooms, closets or spaces used for similar purposes. Exceptions: 1. Means of egress are not prohibited through a kitchen area serving adjoining rooms constituting part of the same dwelling unit or sleeping unit. 2. Means of egress are not prohibited through stockrooms in Group M occupancies where all of the following are met: 2.1. The stock is of the same hazard classification as that found in the main retail area. 2.2. Not more than 50 percent of the exit access is through the stockroom. 2.3. The stockroom is not subject to locking from the egress side. 2.4. There is a demarcated, minimum 1100 mm-wide aisle defined by full- or partial-height fixed walls or similar construction that will maintain the required width and lead directly from the retail area to the exit without obstructions.	CONDITIONAL	1105	Verified
CH10-0400	Section 1016.2.1	Multiple tenants	Exception: The means of egress from a smaller tenant space shall not be prohibited from passing through a larger adjoining tenant space where such rooms or spaces of the smaller tenant occupy less than 10 percent of the area of the larger tenant space through which they pass; are the same or similar occupancy group; a discernible path of egress travel to an exit is provided; and the means of egress into the adjoining space is not subject to locking from the egress side. A required means of egress serving the larger tenant space shall not pass through the smaller tenant space or spaces.	Sl: 10 percent	max	Per Section 1016.2.1 (Multiple tenants).	Exception: The means of egress from a smaller tenant space shall not be prohibited from passing through a larger adjoining tenant space where such rooms or spaces of the smaller tenant occupy less than 10 percent of the area of the larger tenant space through which they pass; are the same or similar occupancy group; a discernible path of egress travel to an exit is provided; and the means of egress into the adjoining space is not subject to locking from the egress side. A required means of egress serving the larger tenant space shall not pass through the smaller tenant space or spaces.	CONDITIONAL	1106	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0401	Section 1016.2.1	Multiple tenants	Where more than one tenant occupies any one floor of a building or structure, each tenant space, dwelling unit and sleeping unit shall be provided with access to the required exits without passing through adjacent tenant spaces, dwelling units and sleeping units.	Sl: one tenant; one floor	trigger	Per Section 1016.2.1 (Multiple tenants).	Exception: The means of egress from a smaller tenant space shall not be prohibited from passing through a larger adjoining tenant space where such rooms or spaces of the smaller tenant occupy less than 10 percent of the area of the larger tenant space through which they pass; are the same or similar occupancy group; a discernible path of egress travel to an exit is provided; and the means of egress into the adjoining space is not subject to locking from the egress side. A required means of egress serving the larger tenant space shall not pass through the smaller tenant space or spaces.	DIRECT	1106	Verified

A.4.1017 — Section 1017 (16 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0402	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy A, E, F-1, I-1, M, R and S-1, the flattened OCR row reads “60” / 75”. Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy A, E, F-1, I-1, M, R and S-1; without-sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	EXTERNAL_VERIFY	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0403	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy B, the flattened OCR row reads "60 / 90". Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy B; without-sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0404	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy F-2, S-2 and U, the flattened OCR row reads “90 / 120”. Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy F-2, S-2 and U; without- sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0405	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy H-1, the flattened OCR row reads “Not Permitted / 23’”. Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy H-1; without-sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0406	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy H-2, the flattened OCR row reads “Not Permitted / 30’”. Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy H-2; without-sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0407	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy H-3, the flattened OCR row reads “Not Permitted / 46’”. Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy H-3; without-sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0408	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy H-4, the flattened OCR row reads “Not Permitted / 53”. Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy H-4; without-sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0409	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy H-5, the flattened OCR row reads “Not Permitted / 60’”. Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy H-5; without-sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0410	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy I-1 (duplicate OCR row), the flattened OCR row reads "Not permitted / 75 ^{0"} . Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy I-1 (duplicate OCR row); without-sprinkler and with- sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0411	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy I-2 and I-3, the flattened OCR row reads “Not Permitted / 60 [”] . Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy I-2 and I-3; without- sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0412	Table 1017.2 (appended-table row); Section 1017.2	Exit access travel distance — unresolved OCR row	Occupancy I-4, the flattened OCR row reads “46 / 60”. Numeric limits and superscript or footnote markers are unresolved; verify the published table before use.	No value adopted — OCR/source verification required	trigger	Occupancy I-4; without-sprinkler and with-sprinkler columns require source verification.	a. See Section 402.8 for the distance limitation in malls. a. See Section 407.4 for the distance limitation in Group I-2. a. See Sections 408.6.1 and 408.8.1 for the distance limitations in Group I-3. a. See Section 411.2 for the distance limitation in special amusement areas. a. See Section 412.6 for the distance limitations in aircraft manufacturing facilities. a. See Section 1006.2.2.2 for the distance limitation in refrigeration machinery rooms. a. See Section 1006.2.2.3 for the distance limitation in refrigerated rooms and spaces. a. See Section 1006.3.4 for buildings with one exit. a. See Section 1017.2.2 for increased distance limitation in Groups F-1 and S-1. a. See Section 1030.7 for increased limitation in assembly seating. a. See Section 3103.4 for temporary structures. a. See Section 3104.9 for pedestrian walkways. b. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. See Section 903 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.2. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1. d. Group H occupancies equipped throughout with an automatic sprinkler system in accordance with Section 903.2.5.1. e. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1180	Verify source
CH10-0413	Section 1017.2.1	Exterior egress balcony increase	Exit access travel distances specified in Table 1017.2 shall be increased up to an additional 30 m provided the last portion of the exit access leading to the exit occurs on an exterior egress balcony constructed in accordance with Section 1021.	Sl: 30 m	max	Per Section 1017.2.1 (Exterior egress balcony increase).	None stated in inventory	CONDITIONAL	1108	Verified
CH10-0414	Section 1017.2.2	Group F-1 and S-1 increase	Item 2 The minimum height from the finished floor to the bottom of the ceiling or roof slab or deck is 7300 mm.	Sl: 7300 mm	min	Per Section 1017.2.2 (Group F-1 and S-1 increase).	1 The portion of the building classified as Group F-1 or S-1 is limited to one story in height. 2 The minimum height from the finished floor to the bottom of the ceiling or roof slab or deck is 7300 mm. 3 The building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1.	NOT_TYPICAL	1108	Verified
CH10-0415	Section 1017.2.2	Group F-1 and S-1 increase	The maximum exit access travel distance shall be 120 m in Group F-1 or S-1 occupancies where all of the following conditions are met:	Sl: 120 m	max	Per Section 1017.2.2 (Group F-1 and S-1 increase).	1 The portion of the building classified as Group F-1 or S-1 is limited to one story in height. 2 The minimum height from the finished floor to the bottom of the ceiling or roof slab or deck is 7300 mm. 3 The building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1.	NOT_TYPICAL	1108	Verified
CH10-0416	Section 1017.3	Measurement	Where more than one exit is required, exit access travel distance shall be measured to the nearest exit.	Sl: one exit	trigger	Per Section 1017.3 (Measurement).	Exceptions: 1. In open parking garages, exit access travel distance is permitted to be measured to the closest riser of an exit access stairway or the closest slope of an exit access ramp. 2. In smoke protected seating and open-air assembly seating, exit access travel	DIRECT	1108	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0417	Section 1017.3.2.3	Exit access travel distance at other than the level of exit discharge	Where the path of egress travel is not at the level of exit discharge from the atrium, that portion of the total permitted exit access travel distance that occurs within the atrium shall be not greater than 60 m.	Sl: 60 m	max	Per Section 1017.3.2.3 (Exit access travel distance at other than the level of exit discharge).	None stated in inventory	CONDITIONAL	1110	Verified

A.4.1018 — Section 1018 (7 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0418	Section 1018.3	Aisles in Groups B and M	Exception: Non-public aisles serving less than 50 people and not required to be accessible by Chapter 11 need not exceed 700 mm in width.	Sl: 700 mm; 50 people	mixed	Per Section 1018.3 (Aisles in Groups B and M).	Exception: Non-public aisles serving less than 50 people and not required to be accessible by Chapter 11 need not exceed 700 mm in width.	CONDITIONAL	1111	Verified
CH10-0419	Section 1018.4	Aisle access-ways in Group M	An aisle access-way shall be provided on not less than one side of each element within the merchandise pad.	Sl: one side	min	Per Section 1018.4 (Aisle access-ways in Group M).	None stated in inventory	NOT_TYPICAL	1111	Verified
CH10-0420	Section 1018.4	Aisle access-ways in Group M	Exception: For areas serving not more than 50 occupants, the common path of egress travel shall not exceed 23 m.	Sl: 50 occupants; 23 m	max	Per Section 1018.4 (Aisle access-ways in Group M).	None stated in inventory	NOT_TYPICAL	1111	Verified
CH10-0421	Section 1018.4	Aisle access-ways in Group M	The 750 mm minimum clear width shall be maintained to provide a path to an adjacent aisle or aisle access-way.	Sl: 750 mm	min	Per Section 1018.4 (Aisle access-ways in Group M).	None stated in inventory	NOT_TYPICAL	1111	Verified
CH10-0422	Section 1018.4	Aisle access-ways in Group M	The common path of egress travel shall not exceed 9 m from any point in the merchandise pad.	Sl: 9 m	max	Per Section 1018.4 (Aisle access-ways in Group M).	None stated in inventory	NOT_TYPICAL	1111	Verified
CH10-0423	Section 1018.4	Aisle access-ways in Group M	The minimum clear width for an aisle access-way not required to be accessible shall be 750 mm.	Sl: 750 mm	min	Per Section 1018.4 (Aisle access-ways in Group M).	None stated in inventory	NOT_TYPICAL	1111	Verified
CH10-0424	Section 1018.5	Aisles in other than assembly spaces and Groups B and M	Exception: Nonpublic aisles serving less than 50 people and not required to be accessible by Chapter 11 need not exceed 700 mm in width.	Sl: 700 mm; 50 people	mixed	Per Section 1018.5 (Aisles in other than assembly spaces and Groups B and M).	Exception: Nonpublic aisles serving less than 50 people and not required to be accessible by Chapter 11 need not exceed 700 mm in width.	CONDITIONAL	1111	Verified

A.4.1019 — Section 1019 (1 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0425	Section 1019.3	Occupancies other than Groups I-2 and I-3	Item 1 Exit access stairways and ramps that serve or atmospherically communicate between only two adjacent stories. Such inter-connected stories shall not be open to other stories.	Sl: two adjacent stories	max	Per Section 1019.3 (Occupancies other than Groups I-2 and I-3).	1 Exit access stairways and ramps that serve or atmospherically communicate between only two adjacent stories. Such inter-connected stories shall not be open to other stories.	CONDITIONAL	1112	Verified

A.4.1020 — Section 1020 (21 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0426	Section 1020.2	Construction	Exception item 1. A fire-resistance rating is not required for corridors in an occupancy in Group E where each room that is used for instruction has not less than one door opening directly to the exterior and rooms for assembly purposes have not less than one-half of the required means of egress doors opening directly to the exterior. Exterior doors specified in this exception are required to be at ground level.	Sl: one door; one-half	mixed	Per Section 1020.2 (Construction).	## Exceptions: 1. A fire-resistance rating is not required for corridors in an occupancy in Group E where each room that is used for instruction has not less than one door opening directly to the exterior and rooms for assembly purposes have not less than one-half of the required means of egress doors opening directly to the exterior. Exterior doors specified in this exception are required to be at ground level. 2. A fire-resistance rating is not required for corridors contained within a dwelling unit or sleeping unit in an occupancy in Groups I-1 and R. 3. A fire-resistance rating is not required for corridors in open parking garages. 4. A fire-resistance rating is not required for corridors in an occupancy in Group B that is a space requiring only a single means of egress complying with Section 1006.2. 5. Corridors adjacent to the exterior walls of buildings shall be permitted to have unprotected openings on unrated exterior walls where unrated walls are permitted by Table 705.5 and unprotected openings are permitted by Table 705.8.	NOT_TYPICAL	1114	Verified
CH10-0427	Table 1020.2 — corridor rating (appended-table row); Section 1020.2	Corridor fire-resistance rating	For Group R corridors serving an occupant load greater than 10 occupants, the OCR table shows Not Permitted without sprinklers and an ambiguous sprinklered fire-resistance rating of 0.5/1 hours; verify the published table and footnote d before selecting either rating.	Sl: occupant load greater than 10; 0.5/1 hours; 10 occupants	trigger	R; occupant load greater than 10	a. For requirements for occupancies in Group I-2, see Sections 407.2 and 407.3. b. For a reduction in the fire-resistance rating for occupancies in Group I-3, see Section 408.8. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 where allowed. d. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	EXTERNAL_VERIFY	1181	Verify source
CH10-0428	Table 1020.2 — corridor rating (appended-table row); Section 1020.2	Corridor fire-resistance rating	Required corridor fire-resistance rating is 1 hour without sprinklers and 0 hours with the applicable sprinkler system.	Sl: 1 hour; 0 hours	trigger	A, B, E, F, M, S and U; occupant load greater than 30	a. For requirements for occupancies in Group I-2, see Sections 407.2 and 407.3. b. For a reduction in the fire-resistance rating for occupancies in Group I-3, see Section 408.8. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 where allowed. d. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1181	Verify source
CH10-0429	Table 1020.2 — corridor rating (appended-table row); Section 1020.2	Corridor fire-resistance rating	Required corridor fire-resistance rating is 1 hour without sprinklers and 0 hours with the applicable sprinkler system.	Sl: 1 hour; 0 hours	trigger	I-4; all occupant loads	a. For requirements for occupancies in Group I-2, see Sections 407.2 and 407.3. b. For a reduction in the fire-resistance rating for occupancies in Group I-3, see Section 408.8. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 where allowed. d. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1181	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0430	Table 1020.2 — corridor rating (appended-table row); Section 1020.2	Corridor fire-resistance rating	Required corridor fire-resistance rating is Not Permitted without sprinklers and 0 hours with the applicable sprinkler system.	Sl: 0 hours	trigger	I-2; all occupant loads	a. For requirements for occupancies in Group I-2, see Sections 407.2 and 407.3. b. For a reduction in the fire-resistance rating for occupancies in Group I-3, see Section 408.8. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 where allowed. d. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1181	Verify source
CH10-0431	Table 1020.2 — corridor rating (appended-table row); Section 1020.2	Corridor fire-resistance rating	Required corridor fire-resistance rating is Not Permitted without sprinklers and 1 hour with the applicable sprinkler system.	Sl: 1 hour	trigger	H-1, H-2 and H-3; all occupant loads	a. For requirements for occupancies in Group I-2, see Sections 407.2 and 407.3. b. For a reduction in the fire-resistance rating for occupancies in Group I-3, see Section 408.8. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 where allowed. d. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1181	Verify source
CH10-0432	Table 1020.2 — corridor rating (appended-table row); Section 1020.2	Corridor fire-resistance rating	Required corridor fire-resistance rating is Not Permitted without sprinklers and 1 hour with the applicable sprinkler system.	Sl: 1 hour	trigger	H-4 and H-5; occupant load greater than 30	a. For requirements for occupancies in Group I-2, see Sections 407.2 and 407.3. b. For a reduction in the fire-resistance rating for occupancies in Group I-3, see Section 408.8. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 where allowed. d. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1181	Verify source
CH10-0433	Table 1020.2 — corridor rating (appended-table row); Section 1020.2	Corridor fire-resistance rating	Required corridor fire-resistance rating is Not Permitted without sprinklers and 1 hour with the applicable sprinkler system.	Sl: 1 hour	trigger	I-1 and I-3; all occupant loads	a. For requirements for occupancies in Group I-2, see Sections 407.2 and 407.3. b. For a reduction in the fire-resistance rating for occupancies in Group I-3, see Section 408.8. c. Buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2 where allowed. d. Group R-3 and R-4 buildings equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.3. See Section 903.2.8 for occupancies where automatic sprinkler systems are permitted in accordance with Section 903.3.1.3.	NOT_TYPICAL	1181	Verify source
CH10-0434	Table 1020.2 — minimum width (appended-table row); Section 1020.2	Minimum corridor width	Minimum corridor width is 1100 mm.	Sl: 1100 mm	min	Any facility not listed below	None stated in inventory	EXTERNAL_VERIFY	1181	Verify source
CH10-0435	Table 1020.2 — minimum width (appended-table row); Section 1020.2	Minimum corridor width	Minimum corridor width is 1800 mm.	Sl: 1800 mm	min	Group E corridor with occupant load 100 or more	None stated in inventory	NOT_TYPICAL	1181	Verify source
CH10-0436	Table 1020.2 — minimum width (appended-table row); Section 1020.2	Minimum corridor width	Minimum corridor width is 1800 mm.	Sl: 1800 mm	min	Corridors and areas serving stretcher traffic in ambulatory care facilities	None stated in inventory	NOT_TYPICAL	1181	Verify source
CH10-0437	Table 1020.2 — minimum width (appended-table row); Section 1020.2	Minimum corridor width	Minimum corridor width is 2400 mm.	Sl: 2400 mm	min	Group I-2 areas required for bed movement	None stated in inventory	NOT_TYPICAL	1181	Verify source
CH10-0438	Table 1020.2 — minimum width (appended-table row); Section 1020.2	Minimum corridor width	Minimum corridor width is 600 mm.	Sl: 600 mm	min	Access to and utilization of mechanical, plumbing or electrical systems or equipment	None stated in inventory	EXTERNAL_VERIFY	1181	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0439	Table 1020.2 — minimum width (appended-table row); Section 1020.2	Minimum corridor width	Minimum corridor width is 900 mm.	Sl: 900 mm	min	Corridor serving an occupant load less than 50	None stated in inventory	EXTERNAL_VERIFY	1181	Verify source
CH10-0440	Table 1020.2 — minimum width (appended-table row); Section 1020.2	Minimum corridor width	Minimum corridor width is 900 mm.	Sl: 900 mm	min	Within a dwelling unit	None stated in inventory	EXTERNAL_VERIFY	1181	Verify source
CH10-0441	Section 1020.3	Width and capacity	Exception: In Group I-2 occupancies, corridors are not required to have a clear width of 2400 mm in areas where there will not be stretcher or bed movement for access to care or as part of the defend-in-place strategy.	Sl: 2400 mm	trigger	Per Section 1020.3 (Width and capacity).	Exception: In Group I-2 occupancies, corridors are not required to have a clear width of 2400 mm in areas where there will not be stretcher or bed movement for access to care or as part of the defend-in-place strategy.	NOT_TYPICAL	1117	Verified
CH10-0442	Section 1020.5	Dead ends	Exception item 1. In Group I-3, Condition 2, 3 or 4, occupancies, the dead end in a corridor shall not exceed 15 m.	Sl: 15 m	max	Per Section 1020.5 (Dead ends).	Exceptions: 1. In Group I-3, Condition 2, 3 or 4, occupancies, the dead end in a corridor shall not exceed 15 m. 2. In occupancies in Groups B, E, F, I-1, M, R-1, R-2, S and U, where the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, the length of the dead-end corridors shall not exceed 15 m. 3. A dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the least width of the dead-end corridor. 4. In Group I-2, Condition 2 occupancies, the length of dead-end corridors that do not serve patient rooms or patient treatment spaces shall not exceed 9 m.	NOT_TYPICAL	1119	Verified
CH10-0443	Section 1020.5	Dead ends	Exception item 2. In occupancies in Groups B, E, F, I-1, M, R-1, R-2, S and U, where the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, the length of the dead-end corridors shall not exceed 15 m.	Sl: 15 m	max	Per Section 1020.5 (Dead ends).	Exceptions: 1. In Group I-3, Condition 2, 3 or 4, occupancies, the dead end in a corridor shall not exceed 15 m. 2. In occupancies in Groups B, E, F, I-1, M, R-1, R-2, S and U, where the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, the length of the dead-end corridors shall not exceed 15 m. 3. A dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the least width of the dead-end corridor. 4. In Group I-2, Condition 2 occupancies, the length of dead-end corridors that do not serve patient rooms or patient treatment spaces shall not exceed 9 m.	CONDITIONAL	1119	Verified
CH10-0444	Section 1020.5	Dead ends	Exception item 4. In Group I-2, Condition 2 occupancies, the length of dead-end corridors that do not serve patient rooms or patient treatment spaces shall not exceed 9 m.	Sl: 9 m	max	Per Section 1020.5 (Dead ends).	Exceptions: 1. In Group I-3, Condition 2, 3 or 4, occupancies, the dead end in a corridor shall not exceed 15 m. 2. In occupancies in Groups B, E, F, I-1, M, R-1, R-2, S and U, where the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, the length of the dead-end corridors shall not exceed 15 m. 3. A dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the least width of the dead-end corridor. 4. In Group I-2, Condition 2 occupancies, the length of dead-end corridors that do not serve patient rooms or patient treatment spaces shall not exceed 9 m.	NOT_TYPICAL	1119	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0445	Section 1020.5	Dead ends	Where more than one exit or exit access doorway is required, the exit access shall be arranged such that dead-end corridors do not exceed 6 m in length.	Sl: one exit; 6 m	trigger	Per Section 1020.5 (Dead ends).	Exceptions: 1. In Group I-3, Condition 2, 3 or 4, occupancies, the dead end in a corridor shall not exceed 15 m. 2. In occupancies in Groups B, E, F, I-1, M, R-1, R-2, S and U, where the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, the length of the dead-end corridors shall not exceed 15 m. 3. A dead-end corridor shall not be limited in length where the length of the dead-end corridor is less than 2.5 times the least width of the dead-end corridor. 4. In Group I-2, Condition 2 occupancies, the length of dead-end corridors that do not serve patient rooms or patient treatment spaces shall not exceed 9 m.	DIRECT	1119	Verified
CH10-0446	Section 1020.6	Air movement in corridors	Exception item 3. Where located within tenant spaces of 100 m² or less in area, utilization of corridors for conveying return air is permitted.	Sl: 100 m²	trigger	Per Section 1020.6 (Air movement in corridors).	Exceptions: 1. Use of a corridor as a source of makeup air for exhaust systems in rooms that open directly onto such corridors, including toilet rooms, bathrooms, dressing rooms, smoking lounges and janitor closets, shall be permitted, provided that each such corridor is directly supplied with outdoor air at a rate greater than the rate of makeup air taken from the corridor. 2. Where located within a dwelling unit, the use of corridors for conveying return air shall not be prohibited. 3. Where located within tenant spaces of 100 m² or less in area, utilization of corridors for conveying return air is permitted. 4. Transfer air movement required to maintain the pressurization difference within health care facilities in accordance with ASHRAE 170.	CONDITIONAL	1120	Verified

A.4.1021 — Section 1021 (3 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0447	Section 1021.2	Wall separation	Exception: Separation is not required where the exterior egress balcony is served by not less than two stairways and a dead-end travel condition does not require travel past an unprotected opening to reach a stairway.	Sl: two stairways	min	Per Section 1021.2 (Wall separation).	Exception: Separation is not required where the exterior egress balcony is served by not less than two stairways and a dead-end travel condition does not require travel past an unprotected opening to reach a stairway.	CONDITIONAL	1122	Verified
CH10-0448	Section 1021.3	Openness	The long side of an egress balcony shall be not less than 50 percent open, and the open area above the guards shall be so distributed as to minimize the accumulation of smoke or toxic gases.	Sl: 50 percent	min	Per Section 1021.3 (Openness).	None stated in inventory	CONDITIONAL	1123	Verified
CH10-0449	Section 1021.4	Location	Exterior egress balconies shall have a minimum fire separation distance of 3000 mm measured at right angles from the exterior edge of the egress balcony to the following:	Sl: 3000 mm	min	Per Section 1021.4 (Location).	1 Adjacent lot lines. 2 Other portions of the building. 3 Other buildings on the same lot unless the adjacent building exterior walls and openings are protected in accordance with Section 705 based on fire separation distance.	CONDITIONAL	1123	Verified

A.4.1022 — Section 1022 (1 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0450	Section 1022.2	Exterior exit doors	Buildings or structures used for human occupancy shall have not less than one exterior door that meets the requirements of Section 1010.1.1.	Sl: one exterior door	min	Per Section 1022.2 (Exterior exit doors).	None stated in inventory	DIRECT	1124	Verified

A.4.1023 — Section 1023 (14 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0451	Section 1023.2	Construction	Enclosures for interior exit stairways and ramps shall have a fire-resistance rating not less than the floor assembly penetrated but need not exceed 2 hours.	Sl: 2 hours	range	Per Section 1023.2 (Construction).	Exceptions: 1. Interior exit stairways and ramps in Group I-3 occupancies in accordance with the provisions of Section 408.3.8. 2. Interior exit stairways within an atrium enclosed in accordance with Section 404.6 3. Interior exit stairways in accordance with Section 510.2.	DIRECT	1125	Verified
CH10-0452	Section 1023.2	Construction	Interior exit stairway and ramp enclosures shall have a fire-resistance rating of not less than 2 hours where connecting four stories or more and not less than 1 hour where connecting less than four stories.	Sl: 2 hours; four stories; 1 hour	mixed	Per Section 1023.2 (Construction).	Exceptions: 1. Interior exit stairways and ramps in Group I-3 occupancies in accordance with the provisions of Section 408.3.8. 2. Interior exit stairways within an atrium enclosed in accordance with Section 404.6 3. Interior exit stairways in accordance with Section 510.2.	DIRECT	1125	Verified
CH10-0453	Section 1023.5	Penetrations	Exception item 6 Electrical raceway serving the interior exit stairway and ramp and terminating at a steel box not exceeding 0.01 m².	Sl: 0.01 m²	trigger	Per Section 1023.5 (Penetrations).	1 Equipment and ductwork necessary for independent ventilation or pressurization. 2 Fire protection systems. 3 Security systems. 4 Two-way communication systems. 5 Electrical raceway for fire department communication systems. 6 Electrical raceway serving the interior exit stairway and ramp and terminating at a steel box not exceeding 0.01 m². 7 Structural elements supporting the interior exit stairway or ramp or enclosure, such as beams or joists. Exception: Membrane penetrations shall be permitted on the outside of the interior exit stairway and ramp. Such penetrations shall be protected in accordance with Section 714.4.2.	CONDITIONAL	1128	Verified
CH10-0454	Section 1023.7	Interior exit stairway and ramp exterior walls	Openings within such exterior walls shall be protected by opening protectives having a fire protection rating of not less than 3/4 hour.	Sl: 3/4 hour	min	Per Section 1023.7 (Interior exit stairway and ramp exterior walls).	None stated in inventory	CONDITIONAL	1129	Verified
CH10-0455	Section 1023.7	Interior exit stairway and ramp exterior walls	This construction shall extend vertically from the ground to a point 3000 mm above the top-most landing of the stairway or ramp, or to the roof line, whichever is lower.	Sl: 3000 mm	trigger	Per Section 1023.7 (Interior exit stairway and ramp exterior walls).	None stated in inventory	CONDITIONAL	1129	Verified
CH10-0456	Section 1023.7	Interior exit stairway and ramp exterior walls	Where non-rated walls or unprotected openings enclose the exterior of the stairway or ramps and the walls or openings are exposed by other parts of the building at an angle of less than 180 degrees, the building exterior walls within 3000 mm horizontally of a nonrated wall or unprotected opening shall have a fire-resistance rating of not less than 1 hour.	Sl: 180 degrees; 3000 mm; 1 hour	mixed	Per Section 1023.7 (Interior exit stairway and ramp exterior walls).	None stated in inventory	CONDITIONAL	1129	Verified
CH10-0457	Section 1023.9	Stairway identification signs	A sign shall be provided at each floor landing in an interior exit stairway and ramp connecting more than three stories designating the floor level, the terminus of the top and bottom of the interior exit stairway and ramp and the identification of the stairway or ramp.	Sl: three stories	trigger	Per Section 1023.9 (Stairway identification signs).	None stated in inventory	DIRECT	1130	Verified
CH10-0458	Section 1023.9	Stairway identification signs	The bottom of the sign shall be located not less than 1500 mm above the floor landing in a position that is readily visible when the doors are in the open and closed positions.	Sl: 1500 mm	min	Per Section 1023.9 (Stairway identification signs).	None stated in inventory	DIRECT	1130	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0459	Section 1023.9.1	Signage requirements	Item 1 The signs shall be a minimum size of 450 mm by 300 mm.	Sl: 450 mm; 300 mm	min	Per Section 1023.9.1 (Signage requirements).	1 The signs shall be a minimum size of 450 mm by 300 mm. 2 The letters designating the identification of the interior exit stairway and ramp shall be not less than 40 mm in height. 3 The number designating the floor level shall be not less than 125 mm in height and located in the center of the sign. 4 Other lettering and numbers shall be not less than 25 mm in height. 5 Characters and their background shall have a nonglare finish. Characters shall contrast with their background, with either light	DIRECT	1130	Verified
CH10-0460	Section 1023.9.1	Signage requirements	Item 2 The letters designating the identification of the interior exit stairway and ramp shall be not less than 40 mm in height.	Sl: 40 mm	min	Per Section 1023.9.1 (Signage requirements).	1 The signs shall be a minimum size of 450 mm by 300 mm. 2 The letters designating the identification of the interior exit stairway and ramp shall be not less than 40 mm in height. 3 The number designating the floor level shall be not less than 125 mm in height and located in the center of the sign. 4 Other lettering and numbers shall be not less than 25 mm in height. 5 Characters and their background shall have a nonglare finish. Characters shall contrast with their background, with either light	DIRECT	1130	Verified
CH10-0461	Section 1023.9.1	Signage requirements	Item 3 The number designating the floor level shall be not less than 125 mm in height and located in the center of the sign.	Sl: 125 mm	min	Per Section 1023.9.1 (Signage requirements).	1 The signs shall be a minimum size of 450 mm by 300 mm. 2 The letters designating the identification of the interior exit stairway and ramp shall be not less than 40 mm in height. 3 The number designating the floor level shall be not less than 125 mm in height and located in the center of the sign. 4 Other lettering and numbers shall be not less than 25 mm in height. 5 Characters and their background shall have a nonglare finish. Characters shall contrast with their background, with either light	DIRECT	1130	Verified
CH10-0462	Section 1023.9.1	Signage requirements	Item 4 Other lettering and numbers shall be not less than 25 mm in height.	Sl: 25 mm	min	Per Section 1023.9.1 (Signage requirements).	1 The signs shall be a minimum size of 450 mm by 300 mm. 2 The letters designating the identification of the interior exit stairway and ramp shall be not less than 40 mm in height. 3 The number designating the floor level shall be not less than 125 mm in height and located in the center of the sign. 4 Other lettering and numbers shall be not less than 25 mm in height. 5 Characters and their background shall have a nonglare finish. Characters shall contrast with their background, with either light	DIRECT	1130	Verified
CH10-0463	Section 1023.10	Elevator lobby identification signs	At landings in interior exit stairways where two or more doors lead to the floor level, any door with direct access to an enclosed elevator lobby shall be identified by signage located on the door or directly adjacent to the door stating, "Elevator Lobby." Signage shall be in accordance with Section 1023.9.1, Items 4, 5 and 6.	Sl: two or more doors	trigger	Per Section 1023.10 (Elevator lobby identification signs).	None stated in inventory	CONDITIONAL	1131	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0464	Section 1023.12.1	Termination and extension	The exit passageway shall be separated from the remainder of the building by 2-hour fire barriers constructed in accordance with Section 707 or horizontal assemblies constructed in accordance with Section 711, or both.	Sl: 2-hour	trigger	Per Section 1023.12.1 (Termination and extension).	Exceptions: 1. Openings in the exit passageway serving a smokeproof enclosure are permitted where the exit passageway is protected and pressurized in the same manner as the smokeproof enclosure, and openings are protected as required for access from other floors. 2. The fire barrier separating the smokeproof enclosure from the exit passageway is not required, provided the exit passageway is protected and pressurized in the same manner as the smokeproof enclosure. 3. A smokeproof enclosure shall be permitted to egress through areas on the level of exit discharge or vestibules as permitted by Section 1028.	CONDITIONAL	1132	Verified

A.4.1024 — Section 1024 (6 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0465	Section 1024.2	Width	The required capacity of exit passageways shall be determined as specified in Section 1005.1 but the minimum width shall be not less than 1100 mm, except that exit passageways serving an occupant load of less than 50 shall be not less than 900 mm in width.	Sl: 1100 mm; 900 mm; 50 occupants	mixed	Per Section 1024.2 (Width).	Exception: Encroachments complying with Section 1005.7.	CONDITIONAL	1133	Verified
CH10-0466	Section 1024.3	Construction	Exit passageway enclosures shall have walls, floors and ceilings of not less than a 1-hour fire-resistance rating, and not less than that required for any connecting interior exit stairway or ramp.	Sl: 1-hour	min	Per Section 1024.3 (Construction).	None stated in inventory	CONDITIONAL	1133	Verified
CH10-0467	Section 1024.6	Penetrations	Exception item 6 Electrical raceway serving the exit passageway and terminating at a steel box not exceeding 0.010 m (^{2}) .	Sl: 0.010 m²	trigger	Per Section 1024.6 (Penetrations).	1 Equipment and ductwork necessary for independent ventilation or pressurization. 2 Fire protection systems. 3 Security systems. 4 Two-way communication systems. 5 Electrical raceway for fire department communication. 6 Electrical raceway serving the exit passageway and terminating at a steel box not exceeding 0.010 m (^{2}) . Exception: Membrane penetrations shall be permitted on the outside of the exit passageway. Such penetrations shall be protected in accordance with Section 714.4.	CONDITIONAL	1135	Verified
CH10-0468	Section 1024.8	Exit passageway exterior walls	Openings within such exterior walls shall be protected by opening protectives having a fire protection rating of not less than 3/4 hour.	Sl: 3/4 hour	min	Per Section 1024.8 (Exit passageway exterior walls).	None stated in inventory	CONDITIONAL	1136	Verified
CH10-0469	Section 1024.8	Exit passageway exterior walls	This construction shall extend vertically from the ground to a point 3 m above the floor of the exit passageway, or to the roof line, whichever is lower.	Sl: 3 m	trigger	Per Section 1024.8 (Exit passageway exterior walls).	None stated in inventory	CONDITIONAL	1136	Verified
CH10-0470	Section 1024.8	Exit passageway exterior walls	Where nonrated walls or unprotected openings enclose the exterior of the exit passageway and the walls or openings are exposed by other parts of the building at an angle of less than 180 degrees, the building exterior walls within 3 m horizontally of a nonrated wall or unprotected opening shall have a fire-resistance rating of not less than 1 hour.	Sl: 180 degrees; 3 m; 1 hour	mixed	Per Section 1024.8 (Exit passageway exterior walls).	None stated in inventory	CONDITIONAL	1136	Verified

A.4.1025 — Section 1025 (20 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0471	Section 1025.2.1	Steps	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	Sl: 25 mm	trigger	Per Section 1025.2.1 (Steps).	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	CONDITIONAL	1137	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0472	Section 1025.2.1	Steps	Outlining stripes shall have a minimum horizontal width of 25 mm and a maximum width of 50 mm.	Sl: 25 mm; 50 mm	range	Per Section 1025.2.1 (Steps).	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	NOT_TYPICAL	1137	Verified
CH10-0473	Section 1025.2.1	Steps	The leading edge of the stripe shall be placed not more than 12.5 mm from the leading edge of the step and the stripe shall not overlap the leading edge of the step by not more than 12.5 mm down the vertical face of the step.	Sl: 12.5 mm	max	Per Section 1025.2.1 (Steps).	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	NOT_TYPICAL	1137	Verified
CH10-0474	Section 1025.2.3	Handrails	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	Sl: 25 mm	trigger	Per Section 1025.2.3 (Handrails).	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	CONDITIONAL	1138	Verified
CH10-0475	Section 1025.2.3	Handrails	Handrails and handrail extensions shall be marked with a solid and continuous stripe having a minimum width of 25 mm.	Sl: 25 mm	min	Per Section 1025.2.3 (Handrails).	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	NOT_TYPICAL	1138	Verified
CH10-0476	Section 1025.2.3	Handrails	Where handrails or handrail extensions bend or turn corners, the stripe shall not have a gap of more than 100 mm.	Sl: 100 mm	max	Per Section 1025.2.3 (Handrails).	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	NOT_TYPICAL	1138	Verified
CH10-0477	Section 1025.2.4	Perimeter demarcation lines	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	Sl: 25 mm	trigger	Per Section 1025.2.4 (Perimeter demarcation lines).	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	CONDITIONAL	1138	Verified
CH10-0478	Section 1025.2.4	Perimeter demarcation lines	The stripes shall be 25 mm to 50 mm wide with interruptions not exceeding 100 mm.	Sl: 25 mm; 50 mm; 100 mm	trigger	Per Section 1025.2.4 (Perimeter demarcation lines).	Exception: The minimum width of 25 mm shall not apply to outlining stripes listed in accordance with UL 1994.	NOT_TYPICAL	1138	Verified
CH10-0479	Section 1025.2.4.1	Floor-mounted demarcation lines	Perimeter demarcation lines shall be placed within 100 mm of the wall and shall extend to within 50 mm of the markings on the leading edge of landings.	Sl: 100 mm; 50 mm	trigger	Per Section 1025.2.4.1 (Floor-mounted demarcation lines).	Exception: Demarcation lines shall not extend in front of exit discharge doors that lead out of an exit and through which occupants must travel to complete the exit path.	NOT_TYPICAL	1138	Verified
CH10-0480	Section 1025.2.4.2	Wall-mounted demarcation lines	At the top or bottom of the stairs, demarcation lines shall drop vertically to the floor within 50 mm of the step or landing edge.	Sl: 50 mm	trigger	Per Section 1025.2.4.2 (Wall-mounted demarcation lines).	Exception: Demarcation lines shall not extend in front of exit discharge doors that lead out of an exit and through which occupants must travel to complete the exit path.	NOT_TYPICAL	1139	Verified
CH10-0481	Section 1025.2.4.2	Wall-mounted demarcation lines	Perimeter demarcation lines shall be placed on the wall with the bottom edge of the stripe not more than 100 mm above the finished floor.	Sl: 100 mm	max	Per Section 1025.2.4.2 (Wall-mounted demarcation lines).	Exception: Demarcation lines shall not extend in front of exit discharge doors that lead out of an exit and through which occupants must travel to complete the exit path.	NOT_TYPICAL	1139	Verified
CH10-0482	Section 1025.2.5	Obstacles	Exception: The minimum width of 25 mm shall not apply to markings listed in accordance with UL 1994.	Sl: 25 mm	trigger	Per Section 1025.2.5 (Obstacles).	Exception: The minimum width of 25 mm shall not apply to markings listed in accordance with UL 1994.	CONDITIONAL	1139	Verified
CH10-0483	Section 1025.2.5	Obstacles	Obstacles at or below 2000 mm in height and projecting more than 100 mm into the egress path shall be outlined with markings not less than 25 mm in width comprised of a pattern of alternating equal bands, of luminous material and black, with the alternating bands not more than 50 mm thick and angled at 45 degrees.	Sl: 2000 mm; 100 mm; 25 mm; 50 mm; 45 degrees	mixed	Per Section 1025.2.5 (Obstacles).	Exception: The minimum width of 25 mm shall not apply to markings listed in accordance with UL 1994.	NOT_TYPICAL	1139	Verified
CH10-0484	Section 1025.2.6.1	Emergency exit symbol height	The low-location luminous emergency exit symbol shall be not less than 100 mm in height.	Sl: 100 mm	min	Doors requiring luminous emergency exit symbols under Section 1025.2.6.1.	None stated in inventory	NOT_TYPICAL	1139	Verified
CH10-0485	Section 1025.2.6.1	Emergency exit symbol mounting height	The symbol shall be mounted on the door, centered horizontally, with the top of the symbol not higher than 450 mm above the finished floor.	Sl: 450 mm	max	Doors requiring luminous emergency exit symbols under Section 1025.2.6.1.	None stated in inventory	NOT_TYPICAL	1139–1140	Verify source
CH10-0486	Section 1025.2.6.2	Door hardware markings	Door hardware shall be marked with not less than 10,000 mm (^{2}) of luminous material.	Sl: 10,000 mm²	min	Per Section 1025.2.6.2 (Door hardware markings).	None stated in inventory	NOT_TYPICAL	1140	Verified
CH10-0487	Section 1025.2.6.2	Door hardware markings	Where a panic bar is installed, such material shall not be less than 25 mm wide for the entire length of the actuating bar or touchpad.	Sl: 25 mm	min	Per Section 1025.2.6.2 (Door hardware markings).	None stated in inventory	NOT_TYPICAL	1140	Verified
CH10-0488	Section 1025.2.6.3	Door frame markings	The top and sides of the door frame shall be marked with a solid and continuous 25 mm to 50 mm-wide stripe.	Sl: 25 mm; 50 mm	trigger	Per Section 1025.2.6.3 (Door frame markings).	None stated in inventory	NOT_TYPICAL	1140	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0489	Section 1025.4	Self-luminous and photo luminescent	Item 2 ASTM E2072, except that the charging source shall be 11 lux of fluorescent illumination for 60 minutes, and the minimum luminance shall be 30 micil-candelas per square meter at 10 minutes and 5 mili-candelas per square meter after 90 minutes.	Sl: 11 lux; 60 minutes; 10 minutes; 90 minutes; 30 micil-candelas per square meter; 5 mili-candelas per square meter	min	Per Section 1025.4 (Self-luminous and photo luminescent).	1 UL 1994. 2 ASTM E2072, except that the charging source shall be 11 lux of fluorescent illumination for 60 minutes, and the minimum luminance shall be 30 micil-candelas per square meter at 10 minutes and 5 mili-candelas per square meter after 90 minutes.	NOT_TYPICAL	1140	Verify source
CH10-0490	Section 1025.5	Illumination	Where photo-luminescent exit path markings are installed, they shall be provided with not less than 11 lux of illumination for not less than 60 minutes prior to periods when the building is occupied and continuously during occupancy.	Sl: 11 lux; 60 minutes	min	Per Section 1025.5 (Illumination).	None stated in inventory	NOT_TYPICAL	1141	Verified

A.4.1026 — Section 1026 (8 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0491	Section 1026.1	General	A horizontal exit shall not serve as the only exit from a portion of a building, and where two or more exits are required, not more than one-half of the total number of exits or total exit minimum width or required capacity shall be horizontal exits.	Sl: two or more exits; one-half	mixed	Per Section 1026.1 (General).	## Exceptions: 1. Horizontal exits are permitted to comprise two-thirds of the required exits from any building or floor area for occupancies in Group I-2. 2. Horizontal exits are permitted to comprise 100 percent of the exits required for occupancies in Group I-3. Not less than 0.6 m² of accessible space per occupant shall be provided on each side of the horizontal exit for the total number of people in adjoining compartments.	CONDITIONAL	1141	Verified
CH10-0492	Section 1026.1	General	Exception item 1. Horizontal exits are permitted to comprise two-thirds of the required exits from any building or floor area for occupancies in Group I-2.	Sl: two-thirds	formula	Per Section 1026.1 (General).	## Exceptions: 1. Horizontal exits are permitted to comprise two-thirds of the required exits from any building or floor area for occupancies in Group I-2. 2. Horizontal exits are permitted to comprise 100 percent of the exits required for occupancies in Group I-3. Not less than 0.6 m² of accessible space per occupant shall be provided on each side of the horizontal exit for the total number of people in adjoining compartments.	NOT_TYPICAL	1141	Verified
CH10-0493	Section 1026.1	General	Exception item 2. Horizontal exits are permitted to comprise 100 percent of the exits required for occupancies in Group I-3. Not less than 0.6 m² of accessible space per occupant shall be provided on each side of the horizontal exit for the total number of people in adjoining compartments.	Sl: 100 percent; 0.6 m²	formula	Per Section 1026.1 (General).	## Exceptions: 1. Horizontal exits are permitted to comprise two-thirds of the required exits from any building or floor area for occupancies in Group I-2. 2. Horizontal exits are permitted to comprise 100 percent of the exits required for occupancies in Group I-3. Not less than 0.6 m² of accessible space per occupant shall be provided on each side of the horizontal exit for the total number of people in adjoining compartments.	NOT_TYPICAL	1141	Verified
CH10-0494	Section 1026.2	Separation	Exception: A fire-resistance rating is not required at horizontal exits between a building area and an above-grade pedestrian walkway constructed in accordance with Section 3104, provided that the distance between connected buildings is more than 6000 mm.	Sl: 6000 mm	trigger	Per Section 1026.2 (Separation).	Exception: A fire-resistance rating is not required at horizontal exits between a building area and an above-grade pedestrian walkway constructed in accordance with Section 3104, provided that the distance between connected buildings is more than 6000 mm.	CONDITIONAL	1141	Verified
CH10-0495	Section 1026.2	Separation	The horizontal exit separation shall extend vertically through all levels of the building unless floor assemblies have a fire-resistance rating of not less than 2 hours with no unprotected openings.	Sl: 2 hours	min	Per Section 1026.2 (Separation).	Exception: A fire-resistance rating is not required at horizontal exits between a building area and an above-grade pedestrian walkway constructed in accordance with Section 3104, provided that the distance between connected buildings is more than 6000 mm.	CONDITIONAL	1141	Verified
CH10-0496	Section 1026.2	Separation	The minimum fire-resistance rating of the separation shall be 2 hours.	Sl: 2 hours	min	Per Section 1026.2 (Separation).	Exception: A fire-resistance rating is not required at horizontal exits between a building area and an above-grade pedestrian walkway constructed in accordance with Section 3104, provided that the distance between connected buildings is more than 6000 mm.	CONDITIONAL	1141	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0497	Section 1026.4.1	Capacity	The capacity of the refuge area shall be computed based on a net floor area allowance of 0.28 m² for each occupant to be accommodated therein.	Sl: 0.28 m²	formula	Per Section 1026.4.1 (Capacity).	None stated in inventory	CONDITIONAL	1142	Verified
CH10-0498	Section 1026.4.2	Number of exits	Not less than one refuge area exit shall lead directly to the exterior or to an interior exit stairway or ramp.	Sl: one refuge area exit	min	Per Section 1026.4.2 (Number of exits).	Exception: The adjoining compartment shall not be required to have a stairway or door leading directly outside, provided that the refuge area into which a horizontal exit leads has stairways or doors leading directly outside and are so arranged that egress shall not require the occupants to return through the compartment from which egress originates.	CONDITIONAL	1143	Verified

A.4.1027 — Section 1027 (10 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0499	Section 1027.2	Use in a means of egress	I-2, exterior exit stairways and ramps shall be permitted as an element of a required means of egress for buildings not exceeding six stories above grade plane or that are not high-rise buildings.	Sl: six stories	trigger	Per Section 1027.2 (Use in a means of egress).	None stated in inventory	NOT_TYPICAL	1144	Verified
CH10-0500	Section 1027.3	Open side	An open side shall have not less than 3.3 m² of aggregate open area adjacent to each floor level and the level of each intermediate landing.	Sl: 3.3 m²	min	Per Section 1027.3 (Open side).	None stated in inventory	CONDITIONAL	1144	Verified
CH10-0501	Section 1027.3	Open side	Exterior exit stairways and ramps serving as an element of a required means of egress shall be open on not less than one side, except for required structural columns, beams, handrails and guards.	Sl: one side	min	Per Section 1027.3 (Open side).	None stated in inventory	CONDITIONAL	1144	Verified
CH10-0502	Section 1027.3	Open side	The required open area shall be located not less than 1000 mm above the adjacent floor or landing level.	Sl: 1000 mm	min	Per Section 1027.3 (Open side).	None stated in inventory	CONDITIONAL	1144	Verified
CH10-0503	Section 1027.5	Location	Exception: Exterior exit stairways and ramps serving individual dwelling units of Group R-3 shall have a minimum fire separation distance of 1500 mm.	Sl: 1500 mm	min	Per Section 1027.5 (Location).	1 Adjacent lot lines. 2 Other portions of the building. 3 Other buildings on the same lot unless the adjacent building exterior walls and openings are protected in accordance with Section 705 based on fire separation distance. Exception: Exterior exit stairways and ramps serving individual dwelling units of Group R-3 shall have a minimum fire separation distance of 1500 mm.	NOT_TYPICAL	1145	Verified
CH10-0504	Section 1027.5	Location	Exterior exit stairways and ramps shall have a minimum fire separation distance of 3000 mm measured at right angles from the exterior edge of the stairway or ramps, including landings, to:	Sl: 3000 mm	min	Per Section 1027.5 (Location).	1 Adjacent lot lines. 2 Other portions of the building. 3 Other buildings on the same lot unless the adjacent building exterior walls and openings are protected in accordance with Section 705 based on fire separation distance. Exception: Exterior exit stairways and ramps serving individual dwelling units of Group R-3 shall have a minimum fire separation distance of 1500 mm.	CONDITIONAL	1145	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0505	Section 1027.6	Exterior exit stairway and ramp protection	Exception item 1. Separation from the interior of the building is not required for occupancies, other than those in Group R-1 or R-2, in buildings that are not more than two stories above grade plane where a level of exit discharge serving such occupancies is the first story above grade plane.	Sl: two stories; first story	max	Per Section 1027.6 (Exterior exit stairway and ramp protection).	Exceptions: 1. Separation from the interior of the building is not required for occupancies, other than those in Group R-1 or R-2, in buildings that are not more than two stories above grade plane where a level of exit discharge serving such occupancies is the first story above grade plane. 2. Separation from the interior of the building is not required where the exterior exit stairway or ramp is served by an exterior exit ramp or balcony that connects two remote exterior exit stairways or other approved exits with a perimeter that is not less than 50 percent open. To be considered open, the opening shall be not less than 50 percent of the height of the enclosing wall, with the top of the openings not less than 2.1 m above the top of the balcony. 3. Separation from the open-ended corridor of the building is not required for exterior exit stairways or ramps, provided that Items 3.1 through 3.5 are met: 4. The building, including open-ended corridors, and stairways and ramps, shall be equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. 5. The open-ended corridors comply with Section 1020. 6. The open-ended corridors are connected on each end to an exterior exit stairway or ramp complying with Section 1027. 7. The exterior walls and openings adjacent to the exterior exit stairway or ramp comply with Section 1023.7. At any location in an open-ended corridor where a change of direction exceeding 45 degrees occurs, a clear opening of not less than 3.3 m² or an exterior stairway or ramp shall be provided. Where clear openings are provided, they shall be located so as to minimize the accumulation of smoke or toxic gases. At any location in an open-ended corridor where a change of direction exceeding 45 degrees occurs, a clear opening of not less than 3.3 m² or an exterior stairway or ramp shall be provided. Where clear openings are provided, they shall be located so as to minimize the accumulation of smoke or toxic gases.	NOT_TYPICAL	1145	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0506	Section 1027.6	Exterior exit stairway and ramp protection	Exception item 2. Separation from the interior of the building is not required where the exterior exit stairway or ramp is served by an exterior exit ramp or balcony that connects two remote exterior exit stairways or other approved exits with a perimeter that is not less than 50 percent open. To be considered open, the opening shall be not less than 50 percent of the height of the enclosing wall, with the top of the openings not less than 2.1 m above the top of the balcony.	Sl: 50 percent; 2.1 m	min	Per Section 1027.6 (Exterior exit stairway and ramp protection).	Exceptions: 1. Separation from the interior of the building is not required for occupancies, other than those in Group R-1 or R-2, in buildings that are not more than two stories above grade plane where a level of exit discharge serving such occupancies is the first story above grade plane. 2. Separation from the interior of the building is not required where the exterior exit stairway or ramp is served by an exterior exit ramp or balcony that connects two remote exterior exit stairways or other approved exits with a perimeter that is not less than 50 percent open. To be considered open, the opening shall be not less than 50 percent of the height of the enclosing wall, with the top of the openings not less than 2.1 m above the top of the balcony. 3. Separation from the open-ended corridor of the building is not required for exterior exit stairways or ramps, provided that Items 3.1 through 3.5 are met: 4. The building, including open-ended corridors, and stairways and ramps, shall be equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. 5. The open-ended corridors comply with Section 1020. 6. The open-ended corridors are connected on each end to an exterior exit stairway or ramp complying with Section 1027. 7. The exterior walls and openings adjacent to the exterior exit stairway or ramp comply with Section 1023.7. At any location in an open-ended corridor where a change of direction exceeding 45 degrees occurs, a clear opening of not less than 3.3 m² or an exterior stairway or ramp shall be provided. Where clear openings are provided, they shall be located so as to minimize the accumulation of smoke or toxic gases. At any location in an open-ended corridor where a change of direction exceeding 45 degrees occurs, a clear opening of not less than 3.3 m² or an exterior stairway or ramp shall be provided. Where clear openings are provided, they shall be located so as to minimize the accumulation of smoke or toxic gases.	CONDITIONAL	1145	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0507	Section 1027.6	Exterior exit stairway and ramp protection	Where a vertical plane projecting from the edge of an exterior exit stairway or ramp and landings is exposed by other parts of the building at an angle of less than 180 degrees, the exterior wall shall be rated in accordance with Section 1023.7.	Sl: 180 degrees	trigger	Per Section 1027.6 (Exterior exit stairway and ramp protection).	Exceptions: 1. Separation from the interior of the building is not required for occupancies, other than those in Group R-1 or R-2, in buildings that are not more than two stories above grade plane where a level of exit discharge serving such occupancies is the first story above grade plane. 2. Separation from the interior of the building is not required where the exterior exit stairway or ramp is served by an exterior exit ramp or balcony that connects two remote exterior exit stairways or other approved exits with a perimeter that is not less than 50 percent open. To be considered open, the opening shall be not less than 50 percent of the height of the enclosing wall, with the top of the openings not less than 2.1 m above the top of the balcony. 3. Separation from the open-ended corridor of the building is not required for exterior exit stairways or ramps, provided that Items 3.1 through 3.5 are met: 4. The building, including open-ended corridors, and stairways and ramps, shall be equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. 5. The open-ended corridors comply with Section 1020. 6. The open-ended corridors are connected on each end to an exterior exit stairway or ramp complying with Section 1027. 7. The exterior walls and openings adjacent to the exterior exit stairway or ramp comply with Section 1023.7. At any location in an open-ended corridor where a change of direction exceeding 45 degrees occurs, a clear opening of not less than 3.3 m² or an exterior stairway or ramp shall be provided. Where clear openings are provided, they shall be located so as to minimize the accumulation of smoke or toxic gases. At any location in an open-ended corridor where a change of direction exceeding 45 degrees occurs, a clear opening of not less than 3.3 m² or an exterior stairway or ramp shall be provided. Where clear openings are provided, they shall be located so as to minimize the accumulation of smoke or toxic gases.	CONDITIONAL	1145	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0508	Section 1027.6	Open-ended corridor direction-change opening	Exception item 8. At any location in an open-ended corridor where a change of direction exceeding 45 degrees occurs, a clear opening of not less than 3.3 m ² or an exterior stairway or ramp shall be provided. Where clear openings are provided, they shall be located so as to minimize the accumulation of smoke or toxic gases.	Sl: 45 degrees; 3.3 m ²	min	Exception item 8: open-ended corridors at direction changes exceeding 45 degrees.	Exceptions: 1. Separation from the interior of the building is not required for occupancies, other than those in Group R-1 or R-2, in buildings that are not more than two stories above grade plane where a level of exit discharge serving such occupancies is the first story above grade plane. 2. Separation from the interior of the building is not required where the exterior exit stairway or ramp is served by an exterior exit ramp or balcony that connects two remote exterior exit stairways or other approved exits with a perimeter that is not less than 50 percent open. To be considered open, the opening shall be not less than 50 percent of the height of the enclosing wall, with the top of the openings not less than 2.1 m above the top of the balcony. 3. Separation from the open-ended corridor of the building is not required for exterior exit stairways or ramps, provided that Items 3.1 through 3.5 are met: 4. The building, including open-ended corridors, and stairways and ramps, shall be equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2. 5. The open-ended corridors comply with Section 1020. 6. The open-ended corridors are connected on each end to an exterior exit stairway or ramp complying with Section 1027. 7. The exterior walls and openings adjacent to the exterior exit stairway or ramp comply with Section 1023.7. At any location in an open-ended corridor where a change of direction exceeding 45 degrees occurs, a clear opening of not less than 3.3 m ² or an exterior stairway or ramp shall be provided. Where clear openings are provided, they shall be located so as to minimize the accumulation of smoke or toxic gases. At any location in an open-ended corridor where a change of direction exceeding 45 degrees occurs, a clear opening of not less than 3.3 m ² or an exterior stairway or ramp shall be provided. Where clear openings are provided, they shall be located so as to minimize the accumulation of smoke or toxic gases.	CONDITIONAL	1145–1146	Verify source

A.4.1028 — Section 1028 (7 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0509	Section 1028.2	Exit discharge	Exception item 1. Not more than 50 percent of the number and minimum width or required capacity of interior exit stairways and ramps is permitted to egress through areas, including atriums, on the level of discharge provided that all of the following conditions are met:	Sl: 50 percent	max	Per Section 1028.2 (Exit discharge).	Exceptions: 1. Not more than 50 percent of the number and minimum width or required capacity of interior exit stairways and ramps is permitted to egress through areas, including atriums, on the level of discharge provided that all of the following conditions are met: 1.1. Discharge of interior exit stairways and ramps shall be provided with a free and unobstructed path of travel to an exterior exit door and such exit is readily visible and identifiable from the point of termination of the enclosure. 1.2. The entire area of the level of exit discharge is separated from areas below by construction conforming to the fire-resistance rating for the enclosure. 1.3. The egress path from the interior exit stairway and ramp on the level of exit discharge is protected throughout by an approved automatic sprinkler system. Portions of the level of exit discharge with access to the egress path shall be either equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, or separated from the egress path in accordance with the requirements for the enclosure of interior exit stairways or ramps. 1.4. Where a required interior exit stairway or ramp and an exit access stairway or ramp serve the same floor level and terminate at the same level of exit discharge, the termination of the exit access stairway or ramp and the exit discharge door of the interior exit stairway or ramp shall be separated by a distance of not less than 9 m or not less than one-fourth the length of the maximum overall diagonal dimension of the building, whichever is less. The distance shall be measured in a straight line between the exit discharge door from the interior exit stairway or ramp and the last tread of the exit access stairway or termination of slope of the exit access ramp. 2. Not more than 50 percent of the number and minimum width or required capacity of the interior exit stairways and ramps is permitted to egress through a vestibule provided all of the following conditions are met: 2.1. The entire area of the vestibule is separated from areas below by construction conforming to the fire-resistance rating of the interior exit stairway or ramp enclosure. 2.2. The depth from the exterior of the building is not greater than 3000 mm and the length is not greater than 9 m. 2.3. The area is separated from the remainder of the level of exit discharge by a fire partition constructed in accordance with Section 708. Exception: The maximum transmitted temperature rise is not required. 2.4. The area is used only for means of egress and exits directly to the outside. 3. Horizontal exits complying with Section 1026 shall not be required to discharge directly to the exterior of the building.	CONDITIONAL	1147	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0510	Section 1028.2	Exit discharge	Exception item 1.4. Where a required interior exit stairway or ramp and an exit access stairway or ramp serve the same floor level and terminate at the same level of exit discharge, the termination of the exit access stairway or ramp and the exit discharge door of the interior exit stairway or ramp shall be separated by a distance of not less than 9 m or not less than one-fourth the length of the maximum overall diagonal dimension of the building, whichever is less. The distance shall be measured in a straight line between the exit discharge door from the interior exit stairway or ramp and the last tread of the exit access stairway or termination of slope of the exit access ramp.	Sl: 9 m; one-fourth building diagonal	formula	Per Section 1028.2 (Exit discharge).	Exceptions: 1. Not more than 50 percent of the number and minimum width or required capacity of interior exit stairways and ramps is permitted to egress through areas, including atriums, on the level of discharge provided that all of the following conditions are met: 1.1. Discharge of interior exit stairways and ramps shall be provided with a free and unobstructed path of travel to an exterior exit door and such exit is readily visible and identifiable from the point of termination of the enclosure. 1.2. The entire area of the level of exit discharge is separated from areas below by construction conforming to the fire-resistance rating for the enclosure. 1.3. The egress path from the interior exit stairway and ramp on the level of exit discharge is protected throughout by an approved automatic sprinkler system. Portions of the level of exit discharge with access to the egress path shall be either equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, or separated from the egress path in accordance with the requirements for the enclosure of interior exit stairways or ramps. 1.4. Where a required interior exit stairway or ramp and an exit access stairway or ramp serve the same floor level and terminate at the same level of exit discharge, the termination of the exit access stairway or ramp and the exit discharge door of the interior exit stairway or ramp shall be separated by a distance of not less than 9 m or not less than one-fourth the length of the maximum overall diagonal dimension of the building, whichever is less. The distance shall be measured in a straight line between the exit discharge door from the interior exit stairway or ramp and the last tread of the exit access stairway or termination of slope of the exit access ramp. 2. Not more than 50 percent of the number and minimum width or required capacity of the interior exit stairways and ramps is permitted to egress through a vestibule provided all of the following conditions are met: 2.1. The entire area of the vestibule is separated from areas below by construction conforming to the fire-resistance rating of the interior exit stairway or ramp enclosure. 2.2. The depth from the exterior of the building is not greater than 3000 mm and the length is not greater than 9 m. 2.3. The area is separated from the remainder of the level of exit discharge by a fire partition constructed in accordance with Section 708. Exception: The maximum transmitted temperature rise is not required. 2.4. The area is used only for means of egress and exits directly to the outside. 3. Horizontal exits complying with Section 1026 shall not be required to discharge directly to the exterior of the building.	CONDITIONAL	1147	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0511	Section 1028.2	Exit discharge	Exception item 2. Not more than 50 percent of the number and minimum width or required capacity of the interior exit stairways and ramps is permitted to egress through a vestibule provided all of the following conditions are met:	Sl: 50 percent	max	Per Section 1028.2 (Exit discharge).	Exceptions: 1. Not more than 50 percent of the number and minimum width or required capacity of interior exit stairways and ramps is permitted to egress through areas, including atriums, on the level of discharge provided that all of the following conditions are met: 1.1. Discharge of interior exit stairways and ramps shall be provided with a free and unobstructed path of travel to an exterior exit door and such exit is readily visible and identifiable from the point of termination of the enclosure. 1.2. The entire area of the level of exit discharge is separated from areas below by construction conforming to the fire-resistance rating for the enclosure. 1.3. The egress path from the interior exit stairway and ramp on the level of exit discharge is protected throughout by an approved automatic sprinkler system. Portions of the level of exit discharge with access to the egress path shall be either equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, or separated from the egress path in accordance with the requirements for the enclosure of interior exit stairways or ramps. 1.4. Where a required interior exit stairway or ramp and an exit access stairway or ramp serve the same floor level and terminate at the same level of exit discharge, the termination of the exit access stairway or ramp and the exit discharge door of the interior exit stairway or ramp shall be separated by a distance of not less than 9 m or not less than one-fourth the length of the maximum overall diagonal dimension of the building, whichever is less. The distance shall be measured in a straight line between the exit discharge door from the interior exit stairway or ramp and the last tread of the exit access stairway or termination of slope of the exit access ramp. 2. Not more than 50 percent of the number and minimum width or required capacity of the interior exit stairways and ramps is permitted to egress through a vestibule provided all of the following conditions are met: 2.1. The entire area of the vestibule is separated from areas below by construction conforming to the fire-resistance rating of the interior exit stairway or ramp enclosure. 2.2. The depth from the exterior of the building is not greater than 3000 mm and the length is not greater than 9 m. 2.3. The area is separated from the remainder of the level of exit discharge by a fire partition constructed in accordance with Section 708. Exception: The maximum transmitted temperature rise is not required. 2.4. The area is used only for means of egress and exits directly to the outside. 3. Horizontal exits complying with Section 1026 shall not be required to discharge directly to the exterior of the building.	CONDITIONAL	1147	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0512	Section 1028.2	Exit discharge	Exception item 2.2. The depth from the exterior of the building is not greater than 3000 mm and the length is not greater than 9 m.	Sl: 3000 mm; 9 m	max	Per Section 1028.2 (Exit discharge).	Exceptions: 1. Not more than 50 percent of the number and minimum width or required capacity of interior exit stairways and ramps is permitted to egress through areas, including atriums, on the level of discharge provided that all of the following conditions are met: 1.1. Discharge of interior exit stairways and ramps shall be provided with a free and unobstructed path of travel to an exterior exit door and such exit is readily visible and identifiable from the point of termination of the enclosure. 1.2. The entire area of the level of exit discharge is separated from areas below by construction conforming to the fire-resistance rating for the enclosure. 1.3. The egress path from the interior exit stairway and ramp on the level of exit discharge is protected throughout by an approved automatic sprinkler system. Portions of the level of exit discharge with access to the egress path shall be either equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, or separated from the egress path in accordance with the requirements for the enclosure of interior exit stairways or ramps. 1.4. Where a required interior exit stairway or ramp and an exit access stairway or ramp serve the same floor level and terminate at the same level of exit discharge, the termination of the exit access stairway or ramp and the exit discharge door of the interior exit stairway or ramp shall be separated by a distance of not less than 9 m or not less than one-fourth the length of the maximum overall diagonal dimension of the building, whichever is less. The distance shall be measured in a straight line between the exit discharge door from the interior exit stairway or ramp and the last tread of the exit access stairway or termination of slope of the exit access ramp. 2. Not more than 50 percent of the number and minimum width or required capacity of the interior exit stairways and ramps is permitted to egress through a vestibule provided all of the following conditions are met: 2.1. The entire area of the vestibule is separated from areas below by construction conforming to the fire-resistance rating of the interior exit stairway or ramp enclosure. 2.2. The depth from the exterior of the building is not greater than 3000 mm and the length is not greater than 9 m. 2.3. The area is separated from the remainder of the level of exit discharge by a fire partition constructed in accordance with Section 708. Exception: The maximum transmitted temperature rise is not required. 2.4. The area is used only for means of egress and exits directly to the outside. 3. Horizontal exits complying with Section 1026 shall not be required to discharge directly to the exterior of the building.	CONDITIONAL	1147	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0513	Section 1028.2	Exit discharge	The combined use of Exceptions 1 and 2 shall not exceed 50 percent of the number and minimum width or required capacity of the required exits.	Sl: 50 percent	max	Per Section 1028.2 (Exit discharge).	Exceptions: 1. Not more than 50 percent of the number and minimum width or required capacity of interior exit stairways and ramps is permitted to egress through areas, including atriums, on the level of discharge provided that all of the following conditions are met: 1.1. Discharge of interior exit stairways and ramps shall be provided with a free and unobstructed path of travel to an exterior exit door and such exit is readily visible and identifiable from the point of termination of the enclosure. 1.2. The entire area of the level of exit discharge is separated from areas below by construction conforming to the fire-resistance rating for the enclosure. 1.3. The egress path from the interior exit stairway and ramp on the level of exit discharge is protected throughout by an approved automatic sprinkler system. Portions of the level of exit discharge with access to the egress path shall be either equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2, or separated from the egress path in accordance with the requirements for the enclosure of interior exit stairways or ramps. 1.4. Where a required interior exit stairway or ramp and an exit access stairway or ramp serve the same floor level and terminate at the same level of exit discharge, the termination of the exit access stairway or ramp and the exit discharge door of the interior exit stairway or ramp shall be separated by a distance of not less than 9 m or not less than one-fourth the length of the maximum overall diagonal dimension of the building, whichever is less. The distance shall be measured in a straight line between the exit discharge door from the interior exit stairway or ramp and the last tread of the exit access stairway or termination of slope of the exit access ramp. 2. Not more than 50 percent of the number and minimum width or required capacity of the interior exit stairways and ramps is permitted to egress through a vestibule provided all of the following conditions are met: 2.1. The entire area of the vestibule is separated from areas below by construction conforming to the fire-resistance rating of the interior exit stairway or ramp enclosure. 2.2. The depth from the exterior of the building is not greater than 3000 mm and the length is not greater than 9 m. 2.3. The area is separated from the remainder of the level of exit discharge by a fire partition constructed in accordance with Section 708. Exception: The maximum transmitted temperature rise is not required. 2.4. The area is used only for means of egress and exits directly to the outside. 3. Horizontal exits complying with Section 1026 shall not be required to discharge directly to the exterior of the building.	CONDITIONAL	1147	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0514	Section 1028.5	Access to a public way	Exception item 1. The area shall be of a size to accommodate not less than 0.46 m ([^] {2}) for each person.	Sl: 0.46 m²	min	Per Section 1028.5 (Access to a public way).	Exception: Where access to a public way cannot be provided, a safe dispersal area shall be provided where all of the following are met: 1. The area shall be of a size to accommodate not less than 0.46 m ([^] {2}) for each person. 2. The area shall be located on the same lot not less than 15 m away from the building requiring egress. 3. The area shall be permanently maintained and identified as a safe dispersal area. 4. The area shall be provided with a safe and unobstructed path of travel from the building.	CONDITIONAL	1149	Verified
CH10-0515	Section 1028.5	Access to a public way	Exception item 2. The area shall be located on the same lot not less than 15 m away from the building requiring egress.	Sl: 15 m	min	Per Section 1028.5 (Access to a public way).	Exception: Where access to a public way cannot be provided, a safe dispersal area shall be provided where all of the following are met: 1. The area shall be of a size to accommodate not less than 0.46 m ([^] {2}) for each person. 2. The area shall be located on the same lot not less than 15 m away from the building requiring egress. 3. The area shall be permanently maintained and identified as a safe dispersal area. 4. The area shall be provided with a safe and unobstructed path of travel from the building.	CONDITIONAL	1149	Verified

A.4.1029 — Section 1029 (5 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0516	Section 1029.2	Width or capacity	Egress courts serving Group R-3 and U occupancies shall be not less than 900 mm in width.	Sl: 900 mm	min	Per Section 1029.2 (Width or capacity).	Exception: Encroachments complying with Section 1005.7.	NOT_TYPICAL	1150	Verified
CH10-0517	Section 1029.2	Width or capacity	The required capacity and width of egress courts shall be unobstructed to a height of 2.1 m.	Sl: 2.1 m	trigger	Per Section 1029.2 (Width or capacity).	Exception: Encroachments complying with Section 1005.7.	CONDITIONAL	1150	Verified
CH10-0518	Section 1029.2	Width or capacity	The required capacity of egress courts shall be determined as specified in Section 1005.1, but the minimum width shall be not less than 1100 mm, except as specified herein.	Sl: 1100 mm	min	Per Section 1029.2 (Width or capacity).	Exception: Encroachments complying with Section 1005.7.	CONDITIONAL	1150	Verified
CH10-0519	Section 1029.3	Construction and openings	Openings within such walls shall be protected by opening protectives having a fire protection rating of not less than 3/4 hour.	Sl: 3/4 hour	min	Per Section 1029.3 (Construction and openings).	Exceptions: 1 Egress courts serving an occupant load of less than 10. 2 Egress courts serving Group R-3.	CONDITIONAL	1150	Verified
CH10-0520	Section 1029.3	Construction and openings	Where an egress court serving a building or portion thereof is less than 3000 mm in width, the egress court walls shall have not less than 1-hour fire-resistance-rated construction for a distance of 3000 mm above the floor of the egress court.	Sl: 3000 mm; 1-hour	mixed	Per Section 1029.3 (Construction and openings).	Exceptions: 1 Egress courts serving an occupant load of less than 10. 2 Egress courts serving Group R-3.	CONDITIONAL	1150	Verified

A.4.1030 — Section 1030 (109 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0521	Section 1030.1.1.1	Spaces under grandstands and bleachers	Exception item 1. Ticket booths less than 9.3 m² in area.	Sl: 9.3 m²	trigger	Per Section 1030.1.1.1 (Spaces under grandstands and bleachers).	Exceptions: 1. Ticket booths less than 9.3 m² in area. 2. Toilet rooms. 3. Other accessory use areas 100 m² or less in area and equipped with an automatic sprinkler system in accordance with Section 903.3.1.1.	CONDITIONAL	1151	Verified
CH10-0522	Section 1030.1.1.1	Spaces under grandstands and bleachers	Exception item 3. Other accessory use areas 100 m² or less in area and equipped with an automatic sprinkler system in accordance with Section 903.3.1.1.	Sl: 100 m²	trigger	Per Section 1030.1.1.1 (Spaces under grandstands and bleachers).	Exceptions: 1. Ticket booths less than 9.3 m² in area. 2. Toilet rooms. 3. Other accessory use areas 100 m² or less in area and equipped with an automatic sprinkler system in accordance with Section 903.3.1.1.	CONDITIONAL	1151	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0523	Section 1030.1.1.1	Spaces under grandstands and bleachers	Spaces under grandstands or bleachers shall be rated by fire barriers complying with Section 707 and horizontal assemblies complying with Section 711 with not less than 1-hour fire-resistance-rated construction.	Sl: 1-hour	min	Per Section 1030.1.1.1 (Spaces under grandstands and bleachers).	Exceptions: 1. Ticket booths less than 9.3 m² in area. 2. Toilet rooms. 3. Other accessory use areas 100 m² or less in area and equipped with an automatic sprinkler system in accordance with Section 903.3.1.1.	CONDITIONAL	1151	Verified
CH10-0524	Section 1030.2	Assembly main exit	A building, room or space used for assembly purposes that has an occupant load of greater than 300 and is provided with a main exit, that main exit shall be of sufficient capacity to accommodate not less than one-half of the occupant load, but such capacity shall be not less than the total required capacity of all means of egress leading to the exit.	Sl: one-half; 300 occupants	mixed	Per Section 1030.2 (Assembly main exit).	None stated in inventory	CONDITIONAL	1152	Verified
CH10-0525	Section 1030.2	Assembly main exit	In a building, room or space used for assembly purposes where there is not a well-defined main exit or where multiple main exits are provided, exits shall be permitted to be distributed around the perimeter of the building provided that the total capacity of egress is not less than 100 percent of the required capacity.	Sl: 100 percent	min	Per Section 1030.2 (Assembly main exit).	None stated in inventory	CONDITIONAL	1152	Verified
CH10-0526	Section 1030.2	Assembly main exit	Where the building is classified as a Group A occupancy, the main exit shall front on not less than one street or an unoccupied space of not less than 3000 mm in width that adjoins a street or public way.	Sl: 3000 mm	min	Per Section 1030.2 (Assembly main exit).	None stated in inventory	CONDITIONAL	1152	Verified
CH10-0527	Section 1030.3	Assembly other exits	In a building used for assembly purposes where there is not a well-defined main exit or where multiple main exits are provided, exits for each level shall be permitted to be distributed around the perimeter of the building, provided that the total width of egress is not less than 100 percent of the required width.	Sl: 100 percent	min	Per Section 1030.3 (Assembly other exits).	None stated in inventory	CONDITIONAL	1152	Verified
CH10-0528	Section 1030.3	Assembly other exits	In addition to having access to a main exit, each level in a building used for assembly purposes having an occupant load greater than 300 and provided with a main exit, shall be provided with additional means of egress that shall provide an egress capacity for not less than one-half of the total occupant load served by that level and shall comply with Section 1007.1.	Sl: occupant load greater than 300; one-half	mixed	Per Section 1030.3 (Assembly other exits).	None stated in inventory	CONDITIONAL	1152	Verified
CH10-0529	Section 1030.5	Interior balcony and gallery means of egress	For balconies, galleries or press boxes having a seating capacity of 50 or more located in a building, room or space used for assembly purposes, not less than two means of egress shall be provided, with one from each side of every balcony, gallery or press box.	Sl: two means of egress; 50 seats	min	Per Section 1030.5 (Interior balcony and gallery means of egress).	None stated in inventory	CONDITIONAL	1153	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0530	Section 1030.6.1	Without smoke protection	Item 1 Not less than 7.6 mm of aisle capacity for each occupant served shall be provided on stepped aisles having riser heights 175 mm or less and tread depths 275 mm or greater, measured horizontally between tread nosings.	Sl: 7.6 mm; 175 mm; 275 mm	min	Per Section 1030.6.1 (Without smoke protection).	1 Not less than 7.6 mm of aisle capacity for each occupant served shall be provided on stepped aisles having riser heights 175 mm or less and tread depths 275 mm or greater, measured horizontally between tread nosings. 2 Not less than 0.127 mm of additional aisle capacity for each occupant shall be provided for each 2.5 mm of riser height above 175 mm. 3 Where egress requires stepped aisle descent, not less than 1.9 mm of additional aisle capacity for each occupant shall be provided on those portions of aisle capacity that do not have a handrail within a horizontal distance of 750 mm. 4 Ramped aisles, where slopes are steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.6 mm of clear aisle capacity for each occupant served. Level or ramped aisles, where slopes are not steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.08 mm of clear aisle capacity for each occupant served.	CONDITIONAL	1154	Verified
CH10-0531	Section 1030.6.1	Without smoke protection	Item 2 Not less than 0.127 mm of additional aisle capacity for each occupant shall be provided for each 2.5 mm of riser height above 175 mm.	Sl: 0.127 mm; 2.5 mm; 175 mm	min	Per Section 1030.6.1 (Without smoke protection).	1 Not less than 7.6 mm of aisle capacity for each occupant served shall be provided on stepped aisles having riser heights 175 mm or less and tread depths 275 mm or greater, measured horizontally between tread nosings. 2 Not less than 0.127 mm of additional aisle capacity for each occupant shall be provided for each 2.5 mm of riser height above 175 mm. 3 Where egress requires stepped aisle descent, not less than 1.9 mm of additional aisle capacity for each occupant shall be provided on those portions of aisle capacity that do not have a handrail within a horizontal distance of 750 mm. 4 Ramped aisles, where slopes are steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.6 mm of clear aisle capacity for each occupant served. Level or ramped aisles, where slopes are not steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.08 mm of clear aisle capacity for each occupant served.	CONDITIONAL	1154	Verified
CH10-0532	Section 1030.6.1	Without smoke protection	Item 3 Where egress requires stepped aisle descent, not less than 1.9 mm of additional aisle capacity for each occupant shall be provided on those portions of aisle capacity that do not have a handrail within a horizontal distance of 750 mm.	Sl: 1.9 mm; 750 mm	min	Per Section 1030.6.1 (Without smoke protection).	1 Not less than 7.6 mm of aisle capacity for each occupant served shall be provided on stepped aisles having riser heights 175 mm or less and tread depths 275 mm or greater, measured horizontally between tread nosings. 2 Not less than 0.127 mm of additional aisle capacity for each occupant shall be provided for each 2.5 mm of riser height above 175 mm. 3 Where egress requires stepped aisle descent, not less than 1.9 mm of additional aisle capacity for each occupant shall be provided on those portions of aisle capacity that do not have a handrail within a horizontal distance of 750 mm. 4 Ramped aisles, where slopes are steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.6 mm of clear aisle capacity for each occupant served. Level or ramped aisles, where slopes are not steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.08 mm of clear aisle capacity for each occupant served.	CONDITIONAL	1154	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0533	Section 1030.6.1	Without smoke protection	Item 4 Ramped aisles, where slopes are steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.6 mm of clear aisle capacity for each occupant served. Level or ramped aisles, where slopes are not steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.08 mm of clear aisle capacity for each occupant served.	Sl: one unit vertical in 12 units horizontal; 8-percent; 5.6 mm; 5.08 mm	min	Per Section 1030.6.1 (Without smoke protection).	1 Not less than 7.6 mm of aisle capacity for each occupant served shall be provided on stepped aisles having riser heights 175 mm or less and tread depths 275 mm or greater, measured horizontally between tread nosings. 2 Not less than 0.127 mm of additional aisle capacity for each occupant shall be provided for each 2.5 mm of riser height above 175 mm. 3 Where egress requires stepped aisle descent, not less than 1.9 mm of additional aisle capacity for each occupant shall be provided on those portions of aisle capacity that do not have a handrail within a horizontal distance of 750 mm. 4 Ramped aisles, where slopes are steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.6 mm of clear aisle capacity for each occupant served. Level or ramped aisles, where slopes are not steeper than one unit vertical in 12 units horizontal (8-percent slope), shall have not less than 5.08 mm of clear aisle capacity for each occupant served.	CONDITIONAL	1154	Verified
CH10-0534	Table 1030.6.2 (appended-table row); Section 1030.6.2	Smoke-protected assembly aisle capacity	For 10,000 seats, provide 3.3 mm per seat for stairs/aisle steps with handrails within 750 mm, 4.14 mm per seat without handrails within 750 mm, 2.54 mm per seat for level/ramped aisles not steeper than 1 in 10, and 2.79 mm per seat for ramped aisles steeper than 1 in 10.	Sl: 10,000 seats; 3.3 mm per seat; 750 mm; 4.14 mm per seat; 2.54 mm per seat; 1 in 10; 2.79 mm per seat	formula	Smoke-protected assembly seating	None stated in inventory	CONDITIONAL	1181	Verified
CH10-0535	Table 1030.6.2 (appended-table row); Section 1030.6.2	Smoke-protected assembly aisle capacity	For 15,000 seats, provide 2.44 mm per seat for stairs/aisle steps with handrails within 750 mm, 3.05 mm per seat without handrails within 750 mm, 1.78 mm per seat for level/ramped aisles not steeper than 1 in 10, and 1.96 mm per seat for ramped aisles steeper than 1 in 10.	Sl: 15,000 seats; 2.44 mm per seat; 750 mm; 3.05 mm per seat; 1.78 mm per seat; 1 in 10; 1.96 mm per seat	formula	Smoke-protected assembly seating	None stated in inventory	CONDITIONAL	1181	Verified
CH10-0536	Table 1030.6.2 (appended-table row); Section 1030.6.2	Smoke-protected assembly aisle capacity	For 20,000 seats, provide 1.93 mm per seat for stairs/aisle steps with handrails within 750 mm, 2.44 mm per seat without handrails within 750 mm, 1.42 mm per seat for level/ramped aisles not steeper than 1 in 10, and 1.57 mm per seat for ramped aisles steeper than 1 in 10.	Sl: 20,000 seats; 1.93 mm per seat; 750 mm; 2.44 mm per seat; 1.42 mm per seat; 1 in 10; 1.57 mm per seat	formula	Smoke-protected assembly seating	None stated in inventory	CONDITIONAL	1181	Verified
CH10-0537	Table 1030.6.2 (appended-table row); Section 1030.6.2	Smoke-protected assembly aisle capacity	For 25,000 seats or more, provide 1.52 mm per seat for stairs/aisle steps with handrails within 750 mm, 1.91 mm per seat without handrails within 750 mm, 1.12 mm per seat for level/ramped aisles not steeper than 1 in 10, and 1.22 mm per seat for ramped aisles steeper than 1 in 10.	Sl: 25,000 seats; 1.52 mm per seat; 750 mm; 1.91 mm per seat; 1.12 mm per seat; 1 in 10; 1.22 mm per seat	formula	Smoke-protected assembly seating	None stated in inventory	CONDITIONAL	1181	Verified
CH10-0538	Table 1030.6.2 (appended-table row); Section 1030.6.2	Smoke-protected assembly aisle capacity	For 5,000 seats or fewer, provide 5.08 mm per seat for stairs/aisle steps with handrails within 750 mm, 6.35 mm per seat without handrails within 750 mm, 3.81 mm per seat for level/ramped aisles not steeper than 1 in 10, and 4.19 mm per seat for ramped aisles steeper than 1 in 10.	Sl: 5,000 seats; 5.08 mm per seat; 750 mm; 6.35 mm per seat; 3.81 mm per seat; 1 in 10; 4.19 mm per seat	formula	Smoke-protected assembly seating	None stated in inventory	CONDITIONAL	1181	Verified
CH10-0539	Section 1030.6.2.1	Smoke control	Aisles and aisle access-ways serving a smoke-protected assembly seating area shall be provided with a smoke control system complying with Section 909 or natural ventilation designed to maintain the smoke level not less than 1800 mm above the floor of the means of egress.	Sl: 1800 mm	min	Per Section 1030.6.2.1 (Smoke control).	None stated in inventory	CONDITIONAL	1155	Verified
CH10-0540	Section 1030.6.2.2	Roof height	A smoke-protected assembly seating area with a roof shall have the lowest portion of the roof deck not less than 4500 mm above the highest aisle or aisle access-way.	Sl: 4500 mm	min	Per Section 1030.6.2.2 (Roof height).	Exception: A roof canopy in an outdoor stadium shall be permitted to be less than 4.5 m above the highest aisle or aisle accessway provided that there are no objects less than 2000 mm above the highest aisle or aisle accessway.	CONDITIONAL	1155	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0541	Section 1030.6.2.2	Roof height	Exception: A roof canopy in an outdoor stadium shall be permitted to be less than 4.5 m above the highest aisle or aisle accessway provided that there are no objects less than 2000 mm above the highest aisle or aisle accessway.	Sl: 4.5 m; 2000 mm	trigger	Per Section 1030.6.2.2 (Roof height).	Exception: A roof canopy in an outdoor stadium shall be permitted to be less than 4.5 m above the highest aisle or aisle accessway provided that there are no objects less than 2000 mm above the highest aisle or aisle accessway.	CONDITIONAL	1155	Verified
CH10-0542	Section 1030.6.2.3	Automatic sprinklers	Exception item 1. The floor area used for contests, performances or entertainment provided the roof construction is more than 15 m above the floor level and the use is restricted to low-fire-hazard uses.	Sl: 15 m	trigger	Per Section 1030.6.2.3 (Automatic sprinklers).	Exceptions: 1. The floor area used for contests, performances or entertainment provided the roof construction is more than 15 m above the floor level and the use is restricted to low-fire-hazard uses. 2. Press boxes and storage facilities less than (100 \, m^{2}) in area.	CONDITIONAL	1155	Verified
CH10-0543	Section 1030.6.3	Open-air assembly seating	In open-air assembly seating, the required capacity in millimeters of aisles shall be not less than the total occupant load served by the egress element multiplied by 2.0 mm where egress is by stepped aisle and multiplied by 1.52 mm where egress is by level aisles and ramped aisles.	Sl: 2.0 mm; 1.52 mm	min	Per Section 1030.6.3 (Open-air assembly seating).	Exception: The required capacity in millimeters of aisles shall be permitted to comply with Section 1030.6.2 for the number of seats in the open-air smoke-protected assembly seating where Section 1030.6.2 permits less capacity.	CONDITIONAL	1156	Verified
CH10-0544	Section 1030.6.3.1	Automatic sprinklers	Exception item 1. The floor area used for contests, performances or entertainment, provided that the roof construction is more than 15 m above the floor level and the use is restricted to low fire hazard uses.	Sl: 15 m	trigger	Per Section 1030.6.3.1 (Automatic sprinklers).	Exceptions: 1. The floor area used for contests, performances or entertainment, provided that the roof construction is more than 15 m above the floor level and the use is restricted to low fire hazard uses. 2. Press boxes and storage facilities less than 100 m² in area. 3. Open-air assembly seating facilities where seating and the means of egress in the seating area are essentially open to the outside.	CONDITIONAL	1156	Verified
CH10-0545	Section 1030.6.3.1	Automatic sprinklers	Exception item 2. Press boxes and storage facilities less than 100 m² in area.	Sl: 100 m²	trigger	Per Section 1030.6.3.1 (Automatic sprinklers).	Exceptions: 1. The floor area used for contests, performances or entertainment, provided that the roof construction is more than 15 m above the floor level and the use is restricted to low fire hazard uses. 2. Press boxes and storage facilities less than 100 m² in area. 3. Open-air assembly seating facilities where seating and the means of egress in the seating area are essentially open to the outside.	CONDITIONAL	1156	Verified
CH10-0546	Section 1030.7	Travel distance	Exception item 1. In facilities with smoke-protected assembly seating, the total exit access travel distance shall be not greater than 120 m. That portion of the total permitted exit access travel distance from each seat to the nearest entrance to a vomitory or concourse shall not exceed 60 m. The portion of the total permitted exit access travel distance from the entrance to the vomitory or concourse to one of the following shall not exceed 60 m: 	Sl: 120 m; 60 m	max	Per Section 1030.7 (Travel distance).	Exceptions: 1. In facilities with smoke-protected assembly seating, the total exit access travel distance shall be not greater than 120 m. That portion of the total permitted exit access travel distance from each seat to the nearest entrance to a vomitory or concourse shall not exceed 60 m. The portion of the total permitted exit access travel distance from the entrance to the vomitory or concourse to one of the following shall not exceed 60 m: 1.1. The closest riser of an exit access stairway. 1.2. The closest slope of an exit access ramp. 1.3. An exit. 2. In facilities with open-air assembly seating of Type III, IV or V construction, the total exit access travel distance to one of the following shall not exceed 120 m: 2.1. The closest riser of an exit access stairway. 2.2. The closest slope of an exit access ramp. 2.3. An exit. 3. In facilities with open-air assembly seating of Type I or II construction, the total exit access travel distance shall not be limited.	CONDITIONAL	1157	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0547	Section 1030.7	Travel distance	Exception item 2. In facilities with open-air assembly seating of Type III, IV or V construction, the total exit access travel distance to one of the following shall not exceed 120 m:	Sl: 120 m	max	Per Section 1030.7 (Travel distance).	Exceptions: 1. In facilities with smoke-protected assembly seating, the total exit access travel distance shall be not greater than 120 m. That portion of the total permitted exit access travel distance from each seat to the nearest entrance to a vomitory or concourse shall not exceed 60 m. The portion of the total permitted exit access travel distance from the entrance to the vomitory or concourse to one of the following shall not exceed 60 m: 1.1. The closest riser of an exit access stairway. 1.2. The closest slope of an exit access ramp. 1.3. An exit. 2. In facilities with open-air assembly seating of Type III, IV or V construction, the total exit access travel distance to one of the following shall not exceed 120 m: 2.1. The closest riser of an exit access stairway. 2.2. The closest slope of an exit access ramp. 2.3. An exit. 3. In facilities with open-air assembly seating of Type I or II construction, the total exit access travel distance shall not be limited.	CONDITIONAL	1157	Verified
CH10-0548	Section 1030.8	Common path of egress travel	Exception item 1. For areas serving less than 50 occupants, the common path of egress travel shall not exceed 23 m.	Sl: 50 occupants; 23 m	max	Per Section 1030.8 (Common path of egress travel).	Exceptions: 1. For areas serving less than 50 occupants, the common path of egress travel shall not exceed 23 m. 2. For smoke-protected or open-air assembly seating, the common path of egress travel shall not exceed 15 m.	CONDITIONAL	1158	Verified
CH10-0549	Section 1030.8	Common path of egress travel	Exception item 2. For smoke-protected or open-air assembly seating, the common path of egress travel shall not exceed 15 m.	Sl: 15 m	max	Per Section 1030.8 (Common path of egress travel).	Exceptions: 1. For areas serving less than 50 occupants, the common path of egress travel shall not exceed 23 m. 2. For smoke-protected or open-air assembly seating, the common path of egress travel shall not exceed 15 m.	CONDITIONAL	1158	Verified
CH10-0550	Section 1030.8	Common path of egress travel	The common path of egress travel shall not exceed 9 m from any seat to a point where an occupant has a choice of two paths of egress travel to two exits.	Sl: 9 m; two exits	max	Per Section 1030.8 (Common path of egress travel).	Exceptions: 1. For areas serving less than 50 occupants, the common path of egress travel shall not exceed 23 m. 2. For smoke-protected or open-air assembly seating, the common path of egress travel shall not exceed 15 m.	CONDITIONAL	1158	Verified
CH10-0551	Section 1030.8.1	Path through adjacent row	Exception: For smoke-protected or open-air assembly seating there shall be not more than 40 seats between the two aisles and the minimum clear width shall be 300 mm plus 7.5 mm for each additional seat.	Sl: 40 seats; 300 mm; 7.5 mm	mixed	Per Section 1030.8.1 (Path through adjacent row).	Exception: For smoke-protected or open-air assembly seating there shall be not more than 40 seats between the two aisles and the minimum clear width shall be 300 mm plus 7.5 mm for each additional seat.	CONDITIONAL	1158	Verified
CH10-0552	Section 1030.8.1	Path through adjacent row	Where one of the two paths of travel is across the aisle through a row of seats to another aisle, there shall be not more than 24 seats between the two aisles, and the minimum clear width between rows for the row between the two aisles shall be 300 mm plus 15.2 mm for each additional seat above seven in the row between aisles.	Sl: 24 seats; 300 mm; 15.2 mm	mixed	Per Section 1030.8.1 (Path through adjacent row).	Exception: For smoke-protected or open-air assembly seating there shall be not more than 40 seats between the two aisles and the minimum clear width shall be 300 mm plus 7.5 mm for each additional seat.	CONDITIONAL	1158	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0553	Section 1030.9.1	Minimum aisle width	Exception item 1 1200 mm for stepped aisles having seating on both sides.	Sl: 1200 mm	trigger	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified
CH10-0554	Section 1030.9.1	Minimum aisle width	Exception item 1. 900 mm where the aisle serves less than 50 seats.	Sl: 900 mm; 50 seats	trigger	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified
CH10-0555	Section 1030.9.1	Minimum aisle width	Exception item 2 900 mm for stepped aisles having seating on only one side.	Sl: 900 mm; one side	trigger	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0556	Section 1030.9.1	Minimum aisle width	Exception item 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route.	Sl: 750 mm; 15 seats	trigger	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified
CH10-0557	Section 1030.9.1	Minimum aisle width	Exception item 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail.	Sl: 600 mm	min	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified
CH10-0558	Section 1030.9.1	Minimum aisle width	Exception item 4 1100 mm for level or ramped aisles having seating on both sides.	Sl: 1100 mm	trigger	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0559	Section 1030.9.1	Minimum aisle width	Exception item 5 900 mm for level or ramped aisles having seating on only one side.	Sl: 900 mm; one side	trigger	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified
CH10-0560	Section 1030.9.1	Minimum aisle width	Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side.	Sl: 600 mm; five rows; one side	mixed	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified
CH10-0561	Section 1030.9.1	Minimum aisle width	Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	Sl: 750 mm; 15 seats	trigger	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0562	Section 1030.9.1	Minimum aisle width	Exception: 900 mm where the stepped aisles serve less than 50 seats.	Sl: 900 mm; 50 seats	trigger	Per Section 1030.9.1 (Minimum aisle width).	1 1200 mm for stepped aisles having seating on both sides. Exception: 900 mm where the stepped aisles serve less than 50 seats. 2 900 mm for stepped aisles having seating on only one side. Exception: 600 mm between a stepped aisle handrail and seating where a stepped aisle does not serve more than five rows on one side. 3 600 mm between a stepped aisle handrail or guard and seating where the stepped aisle is subdivided by a mid-aisle handrail. 4 1100 mm for level or ramped aisles having seating on both sides. Exceptions: 1. 900 mm where the aisle serves less than 50 seats. 2. 750 mm where the aisle serves less than 15 seats and does not serve as part of an accessible route. 5 900 mm for level or ramped aisles having seating on only one side. Exception: 750 mm where the aisle serves fewer than 15 seats and does not serve as part of an accessible route.	CONDITIONAL	1158	Verified
CH10-0563	Section 1030.9.4	Assembly aisle uniform width and capacity	Portions of aisles where egress is possible in either of two directions shall be uniform in minimum width or required capacity.	Sl: two directions	configuration	Assembly aisle permitting egress in either direction.	None stated in inventory	CONDITIONAL	1159	Verified
CH10-0564	Section 1030.9.5	Dead end aisles	Exception item 1. Dead-end aisles shall be not greater than 6000 mm in length.	Sl: 6000 mm	max	Per Section 1030.9.5 (Dead end aisles).	Exceptions: 1. Dead-end aisles shall be not greater than 6000 mm in length. 2. Dead-end aisles longer than 16 rows are permitted where seats beyond the 16th row dead-end aisle are not more than 24 seats from another aisle, measured along a row of seats having a minimum clear width of 300 mm plus 15 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row. 3. For smoke-protected or open-air assembly seating, the dead-end aisle length of vertical aisles shall not exceed a distance of 21 rows. 4. For smoke-protected or open-air assembly seating, a longer dead-end aisle is permitted where seats beyond the 21-row dead-end aisle are not more than 40 seats from another aisle, measured along a row of seats having an aisle access-way with a minimum clear width of 300 mm plus 7.6 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row.	CONDITIONAL	1160	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0565	Section 1030.9.5	Dead end aisles	Exception item 2. Dead-end aisles longer than 16 rows are permitted where seats beyond the 16th row dead-end aisle are not more than 24 seats from another aisle, measured along a row of seats having a minimum clear width of 300 mm plus 15 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row.	Sl: 16 rows; 24 seats; 300 mm; 15 mm; seven seats; 10 seats	mixed	Per Section 1030.9.5 (Dead end aisles).	Exceptions: 1. Dead-end aisles shall be not greater than 6000 mm in length. 2. Dead-end aisles longer than 16 rows are permitted where seats beyond the 16th row dead-end aisle are not more than 24 seats from another aisle, measured along a row of seats having a minimum clear width of 300 mm plus 15 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row. 3. For smoke-protected or open-air assembly seating, the dead-end aisle length of vertical aisles shall not exceed a distance of 21 rows. 4. For smoke-protected or open-air assembly seating, a longer dead-end aisle is permitted where seats beyond the 21-row dead-end aisle are not more than 40 seats from another aisle, measured along a row of seats having an aisle access-way with a minimum clear width of 300 mm plus 7.6 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row.	CONDITIONAL	1160	Verified
CH10-0566	Section 1030.9.5	Dead end aisles	Exception item 3. For smoke-protected or open-air assembly seating, the dead-end aisle length of vertical aisles shall not exceed a distance of 21 rows.	Sl: 21 rows	max	Per Section 1030.9.5 (Dead end aisles).	Exceptions: 1. Dead-end aisles shall be not greater than 6000 mm in length. 2. Dead-end aisles longer than 16 rows are permitted where seats beyond the 16th row dead-end aisle are not more than 24 seats from another aisle, measured along a row of seats having a minimum clear width of 300 mm plus 15 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row. 3. For smoke-protected or open-air assembly seating, the dead-end aisle length of vertical aisles shall not exceed a distance of 21 rows. 4. For smoke-protected or open-air assembly seating, a longer dead-end aisle is permitted where seats beyond the 21-row dead-end aisle are not more than 40 seats from another aisle, measured along a row of seats having an aisle access-way with a minimum clear width of 300 mm plus 7.6 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row.	CONDITIONAL	1160	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0567	Section 1030.9.5	Dead end aisles	Exception item 4. For smoke-protected or open-air assembly seating, a longer dead-end aisle is permitted where seats beyond the 21-row dead-end aisle are not more than 40 seats from another aisle, measured along a row of seats having an aisle access-way with a minimum clear width of 300 mm plus 7.6 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row.	Sl: 40 seats; 300 mm; 7.6 mm; 21 rows; seven seats; 10 seats	mixed	Per Section 1030.9.5 (Dead end aisles).	Exceptions: 1. Dead-end aisles shall be not greater than 6000 mm in length. 2. Dead-end aisles longer than 16 rows are permitted where seats beyond the 16th row dead-end aisle are not more than 24 seats from another aisle, measured along a row of seats having a minimum clear width of 300 mm plus 15 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row. 3. For smoke-protected or open-air assembly seating, the dead-end aisle length of vertical aisles shall not exceed a distance of 21 rows. 4. For smoke-protected or open-air assembly seating, a longer dead-end aisle is permitted where seats beyond the 21-row dead-end aisle are not more than 40 seats from another aisle, measured along a row of seats having an aisle access-way with a minimum clear width of 300 mm plus 7.6 mm for each additional seat above seven in the row where seats have backrests or beyond 10 where seats are without backrests in the row.	CONDITIONAL	1160	Verified
CH10-0568	Section 1030.10.1	Transitions to stairways that maintain stepped aisle riser and tread dimensions	Stepped aisles, transitions and stairways that maintain the stepped aisle riser and tread dimensions shall comply with Section 1030.14 as one exit access component.	Sl: one exit	trigger	Per Section 1030.10.1 (Transitions to stairways that maintain stepped aisle riser and tread dimensions).	None stated in inventory	CONDITIONAL	1161	Verified
CH10-0569	Section 1030.10.2.1	Stairways and stepped aisles in a straight run	Item 1 A depth of not less than 550 mm where the treads on the descending side of the transition have greater depth.	Sl: 550 mm	min	Per Section 1030.10.2.1 (Stairways and stepped aisles in a straight run).	1 A depth of not less than 550 mm where the treads on the descending side of the transition have greater depth. 2 A depth of not less than 750 mm where the treads on the descending side of the transition have lesser depth.	CONDITIONAL	1161	Verified
CH10-0570	Section 1030.10.2.1	Stairways and stepped aisles in a straight run	Item 2 A depth of not less than 750 mm where the treads on the descending side of the transition have lesser depth.	Sl: 750 mm	min	Per Section 1030.10.2.1 (Stairways and stepped aisles in a straight run).	1 A depth of not less than 550 mm where the treads on the descending side of the transition have greater depth. 2 A depth of not less than 750 mm where the treads on the descending side of the transition have lesser depth.	CONDITIONAL	1161	Verified
CH10-0571	Section 1030.10.2.2	Stairways that change direction from stepped aisles	Transitions where the stairway changes direction from the stepped aisle shall have a minimum depth of 275 mm or the stepped aisle tread depth, whichever is greater, between the stepped aisle and stairway.	Sl: 275 mm	min	Per Section 1030.10.2.2 (Stairways that change direction from stepped aisles).	None stated in inventory	CONDITIONAL	1161	Verified
CH10-0572	Section 1030.10.3	Transition marking	Such stripe shall be not less than 25 mm, and not more than 50 mm, wide.	Sl: 25 mm; 50 mm	range	Per Section 1030.10.3 (Transition marking).	None stated in inventory	CONDITIONAL	1161	Verified
CH10-0573	Section 1030.11.1	Stepped aisles that change direction at vomitories	Stepped aisle treads where the stepped aisle changes direction at a vomitory shall have a depth of not less than 275 mm or the stepped aisle tread depth, whichever is greater.	Sl: 275 mm	min	Per Section 1030.11.1 (Stepped aisles that change direction at vomitories).	None stated in inventory	CONDITIONAL	1162	Verified
CH10-0574	Section 1030.11.2	Stepped aisle transitions at the top of vomitories	Transitions between the stepped aisle above a vomitory and stepped aisles to the side of a vomitory shall have a depth of not less than 275 mm or the stepped aisle tread depth, whichever is greater.	Sl: 275 mm	min	Per Section 1030.11.2 (Stepped aisle transitions at the top of vomitories).	None stated in inventory	CONDITIONAL	1162	Verified
CH10-0575	Section 1030.13.1	Seating at tables	The 480 mm distance shall be measured perpendicular to the side of the table or counter.	Sl: 480 mm	trigger	Per Section 1030.13.1 (Seating at tables).	Exception: Where tables or counters are served by fixed seats, the width of the aisle or aisle access-way shall be measured from the back of the seat.	CONDITIONAL	1162	Verified
CH10-0576	Section 1030.13.1	Seating at tables	Where seating is located at a table or counter and is adjacent to an aisle or aisle access-way, the measurement of required clear width of the aisle or aisle access-way shall be made to a line 480 mm away from and parallel to the edge of the table or counter.	Sl: 480 mm	trigger	Per Section 1030.13.1 (Seating at tables).	Exception: Where tables or counters are served by fixed seats, the width of the aisle or aisle access-way shall be measured from the back of the seat.	CONDITIONAL	1162	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0577	Section 1030.13.1.1	Aisle access-way capacity and width for seating at tables	Aisle access-ways serving arrangements of seating at tables or counters shall comply with the capacity requirements of Section 1005.1 but shall not have less than 300 mm of width plus 12.5 mm of width for each additional 300 mm, or fraction thereof, beyond 3600 mm of aisle access-way length measured from the center of the seat farthest from an aisle.	Sl: 300 mm; 12.5 mm; 3600 mm	formula	Per Section 1030.13.1.1 (Aisle access-way capacity and width for seating at tables).	Exception: Portions of an aisle access-way having a length not exceeding 1800 mm and used by a total of not more than four persons.	CONDITIONAL	1163	Verified
CH10-0578	Section 1030.13.1.1	Aisle access-way capacity and width for seating at tables	Exception: Portions of an aisle access-way having a length not exceeding 1800 mm and used by a total of not more than four persons.	Sl: 1800 mm; four persons	max	Per Section 1030.13.1.1 (Aisle access-way capacity and width for seating at tables).	Exception: Portions of an aisle access-way having a length not exceeding 1800 mm and used by a total of not more than four persons.	CONDITIONAL	1163	Verified
CH10-0579	Section 1030.13.1.2	Seating at table aisle access-way length	The length of travel along the aisle access-way shall not exceed 9 m from any seat to the point where a person has a choice of two or more paths of egress travel to separate exits.	Sl: 9 m	max	Per Section 1030.13.1.2 (Seating at table aisle access-way length).	None stated in inventory	CONDITIONAL	1163	Verified
CH10-0580	Section 1030.13.2	Clear width of aisle access-ways serving seating in rows	Exception: For seats with folding tablet arms, row spacing is permitted to be determined with the tablet arm in the stored position where the tablet arm when raised manually to vertical position in one motion automatically returns to the stored position by force of gravity.	Sl: one motion	trigger	Per Section 1030.13.2 (Clear width of aisle access-ways serving seating in rows).	Exception: For seats with folding tablet arms, row spacing is permitted to be determined with the tablet arm in the stored position where the tablet arm when raised manually to vertical position in one motion automatically returns to the stored position by force of gravity.	CONDITIONAL	1163	Verified
CH10-0581	Section 1030.13.2	Clear width of aisle access-ways serving seating in rows	Where seating rows have 14 or fewer seats, the minimum clear aisle access-way width shall be not less than 300 mm measured as the clear horizontal distance from the back of the row ahead and the nearest projection of the row behind.	Sl: 300 mm; 14 seats	min	Per Section 1030.13.2 (Clear width of aisle access-ways serving seating in rows).	Exception: For seats with folding tablet arms, row spacing is permitted to be determined with the tablet arm in the stored position where the tablet arm when raised manually to vertical position in one motion automatically returns to the stored position by force of gravity.	CONDITIONAL	1163	Verified
CH10-0582	Section 1030.13.2.1	Dual access	Exception: For smoke-protected or open-air assembly seating, the row length limits for a 300 mm aisle accessway, beyond which the aisle accessway minimum clear width shall be increased, are in Table 1030.13.2.1.	Sl: 300 mm	min	Per Section 1030.13.2.1 (Dual access).	Exception: For smoke-protected or open-air assembly seating, the row length limits for a 300 mm aisle accessway, beyond which the aisle accessway minimum clear width shall be increased, are in Table 1030.13.2.1.	CONDITIONAL	1164	Verified
CH10-0583	Section 1030.13.2.1	Dual access	For rows of seating served by aisles or doorways at both ends, there shall be not more than 100 seats per row.	Sl: 100 seats	max	Per Section 1030.13.2.1 (Dual access).	Exception: For smoke-protected or open-air assembly seating, the row length limits for a 300 mm aisle accessway, beyond which the aisle accessway minimum clear width shall be increased, are in Table 1030.13.2.1.	CONDITIONAL	1164	Verified
CH10-0584	Section 1030.13.2.1	Dual access	The minimum clear width is not required to exceed 550 mm.	Sl: 550 mm	max	Per Section 1030.13.2.1 (Dual access).	Exception: For smoke-protected or open-air assembly seating, the row length limits for a 300 mm aisle accessway, beyond which the aisle accessway minimum clear width shall be increased, are in Table 1030.13.2.1.	CONDITIONAL	1164	Verified
CH10-0585	Section 1030.13.2.1	Dual access	The minimum clear width of 300 mm between rows shall be increased by 7.6 mm for every additional seat beyond 14 seats where seats have backrests or beyond 21 where seats are without backrests.	Sl: 300 mm; 7.6 mm; 14 seats; 21 seats	min	Per Section 1030.13.2.1 (Dual access).	Exception: For smoke-protected or open-air assembly seating, the row length limits for a 300 mm aisle accessway, beyond which the aisle accessway minimum clear width shall be increased, are in Table 1030.13.2.1.	CONDITIONAL	1164	Verified
CH10-0586	Table 1030.13.2.1 (appended-table row); Section 1030.13.2.1	Assembly aisle access-way row limits	For 10,000 to 12,999 seats and a minimum 300 mm clear aisle access-way: maximum seats per row are 17 seats with backrests and 24 seats without backrests where aisles/doorways serve both ends; 8 seats with backrests and 11 seats without backrests where only one end is served.	Sl: 10,000 to 12,999 seats; 300 mm; 17 seats; 24 seats; 8 seats; 11 seats	mixed	Smoke-protected or open-air assembly seating	None stated in inventory	CONDITIONAL	1182	Verify source
CH10-0587	Table 1030.13.2.1 (appended-table row); Section 1030.13.2.1	Assembly aisle access-way row limits	For 13,000 to 15,999 seats and a minimum 300 mm clear aisle access-way: maximum seats per row are 18 seats with backrests and 25 seats without backrests where aisles/doorways serve both ends; 9 seats with backrests and 12 seats without backrests where only one end is served.	Sl: 13,000 to 15,999 seats; 300 mm; 18 seats; 25 seats; 9 seats; 12 seats	mixed	Smoke-protected or open-air assembly seating	None stated in inventory	CONDITIONAL	1182	Verify source

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0588	Table 1030.13.2.1 (appended-table row); Section 1030.13.2.1	Assembly aisle access-way row limits	For 16,000 to 18,999 seats and a minimum 300 mm clear aisle access-way: maximum seats per row are 19 seats with backrests and 26 seats without backrests where aisles/doorways serve both ends; 9 seats with backrests and 12 seats without backrests where only one end is served.	Sl: 16,000 to 18,999 seats; 300 mm; 19 seats; 26 seats; 9 seats; 12 seats	mixed	Smoke-protected or open-air assembly seating	None stated in inventory	CONDITIONAL	1182	Verify source
CH10-0589	Table 1030.13.2.1 (appended-table row); Section 1030.13.2.1	Assembly aisle access-way row limits	For 19,000 to 21,999 seats and a minimum 300 mm clear aisle access-way: maximum seats per row are 20 seats with backrests and 27 seats without backrests where aisles/doorways serve both ends; 10 seats with backrests and 13 seats without backrests where only one end is served.	Sl: 19,000 to 21,999 seats; 300 mm; 20 seats; 27 seats; 10 seats; 13 seats	mixed	Smoke-protected or open-air assembly seating	None stated in inventory	CONDITIONAL	1182	Verify source
CH10-0590	Table 1030.13.2.1 (appended-table row); Section 1030.13.2.1	Assembly aisle access-way row limits	For 22,000 seats and greater and a minimum 300 mm clear aisle access-way: maximum seats per row are 21 seats with backrests and 28 seats without backrests where aisles/doorways serve both ends; 11 seats with backrests and 14 seats without backrests where only one end is served.	Sl: 22,000 seats; 300 mm; 21 seats; 28 seats; 11 seats; 14 seats	mixed	Smoke-protected or open-air assembly seating	None stated in inventory	CONDITIONAL	1182	Verify source
CH10-0591	Table 1030.13.2.1 (appended-table row); Section 1030.13.2.1	Assembly aisle access-way row limits	For 4,000 to 6,999 seats and a minimum 300 mm clear aisle access-way: maximum seats per row are 15 seats with backrests and 22 seats without backrests where aisles/doorways serve both ends; 7 seats with backrests and 10 seats without backrests where only one end is served.	Sl: 4,000 to 6,999 seats; 300 mm; 15 seats; 22 seats; 7 seats; 10 seats	mixed	Smoke-protected or open-air assembly seating	None stated in inventory	CONDITIONAL	1182	Verify source
CH10-0592	Table 1030.13.2.1 (appended-table row); Section 1030.13.2.1	Assembly aisle access-way row limits	For 7,000 to 9,999 seats and a minimum 300 mm clear aisle access-way: maximum seats per row are 16 seats with backrests and 23 seats without backrests where aisles/doorways serve both ends; 8 seats with backrests and 11 seats without backrests where only one end is served.	Sl: 7,000 to 9,999 seats; 300 mm; 16 seats; 23 seats; 8 seats; 11 seats	mixed	Smoke-protected or open-air assembly seating	None stated in inventory	CONDITIONAL	1182	Verify source
CH10-0593	Table 1030.13.2.1 (appended-table row); Section 1030.13.2.1	Assembly aisle access-way row limits	For less than 4,000 seats and a minimum 300 mm clear aisle access-way: maximum seats per row are 14 seats with backrests and 21 seats without backrests where aisles/doorways serve both ends; 7 seats with backrests and 10 seats without backrests where only one end is served.	Sl: 4,000 seats; 300 mm; 14 seats; 21 seats; 7 seats; 10 seats	mixed	Smoke-protected or open-air assembly seating	None stated in inventory	CONDITIONAL	1182	Verify source
CH10-0594	Section 1030.13.2.2	Single access	Exception: For smoke-protected or open-air assembly seating, the row length limits for a 300 mm aisle access-way, beyond which the aisle access-way minimum clear width shall be increased, are in Table 1030.13.2.1.	Sl: 300 mm	min	Per Section 1030.13.2.2 (Single access).	Exception: For smoke-protected or open-air assembly seating, the row length limits for a 300 mm aisle access-way, beyond which the aisle access-way minimum clear width shall be increased, are in Table 1030.13.2.1.	CONDITIONAL	1164	Verified
CH10-0595	Section 1030.13.2.2	Single access	For rows of seating served by an aisle or doorway at only one end of the row, the minimum clear width of 300 mm between rows shall be increased by 15.2 mm for every additional seat beyond seven seats where seats have backrests or beyond 10 where seats are without backrests.	Sl: 300 mm; 15.2 mm; seven seats; 10 seats	min	Per Section 1030.13.2.2 (Single access).	Exception: For smoke-protected or open-air assembly seating, the row length limits for a 300 mm aisle access-way, beyond which the aisle access-way minimum clear width shall be increased, are in Table 1030.13.2.1.	CONDITIONAL	1164	Verified
CH10-0596	Section 1030.13.2.2	Single access	The minimum clear width is not required to exceed 550 mm.	Sl: 550 mm	max	Per Section 1030.13.2.2 (Single access).	Exception: For smoke-protected or open-air assembly seating, the row length limits for a 300 mm aisle access-way, beyond which the aisle access-way minimum clear width shall be increased, are in Table 1030.13.2.1.	CONDITIONAL	1164	Verified
CH10-0597	Section 1030.14.1	Ramped aisles	Aisles that are sloped more than 1 unit vertical in 20 units horizontal (5-percent slope) shall be considered to be a ramped aisle.	Sl: 1 unit vertical in 20 units horizontal; 5-percent	trigger	Per Section 1030.14.1 (Ramped aisles).	None stated in inventory	CONDITIONAL	1165	Verified
CH10-0598	Section 1030.14.1	Ramped aisles	Ramped aisles that serve as part of an accessible route in accordance with Sections 1009 and 1109.2 shall have a maximum slope of 1 unit vertical in 12 units horizontal (8-percent slope).	Sl: 1 unit vertical in 12 units horizontal; 8-percent	max	Per Section 1030.14.1 (Ramped aisles).	None stated in inventory	CONDITIONAL	1165	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0599	Section 1030.14.1	Ramped aisles	The slope of other ramped aisles shall not exceed 1 unit vertical in 8 units horizontal (12.5-percent slope).	Sl: 1 unit vertical in 8 units horizontal; 12.5-percent	max	Per Section 1030.14.1 (Ramped aisles).	None stated in inventory	CONDITIONAL	1165	Verified
CH10-0600	Section 1030.14.1.1	Cross slope	The slope measured perpendicular to the direction of travel of a ramped aisle shall not be steeper than one unit vertical in 48 units horizontal (2-percent slope).	Sl: one unit vertical in 48 units horizontal; 2-percent	max	Per Section 1030.14.1.1 (Cross slope).	None stated in inventory	CONDITIONAL	1165	Verified
CH10-0601	Section 1030.14.2	Stepped aisles	Aisles with a slope exceeding one unit vertical in eight units horizontal (12.5-percent slope) shall consist of a series of risers and treads that extends across the full width of aisles and complies with Sections 1030.14.2.1 through 1030.14.2.4.	Sl: 12.5-percent; one unit vertical in eight units horizontal	trigger	Per Section 1030.14.2 (Stepped aisles).	None stated in inventory	CONDITIONAL	1165	Verified
CH10-0602	Section 1030.14.2.1	Treads	Exception: The tolerance between adjacent treads shall not exceed 5 mm.	Sl: 5 mm	max	Per Section 1030.14.2.1 (Treads).	Exception: The tolerance between adjacent treads shall not exceed 5 mm.	CONDITIONAL	1166	Verified
CH10-0603	Section 1030.14.2.1	Treads	Tread depths shall be not less than 275 mm and shall have dimensional uniformity.	Sl: 275 mm	min	Per Section 1030.14.2.1 (Treads).	Exception: The tolerance between adjacent treads shall not exceed 5 mm.	CONDITIONAL	1166	Verified
CH10-0604	Section 1030.14.2.2	Risers	Exception item 1. Riser height non-uniformity shall be limited to the extent necessitated by changes in the gradient of the adjoining seating area to maintain adequate sightlines. Where non-uniformities exceed 5 mm between adjacent risers, the exact location of such non-uniformities shall be indicated with a distinctive marking stripe on each tread at the nosing or leading edge adjacent to the non-uniform risers. Such stripe shall be not less than 25 mm, and not more than 50 mm, wide. The edge marking stripe shall be distinctively different from the contrasting marking stripe.	Sl: 5 mm; 25 mm; 50 mm	mixed	Per Section 1030.14.2.2 (Risers).	Exceptions: 1. Riser height non-uniformity shall be limited to the extent necessitated by changes in the gradient of the adjoining seating area to maintain adequate sightlines. Where non-uniformities exceed 5 mm between adjacent risers, the exact location of such non-uniformities shall be indicated with a distinctive marking stripe on each tread at the nosing or leading edge adjacent to the non-uniform risers. Such stripe shall be not less than 25 mm, and not more than 50 mm, wide. The edge marking stripe shall be distinctively different from the contrasting marking stripe. 2. Riser heights not exceeding 225 mm shall be permitted where they are necessitated by the slope of the adjacent seating areas to maintain sightlines.	CONDITIONAL	1166	Verified
CH10-0605	Section 1030.14.2.2	Risers	Exception item 2. Riser heights not exceeding 225 mm shall be permitted where they are necessitated by the slope of the adjacent seating areas to maintain sightlines.	Sl: 225 mm	trigger	Per Section 1030.14.2.2 (Risers).	Exceptions: 1. Riser height non-uniformity shall be limited to the extent necessitated by changes in the gradient of the adjoining seating area to maintain adequate sightlines. Where non-uniformities exceed 5 mm between adjacent risers, the exact location of such non-uniformities shall be indicated with a distinctive marking stripe on each tread at the nosing or leading edge adjacent to the non-uniform risers. Such stripe shall be not less than 25 mm, and not more than 50 mm, wide. The edge marking stripe shall be distinctively different from the contrasting marking stripe. 2. Riser heights not exceeding 225 mm shall be permitted where they are necessitated by the slope of the adjacent seating areas to maintain sightlines.	CONDITIONAL	1166	Verified
CH10-0606	Section 1030.14.2.2	Risers	Where the gradient of stepped aisles is to be the same as the gradient of adjoining seating areas, the riser height shall be not less than 100 mm nor more than 200 mm and shall be uniform within each flight.	Sl: 100 mm; 200 mm	range	Per Section 1030.14.2.2 (Risers).	Exceptions: 1. Riser height non-uniformity shall be limited to the extent necessitated by changes in the gradient of the adjoining seating area to maintain adequate sightlines. Where non-uniformities exceed 5 mm between adjacent risers, the exact location of such non-uniformities shall be indicated with a distinctive marking stripe on each tread at the nosing or leading edge adjacent to the non-uniform risers. Such stripe shall be not less than 25 mm, and not more than 50 mm, wide. The edge marking stripe shall be distinctively different from the contrasting marking stripe. 2. Riser heights not exceeding 225 mm shall be permitted where they are necessitated by the slope of the adjacent seating areas to maintain sightlines.	CONDITIONAL	1166	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0607	Section 1030.14.2.2.1	Construction tolerances	Where the stepped aisle is designed in accordance with Exception 1 of Section 1030.14.2.2, the stepped aisle shall be constructed so that each riser of unequal height, determined in the direction of descent, is not more than 10 mm in height different from adjacent risers where stepped aisle treads are less than 550 mm in depth and 20 mm in height different from adjacent risers where stepped aisle treads are 550 mm or greater in depth.	Sl: 10 mm; 550 mm; 20 mm	max	Per Section 1030.14.2.2.1 (Construction tolerances).	None stated in inventory	CONDITIONAL	1166–1167	Verified
CH10-0608	Section 1030.14.2.2.1	Construction tolerances	The tolerance between adjacent risers on a stepped aisle that were designed to be equal height shall not exceed 5 mm.	Sl: 5 mm	max	Per Section 1030.14.2.2.1 (Construction tolerances).	None stated in inventory	CONDITIONAL	1166	Verified
CH10-0609	Section 1030.14.2.3	Tread contrasting marking stripe	Such stripe shall be not less than 25 mm, and not more than 50 mm, wide.	Sl: 25 mm; 50 mm	range	Per Section 1030.14.2.3 (Tread contrasting marking stripe).	Exception: The contrasting marking stripe is permitted to be omitted where tread surfaces are such that the location of each tread is readily apparent when viewed in descent.	CONDITIONAL	1167	Verified
CH10-0610	Section 1030.15	Seat stability	Exception item 3. In a building, room or space used for assembly purposes or portions thereof without ramped or tiered floors for seating and with greater than 200 seats, the seats shall be fastened together in groups of not less than three or the seats shall be securely fastened to the floor.	Sl: 200 seats	mixed	Per Section 1030.15 (Seat stability).	Exceptions: 1. In a building, room or space used for assembly purposes or portions thereof without ramped or tiered floors for seating and with 200 or fewer seats, the seats shall not be required to be fastened to the floor. 2. In a building, room or space used for assembly purposes or portions thereof with seating at tables and without ramped or tiered floors for seating, the seats shall not be required to be fastened to the floor. 3. In a building, room or space used for assembly purposes or portions thereof without ramped or tiered floors for seating and with greater than 200 seats, the seats shall be fastened together in groups of not less than three or the seats shall be securely fastened to the floor. 4. In a building, room or space used for assembly purposes where flexibility of the seating arrangement is an integral part of the design and function of the space and seating is on tiered levels, not more than 200 seats shall not be required to be fastened to the floor. Plans showing seating, tiers and aisles shall be submitted for approval. 5. Groups of seats within a building, room or space used for assembly purposes separated from other seating by railings, guards, partial height walls or similar barriers with level floors and having not more than 14 seats per group shall not be required to be fastened to the floor. 6. Seats intended for musicians or other performers and separated by railings, guards, partial height walls or similar barriers shall not be required to be fastened to the floor.	CONDITIONAL	1167	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0611	Section 1030.15	Seat stability	Exception item 4. In a building, room or space used for assembly purposes where flexibility of the seating arrangement is an integral part of the design and function of the space and seating is on tiered levels, not more than 200 seats shall not be required to be fastened to the floor. Plans showing seating, tiers and aisles shall be submitted for approval.	Sl: 200 seats	max	Per Section 1030.15 (Seat stability).	Exceptions: 1. In a building, room or space used for assembly purposes or portions thereof without ramped or tiered floors for seating and with 200 or fewer seats, the seats shall not be required to be fastened to the floor. 2. In a building, room or space used for assembly purposes or portions thereof with seating at tables and without ramped or tiered floors for seating, the seats shall not be required to be fastened to the floor. 3. In a building, room or space used for assembly purposes or portions thereof without ramped or tiered floors for seating and with greater than 200 seats, the seats shall be fastened together in groups of not less than three or the seats shall be securely fastened to the floor. 4. In a building, room or space used for assembly purposes where flexibility of the seating arrangement is an integral part of the design and function of the space and seating is on tiered levels, not more than 200 seats shall not be required to be fastened to the floor. Plans showing seating, tiers and aisles shall be submitted for approval. 5. Groups of seats within a building, room or space used for assembly purposes separated from other seating by railings, guards, partial height walls or similar barriers with level floors and having not more than 14 seats per group shall not be required to be fastened to the floor. 6. Seats intended for musicians or other performers and separated by railings, guards, partial height walls or similar barriers shall not be required to be fastened to the floor.	CONDITIONAL	1167	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0612	Section 1030.15	Seat stability	Exception item 5. Groups of seats within a building, room or space used for assembly purposes separated from other seating by railings, guards, partial height walls or similar barriers with level floors and having not more than 14 seats per group shall not be required to be fastened to the floor.	Sl: 14 seats	max	Per Section 1030.15 (Seat stability).	Exceptions: 1. In a building, room or space used for assembly purposes or portions thereof without ramped or tiered floors for seating and with 200 or fewer seats, the seats shall not be required to be fastened to the floor. 2. In a building, room or space used for assembly purposes or portions thereof with seating at tables and without ramped or tiered floors for seating, the seats shall not be required to be fastened to the floor. 3. In a building, room or space used for assembly purposes or portions thereof without ramped or tiered floors for seating and with greater than 200 seats, the seats shall be fastened together in groups of not less than three or the seats shall be securely fastened to the floor. 4. In a building, room or space used for assembly purposes where flexibility of the seating arrangement is an integral part of the design and function of the space and seating is on tiered levels, not more than 200 seats shall not be required to be fastened to the floor. Plans showing seating, tiers and aisles shall be submitted for approval. 5. Groups of seats within a building, room or space used for assembly purposes separated from other seating by railings, guards, partial height walls or similar barriers with level floors and having not more than 14 seats per group shall not be required to be fastened to the floor. 6. Seats intended for musicians or other performers and separated by railings, guards, partial height walls or similar barriers shall not be required to be fastened to the floor.	CONDITIONAL	1167	Verified
CH10-0613	Section 1030.16	Handrails	Ramped aisles having a slope exceeding one unit vertical in 15 units horizontal (6.7-percent slope) and stepped aisles shall be provided with handrails in compliance with Section 1014 located either at one or both sides of the aisle or within the aisle width.	Sl: one unit vertical in 15 units horizontal; 6.7-percent	trigger	Per Section 1030.16 (Handrails).	## Exceptions: 1. Handrails are not required for ramped aisles with seating on both sides. 2. Handrails are not required where, at the side of the aisle, there is a guard with a top surface that complies with the graspability requirements of handrails in accordance with Section 1014.3. 3. Handrail extensions are not required at the top and bottom of stepped aisles and ramped aisles to permit crossovers within the aisles.	CONDITIONAL	1167	Verified
CH10-0614	Section 1030.16	Handrails	Where stepped aisles have seating on one side and the aisle width is 1850 mm or greater, two handrails are required.	Sl: one side; 1850 mm	trigger	Per Section 1030.16 (Handrails).	## Exceptions: 1. Handrails are not required for ramped aisles with seating on both sides. 2. Handrails are not required where, at the side of the aisle, there is a guard with a top surface that complies with the graspability requirements of handrails in accordance with Section 1014.3. 3. Handrail extensions are not required at the top and bottom of stepped aisles and ramped aisles to permit crossovers within the aisles.	CONDITIONAL	1167	Verified
CH10-0615	Section 1030.16	Handrails	Where two handrails are required, one of the handrails shall be within 750 mm horizontally of the stepped aisle.	Sl: 750 mm	trigger	Per Section 1030.16 (Handrails).	## Exceptions: 1. Handrails are not required for ramped aisles with seating on both sides. 2. Handrails are not required where, at the side of the aisle, there is a guard with a top surface that complies with the graspability requirements of handrails in accordance with Section 1014.3. 3. Handrail extensions are not required at the top and bottom of stepped aisles and ramped aisles to permit crossovers within the aisles.	CONDITIONAL	1167	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0616	Section 1030.16.1	Discontinuous handrails	Gaps or breaks shall be provided at intervals not exceeding five rows to facilitate access to seating and to permit crossing from one side of the aisle to the other.	Sl: five rows; one side	trigger	Per Section 1030.16.1 (Discontinuous handrails).	None stated in inventory	CONDITIONAL	1168	Verified
CH10-0617	Section 1030.16.1	Discontinuous handrails	These gaps or breaks shall have a clear width of not less than 550 mm and not greater than 900 mm, measured horizontally, and the mid-aisle handrail shall have rounded terminations or bends.	Sl: 550 mm; 900 mm	range	Per Section 1030.16.1 (Discontinuous handrails).	None stated in inventory	CONDITIONAL	1168–1169	Verified
CH10-0618	Section 1030.16.3	Mid-aisle termination	Mid-aisle handrails shall not extend beyond the lowest riser and shall terminate within 450 mm, measured horizontally, from the lowest riser.	Sl: 450 mm	max	Per Section 1030.16.3 (Mid-aisle termination).	None stated in inventory	CONDITIONAL	1169	Verified
CH10-0619	Section 1030.16.4	Rails	Where mid-aisle handrails are provided in stepped aisles, there shall be an additional rail located approximately 300 mm below the handrail.	Sl: 300 mm	trigger	Per Section 1030.16.4 (Rails).	None stated in inventory	CONDITIONAL	1169	Verified
CH10-0620	Section 1030.17.1	Perimeter guards	Exception item 2. Bleachers, grandstands and folding and telescopic seating shall not be required to have perimeter guards where the seating is located adjacent to a wall and the space between the wall and the seating is less than 100 mm.	Sl: 100 mm	max	Per Section 1030.17.1 (Perimeter guards).	## Exceptions: 1. Guards that impact sightlines shall be permitted to comply with Section 1030.17.3 2. Bleachers, grandstands and folding and telescopic seating shall not be required to have perimeter guards where the seating is located adjacent to a wall and the space between the wall and the seating is less than 100 mm.	CONDITIONAL	1170	Verified
CH10-0621	Section 1030.17.1	Perimeter guards	Perimeter guards shall be provided where the footboards or walking surface of seating facilities are more than 750 mm above the floor or grade below.	Sl: 750 mm	trigger	Per Section 1030.17.1 (Perimeter guards).	## Exceptions: 1. Guards that impact sightlines shall be permitted to comply with Section 1030.17.3 2. Bleachers, grandstands and folding and telescopic seating shall not be required to have perimeter guards where the seating is located adjacent to a wall and the space between the wall and the seating is less than 100 mm.	CONDITIONAL	1170	Verified
CH10-0622	Section 1030.17.1	Perimeter guards	Where the seat boards are adjacent to the perimeter, guard height shall be 1000 mm high minimum, measured from the seat board.	Sl: 1000 mm	min	Per Section 1030.17.1 (Perimeter guards).	## Exceptions: 1. Guards that impact sightlines shall be permitted to comply with Section 1030.17.3 2. Bleachers, grandstands and folding and telescopic seating shall not be required to have perimeter guards where the seating is located adjacent to a wall and the space between the wall and the seating is less than 100 mm.	CONDITIONAL	1170	Verified
CH10-0623	Section 1030.17.1	Perimeter guards	Where the seats are self-rising, guard height shall be 1000 mm high minimum, measured from the floor surface.	Sl: 1000 mm	min	Per Section 1030.17.1 (Perimeter guards).	## Exceptions: 1. Guards that impact sightlines shall be permitted to comply with Section 1030.17.3 2. Bleachers, grandstands and folding and telescopic seating shall not be required to have perimeter guards where the seating is located adjacent to a wall and the space between the wall and the seating is less than 100 mm.	CONDITIONAL	1170	Verified
CH10-0624	Section 1030.17.2	Cross aisles	Cross aisles located more than 750 mm above the floor or grade below shall have guards in accordance with Section 1015.	Sl: 750 mm	trigger	Per Section 1030.17.2 (Cross aisles).	Exception: Where the backs of seats on the front of the cross-aisle project 600 mm or more above the adjacent floor of the aisle, a guard need not be provided.	CONDITIONAL	1170	Verified
CH10-0625	Section 1030.17.2	Cross aisles	Exception: Where the backs of seats on the front of the cross-aisle project 600 mm or more above the adjacent floor of the aisle, a guard need not be provided.	Sl: 600 mm	trigger	Per Section 1030.17.2 (Cross aisles).	Exception: Where the backs of seats on the front of the cross-aisle project 600 mm or more above the adjacent floor of the aisle, a guard need not be provided.	CONDITIONAL	1170	Verified
CH10-0626	Section 1030.17.2	Cross aisles	Where an elevation change of 750 mm or less occurs between a cross aisle and the adjacent floor or grade below, guards not less than 650 mm above the aisle floor shall be provided.	Sl: 750 mm; 650 mm	mixed	Per Section 1030.17.2 (Cross aisles).	Exception: Where the backs of seats on the front of the cross-aisle project 600 mm or more above the adjacent floor of the aisle, a guard need not be provided.	CONDITIONAL	1170	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0627	Section 1030.17.3	Sightline-constrained guard heights	Unless subject to the requirements of Section 1030.17.4, a fascia or railing system in accordance with the guard requirements of Section 1015 and having a minimum height of 650 mm shall be provided where the floor or footboard elevation is more than 750 mm above the floor or grade below and the fascia or railing would otherwise interfere with the sightlines of immediately adjacent seating.	Sl: 650 mm; 750 mm	min	Per Section 1030.17.3 (Sightline-constrained guard heights).	None stated in inventory	CONDITIONAL	1170	Verify source
CH10-0628	Section 1030.17.4	Guards at the end of aisles	A fascia or railing system complying with the guard requirements of Section 1015 shall be provided for the full width of the aisle where the foot of the aisle is more than 750 mm above the floor or grade below.	Sl: 750 mm	trigger	Per Section 1030.17.4 (Guards at the end of aisles).	None stated in inventory	CONDITIONAL	1171	Verify source
CH10-0629	Section 1030.17.4	Guards at the end of aisles	The fascia or railing shall be not less than 900 mm high and shall provide not less than 1050 mm measured diagonally between the top of the rail and the nosing of the nearest tread.	Sl: 900 mm; 1050 mm	min	Per Section 1030.17.4 (Guards at the end of aisles).	None stated in inventory	CONDITIONAL	1171	Verify source

A.4.1031 — Section 1031 (16 records)

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0630	Section 1031.2	Where required	Exception item 1 Group R-2 occupancies located in stories with only one exit or access to only one exit as permitted by Table 1006.3.4(1) and Table 1006.3.4(2). 2 Group R-3 and R-4 occupancies.	Sl: one exit	trigger	Per Section 1031.2 (Where required).	1 Group R-2 occupancies located in stories with only one exit or access to only one exit as permitted by Table 1006.3.4(1) and Table 1006.3.4(2). 2 Group R-3 and R-4 occupancies. Exceptions: 1. Basements with a ceiling height of less than 2000 mm shall not be required to have emergency escape and rescue openings. 2. Emergency escape and rescue openings are not required from basements or sleeping rooms that have an exit door or exit access door that opens directly into a public way or to a yard, court or exterior egress balcony that opens to a public way. 3. Basements without habitable spaces and having not more than 18 m² in floor area shall not be required to have emergency escape and rescue openings. 4. Storm shelters are not required to comply with this section where the shelter is constructed in accordance with ICC 500. 5. Within individual dwelling and sleeping units in Groups R-2 and R-3, where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1, 903.3.1.2 or 903.3.1.3, sleeping rooms in basements shall not be required to have emergency escape and rescue openings provided that the basement has one of the following: 5.1. One means of egress and one emergency escape and rescue opening. 5.2. Two means of egress.	CONDITIONAL	1171	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0631	Section 1031.2	Where required	Exception item 1. Basements with a ceiling height of less than 2000 mm shall not be required to have emergency escape and rescue openings.	Sl: 2000 mm	max	Per Section 1031.2 (Where required).	1 Group R-2 occupancies located in stories with only one exit or access to only one exit as permitted by Table 1006.3.4(1) and Table 1006.3.4(2). 2 Group R-3 and R-4 occupancies. Exceptions: 1. Basements with a ceiling height of less than 2000 mm shall not be required to have emergency escape and rescue openings. 2. Emergency escape and rescue openings are not required from basements or sleeping rooms that have an exit door or exit access door that opens directly into a public way or to a yard, court or exterior egress balcony that opens to a public way. 3. Basements without habitable spaces and having not more than 18 m ² in floor area shall not be required to have emergency escape and rescue openings. 4. Storm shelters are not required to comply with this section where the shelter is constructed in accordance with ICC 500. 5. Within individual dwelling and sleeping units in Groups R-2 and R-3, where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1, 903.3.1.2 or 903.3.1.3, sleeping rooms in basements shall not be required to have emergency escape and rescue openings provided that the basement has one of the following: 5.1. One means of egress and one emergency escape and rescue opening. 5.2. Two means of egress.	CONDITIONAL	1171	Verified
CH10-0632	Section 1031.2	Where required	Exception item 3. Basements without habitable spaces and having not more than 18 m ² in floor area shall not be required to have emergency escape and rescue openings.	Sl: 18 m ²	max	Per Section 1031.2 (Where required).	1 Group R-2 occupancies located in stories with only one exit or access to only one exit as permitted by Table 1006.3.4(1) and Table 1006.3.4(2). 2 Group R-3 and R-4 occupancies. Exceptions: 1. Basements with a ceiling height of less than 2000 mm shall not be required to have emergency escape and rescue openings. 2. Emergency escape and rescue openings are not required from basements or sleeping rooms that have an exit door or exit access door that opens directly into a public way or to a yard, court or exterior egress balcony that opens to a public way. 3. Basements without habitable spaces and having not more than 18 m ² in floor area shall not be required to have emergency escape and rescue openings. 4. Storm shelters are not required to comply with this section where the shelter is constructed in accordance with ICC 500. 5. Within individual dwelling and sleeping units in Groups R-2 and R-3, where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1, 903.3.1.2 or 903.3.1.3, sleeping rooms in basements shall not be required to have emergency escape and rescue openings provided that the basement has one of the following: 5.1. One means of egress and one emergency escape and rescue opening. 5.2. Two means of egress.	CONDITIONAL	1171	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0633	Section 1031.2	Where required	Exception item 5.1. One means of egress and one emergency escape and rescue opening. 5.2. Two means of egress.	Sl: One means of egress; Two means of egress	trigger	Per Section 1031.2 (Where required).	1 Group R-2 occupancies located in stories with only one exit or access to only one exit as permitted by Table 1006.3.4(1) and Table 1006.3.4(2). 2 Group R-3 and R-4 occupancies. Exceptions: 1. Basements with a ceiling height of less than 2000 mm shall not be required to have emergency escape and rescue openings. 2. Emergency escape and rescue openings are not required from basements or sleeping rooms that have an exit door or exit access door that opens directly into a public way or to a yard, court or exterior egress balcony that opens to a public way. 3. Basements without habitable spaces and having not more than 18 m² in floor area shall not be required to have emergency escape and rescue openings. 4. Storm shelters are not required to comply with this section where the shelter is constructed in accordance with ICC 500. 5. Within individual dwelling and sleeping units in Groups R-2 and R-3, where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1, 903.3.1.2 or 903.3.1.3, sleeping rooms in basements shall not be required to have emergency escape and rescue openings provided that the basement has one of the following: 5.1. One means of egress and one emergency escape and rescue opening. 5.2. Two means of egress.	CONDITIONAL	1171	Verified
CH10-0634	Section 1031.3.1	Minimum size	Emergency escape and rescue openings shall have a minimum net clear opening of 0.53 m².	Sl: 0.53 m²	min	Per Section 1031.3.1 (Minimum size).	Exception: The minimum net clear opening for grade-floor emergency escape and rescue openings shall be 0.46 m².	CONDITIONAL	1172	Verified
CH10-0635	Section 1031.3.1	Minimum size	Exception: The minimum net clear opening for grade-floor emergency escape and rescue openings shall be 0.46 m².	Sl: 0.46 m²	min	Per Section 1031.3.1 (Minimum size).	Exception: The minimum net clear opening for grade-floor emergency escape and rescue openings shall be 0.46 m².	CONDITIONAL	1172	Verified
CH10-0636	Section 1031.3.2	Minimum dimensions	The minimum net clear opening height dimension shall be 600 mm.	Sl: 600 mm	min	Per Section 1031.3.2 (Minimum dimensions).	None stated in inventory	CONDITIONAL	1173	Verified
CH10-0637	Section 1031.3.2	Minimum dimensions	The minimum net clear opening width dimension shall be 500 mm.	Sl: 500 mm	min	Per Section 1031.3.2 (Minimum dimensions).	None stated in inventory	CONDITIONAL	1173	Verified
CH10-0638	Section 1031.3.3	Maximum height from floor	Emergency escape and rescue openings shall have the bottom of the clear opening not greater than 1100 mm measured from the floor.	Sl: 1100 mm	max	Per Section 1031.3.3 (Maximum height from floor).	None stated in inventory	CONDITIONAL	1173	Verified
CH10-0639	Section 1031.5.1	Minimum size	Exception: The ladder or steps required by Section 1031.5.2 shall be permitted to encroach not more than 150 mm into the required dimensions of the area well.	Sl: 150 mm	max	Per Section 1031.5.1 (Minimum size).	Exception: The ladder or steps required by Section 1031.5.2 shall be permitted to encroach not more than 150 mm into the required dimensions of the area well.	CONDITIONAL	1173	Verified
CH10-0640	Section 1031.5.1	Minimum size	The minimum horizontal area of the area well shall be 0.84 m², with a horizontal projection and width of not less than 900 mm.	Sl: 0.84 m²; 900 mm	min	Per Section 1031.5.1 (Minimum size).	Exception: The ladder or steps required by Section 1031.5.2 shall be permitted to encroach not more than 150 mm into the required dimensions of the area well.	CONDITIONAL	1173	Verified
CH10-0641	Section 1031.5.2	Ladders or steps	Area wells with a vertical depth of more than 1100 mm shall be equipped with an approved permanently affixed ladder or steps.	Sl: 1100 mm	trigger	Per Section 1031.5.2 (Ladders or steps).	None stated in inventory	CONDITIONAL	1173	Verified
CH10-0642	Section 1031.5.2.1	Area-well ladder projection	Area-well ladders or rungs shall project at least 75 mm from the wall.	Sl: 75 mm	min	Ladders or rungs required for area wells.	None stated in inventory	CONDITIONAL	1175	Verified
CH10-0643	Section 1031.5.2.1	Area-well ladder spacing	Area-well ladders or rungs shall be spaced not more than 450 mm on center vertically for the full height of the area well.	Sl: 450 mm	max	Ladders or rungs required for area wells.	None stated in inventory	CONDITIONAL	1175	Verified
CH10-0644	Section 1031.5.2.1	Area-well ladder width	Area-well ladders or rungs shall have an inside width of at least 300 mm.	Sl: 300 mm	min	Ladders or rungs required for area wells.	None stated in inventory	CONDITIONAL	1175	Verified

ID	Section / table	Topic / check	Mandatory requirement	Exact extracted values	Relationship	Applicability / trigger	Exceptions / footnotes	R-2 high-rise relevance	Source page	Confidence
CH10-0645	Section 1031.5.2.2	Steps	Steps shall have an inside width of not less than 350 mm, shall have treads greater than 125 mm in depth and a riser height not greater than 450 mm for the full height of the area well.	Sl: 350 mm; 125 mm; 450 mm	mixed	Per Section 1031.5.2.2 (Steps).	None stated in inventory	CONDITIONAL	1174	Verified