

SBC 201 Chapter 11 Accessibility — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise; an occupied floor is stated to be more than 23 m above the relevant reference level.
- **Deliverable tier:** Project-use matrices in Sections 1–17 (design-check rows, not pasted inventory), plus a coverage summary and unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 11, source file Reference\SBC 201 2024\source_reference\Chapter_11 – ACCESSIBILITY.txt.
- **Extraction audit:** Skill-finetune re-run. Project-use rows follow the chapter-extract row contract (noun-phrase checks, bold SI values, building-language triggers, named exceptions, check-specific actions). Internal inventory: **276** independently checkable numeric records (**192** Verified, **84** Verify source). Unresolved OCR is listed in the register and is not a design-release value. Pre-skill baseline retained as ..._Grok-4.6.md.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, accessibility consultant report, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from ICC A117.1, Chapter 10, Chapter 9, Section 403, Chapter 30, SBC 701, SBC 901, HUD/FHAG, ADA, commentary examples, or the existing chapter summary. Where Chapter 11 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group R-2 and high-rise status are project statements, not independently verified classifications.
2. The exact Riyadh AHJ/permit pathway, project stage and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Unit type is unconfirmed. The lead apartment-house path is **Section 1108.6.2.2** (Type A + Type B). Table 1108.6.1.1 Accessible-unit quotas apply to Group R-1 and to Group R-2 **other than** live/work and apartment houses. They are not applied to a conventional apartment tower unless the unit type is congregate.
4. Automatic sprinkler protection is not selected in this chapter extract. Chapter 11 does not branch residential unit scoping on NFPA 13 versus 13R.
5. Building height, storey count, grade plane, occupied-roof configuration, parking counts/types, mixed-use podium, amenity/recreation layouts and EV provision are unconfirmed.
6. Chapter 11 is **scoping**. Technical millimetre geometry for accessible routes, doors, toilets, kitchens and Type A/B units is ICC A117.1. Charging **1102.1** names ICC A117.1 with **no edition year**. General Comments name 2009; later commentary discusses 2017 anthropometry. Neither commentary year is adopted as a charging substitution.
7. All eight appended tables are concatenated OCR. No reconstructed cell is adopted as a design-release value. Affected project-use rows are **Verify source**.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, use, occupant load, unit type or mixed-use/podium condition exists.
Not typical	Unrelated occupancy-only rule; omitted from this deliverable unless the gap register already opened that use.
External verification	Chapter 11 points to another section/code/standard, or the project/AHJ basis must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 11 source text.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 11 application	Required project action
ICC A117.1 edition	Charging 1102.1 has no year; General Comments name 2009; commentary discusses 2017	Controls turning spaces, clear floor space, door manoeuvring, Type A/B unit interiors	AHJ/code consultant to lock the referenced edition; do not silently switch editions
Unit type	Unconfirmed: apartment dwelling units vs sleeping units vs congregate bedrooms	Selects 1108.6.2.2 (Type A/B) versus 1108.6.2.3 + Table 1108.6.1.1 (Accessible units)	Classify every R-2 unit type and show the applicable branch on accessibility plans
Site unit count	Unconfirmed; typical tower exceeds 20 units	Type A trigger is more than 20 dwelling/sleeping units on the site	Issue a signed unit schedule for the site, excluding existing structures per 1108.6.2.2.1 Exception 2
Elevator service	High-rise implies elevator service, not independently verified	1108.7 nonelevator reductions do not apply to a true elevator building except 1108.7.3 limited-elevator branch	Confirm passenger-elevator service to all stories containing units; if a lift serves only the lowest unit story, re-test 1108.7.3
Parking count and type	Unconfirmed	1106.3 Item 1 (2% of each type) versus Item 3 (one accessible space per Accessible/Type A unit where parking is 1:1); Item 4 if parking is in/under the building	Produce a parking schedule by facility and type (resident, visitor, accessible, van, EV)
Mixed-use podium	Unconfirmed	Shared routes, 60% public entrances, Table 1105.1.1 power doors (A/B/M/R-1 only), family toilets, assembly seating	Freeze occupancy by room; do not apply R-1 power-door loads to R-2
Recreation / pool	Unconfirmed	1111.2.2 25% of each type for Type A/B; 1111.4.14 Exception 3 waives water-entry for Type A/B pools but not for Accessible-unit recreation	Map every recreational facility type serving the tower
EV charging	Unconfirmed	1107.2 exception for EV serving R-2; 5% / 3300 mm / 1500 mm apply only if the exception does not cover the installation	Confirm whether chargers serve R-2 residents only or a public/commercial facility

Decision / gap	Current project basis	Why it controls Chapter 11 application	Required project action
Occupied roof / amenities	Unconfirmed	1104.4 Exception 1 does not apply to structures with 4 or more dwelling units; common rooms serving Type B units must be accessible (1108.3)	Show an accessible route to every required accessible story, mezzanine and occupied roof
NOC / accessibility consultant	Unconfirmed	Technical A117.1 geometry, assisted-evacuation and SCD acceptance cannot be concluded from Chapter 11 scoping alone	Engage the qualified local accessibility/fire consultants before design freeze

4. Scoping versus technical standard

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1101.1	Chapter scope	This chapter controls design and construction of facilities for accessibility	All facilities in scope	None stated	Direct	Treat Chapter 11 as the scoping document for the tower and site	Verified
1102.1	ICC A117.1	Accessible in accordance with this code and ICC A117.1 (no year)	All required accessible facilities	None stated	External verification	Lock the A117.1 edition with the AHJ; do not import millimetre geometry here	Verified
1108.2	Unit interiors	Accessible / Type A / Type B units comply with applicable portions of Chapter 11 of ICC A117.1 ; higher unit types may substitute	Required unit types	Type A may be built as Accessible; Type B as Accessible or Type A	External verification	Produce unit-type typical details from the referenced A117.1 chapter, not from commentary millimetres	Verified
1110.1 Exception	Unit toilets/kitchens	Accessible, Type A and Type B units shall comply with Chapter 10 of ICC A117.1	Those unit types	1110 otherwise still governs common/public features	External verification	Note the source names Chapter 10 here and Chapter 11 at 1108.2; verify the printed A117.1 mapping before detailing	Verified
1108.3	Common rooms serving units	Rooms and spaces available to the public or residents and serving Accessible, Type A or Type B units shall be accessible, including toilet/bathing, kitchen, living/dining and exterior patios/terraces/balconies	Amenities serving required units	1108.4 story exemptions; 1111.2 recreation; Type B impervious balcony step-down 100 mm maximum	Direct	Put lobby, mail, laundry, refuse, shared toilets, gym and roof terrace on an accessible route	Verified

5. General applicability and surviving exceptions

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1103.1	Default accessibility	Sites, buildings, structures, facilities, elements and spaces, temporary or permanent, shall be accessible	All construction	Only to the extent permitted by 1103.2 / 1104–1112	Direct	Assume accessible unless a numbered exception is proven	Verified
1103.2.2	Employee work areas	Approach, enter and exit plus 907.5.2.3.1, 1009 and 1104.3.1 only	Employee work areas	Portions < 28 m² and ≥ 175 mm essential level change exempt from all requirements (not courtroom stations)	Conditional	Apply to BOH, security desks and plant-adjacent workstations; keep visible alarm and accessible MOE outbound	Verified
1103.2.9	Equipment spaces	Spaces frequented only by service personnel for maintenance, repair or occasional monitoring of equipment are not required to comply with this chapter	Service-only equipment spaces	None stated	Direct	Do not force an accessible route into elevator pits, penthouses or typical MEP rooms	Verified
1104.3.1 Ex. 1	Small work-area path	Common-use circulation paths in employee work areas < 100 m² defined by permanent partitions/furnishings need not be accessible routes	Employee work areas	Equipment-integral and weather-exposed exterior path exceptions also stated	Conditional	Keep an accessible route to the work area; the path through a small defined workstation may be exempt	Verified

6. Accessible routes and stories

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1104.1	Site arrival route	At least one accessible route from transit, accessible parking, accessible loading, streets/sidewalks to the accessible entrance	Site arrival points	Vehicular-way-only exception does not apply to buildings containing or serving Type B units	Direct	Provide a pedestrian accessible route from every applicable arrival point; do not rely on a driveway-only exception	Verified
1104.2	On-site connections	At least one accessible route connecting accessible buildings, facilities, elements and spaces on the same site	Multiple accessible elements on one site	Vehicular-way-only; recreation only as 1111	Direct	Connect podium, parking, lobby and recreation to the same accessible network	Verified
1104.3	Connected spaces	At least one accessible route to each required accessible portion, to accessible entrances connecting accessible walkways, and to the public way	Building required to be accessible	1104.4 story skips; assembly levels without wheelchair spaces; courtroom workstations; 1111 recreation	Direct	Trace the accessible route from public way through lobby, lifts and common floors	Verified
1104.4	Multistory / occupied roof	At least one accessible route shall connect each accessible story, mezzanine and occupied roofs	Multilevel buildings	Exception 1 (≤ 279 m² aggregate above+below) shall not apply to structures with 4 or more dwelling units	Direct	Do not use the 279 m² story-skip on this R-2 tower; serve every required accessible level including occupied roof	Verified
1104.5	Route coincidence	Accessible routes shall coincide with or be in the same area as general circulation; interior circulation requires an interior accessible route; a single accessible route shall not pass through kitchens, storage, restrooms, closets or similar	Accessible routes	1. Garage-to-Type B routes need not be interior. 2. A single route may pass through a kitchen or storage room inside an Accessible, Type A or Type B unit	Direct	Keep common accessible routes in public circulation, not through service rooms	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1108.4	Route to units	At least one accessible route shall connect accessible building entrances with the primary entrance of each Accessible, Type A and Type B unit and with interior/exterior spaces serving the units	Required units	1. 1:12 / legal-barrier vehicular substitute. 3. R-2 with Type A units: stories need not connect where Type A units, their common use and all public use are already on an accessible route. 7. Type B stories exempted by 1108.7	Direct	For an elevator high-rise, serve every Type A and Type B unit entrance from an accessible building entrance	Verified
1108.3 Ex. 3	Type B balcony step	Type B unit impervious decks/patios/balconies not more than 100 mm below adjacent interior finished floor	Type B unit private outdoor space	Community/public decks are not this exception	Direct	Limit unit balcony step-down to 100 mm where the walking surface is impervious; keep community terraces fully accessible	Verified

7. Entrances

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1105.1	Public entrances	At least 60 percent of all public entrances shall be accessible, in addition to 1105.1.2–1105.1.8	Public entrances	Areas not required to be accessible; loading/service entrances that are not the only tenant entrance	Direct	Count public doors (not egress-only doors) and make ≥ 60% accessible	Verified
1105.1.1 / Table 1105.1.1	Power-operated public entrance	One full-power or low-energy power-operated door at each required accessible public entrance when occupancy and building occupant load exceed the table; vestibule: one leaf in and one leaf out	Table lists Groups A-1–A-4 and B, M, R-1 ; mixed-use uses the most restrictive listed load	Group R-2 is not listed. Flattened OCR occupant-load cells are not adopted	Conditional	Do not apply an R-1 occupant trigger to R-2. If a podium A/B/M/R-1 load exceeds the published table, power-operate those occupancies’ accessible public entrances after source check	Verify source
1105.1.2	Parking-garage entrance	Direct pedestrian access from parking structures to building/facility entrances shall be accessible	Direct garage-to-building pedestrian access	None stated	Direct	Provide an accessible pedestrian door from the parking structure into the tower	Verified
1105.1.7	Tenant entrance	At least one accessible entrance to each tenant in a facility	Multi-tenant facility	Self-service storage not required to be accessible	Conditional	If podium tenancies exist, give each tenant an accessible entrance in addition to the 60% building count	Verified
1105.1.8	Unit entrance	At least one accessible entrance to each dwelling/sleeping unit	Dwelling and sleeping units	Not required to units that are not Accessible, Type A or Type B	Direct	Every Type A and Type B unit gets an accessible entrance; shared lobby doors still count toward 60%	Verified

8. Parking, vans and passenger loading

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1106.3 Item 1	R-2 accessible parking	At least 2 percent , but not less than one , of each type of parking space provided shall be accessible	R-2 required to have Accessible, Type A or Type B units	Table 1106.2 is the I-1/R-1 path (Item 2), not the R-2 default	Direct	Count resident, visitor and any other parking types separately and take 2% (≥ 1) of each	Verified
1106.3 Item 3	1:1 parking vs Type A	Where at least one parking space is provided for each dwelling/sleeping unit, at least one accessible parking space shall be provided for each Accessible and Type A unit	Parking provided at ≥ 1 space per unit	Code does not state that Item 1 and Item 3 are additive	Conditional	If assigned 1:1 parking exists, provide an accessible stall for every Type A (and Accessible) unit and compare with Item 1	Verified
1106.3 Item 4	In-building parking	Where parking is within or beneath a building, accessible parking shall also be within or beneath the building	Parking in/under the building	None stated	Direct	Put accessible stalls in the podium/basement garage, not only on the surface lot	Verified
1106.6	Van spaces	For every six or fraction of six accessible parking spaces, at least one shall be van-accessible	Accessible parking provided	Group U private garages serving R-2/R-3: van routes/spaces/aisles permitted 2100 mm minimum vertical clearance	Direct	Provide 1-in-6 vans; use 2100 mm only for qualifying Group U private garages — do not import A117.1 van height from commentary	Verified
1106.7 Ex. 1	Van-space level	In multilevel parking structures, van-accessible parking spaces are permitted on one level	Multilevel parking	Accessible spaces still dispersed; van-height millimetres are A117.1 (not imported)	Direct	Concentrate van stalls on the level that can provide the A117.1 van clearance	Verified
Table 1106.2	General parking table	Flattened OCR table; no reconstructed stall-count cell is adopted	Parking facilities using 1106.2	R-2 residential parking uses 1106.3 first	Conditional	Use only for non-residential facilities or I-1/R-1 after published-source check	Verify source
1106.9.1	Continuous loading zone	One accessible passenger loading zone in every continuous 30 m maximum	Passenger loading zones provided	None stated	Conditional	If a porte-cochère or kerbside drop-off exists, space accessible zones at ≤ 30 m	Verified
1112.1 Item 2 Ex.	Assigned-stall signage	In Group R-2, where parking is assigned to specific units, identification of accessible parking spaces is not required	1106.3 accessible spaces that are assigned	Identification exception only; stalls still required	Conditional	Keep stall geometry; ISA signs may be omitted only for assigned unit spaces	Verified

9. Electrical vehicle charging

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1107.2 Exception	R-2 EV exemption	EV charging stations provided to serve Groups R-2, R-3 and R-4 are not required to comply with Section 1107.2	EV serving those occupancies	Public/commercial EV on the same site is not this exception	Direct	Resident-assigned R-2 chargers are not scoped by 1107.2; still provide an accessible route to required accessible parking	Verified
1107.2.1	Accessible EV count	Not less than 5 percent of vehicle spaces served by EV systems, but not fewer than one of each type , shall be accessible	EV systems not covered by the R-2 serving exception	None stated beyond 1107.2	Conditional	If podium/public chargers exist, reserve 5% (≥ 1 of each charger type)	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1107.2.2	Accessible EV stall size	3300 mm minimum vehicle-space width with adjoining access aisle 1500 mm minimum	Accessible EV spaces required by 1107.2.1	R-2 serving exception	Conditional	Do not substitute a narrower A117.1 van option; this section specifies 3300 + 1500	Verified

10. Dwelling-unit mix (Accessible / Type A / Type B)

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1108.6.2.2.1	Type A apartments	In Group R-2 containing more than 20 dwelling/sleeping units, at least 2 percent but not less than one shall be Type A; all Group R-2 units on a site counted; disperse among classes	Apartment houses / condominiums	1. Reduction only as permitted by 1108.7. 2. Existing structures do not contribute to the site count	Direct	For a typical tower > 20 units, provide ≥ 2% Type A, dispersed by bedroom class, calculated on the site	Verified
1108.6.2.2.2	Type B apartments	Where four or more dwelling/sleeping units intended to be occupied as a residence are in a single structure, every such unit shall be Type B	Apartment/condo structure	Reduction permitted per 1108.7	Direct	Treat the high-rise as one structure; all residence units are Type B (Type A already exceeds Type B)	Verified
1108.6.2.3.1 / Table 1108.6.1.1	Accessible units (congregate)	Accessible units per Table 1108.6.1.1, including without/with roll-in shower split; only one bedroom in a grouped unit counts toward required Accessible units	R-2 other than live/work and apartment houses	Flattened OCR table cells are not adopted	Conditional	Do not apply hotel/dorm Accessible-unit quotas to conventional apartments; verify published table if congregate bedrooms exist	Verify source
1108.6.2.1	Live/work units	Nonresidential portion accessible; residential portion Type B if four or more live/work units intended as residence	Section 419 live/work	1108.7 Type B reductions	Conditional	If live/work appears in the podium, split residential vs work accessibility	Verified

11. Section 1108.7 reductions (elevator high-rise)

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1108.7.3	Elevator only to lowest unit story	Where elevator service provides an accessible route only to the lowest story containing residence units, only units on that story need be Type B	Elevator limited to the lowest unit story	Upper unit stories then not Type B under this exception	Conditional	If the lift core serves all residential floors, this exception is not available	Verified
1108.7.2	Multistory units	A multistory unit without elevator service is not required to be Type B; with external elevator to only one floor, that floor is the primary entry, shall be Type B, and shall contain living, kitchen and toilet where those are provided in the unit	Multistory dwelling/sleeping units	None stated for Type A	Conditional	Typical stacked apartments are single-story units; apply only to duplex/townhouse products	Verified

12. Common toilets, kitchens, drinking fountains and lifts

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1110.2	Toilet/bathing rooms	Each toilet room and bathing room shall be accessible; at least one of each type of fixture/element/control/dispenser accessible	Toilet/bathing rooms	Ex. 2: rooms serving dwelling/sleeping units not required to be accessible by 1108 . Ex. 3: clustered single-user rooms ≥ 50% (≥ 1 of each use). Do not locate the only toilets on a non-accessible floor	Direct	Make lobby, amenity and podium public toilets accessible; unit bathrooms follow A117.1 by unit type	Verified
1110.2.1	Family/assisted-use toilet	Required in assembly and mercantile where aggregate male+female water closets ≥ 6 ; travel ≤ 150 m and ≤ one story from separate-sex rooms	Assembly/mercantile fixture count	Mixed occupancy: count only A/M water closets	Conditional	If podium retail/assembly hits six WCs, add a family room on an accessible route	Verified
1110.2.4	Compartments	≥ 5% of compartments wheelchair-accessible; if compartments+urinals ≥ 6 , ≥ 5% ambulatory-accessible in addition	Multi-compartment toilets	Unit bathrooms excepted via 1110.2 Ex. 2	Conditional	Size amenity toilets with a wheelchair stall; add ambulatory stall when the room is large	Verified
1110.2.5	Lavatories	≥ 5% (≥ 1) accessible; extra accessible lavatory if the only one is inside the accessible stall; ≥ 6 lavatories → one enhanced-reach	Lavatories provided	Enhanced reach per A117.1 (not imported)	Conditional	Do not hide the only accessible lavatory inside the accessible stall	Verified
1110.4	Kitchens and kitchenettes	Kitchens and kitchenettes in accessible spaces or rooms shall be accessible	Common kitchens / kitchenettes	Unit kitchens follow 1110.1 Exception / A117.1 (not imported)	Direct	Detail lobby pantry, resident lounge kitchen and staff break kitchenettes as accessible	Verified
1110.5.1	Drinking fountains	No fewer than two : one wheelchair, one standing (or dual-spout substitute)	Drinking fountains provided on a floor/site/secured area	Children’s standing spout 760 mm minimum	Conditional	If fountains are provided, install hi-lo; do not import SBC 701 fixture counts	Verified
1110.8	Elevators	Passenger elevators on an accessible route shall be accessible and comply with Chapter 30	Passenger elevators on an accessible route	Freight/construction elevators not this section	External verification	All passenger cars on the accessible route are accessible; stretcher/FSAE sizes live in Chapter 30 / 403, not here	Verified
1110.9 Item 4	Platform lifts in units	Platform lifts permitted on a required accessible route within an individual Accessible, Type A or Type B unit	New construction	ASME A18.1 (not imported)	Conditional	Use a lift inside a multi-level Type A unit only if chosen; it does not replace building elevators	Verified

13. Recreational facilities

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1111.2.1	Recreation serving Accessible units	Every recreational facility of each type serving Accessible units shall be accessible	R-2/R-4 where recreation serves Accessible units	Applies if 1108.6.2.3 Accessible units exist	Conditional	Conventional apartments without Accessible units do not use this 100% rule	Verified
1111.2.2	Recreation serving Type A/B (single building)	25 percent , but not less than one , of each type of recreational facility shall be accessible	Recreation serving a single building containing Type A or Type B units	Count every facility of each type on the site to determine the number	Direct	For one tower, make ≥ 25% (≥ 1) of each pool, court, gym, playground type accessible	Verified
1111.4.14 Ex. 3	Pool water entry	Pools/spas required to be accessible only by 1111.2.2 / 1111.2.3 are not required to provide accessible means of entry into the water	Type A/B recreation scoping	Does not apply where 1111.2.1 requires every facility serving Accessible units	Direct	Provide an accessible route to the pool; water-entry equipment is not scoped by 1111.2.2/2.3. Technical entry methods remain in A117.1 if otherwise required	Verified
1111.4.10	Exercise machines	At least one of each type of exercise machine and equipment shall be on an accessible route	Exercise machines provided	Operable-part heights are A117.1 (not imported)	Conditional	Put at least one of each gym machine type on the accessible route	Verified
1111.4.2	Player seating	At least one wheelchair space in team/player seating serving areas of sport activity	Team/player seating provided	Bowling-lane exception	Conditional	If a court has player benches, provide one wheelchair space	Verified
1111.4.4	Court sides	At least one accessible route shall directly connect both sides of the court	Court sports	None stated	Conditional	If tennis/padel/basketball courts exist, connect both sides without leaving the court area	Verified

14. Signage

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1112.1 Items 4–7	Partial-access identification	Identify accessible toilets, entrances, check-out aisles and dressing/locker rooms where not all are accessible	Mixed accessible/non-accessible sets	None stated	Direct	Sign the accessible lobby entrance if any public entrance remains inaccessible	Verified
1112.1 Items 8–9	Accessible MOE signs	Accessible areas of refuge and exterior areas for assisted rescue in accordance with Section 1009.9	Those elements provided	Values not in Chapter 11	External verification	Coordinate ISA with the Chapter 10 accessible-egress package	Verified
1112.3	Directional signs	Directional ISA signage at inaccessible entrances, toilets, elevators not on an accessible route, family-toilet locations, exits not providing approved accessible MOE (1009.10), and split hi-lo fountains	Those conditions	Visual characters per A117.1 (not imported)	Direct	Place directional copy at every inaccessible public entrance	Verified

15. Podium, amenity and assembly (conditional)

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
Table 1109.2.2.1	Wheelchair spaces	Flattened OCR table; no reconstructed seating-capacity cell is adopted	Assembly with fixed seating	Companion seat per 1109.2.3; 5% designated aisle seats	Conditional	If a cinema, mosque hall or lecture room has fixed seats, apply the published table after source check	Verify source
1109.2.5	Designated aisle seats	≥ 5% (≥ 1) of aisle seats, closest to accessible routes	Aisle seats provided	Not required in team/player seating	Conditional	Mark aisle seats nearest the accessible route in amenity auditoria	Verified
1109.2.9.1	Dining surfaces	≥ 5% (≥ 1) of dining surfaces for seating and standing spaces accessible, distributed, on an accessible level	Dining surfaces provided	Mezzanine < 25% dining area exception	Conditional	Provide wheelchair dining in café/amenity restaurant	Verified
Table 1109.2.7.1	ALS receivers	Flattened OCR table; asterisks unresolved; no reconstructed receiver-count cell is adopted	Assembly where audible communication is integral	Not required (except courtrooms) where there is no audio amplification; induction-loop HAC exception	Conditional	If an amenity hall has a PA, provide receivers after published-source check of the table	Verify source

16. High-rise and outbound controls

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1009 (named)	Accessible means of egress	Chapter 11 repeatedly sends accessible egress to Section 1009	Accessible floors and occupied roofs	No 1009 values imported	External verification	Use the Chapter 10 R-2 matrix for AMOE; do not copy those numbers here	Verified
1110.8 / Ch. 30 / 403	Elevators	Passenger elevators on the accessible route: accessible + Chapter 30. Commentary also names stretcher, 1009.2.1 and 36 m FSAE — commentary numbers are not adopted	Elevators / high-rise	Charging 1110.8 does not itself state 36 m or four-storey triggers	External verification	Coordinate stretcher, FSAE and occupant-evacuation elevators from Chapter 30 / 403, not from Chapter 11 commentary	Verified
SBC 901 §306	Existing buildings	Named in General Comments only	Existing buildings	Not quantified in this chapter’s code paragraphs	External verification	Alterations are outside this new-construction extract	Verified

17. Project-use controls

1. Use **Verified** rows for initial scoping after the row trigger and branch are confirmed.
2. Treat every **Verify source** row (all reconstructed appended tables) as a design hold point; no affected value is to be placed in issued-for-approval drawings without a published-source check.

- 3. Do not apply Table 1108.6.1.1 Accessible-unit quotas to conventional R-2 apartments.
- 4. Do not apply Table 1105.1.1 power-door occupant loads to Group R-2.
- 5. Do not import ICC A117.1 millimetres, Chapter 10 AMOE dimensions, or commentary examples (810 mm doors, 2500 mm van height, 2050 mm vs 2100 mm, 50°C shower temperature).
- 6. Record AHJ, unit-type, parking and recreation decisions in the project Golden Thread; this matrix is not evidence of SCD NOC or stamped compliance.

18. Coverage summary

Internal inventory of the attached Chapter 11 extract (numbered code, exceptions, tables, footnotes; commentary excluded). Row-level records are not published.

- **Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)
- **Total independently checkable numeric records:** 276
- **Verified:** 192
- **Verify source:** 84
- **Numeric records in Sections 1101 and 1102:** 0

Counts by top-level section

Top-level section	Records
1101	0
1102	0
1103	3
1104	12
1105	9
1106	12
1107	4
1108	51
1109	16
1110	62
1111	22
1112	1

Appended-table coverage

Appended table	Records	Verify source records
Table 1105.1.1	2	2
Table 1106.2	11	11
Table 1108.6.1.1	33	33
Table 1109.2.2.1	7	7
Table 1109.2.7.1	12	12
Table 1109.3	2	2
Table 1110.13.1	4	4
TABLE 111.4.9.1 (OCR title)	13	13

Coverage cross-check against SBC 201 Chapter 11 Accessibility (2024)_CS.md was topics-only: scoping vs ICC A117.1; 1103.2 exceptions; routes and stories; entrances and power doors; parking/vans; EV charging; dwelling-unit mix; assembly seating and toilets. No CS.md value was copied into a matrix cell.

19. Unresolved-source register

Hold points for the 84 **Verify source** inventory records. Counts are record counts, not distinct numeric values. No value in this register is a design-release figure.

Affected table / clause	Why unverified	Control note
Table 1105.1.1	2 flattened occupancy/load cells	Verify published table; do not apply reconstructed A/B/M/R-1 occupant loads to Group R-2
Table 1106.2	11 flattened stall-count rows	R-2 residential parking uses 1106.3 first; verify published table before any 1106.2 use
Table 1108.6.1.1	33 flattened Accessible-unit cells (without / with roll-in / total)	Applies to R-1 and congregate R-2, not conventional apartment houses; verify published table if congregate bedrooms exist
Table 1109.2.2.1	7 flattened wheelchair-space rows	Verify published table before amenity/assembly seating
Table 1109.2.7.1	12 flattened receiver/HAC cells; asterisks unresolved	Verify published table before ALS receiver counts
Table 1109.3	2 flattened self-storage rows	Not typical for this R-2 tower; verify published table only if self-storage is added
Table 1110.13.1	4 flattened check-out-aisle rows	Not typical unless podium retail check-out aisles exist; verify published table

Affected table / clause	Why unverified	Control note
TABLE 111.4.9.1 (OCR title as printed)	13 flattened boat-slip rows	Title OCR; not typical for this R-2 tower; verify published Table 1111.4.9.1 if a marina is added