

SBC 201 Chapter 12 Interior Environment — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise; an occupied floor is stated to be more than 23 m above the relevant reference level.
- **Deliverable tier:** Project-use matrices in Sections 1–16 (design-check rows, not pasted inventory), plus a coverage summary and unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 12, source file Reference\SBC 201 2024\source_reference\Chapter_12 – INTERIOR ENVIRONMENT.txt.
- **Extraction audit:** Skill-finetune run. Project-use rows follow the chapter-extract row contract (noun-phrase checks, bold SI values, building-language triggers, named exceptions, check-specific actions). Internal inventory: **116** independently checkable numeric records (**108** Verified, **8** Verify source). Unresolved OCR is listed in the register and is not a design-release value.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, mechanical/electrical/acoustic report, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from SBC 501, SBC 401 / NFPA 70, SBC 601 / SBC 602 / IECC, SBC 701, SBC 801, ASCE 24, TMS 302, Chapter 10 Section 1008, Chapter 29, Section 505.1, ICC A117.1 Section 808, commentary examples, Figure 1205.1, or the existing chapter summary. Where Chapter 12 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group R-2 and high-rise status are project statements, not independently verified classifications.
2. The exact Riyadh AHJ/permit pathway, project stage and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Natural versus mechanical ventilation and natural versus artificial light are designer choices **per room**. Section 1205 yards and courts apply only where exterior openings provide required natural light or ventilation.
4. Climate zone for attic exceptions and Table 1202.3 is unconfirmed. Climate Zones 1–8 are shown as branches; a Riyadh zone is not assumed.
5. Automatic sprinkler protection is not selected in this chapter extract. Chapter 12 does not branch interior-environment dimensions on NFPA 13 versus 13R.
6. Building height, storey count above grade plane, basement versus crawl, mixed-use podium, amenity toilets and efficiency-unit mix are unconfirmed.
7. Table 1202.3 is concatenated OCR. No reconstructed climate-zone R-value is adopted as a design-release value.
8. Section 1207 enhanced classroom acoustics is Group E only and is omitted from project-use tables. The **565 m³** trigger is inventoried for coverage only.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, use, climate-zone branch, natural-light/vent path or exception exists.
Not typical	Unrelated occupancy-only rule; omitted from this deliverable unless the gap register already opened that use.
External verification	Chapter 12 points to another section/code/standard, or the project/AHJ basis must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 12 source text.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 12 application	Required project action
Natural vs mechanical ventilation	Unconfirmed per room	Selects 1202.5 openable-area / borrowed-vent rules versus SBC 501 rates; also switches Section 1205 on or off	Issue a room-by-room environmental schedule (natural, mechanical, or mixed) before freezing window and court sizes
Tight-dwelling ACH	Unconfirmed; high-rise envelopes are typically below 5 ACH at 50 Pa	1202.1 requires mechanical ventilation per SBC 501 Section 403 when the dwelling-unit test is below that threshold	Energy consultant to record blower-door results; until then treat units as mechanically ventilated and do not import Section 403 rates
Natural vs artificial light	Unconfirmed per room	Selects 1204.2 8 percent glazing and 1205 yards/courts versus 1204.3 107 lux	Lock daylight versus electric light per habitable room on the same environmental schedule
Climate zone	Unconfirmed	Controls 1202.2.1 1/300 attic exception (Zones 6–8), 1202.3 Item 4 (Zones 5–8), Item 5.2 (Zones 1–3) and Table 1202.3 R-values	Energy consultant / AHJ to lock the SBC climate zone; do not assume a Riyadh zone from memory
Roof / attic type	Unconfirmed: vented attic, unvented attic, or no concealed roof space	1202.2 versus 1202.3; concrete roofs without attics do not take 1202.2.1 net-free area	Mark each roof assembly as vented, unvented (1202.3 items complete) or solid (no concealed space)
Storey count above grade plane	Occupied floor stated above 23 m; exact storeys unconfirmed	1205.2 / 1205.3 grow yard/court width and court length per storey, capped at 14 stories, only if natural light/vent is used	Issue a signed datum sheet (grade plane, storeys, occupied-floor elevations) before sizing any required yard or court
Foundation type	Unconfirmed; high-rise typically basement/cellar	1202.4 under-floor ventilation excepts spaces occupied by basements or cellars	Confirm crawl versus basement; skip 1202.4 if the tower sits on a basement
Unit type	Unconfirmed: standard dwelling vs efficiency; Accessible / Type A / Type B mix	1208.3 areas versus 1208.4 17.7 m² living room and 750 mm kitchen working space	Classify every unit; apply 1208.4 only to efficiency dwellings
Amenity / podium toilets	Unconfirmed	1210.2.1 floor/base and 1210.3 privacy apply to spaces other than dwelling units and to public restrooms	Freeze which toilets are public/employee versus in-unit

Decision / gap	Current project basis	Why it controls Chapter 12 application	Required project action
Mixed-use / Group E	Unconfirmed	1207 classroom acoustics and 1203 Exception 2 (F, H, S, U) are not R-2 dwelling rules	Do not apply Group E 565 m³ classroom criteria or F/H/S/U heating exceptions to apartments
NOC / consultants	Unconfirmed	SBC 501 rates, acoustic laboratory ratings and SCD acceptance cannot be concluded from Chapter 12 alone	Engage mechanical, acoustic and local code consultants before design freeze

4. Scope and outbound controls

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1201.1	Chapter scope	This chapter governs ventilation, temperature control, lighting, yards and courts, sound transmission, room dimensions, surrounding materials and rodent proofing of interior spaces	Interior spaces of buildings	None stated	Direct	Treat Chapter 12 as the interior-environment document for units, common rooms and roof spaces	Verified
1202.5.2.1	Bathroom mechanical exhaust	Rooms containing bathtubs, showers, spas and similar bathing fixtures shall be mechanically ventilated in accordance with SBC 501	Bathing rooms	None stated	External verification	Provide mechanical exhaust for every unit and amenity bath; rates from SBC 501	Verified
1202.5.2 / 1202.6	Contaminant and hazard exhaust	Contaminant sources, flammable or combustible hazards and other sources covered in SBC 501 or SBC 801 shall be exhausted as required by both codes	Naturally ventilated or other spaces with those sources	None stated	External verification	Identify parking, commercial kitchen and chemical rooms and exhaust per those codes	Verified
1204.5	Means-of-egress lighting	Means of egress illuminated in accordance with Section 1008.1	Means of egress	None stated	External verification	Use the Chapter 10 matrix for egress illumination; do not copy 1008 values here	Verified
1205.3.3	Court drainage	Bottom of every court graded and drained to a public sewer or other approved disposal complying with SBC 701	Every court	None stated	External verification	Detail court drainage to SBC 701; do not import drainage sizes here	Verified
1209.3	Appliance access	Access to mechanical appliances in under-floor areas, attics, roofs or elevated structures in accordance with SBC 501	Appliances in those locations	None stated	External verification	Size appliance access from SBC 501	Verified
1210.1	Plumbing fixture count	Number and type of plumbing fixtures in any occupancy shall comply with Chapter 29	Any occupancy	None stated	External verification	Count fixtures from Chapter 29	Verified

5. Occupied-space ventilation

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1202.1	Occupied-space ventilation choice	Natural ventilation in accordance with Section 1202.5, or mechanical ventilation in accordance with SBC 501	Buildings	Bathroom mechanical exhaust still required by 1202.5.2.1; tight dwelling units: SBC 501 Section 403; I-2 / ambulatory care: SBC 501 Section 407 (not this occupancy)	Direct	Lock natural versus mechanical per room on the environmental schedule; do not import SBC 501 rates	Verified
1202.1	Tight-dwelling mechanical ventilation	Dwelling unit with infiltration less than 5 air changes per hour when tested at 50 Pa (IECC residential provisions Section 402.4.1.2 or equivalent in SBC 602) shall be ventilated by mechanical means in accordance with Section 403 of SBC 501	Dwelling units at that tightness	Ambulatory care and Group I-2 use SBC 501 Section 407, not this R-2 path	Direct	Treat sealed high-rise units as mechanically ventilated until blower-door results prove otherwise; do not import Section 403 rates	Verified
1202.5	Occupant-controlled openings	Natural ventilation through windows, doors, louvres or other openings to the outdoors, with operating mechanisms readily accessible and controllable by occupants	Occupied spaces using the natural path	None stated	Conditional	If a room is natural-vent, keep operators accessible to occupants	Verified
1202.5.1	Openable ventilation area	Openable area of openings to the outdoors not less than 4 percent of the floor area being ventilated	Occupied spaces using natural ventilation	None stated	Conditional	Schedule openable area at least 4 percent of each naturally ventilated room	Verified
1202.5.1.1	Borrowed ventilation opening	Unobstructed opening to the adjoining room not less than 8 percent of the interior-room floor area and not less than 2.3 m² ; outdoor openable area based on the total floor area being ventilated	Interior room without outdoor openings, ventilated through an adjoining room	Sunroom with thermal isolation or patio cover: opening not less than 8 percent and not less than 1.86 m²	Conditional	Do not put a door in a borrowed-vent opening; size the outer-room openable area on the combined floor area	Verified
1202.5.1.2	Below-grade vent well	Outside horizontal clear space measured perpendicular to the opening shall be one and one-half times the depth of the opening (depth from average adjoining ground to the bottom of the opening)	Required natural-ventilation openings below grade	None stated	Conditional	Size window wells at 1.5 times opening depth if basement rooms are naturally ventilated	Verified
1202.5.3	Vent openings onto yards	Where natural ventilation is provided by openings onto yards or courts, those yards or courts shall comply with Section 1205	Natural ventilation onto a yard or court	None stated	Conditional	Apply Section 10 of this matrix only to rooms that take outdoor air from a yard or court	Verified

6. Roof and attic ventilation

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1202.2	Roof ventilation path	Roof assemblies shall be ventilated in accordance with this section or shall comply with Section 1202.3	Roof assemblies	None stated	Conditional	Pick vented or unvented attic on the roof section; do not mix the two in one concealed space	Verified
1202.2.1	Vented attic airspace and NFVA	Cross ventilation of each enclosed attic or rafter space; airspace not less than 25 mm between insulation and roof sheathing; net free ventilating area not less than 1/150 of the space ventilated	Enclosed attics and rafter spaces with ceiling applied to the underside of roof framing	Exception: net free area 1/300 where both Climate Zones 6, 7 or 8 with Class I or II vapor retarder on the warm-in-winter side of the ceiling and at least 40 percent and not more than 50 percent of required venting in the upper portion, upper vents not more than 900 mm below the ridge (framing conflict may place them lower)	Conditional	On vented roofs keep a 25 mm ventilation path and size net-free vents at 1/150 unless both exception conditions are proven	Verified
1202.2.2	Attic vent opening protection	Vent openings with a least dimension not less than 1.6 mm and not more than 6.4 mm are permitted; openings larger than 6.4 mm shall be screened with corrosion-resistant material having openings 1.6 mm to 6.4 mm	Exterior openings into an attic of a building intended for human occupancy	Combustion air from an attic: Chapter 7 of SBC 501 (no values imported)	Direct	Specify insect and rodent screens on every attic vent	Verified
1202.3	Unvented attic envelope	Unvented attic and unvented enclosed rafter assemblies permitted only where Items 1–5 are met, including the attic completely within the building thermal envelope and no interior Class I vapor retarder on the attic floor	Unvented attic or unvented enclosed rafter assembly	1. Special-use enclosures (swimming pool, data processing, hospital, art gallery). 2. Climate Zones 5 through 8 humidified beyond 35 percent during the three coldest months	Conditional	Do not claim 1202.3 unless every listed item is on the roof detail	Verified
1202.3 Item 3	Wood-shingle drying space	Where wood shingles or shakes are used, vented airspace not less than 6.4 mm between the shingles or shakes and the roofing underlayment above the structural sheathing	Unvented attic with wood shingles or shakes	None stated	Conditional	Keep a 6.4 mm drying space under wood roofs even if the attic is unvented	Verified
1202.3 Item 4	Cold-climate vapor retarder	In Climate Zones 5, 6, 7 and 8 , any air-impermeable insulation shall be a Class II vapor retarder or shall have a Class II vapor retarder coating or covering in direct contact with the underside of the insulation	Unvented attic in those climate zones	Riyadh climate zone is unconfirmed	Conditional	Apply only after the energy consultant locks the climate zone	Verified
1202.3 Item 5.1.4	Sheathing temperature method	Sufficient rigid board or sheet insulation above the structural roof sheathing to keep the monthly average underside temperature above 7°C , assuming interior air 20°C and exterior air equal to the monthly average of the three coldest months	Alternative to Table 1202.3 R-values under Item 5.1	None stated	Conditional	Document the three-month average outdoor temperatures; do not use commentary examples	Verified
1202.3 Item 5.2	Climate 1–3 vapor-diffusion port	In Climate Zones 1, 2 and 3 , air-permeable insulation in unvented attics: vapor-diffusion port not more than 300 mm below the highest roof point; port area not less than 1/600 of the ceiling area; membrane not less than 20 perms (ASTM E96 Procedure A); not less than 50 mm between blocking and roof sheathing; roof slope not less than 3:12 ; where only air-permeable insulation is used directly below the sheathing, supply air not less than 23.6 L/s per 100 m² of ceiling	Unvented attic using Item 5.2	Item 5.3: air supplied from occupiable-space ductwork or a supply fan while the conditioning system operates	Conditional	Use this package only if the climate zone is 1–3	Verified
Table 1202.3	Unvented-attic R-value	Flattened OCR table; no reconstructed climate-zone R-value is adopted	Items 5.1.2 and 5.1.3 condensation control	Footnote a points to IECC Section C402.2.1 or equivalent in SBC 601 / SBC 602 (no value imported)	Conditional	Hold the insulation R-value until a published Table 1202.3 is checked	Verify source

7. Under-floor and crawl-space ventilation

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1202.4	Under-floor ventilation	Space between the bottom of the floor joists and the earth shall be ventilated in accordance with 1202.4.1, 1202.4.2 or 1202.4.3	Under-floor space	Spaces occupied by basements or cellars are excepted	Conditional	If the tower sits on a basement, skip this section; if a true crawl exists, pick one of the three methods	Verified
1202.4.1	Crawl vent covers	Cross-ventilation openings through foundation walls; covering least dimension not greater than 6.4 mm ; listed covers include perforated plate not less than 1.8 mm thick, expanded plate not less than 1.2 mm thick, hardware cloth of 0.90 mm wire or heavier, and mesh with least dimension not greater than 3.2 mm	Natural crawl ventilation	Operable louvres only where ventilation is per 1202.4.1.2	Conditional	Specify a listed cover with openings not greater than 6.4 mm	Verified
1202.4.1.1	Open-earth crawl vents	Net area of ventilation openings not less than 0.67 m² for each 100 m² of crawl-space area	Crawl with uncovered earth floor	None stated	Conditional	Size foundation vents at 0.67 m² per 100 m² of crawl area	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1202.4.1.2	Covered-earth crawl vents	Net area of ventilation openings not less than 0.67 m² for each 1000 m² of crawl-space area	Ground covered with a Class I vapor retarder	None stated	Conditional	With a Class I ground cover, size vents at 0.67 m² per 1000 m²	Verified
1202.4.3.1	Mechanical crawl ventilation	Continuously operated mechanical ventilation at 1.02 L/s for each 10 m² of crawl-space ground surface, with the ground covered by a Class I vapor retarder	Mechanically ventilated crawl	Alternative: condition the crawl in accordance with SBC 501 and insulate walls per IECC or equivalent in SBC 601 or 602 (1202.4.3.2)	Conditional	If using fans instead of vents, provide 1.02 L/s per 10 m² and a Class I ground cover	Verified
1202.4.4	Flood openings	Under-floor ventilation openings deemed to meet ASCE 24 flood-opening requirements only where designed and installed in accordance with ASCE 24	Buildings in flood hazard areas	No ASCE 24 values imported	External verification	If the site is in a flood hazard area, coordinate flood openings with ASCE 24 separately	Verified

8. Temperature control

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1203.1	Occupied-space heating	Active or passive space heating capable of maintaining an indoor temperature of not less than 20°C at a point 900 mm above the floor on the design heating day	Interior spaces intended for human occupancy	1. Spaces whose primary purpose is not associated with human comfort. 2. Group F, H, S or U occupancies	Direct	Show heating capacity for units, corridors and amenity rooms; outdoor design temperatures are named as SBC 701 Appendix D and are not imported	Verified

9. Lighting

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1204.1	Occupied-space lighting choice	Natural light by exterior glazed openings in accordance with 1204.2 or artificial light in accordance with 1204.3; required glazed openings shall open onto a public way, yard or court in accordance with 1205	Every space intended for human occupancy	None stated	Direct	Lock natural versus artificial light per room; Section 1205 applies only to rooms that take required natural light	Verified
1204.2	Natural glazed area	Minimum net glazed area not less than 8 percent of the floor area of the room served	Spaces using natural light	None stated	Conditional	Schedule glazed area at least 8 percent of each naturally lit room	Verified
1204.2.1	Borrowed natural light	Interior room permitted as a portion of an adjoining room where one-half of the common wall is open and unobstructed and the opening is not less than one-tenth of the interior-room floor area or 2.3 m² , whichever is greater	Interior room without its own required glazing	Sunroom with thermal isolation or patio cover: glazed common-wall area not less than one-tenth of the interior-room floor area or 1.86 m² , whichever is greater	Conditional	Keep borrowed-light openings at least half the wall and at least 2.3 m² (or 1.86 m² for a sunroom); size outer glazing on the combined floor area	Verified
1204.2.2	Natural-light exterior opening	Required 1204.2 openings shall open directly onto a public way, yard or court as set forth in Section 1205	Required natural-light openings	1. Roofed porch abutting a public way, yard or court, with ceiling height not less than 2.1 m and longer side at least 65 percent open and unobstructed. 2. Skylights need not open directly onto a public way, yard or court	Conditional	Do not count a glazed opening onto an enclosed balcony unless the porch exception is met	Verified
1204.3	Artificial illumination	Average illumination of 107 lux over the area of the room at a height of 750 mm above the floor	Spaces using artificial light instead of 1204.2	None stated	Direct	Specify 107 lux at 750 mm in interior rooms without qualifying natural light	Verified
1204.4	Dwelling-unit stair illumination	Stairways within dwelling units and exterior stairways serving a dwelling unit shall have not less than 11 lux on tread runs	Those stairways	Stairways in other occupancies are governed by Chapter 10 (no values imported). Controls: NFPA 70 or equivalent in SBC 401 (1204.4.1)	Direct	Light in-unit and unit-serving exterior stairs to 11 lux on treads; locate switches per the electrical code; common egress stairs follow Chapter 10	Verified

10. Yards and courts

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1205.1	Yard and court applicability	This section applies to yards and courts adjacent to exterior openings that provide natural light or ventilation; such yards and courts shall be on the same lot as the building	Those openings	Does not apply where the facing rooms use mechanical ventilation and artificial light	Conditional	Skip this section for mechanically ventilated, artificially lit rooms	Verified
1205.2	Yard width	Yards not less than 900 mm in width for buildings two stories or less above grade plane; for buildings more than two stories, increased at 300 mm for each additional story; buildings exceeding 14 stories computed on the basis of 14 stories	Yards serving required natural light or ventilation openings	None stated	Conditional	Compute yard width from storey count above grade plane; do not use Figure 1205.1 commentary millimetres	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1205.3	Court width and length	Courts not less than 900 mm in width (1800 mm where windows open on opposite sides); length not less than 3000 mm unless bounded on one end by a public way or yard; more than two stories: increase 300 mm in width and 600 mm in length for each additional story; buildings exceeding 14 stories computed on 14 stories	Courts serving required natural light or ventilation openings	None stated	Conditional	Size the court from storey count; do not copy commentary five-storey examples	Verified
1205.3.1–1205.3.2	Court access and air intake	Access shall be provided to the bottom of courts for cleaning; courts more than two stories in height shall have a horizontal air intake at the bottom not less than 1.0 m² leading to the exterior unless abutting a yard or public way	Courts as 1205.3	Air intake not required if the court abuts a yard or public way	Conditional	Provide a 1.0 m² low-level intake on fully bounded courts taller than two stories	Verified

11. Sound transmission

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1206.1	Sound-transmission scope	Common interior walls, partitions and floor/ceiling assemblies between adjacent dwelling units and sleeping units, or between those units and adjacent public areas	R-2 units and public or service areas	None stated	Direct	Apply this section to every demising wall and every unit-to-corridor or lobby floor	Verified
1206.2	Airborne sound rating	STC not less than 50 where tested in accordance with ASTM E90, or field NNIC not less than 45 in accordance with ASTM E336; penetrations treated to maintain the required ratings	Separations in 1206.1	Entrance doors are not required to meet the STC/NNIC number but shall be tight fitting to the frame and sill; masonry STC may be calculated per TMS 302 or tested per ASTM E90	Direct	Specify STC 50 (or NNIC 45 field) wall and floor-ceiling types; keep unit entry doors tight-fitting	Verified
1206.3	Impact sound rating	Floor-ceiling assemblies shall have IIC not less than 50 where tested in accordance with ASTM E492, or field NISR not less than 45 in accordance with ASTM E1007	Floor-ceilings between units, or between a unit and a public or service area	Engineering analysis comparison to ASTM E492 assemblies is permitted	Direct	Specify IIC 50 (or NISR 45 field) on every unit-to-unit and unit-to-corridor floor	Verified

12. Interior room dimensions

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1208.1	Habitable room plan dimension	Habitable spaces other than a kitchen not less than 2100 mm in any plan dimension; kitchens shall have a clear passageway not less than 900 mm between counter fronts and appliances or counter fronts and walls	Habitable spaces and kitchens	Kitchens are exempt from the 2100 mm plan-dimension rule	Direct	Keep bedrooms, living and dining as a 2100 mm plan cylinder; keep 900 mm kitchen passage	Verified
1208.2	Occupiable ceiling height	Occupiable spaces, habitable spaces and corridors: ceiling height not less than 2250 mm above the finished floor; bathrooms, toilet rooms, kitchens, storage rooms and laundry rooms: not less than 2100 mm	Those rooms	2. Sloped ceiling: prescribed height in one-half the area; portions less than 1500 mm AFF excluded from 1208.3 area. 3. Mezzanines: Section 505.1 (no value imported). 4. Corridors contained within a Group R dwelling or sleeping unit: not less than 2100 mm . Exception 1 (one- and two-family beams) is not this occupancy	Direct	Hold 2250 mm in units, common rooms and public corridors; 2100 mm in baths, kitchens, stores, laundry and in-unit corridors	Verified
1208.2.1	Lowered ceiling area	Any room with a lowered ceiling shall have the minimum ceiling height in two-thirds of the area thereof; the lowered ceiling shall be not less than 2100 mm	Rooms required to have the 1208.2 minimum ceiling height	Section title is OCR-damaged (Faturated / fumed); the two-thirds and 2100 mm figures are unambiguous in the charging sentence	Direct	If a bulkhead or dropped ceiling is used, keep the full minimum height over at least two-thirds of the room and never drop below 2100 mm	Verified
1208.3	Dwelling-unit room area	Every dwelling unit shall have no fewer than one room of not less than 11.2 m² net floor area; other habitable rooms not less than 6.5 m² net	Dwelling units	Kitchens are not required to be of a minimum floor area	Direct	Show at least one 11.2 m² room per unit; keep other habitable rooms at least 6.5 m²	Verified

13. Efficiency dwelling units

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1208.4 Item 1	Efficiency living-room area	Living room of not less than 17.7 m² of floor area	Efficiency dwelling units	Efficiency units conforming to 1208.4 are not required to comply with 1208.3 minimum areas	Conditional	If studios are efficiency units, give the living room 17.7 m²; do not use the commentary 17.5 m² figure	Verified
1208.4 Items 2 and 4	Efficiency closet and bathroom	Separate closet; separate bathroom containing a water closet, lavatory and bathtub or shower	Efficiency dwelling units	None stated	Conditional	Plan a separate closet and a full bathroom; fixture clearances named as SBC 701 are not imported	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1208.4 Item 3	Efficiency kitchen working space	Kitchen sink, cooking appliance and refrigerator each having a clear working space of not less than 750 mm in front; light and ventilation conforming to this chapter	Efficiency dwelling units other than Accessible, Type A and Type B	Accessible, Type A and Type B units follow those unit standards instead of the 750 mm working-space rule	Conditional	Keep 750 mm in front of sink, cooktop and fridge unless the unit is Accessible, Type A or Type B	Verified

14. Access to unoccupied spaces

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1209.1	Crawl access opening	Not fewer than one access opening not less than 450 mm by 600 mm	Crawl spaces	None stated	Conditional	Provide a 450 × 600 mm crawl hatch if a crawl exists	Verified
1209.2	Attic access opening	Opening not less than 560 mm by 760 mm to any attic area having a clear height of over 760 mm ; clear headroom not less than 760 mm in the attic at or above the access opening	Attics exceeding 760 mm clear height	None stated	Direct	Provide a 560 × 760 mm attic hatch with 760 mm headroom at the opening	Verified

15. Toilet and bathroom finishes and privacy

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
1210.2.1	Non-dwelling wet-room floor	In other than dwelling units, toilet, bathing and shower-room floors shall have a smooth, hard, non-absorbent surface; wall base not less than 100 mm	Common and amenity toilet and bathing rooms	Dwelling-unit bathrooms are outside this floor and base rule	Conditional	Use a 100 mm non-absorbent base in lobby, gym and podium toilets; do not use the commentary 150 mm figure	Verified
1210.2.2	Splash-zone wall finish	Walls and partitions within 600 mm of service sinks, urinals and water closets shall have a smooth, hard, non-absorbent surface to a height of not less than 1200 mm above the floor; accessories sealed to protect structural elements from moisture	Those fixtures	1. Dwelling units and sleeping units. 2. Toilet rooms not accessible to the public and having not more than one water closet	Conditional	Tile or equivalent to 1200 mm within 600 mm of amenity water closets, urinals and service sinks	Verified
1210.2.3–1210.2.4	Shower surround and tub joint	Shower compartments and walls above bathtubs with installed shower heads finished with a smooth non-absorbent surface to a height not less than 1800 mm above the drain inlet; built-in tubs with showers shall have waterproof joints between the tub and adjacent wall	Showers and tubs with shower heads	None stated	Direct	Take wet-area finishes to 1800 mm above the drain in unit and amenity showers; seal tub-to-wall joints	Verified
1210.3	Public restroom visual screening	Public restrooms shall be visually screened from outside entry or exit doorways, including where mirrors would compromise personal privacy	Public restrooms	Visual screening not required for single-occupant toilet rooms with a lockable door	Conditional	Offset or screen amenity toilet entries so the room is not visible from the door	Verified
1210.3.1	Water-closet compartments	Each water closet utilized by the public or employees shall occupy a separate compartment with walls or partitions and a door	Public or employee water closets	1. Single-occupant toilet room with a lockable door. 2. Child day-care toilet rooms with two or more water closets may omit one compartment (not typical). 3. Group I-3 housing areas (not typical)	Conditional	Enclose every amenity and employee water closet unless it is a lockable single-occupant room	Verified
1210.3.2	Urinal partitions	Partitions shall begin at a height not more than 300 mm from the finished floor and extend not less than 1500 mm above the finished floor; they shall extend from the wall not less than 450 mm or to a point not less than 150 mm beyond the outermost front lip of the urinal, whichever is greater	Urinals used by the public or employees	1. Single-occupant or family/assisted-use toilet room with a lockable door. 2. Child day-care toilet rooms with two or more urinals may omit partitions at one urinal (not typical)	Conditional	If amenity urinals exist, provide partitions from not more than 300 mm to at least 1500 mm AFF and at least 450 mm deep, or 150 mm beyond the lip	Verified

16. Project-use controls

1. Use **Verified** rows for initial scoping after the row trigger and branch are confirmed.
2. Treat every **Verify source** row (Table 1202.3) as a design hold point; no affected value is to be placed in issued-for-approval drawings without a published-source check.
3. Do not apply Section 1205 yard and court growth to rooms that are mechanically ventilated and artificially lit.
4. Do not apply Group E Section 1207 classroom acoustics, one- and two-family 1208.2 Exception 1 beam projections, or F/H/S/U heating exceptions to this R-2 tower.
5. Do not import SBC 501 ventilation rates, SBC 701 Appendix D outdoor design temperatures, ICC A117.1 Section 808 criteria, Chapter 10 Section 1008 lux values, Chapter 29 fixture counts, commentary 150 mm wall bases, commentary 17.5 m² efficiency rooms, or Figure 1205.1 millimetres.
6. Record AHJ, climate-zone, ventilation-path and unit-type decisions in the project Golden Thread; this matrix is not evidence of SCD NOC or stamped compliance.

17. Coverage summary

Internal inventory of the attached Chapter 12 extract (numbered code, exceptions, tables, footnotes; commentary excluded). Row-level records are not published.

- Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)

- **Total independently checkable numeric records:** 116
- **Verified:** 108
- **Verify source:** 8
- **Numeric records in Section 1201:** 0

Counts by top-level section

Top-level section	Records
1201	0
1202	50
1203	2
1204	11
1205	13
1206	4
1207	1
1208	15
1209	7
1210	13

Appended-table coverage

Appended table	Records	Verify source records
Table 1202.3	8	8

Coverage cross-check against SBC 201 Chapter 12 Interior Environment (2024)_CS.md was topics-only: ventilation path and ACH trigger; attic/crawl; heating and light; yards/courts; STC/IIC; room dimensions; toilet finishes. No CS.md value was copied into a matrix cell. Commentary-only quantities (attic worked example 0.67 m², 150 mm wall base, 17.5 m² efficiency living room, Figure 1205.1 yard millimetres) were not inventoried as code records.

18. Unresolved-source register

Hold points for the 8 **Verify source** inventory records. Counts are record counts, not distinct numeric values. No value in this register is a design-release figure.

Affected table / clause	Why unverified	Control note
Table 1202.3	8 flattened climate-zone / R-value cells (CLIMATE ZONEMINIMUM R-VALUE...R-54R-10...)	Verify the published table before specifying unvented-attic rigid insulation under Items 5.1.2 and 5.1.3; do not reconstruct R-values from memory