

SBC 201 Chapter 2 Definitions — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise; an occupied floor is stated to be more than 23 m above the relevant fire-department vehicle-access level.
- **Deliverable tier:** Project-use matrices in Sections 1–13 (design-check rows, not pasted inventory), plus a coverage summary and unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 2, source file Reference\SBC 201 2024\source_reference\Chapter_02 – DEFINITIONS.txt.
- **Extraction audit:** Skill-finetune run. Project-use rows follow the chapter-extract row contract (noun-phrase checks, bold published tokens, building-language triggers, named exceptions, check-specific actions). Internal inventory: **208** independently checkable numeric records (**208** Verified, **0** Verify source). Commentary, bibliography and Chapter 2 figures were excluded. Unrelated occupancy/chemical classification thresholds were inventoried internally and omitted from lead tables.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, occupancy classification, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from Chapter 3, 4, 5, 9, 10, 11, 15, 16, 403, 404, 505, 1031, ICC A117.1, SBC 601/602, SBC 801, SBC 901, SBC 1101/1102, commentary examples (including **36 m / 126 m** high-rise commentary), figure captions, or the existing chapter summary. Where Chapter 2 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group R-2 and high-rise status are project statements. High-rise is defined here as an occupied floor more than **23 m** above the lowest level of fire department vehicle access; that measurement is not independently verified for this project.
2. The exact Riyadh AHJ/permit pathway, project stage and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Automatic sprinkler protection, storey count, mixed-use podium, amenity/assembly program, atrium, mezzanine, penthouse use and unit type (apartment dwelling units versus sleeping/congregate/live-work) are unconfirmed.
4. Chapter 2 defines terms. It does not classify occupancy (Chapter 3), set height/area (Chapter 5), scope accessibility counts (Chapter 11), or publish egress millimetre geometry (Chapter 10).
5. Commentary after each definition, the chapter bibliography, and FIGURES OF CHAPTER 2 are not mandatory source text. Figure examples (including grade-plane sample elevations) are not adopted.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, use, occupant load, sprinkler branch or exception exists.
Not typical	Unrelated occupancy-only rule; omitted from this deliverable unless the gap register already opened that use.
External verification	Chapter 2 points to another section/code/standard, or the project/AHJ basis must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 2 source text.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 2 application	Required project action
High-rise confirmation	Stated; not measured here	202 high-rise is occupied floor > 23 m above lowest fire-department vehicle access, not building height from grade plane	Survey FD access elevation and the lowest occupied floor; lock the 23 m test before applying Section 403
Additional high-rise tiers	Not in this chapter’s definition text	Commentary mentions further rules above 36 m and 126 m ; those numbers are not 202 source values	Take additional high-rise thresholds from Section 403 , not from this matrix
Unit type	Unconfirmed apartment dwelling units vs sleeping/congregate/live-work	Dwelling unit vs sleeping unit vs congregate living vs live/work changes Chapter 10/11 branches without changing this chapter’s definitions	Classify every unit on a signed schedule (kitchen + sanitation together = dwelling unit)
Transient vs nontransient	Assumed nontransient R-2	202 transient is occupancy of a dwelling/sleeping unit for not more than 30 days	Confirm lease/stay duration; stays ≤ 30 days are transient (typically R-1), not this R-2 basis
Mixed-use / podium	Unconfirmed	Fire area, FSD, atrium story-count and public-way geometry still use these definitions	Freeze occupancy by space; measure FSD and atrium stories with the 202 methods
Atrium / mezzanine / penthouse	Unconfirmed	Atrium for this occupancy is a closed-top void connecting three or more stories; mezzanine geometry is Section 505 ; penthouse is unoccupied rooftop MEP/shafts	Identify every multi-storey void, intermediate level and rooftop enclosure before locking 404/505/1511
Townhouse / SBC 1101-1102 product	Not assumed on this tower	Townhouse is three or more attached foundation-to-roof units with open space on at least two sides; the four-test 1101/1102 exception is commentary	Do not apply the townhouse definition unless that attached product is added
Grade plane / stories above grade	Unconfirmed site grades	1.8 m lot-line offset and 1.8 m / 3.6 m story-above-grade tests control height in stories (Chapter 5)	Produce a grade-plane diagram from finished ground, not from a single corner spot-height
Sprinkler / NOC / fire strategy	Unconfirmed	Chapter 2 does not select NFPA 13 vs 13R; commentary on sprinkler types is not adopted	Lock the sprinkler standard from Chapter 9 / the fire strategy, not from this glossary
Accessibility edition	Not published here	Accessible / Type A / Type B are labels pointing to Chapter 11 and ICC A117.1	Keep millimetre unit geometry on the locked A117.1 edition

4. Term application

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
201.1	Chapter term meanings	Unless otherwise expressly stated, words and terms shall have the meanings shown in this chapter	All applications of this code	None stated	Direct	Put Chapter 2 on the code sheet as the glossary for defined terms used on the drawings	Verified
201.2	Tense gender number	Present tense includes the future; masculine includes feminine; singular includes plural and plural the singular	Reading any defined or undefined term	None stated	Direct	Do not treat singular “dwelling unit” or “exit” as limiting the count of those elements	Verified
201.3	Terms in other Saudi codes	Where terms are not defined in this code and are defined in other referenced Saudi codes, those meanings apply	Term absent from Chapter 2	None stated	External verification	Look up the missing term in the named Saudi code; do not import that code’s numbers into this matrix	Verified
201.4	Terms not defined	Where terms are not defined through the methods authorized by this section, they have ordinarily accepted meanings as the context implies	Term absent from this code and other referenced Saudi codes	None stated	Direct	Use ordinary construction meaning; do not invent a Chapter 2 threshold	Verified

5. Height, grade plane, story and high-rise

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Grade plane	Average of finished ground adjoining the building at exterior walls. Where ground slopes away, use the lowest points between the building and the lot line, or a point 1.8 m from the building where the lot line is more than 1.8 m away	Building height, stories above grade plane, basement classification	None stated	Direct	Draw grade plane from perimeter finished grades using the 1.8 m offset; do not use a single corner elevation	Verified
202	Story	Portion of a building between the upper surface of a floor and the upper surface of the floor or roof next above, measured top-to-top of successive finished floors (or to ceiling joists/roof rafters at the top story)	Every building level	See basement, building height, grade plane and mezzanine	Direct	Count each stacked floor-to-floor volume as a story, including basements; treat a qualifying mezzanine as part of its story	Verified
202	Story above grade plane	Any story with finished floor entirely above grade plane, or in which the floor next above is more than 1.8 m above grade plane, or more than 3.6 m above finished ground at any point	Height in stories (Chapter 5)	A level that fails this test is a basement	Direct	Test every below-grade and hillside level against 1.8 m and 3.6 m before dropping it from the story count	Verified
202	Basement	A story that is not a story above grade plane	Levels that fail the story-above-grade-plane test	This basement definition does not apply to Section 1612 flood loads	Direct	Exclude true basements from Table 504 story limits; use the flood basement definition only if 1612 applies	Verified
202	Building height	Vertical distance from grade plane to the average height of the highest roof surface	Height in metres (Chapter 5)	None stated in this definition	Direct	Measure to the average of the highest roof, not to a penthouse that remains a 202 penthouse	Verified
202	High-rise building	Building with an occupied floor located more than 23 m above the lowest level of fire department vehicle access	Occupied floor vs FD vehicle access	Not a measurement of building height from grade plane	Direct	Dimension FD access to the lowest occupied floor on the life-safety section; if > 23 m , apply Section 403 without importing 403 values here	Verified

6. Area, fire area and fire separation distance

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Building area	Area within surrounding exterior walls (or exterior walls and fire walls), exclusive of vent shafts and courts. Areas without surrounding walls count if they lie within the horizontal projection of the roof or floor above	Allowable area (Chapter 5)	Vent shafts and courts are excluded	Direct	Take the footprint inside exterior/fire walls; add projected open-sided area; keep courts and vent shafts out of the area takeoff	Verified
202	Gross floor area	Floor area within the inside perimeter of exterior walls, exclusive of vent shafts and courts, without deduction for corridors, stairways, ramps, closets, interior walls, columns or other features. Unwalled portions use usable area under the horizontal projection of the roof or floor above. Shafts with no openings and interior courts are excluded	Occupant-load and other gross-area applications	Shafts with no openings and interior courts omitted	Direct	Use inside-face exterior-wall takeoff for Table 1004.5 gross rows; do not net-out corridors	Verified
202	Net floor area	Actual occupied area, not including unoccupied accessory areas such as corridors, stairways, ramps, toilet rooms, mechanical rooms and closets	Occupant-load net-area applications	Accessory unoccupied rooms omitted	Direct	Use net area only for spaces Table 1004.5 assigns as net; keep toilets and corridors out of that takeoff	Verified
202	Fire area	Aggregate floor area enclosed and bounded by fire walls, fire barriers, exterior walls or horizontal assemblies. Unwalled areas count if they sit under the horizontal projection of the roof or floor next above	Sprinkler, alarm and other fire-area triggers (Chapter 9)	None stated	Direct	Sum every story (and any mezzanine area the later chapter includes) inside the bounding rated assemblies; do not import Chapter 9 thresholds here	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Fire separation distance	Distance from the building face, measured at right angles from the wall, to: (1) the closest interior lot line; (2) the centerline of a street, alley or public way; or (3) an imaginary line between two buildings on the lot	Exterior-wall rating and opening limits (Chapter 7)	Designer locates the imaginary line, then it applies to both buildings	Direct	Dimension FSD perpendicular to each exterior face on the site plan; freeze any same-lot imaginary line before rating the walls	Verified

7. Residential occupancy and unit types

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Dwelling unit	Single unit with complete independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking and sanitation	Conventional apartment with a full kitchen and bathroom	Distinguished from sleeping unit	Direct	Schedule every apartment with permanent cooking and sanitation as a dwelling unit on the unit matrix	Verified
202	Efficiency dwelling unit	Dwelling unit where all permanent provisions for living, sleeping, eating and cooking are contained in a single room	Studio / efficiency apartment	Still a dwelling unit	Direct	Treat studios with permanent cooking as dwelling units, not sleeping units, for Chapter 10/11 scoping	Verified
202	Sleeping unit	Rooms/spaces for one or more persons with permanent sleeping; may include living, eating and either sanitation or kitchen, but not both. Spaces that are also part of a dwelling unit are not sleeping units	Hotel-style rooms, congregate bedrooms, kitchenette-only studios	Spaces inside a dwelling unit are not sleeping units	Conditional	If a unit has a kitchenette or a bathroom but not both, classify it as a sleeping unit and switch the 1108/1006 branch	Verified
202	Congregate living facilities	Building or part thereof that contains sleeping units where residents share bathroom or kitchen facilities, or both	Shared-bath or shared-kitchen housing	Occupant-count classification is Chapter 3, not this definition	Conditional	If bathrooms or kitchens are shared, label the product congregate living; do not import the commentary 10/16-person splits	Verified
202	Live/work unit	Dwelling unit or sleeping unit in which a significant portion of the space includes a nonresidential use operated by the tenant	Combined living and tenant-operated work	None stated	Conditional	If live/work is programmed, tag those units and apply the live/work sections of later chapters without importing their numbers here	Verified
202	Multistory unit	Dwelling unit or sleeping unit with habitable space on more than one story	Maisonette / duplex apartment	None stated	Conditional	Flag every split-level unit for the Chapter 11 multistory-unit accessibility branch	Verified
202	Transient occupancy	Occupancy of a dwelling unit or sleeping unit for not more than 30 days	Stay-duration test for R-1 vs R-2	None stated	Direct	Confirm residential stays exceed 30 days ; if any block is ≤ 30 days , reclassify that block as transient	Verified
202	Intended as a residence	Dwelling unit or sleeping unit that can or will be used all or part of the time as the occupant's place of abode	Type B / Fair-Housing-style scoping in Chapter 11	None stated	Direct	Treat the apartments as places of abode for Chapter 11 Type B intent; keep A117.1 millimetres outbound	Verified

8. Accessibility unit labels

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Accessible	Site, building, facility or portion thereof that complies with Chapter 11	Any claim that a route or space is accessible	Technical millimetres are not in this chapter	External verification	Show Chapter 11 scoping on the accessibility sheet; do not copy ICC A117.1 geometry into this matrix	Verified
202	Accessible route	Continuous, unobstructed path that complies with Chapter 11	Accessible approach, entry and circulation	None stated	External verification	Draw the Chapter 11 accessible route; keep A117.1 clearances on that standard	Verified
202	Accessible means of egress	Continuous and unobstructed way of egress travel from any accessible point in a building or facility to a public way	Accessible egress (Section 1009)	Ingress route may differ (1104/1105)	External verification	Coordinate accessible egress to 1009; do not import area-of-refuge sizes from Chapter 10	Verified
202	Accessible unit	Dwelling or sleeping unit that complies with this code and Accessible units in ICC A117.1	Units scoped as Accessible (capital A)	Counts are Chapter 11, not this definition	External verification	Use this label only for units Chapter 11 actually assigns as Accessible; keep A117.1 interiors outbound	Verified
202	Type A unit	Dwelling or sleeping unit designed and constructed for accessibility in accordance with this code and Type A units in ICC A117.1	Units scoped as Type A	Counts are Chapter 11	External verification	Apply the Type A label to the Chapter 11 apartment-house quota; do not import A117.1 millimetres	Verified
202	Type B unit	Dwelling or sleeping unit designed and constructed for accessibility in accordance with this code and Type B units in ICC A117.1	Units intended to be occupied as a residence	Counts and exceptions are Chapter 11	External verification	Label the remaining residential units Type B per Chapter 11; keep technical criteria on A117.1	Verified

9. Vertical space, mezzanine and penthouse

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Atrium	Vertical space closed at the top, connecting two or more stories in Group I-2 and I-3 or three or more stories in all other occupancies	Multi-storey enclosed void	I-2/I-3 use the two-story branch; this R-2 tower uses three or more stories. Open-to-sky courts are courts, not atria	Conditional	If a closed-top void links three or more stories, call it an atrium and take enclosure from Section 404.6 without importing 404 values	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Mezzanine	Intermediate level or levels between the floor and ceiling of any story and in accordance with Section 505	Intermediate loft within a story	Numeric area fraction is not in this definition	External verification	Size every intermediate level from Section 505 ; do not adopt commentary “one-third” as a Chapter 2 value	Verified
202	Penthouse	Enclosed, unoccupied roof-top structure used for sheltering mechanical and electrical equipment, tanks, elevators and related machinery, and vertical shaft openings	Rooftop MEP / shaft enclosure	Habitable or occupied rooftop program is not a 202 penthouse	Conditional	Keep penthouses unoccupied and MEP/shaft-only; occupied amenity rooms are stories, not penthouses. Geometry is Section 1511	Verified
202	Attic	Space between the ceiling framing of the top story and the underside of the roof	Roof void above the top ceiling	None stated	Conditional	If a framed ceiling creates an attic, apply Chapter 12 ventilation and Chapter 7 draftstop rules from those chapters, not from this glossary	Verified
202	Court	Open, uncovered space, unobstructed to the sky, bounded on three or more sides by exterior building walls or other enclosing devices	Light well / enclosed yard open at the top	Not an atrium (atrium is closed at the top)	Conditional	Label open-to-sky wells as courts; do not apply atrium (404) rules to an uncovered court	Verified
202	Yard	Open space, other than a court, unobstructed from the ground to the sky, except where specifically provided by this code, on the lot on which a building is situated	On-lot open space	Distinct from a court	Direct	Show yards on the site plan as open-to-sky lot space that is not a three-sided court	Verified

10. Space types and public way

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Habitable space	Space in a building for living, sleeping, eating or cooking. Bathrooms, toilet rooms, closets, halls, storage or utility spaces and similar areas are not habitable spaces	Unit interior rooms	Bathrooms, halls, closets and utilities are not habitable	Direct	Apply Chapter 12 habitable-room light/ventilation only to living/sleeping/eating/cooking rooms	Verified
202	Occupiable space	Room or enclosed space designed for human occupancy in which individuals congregate for amusement, educational or similar purposes or in which occupants are engaged at labor, and which is equipped with means of egress and light and ventilation meeting this code	Occupied rooms, including residential	Crawl spaces, attics, penthouses and equipment platforms are identified elsewhere as unoccupied	Direct	Provide egress, light and ventilation for every occupiable room; do not treat penthouses or attics as occupiable	Verified
202	Common use	Interior or exterior circulation paths, rooms, spaces or elements that are not for public use and are made available for the shared use of two or more people	Resident corridors, shared lounges, shared toilets	Not public-use	Direct	Tag resident-only shared rooms as common use for Chapter 11; do not treat them as public-use areas	Verified
202	Public-use areas	Interior or exterior rooms or spaces made available to the general public	Lobbies or amenities open to the public	Distinct from common use	Conditional	If a lobby or amenity is open to the general public, label it public-use and apply the Chapter 11 public-use branch	Verified
202	Public way	Street, alley or other parcel of land open to the outside air leading to a street, deeded/dedicated/appropriated to the public, with clear width and height of not less than 3 m	Exit-discharge destination; FSD to public way	None stated	Direct	Confirm the discharge street/alley is ≥ 3 m wide and ≥ 3 m high before calling it a public way	Verified
202	Lot line	Line dividing one lot from another, or from a street or any public place	FSD and yard measurement	Condominium ownership lines are not lot lines (commentary not adopted as a substitute)	Direct	Measure FSD to recorded lot lines, not to unit-demise lines	Verified

11. Egress term locks

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Means of egress	Continuous and unobstructed path of vertical and horizontal egress travel from any occupied portion of a building or structure to a public way, consisting of exit access, exit and exit discharge	Entire occupant escape path	None stated	Direct	Show the three-part egress path to a qualifying public way on the life-safety plan; keep Chapter 10 widths outbound	Verified
202	Exit	Portion of the means of egress between the exit access and the exit discharge or public way. Components: exterior exit doors at the level of exit discharge, interior exit stairways and ramps, exit passageways, exterior exit stairways and ramps, and horizontal exits	Protected egress after exit access	None stated	Direct	Tag only those components as exits; unenclosed stairs remain exit access	Verified
202	Exit access	Portion of the means of egress that leads from any occupied portion of a building or structure to an exit	Rooms, corridors, exit-access stairs/ramps	Crawl spaces and concealed attics are not exit access	Direct	Measure travel distance in the exit-access portion only; do not import 1017 limits here	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Common path of egress travel	Exit-access travel from the most remote point of each room, area or space to the point where occupants have separate and distinct access to two exits or exit-access doorways	Rooms or units with a single direction of travel	Part of overall exit-access travel distance	Direct	Dimension the one-way path inside each apartment to the two-way choice; keep 1006 mm limits on Chapter 10	Verified
202	Area of refuge	Area where persons unable to use stairways can remain temporarily to await instructions or assistance during emergency evacuation	Accessible egress waiting area	Required locations are Section 1009	External verification	Provide 1009 areas of refuge where that section requires them; do not invent sizes from this definition	Verified
202	Open-ended corridor	Interior corridor open on each end and connecting to an exterior stairway or ramp at each end with no intervening doors or separation from the corridor	Breezeway / open corridor	Exterior-stair rules are Section 1027	Conditional	If a breezeway is used, keep both ends open to exterior stairs with no doors; take 1027 geometry from Chapter 10	Verified
202	Grade-floor emergency escape opening	Emergency escape and rescue opening whose clear-opening bottom is not more than 1100 mm above or below the finished ground level adjacent to the opening	Grade-level EERO classification (Section 1031)	Window/door still must meet 1031 size and location	Conditional	If a unit EERO is claimed as grade-floor, keep the sill within 1100 mm of adjacent grade; keep 1031 opening size outbound	Verified
202	Interior exit stairway	Exit component that meets one or more means of egress design requirements (number of exits or exit-access travel distance) and provides a protected path to the exit discharge or public way	Enclosed exit stairs	Unenclosed stairs are exit access	Direct	Enclose tower stairs as interior exit stairways; measure travel to the enclosure door, not down the stair	Verified
202	Smokeproof enclosure	Exit stairway or ramp designed and constructed so that movement of products of combustion into the enclosure is limited	High-rise / underground exit stairs (later chapters)	Construction details are not in this definition	External verification	Flag high-rise exit stairs for the smokeproof-enclosure provisions of Chapter 10 / 403; do not invent vestibule sizes here	Verified

12. Fire-protection and roof term locks

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
202	Class I standpipe	System providing 65 mm hose connections for fire departments and those trained in handling heavy fire streams	FD-use standpipe	Class selection is Chapter 9 / NFPA 14	Direct	Show 65 mm FD hose valves on the standpipe schematic; do not size residual pressure from this definition	Verified
202	Class II standpipe	System providing 40 mm hose stations primarily for building occupants or FD initial response	Occupant-use hose stations	Often omitted where a Class I system is used	Conditional	Provide 40 mm occupant hose stations only if a Class II or III system is selected in Chapter 9	Verified
202	Class III standpipe	System providing 40 mm hose stations for occupants and 65 mm hose connections for the fire department	Combined occupant and FD use	None stated	Conditional	If Class III is selected, schedule both 40 mm stations and 65 mm connections	Verified
202	Steep slope	Roof slope 2 units vertical in 12 units horizontal (17-percent slope) or greater	Roof-covering classification	Material-specific slopes are Chapter 15	Conditional	If any roof equals or exceeds 2:12 (17-percent) , treat it as steep-slope in the Chapter 15 covering tables	Verified
202	Positive roof drainage	Design that accounts for deflections from all design loads and has sufficient additional slope so drainage occurs within 48 hours of precipitation	Roof drainage design	None stated	Direct	Coordinate structure and roof slope so water leaves within 48 hours ; keep 1502 / 1611 drain sizes outbound	Verified
202	Metal roof panel	Interlocking metal sheet having a minimum installed weather exposure of 0.28 m² per sheet	Metal-panel roof covering	None stated	Conditional	If metal panels are used, confirm each sheet’s exposed area is ≥ 0.28 m² ; keep Chapter 15 slopes outbound	Verified

13. Project-use controls

1. Use **Verified** rows for initial scoping after the row trigger and branch are confirmed.
2. There is no **Verify source** row in this deliverable. The attached Chapter 2 extract has no appended dimensional tables. A stray parenthesis on the grade-plane **1.8 m** token was read as **1.8 m** and is treated as Verified.
3. Do not import Chapter 3 occupancy counts, Chapter 5 height/area tables, Chapter 9 sprinkler thresholds, Chapter 10 egress millimetres, Chapter 11 unit quotas, Section 403 high-rise extras, Section 505 mezzanine fractions, or ICC A117.1 geometry from this matrix.
4. Do not adopt commentary numbers (**36 m / 126 m** high-rise, mezzanine “one-third”, townhouse four-test 1101/1102 path, NFPA 13 vs 13R) as Chapter 2 requirements.
5. Do not apply Group H chemical thresholds, flood/coastal definitions, agricultural, aircraft-hangar or similar unrelated occupancy locks to this R-2 tower unless the gap register is reopened for that use.
6. Record grade plane, FD-access height, unit type and public-way confirmation in the project Golden Thread; this matrix is not evidence of SCD NOC, SBPS approval or stamped compliance.

14. Coverage summary

Internal inventory of the attached Chapter 2 extract (numbered code, definition text, numbered list items in definitions; commentary, bibliography and figures excluded). Row-level records are not published.

- **Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)
- **Total independently checkable numeric records:** 208
- **Verified:** 208
- **Verify source:** 0

Counts by top-level section

Top-level section	Records
201	0
202	208

Coverage cross-check against SBC 201 Chapter 2 Definitions (2024)_CS.md was topics-only: grade plane / story above grade plane / high-rise **23 m**, dwelling vs sleeping unit, atrium story count, and Accessible / Type A / Type B labels. No CS.md value was copied into a matrix cell. Commentary **36 m / 126 m** high-rise tiers in the CS.md were not adopted.

H-occupancy chemical, flood, masonry-unit, aerosol, explosive and similar classification thresholds are included in the **208** internal count and are omitted from Sections 4–12 as **Not typical** for this occupancy.

15. Unresolved-source register

No OCR, flattened-table or unreadable-footnote hold point remains in mandatory Chapter 2 text used for project-use rows. Page-split definition sentences (including grade-floor EERO and toxic LD50 item 2) join unambiguously. Figures were not used as source.

Affected table / clause	Why unverified	Control note
—	No independently checkable numeric cell left unverified in the attached extract	Do not reconstruct outbound Chapter 3/5/9/10/11/403/505 or A117.1 values here; lock those from their own extracts