

SBC 201 Chapter 26 Plastics — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise; an occupied floor is stated to be more than 23 m above the relevant reference level.
- **Deliverable tier:** Project-use matrices in Sections 4–19 (design-check rows, not pasted inventory), plus a coverage summary and unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 26, source file Reference\SBC 201 2024\source_reference\Chapter_26 – PLASTICS.txt.
- **Extraction audit:** Skill extract. Project-use rows follow the chapter-extract row contract (noun-phrase checks, bold SI values, building-language triggers, named exceptions, check-specific actions). Internal inventory: **186** independently checkable numeric records (**151** Verified, **35** Verify source). OCR-destroyed fastening tables, flattened Tables 2607.4 and 2609.4, and the missing 2603.4.1.4 heading are listed in the register and are not design-release values.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, facade-engineering report, fire-engineering report, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from Chapter 8, Chapter 14, Chapter 16, Section 402.6.4, Section 602.4, Section 705.8, Section 718, Table 601, Section 803.1.1.1, Section 903.3.1.1 sprinkler design, Section 910, Section 2405.5, Chapter 24 safety glazing, SBC 801, ICC 1100, NFPA 285/268/275/259 acceptance criteria beyond the numeric triggers stated in this chapter, commentary examples, figures, bibliography edition years, or the existing chapter summary. Where Chapter 26 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group R-2 and high-rise status are project statements, not independently verified classifications.
2. The exact Riyadh AHJ/permit pathway, project stage, fire-strategy status and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Type of construction is unconfirmed. An occupied floor above **23 m** is treated as putting foam plastic in Type I–IV exterior walls onto the 2603.5 path **if** foam is specified. Type V framed walls, Type VB plastic glazing, and 2612 plastic-composite decks are not assumed for the tower shaft.
4. Automatic sprinkler protection is not selected. Where this chapter names Section **903.3.1.1**, both the sprinklered and unsprinklered branches are shown. NFPA 13 versus 13R is not assumed.
5. Foam in the envelope, plastic veneer, light-transmitting wall panels/glazing/skylights, plenums, FRP ornament and reflective plastic core insulation are unconfirmed.
6. Tables 2603.12.1, 2603.12.2, 2603.13.1 and 2603.13.2 are OCR-destroyed. Tables 2607.4 and 2609.4 are concatenated. Section 2603.4.1.4 has no numbered heading in the extract. Affected rows are **Verify source**.
7. Coolers/freezers, covered-mall signs, greenhouses, solar collectors on buildings not over three stories, Type V sill-plate spray foam, R-3 patio/skylight/garage exceptions and plastic lumber decks are omitted from lead tables unless a later gap register opens those uses.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, product, construction type, sprinkler branch or exception exists.
Not typical	Unrelated occupancy-only or low-rise/Type V-only rule; omitted from this deliverable unless the gap register already opened that use.
External verification	Chapter 26 points to another section/code/standard, or OCR/AHJ must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 26 source text.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 26 application	Required project action
Construction type	Unconfirmed; high-rise R-2 typically Type I or II, not verified	2603.5 applies to Type I–IV exterior walls of any height; Type V uses 2603.2–2603.4 only. 2608.1 Type VB glazing and 2612 decks are Type V/VB paths	Freeze type of construction on the code data sheet before specifying foam walls or plastic glazing
Foam in the envelope	Unconfirmed	2603.4 thermal barrier, 2603.5 NFPA 285/268 and 2603.11–2603.13 through-foam fasteners apply only if foam is in the wall, roof or floor	Facade and energy consultants to confirm every foam board, spray foam and foam-cored panel
Sprinkler standard	Unconfirmed; high-rise typically sprinklered, NFPA 13 vs 13R not locked	2603.3 Exception 2, 2606.7, 2606.7.4–2606.7.5, 2607.5, 2608.2, 2609.2/2609.4, 2610.4–2610.6 and 2611.2 name 903.3.1.1 only	Freeze the building sprinkler standard; do not apply 903.3.1.1 area/height increases on a 13R-only building
Plastic wall panels / glazing	Unconfirmed	Wall panels are capped at 23 m even when sprinklered. Glazing 23 m is waived only under 903.3.1.1. Occupied floor is already above 23 m	Treat tower-shaft plastic wall panels as prohibited above 23 m ; plastic glazing above that height needs the 903.3.1.1 exception
Exterior plastic veneer	Unconfirmed	2605.2 stops veneer at 15 m above grade with 28 m² sections. Plastic siding is Chapter 14, not 2605.2	Confine any plastic veneer to the lower 15 m band; send vinyl/PP siding to Chapter 14
Light-transmitting roof / skylights	Unconfirmed amenity or roof glazing	2609 and 2610 area, curb, slope and 1.2 m / 1.8 m separations apply; Table 2609.4 is OCR-held	If skylights or plastic roof panels are added, lock CC1 vs CC2 and sprinkler/smoke-vent branch before sizing
Plenums	Unconfirmed	2603.7 / 2604.1.1 tighten foam FSI/SDI in plenums unless a listed barrier is provided	Identify return-air plenums above ceilings before specifying foam finish or trim

Decision / gap	Current project basis	Why it controls Chapter 26 application	Required project action
Termite “very heavy”	Unconfirmed for Riyadh	2603.8 bans below-grade foam and requires 150 mm above-grade clearance unless an exception applies	Geotech/AHJ to confirm termite probability before placing foam on or under foundations
Cladding through foam sheathing	Unconfirmed substrate (masonry, CFS, wood)	2603.11 is engineered; 2603.12–2603.13 tables are OCR-destroyed	Do not issue fastener spacing from this matrix; use manufacturer/approved design after verifying published tables
FRP ornament / low walls	Unconfirmed	2613.5 default is 2603.5. Exception 1 is area-limited ornament. Exception 2 is 12 m height	Keep FRP cornices on the Exception 1 area/FSI path or a 2603.5 listed wall; do not use the 12 m path on the shaft
Mixed-use / amenity / mall	Unconfirmed	Coolers, mall signs (402.6.4), greenhouses and solar collectors are omitted here	If a podium mall, greenhouse or walk-in cooler is added, re-filter those 2603.4.1 / 2606.11–2606.12 clauses
NOC and fire strategy	SCD NOC and stamped fire-strategy status unconfirmed	NFPA 285 wall listings, thermal-barrier substitutions and SCD acceptance cannot be concluded from Chapter 26 alone	Engage the qualified local/fire/facade consultants before design freeze

4. Scope and outbound references

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2601.1	Chapter plastics scope	This chapter governs materials, design, application, construction and installation of foam plastic, foam plastic insulation, plastic veneer, interior plastic finish and trim, light-transmitting plastics and plastic composites, including plastic lumber	Those plastic products on the building	None stated	Direct	List every foam, plastic veneer, plastic finish/trim, light-transmitting plastic and plastic-composite package on the drawing index and send each to the matching 2603–2614 section	Verified
2602.1	Exterior covering outbound	Exterior wall covering and architectural trim: see Chapter 14	Exterior plastic covering or architectural trim	Plastic veneer other than siding remains in 2605.2	External verification	Do not take covering thicknesses from this chapter; use Chapter 14 for siding, trim and weather covering	Verified
2602.2	Interior finish outbound	Interior finish and trim: see Section 2604	Interior plastic finish or trim	Chapter 8 classes are not imported	External verification	Send interior plastic finish/trim through 2604 and Chapter 8, not through 2602	Verified
2603.1.1	Spray-applied foam standard	Single- and multiple-component spray-applied foam plastic insulation shall comply with Section 2603 and ICC 1100-2018	Spray-applied foam specified	ICC 1100 physical properties are not imported	Conditional	Name ICC 1100-2018 on the spray-foam specification in addition to 2603	Verified
2603.2	Foam labeling	Packages and containers of foam plastic insulation and components delivered to the job site shall bear the label of an approved agency showing manufacturer name, product listing, product identification and information sufficient to determine end-use compliance	Foam plastic delivered to site	None stated	Conditional	Require labeled drums/board packages on the foam submittal; reject unlabeled product	Verified

5. Foam surface burning and thermal barrier

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2603.3	Foam surface-burning indices	Foam plastic insulation and foam plastic cores of manufactured assemblies: flame spread index not more than 75 and smoke-developed index not more than 450 , ASTM E84 or UL 723, maximum thickness intended for use. Loose-fill foam tested as board stock	Foam plastic insulation or foam cores	Exception 1: interior trim SDI per 2604.2. Exception 2: cold-storage fully sprinklered per 903.3.1.1, tested at 100 mm , permitted up to 250 mm . Exception 3: Class A, B or C roof assembly passing NFPA 276 or UL 1256; SDI not limited for roof applications. Exception 4: thickness greater than 100 mm still FSI 75 / SDI 450 when tested at not less than 100 mm , with 2603.9 approval at the installed thickness. Exception 5: mall interior signs per 402.6.4	Conditional	Put FSI/SDI and the tested thickness on every foam product data sheet; do not use the cold-storage or mall exceptions on dwelling floors	Verified
2603.4	Interior thermal barrier	Separate foam plastic from the interior by an approved thermal barrier of 12.5 mm gypsum wallboard, heavy timber in accordance with Section 602.4, or a material meeting both NFPA 275 Temperature Transmission and Integrity Fire Tests. Combustible concealed spaces: Section 718	Foam plastic in the building	2603.4.1.1 through 2603.4.1.14 omissions; 2603.9 special approval. Section 602.4 and 718 values are not imported	Conditional	Show 12.5 mm gypsum or an NFPA 275-listed barrier on the occupied side of every foam cavity unless a numbered 2603.4.1 omission is demonstrated	Verified

6. Thermal-barrier omissions (R-2 relevant)

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2603.4.1.1	Masonry or concrete encapsulation	Thermal barrier not required where foam is covered on each face by not less than 25 mm of masonry or concrete	Foam in a masonry or concrete wall, floor or roof	Exterior surface still 2603.5 where that section applies	Conditional	Dimension 25 mm cover on both faces of insulated masonry/concrete panels; do not treat a single-face wythe as this omission	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2603.4.1.5	Roof-assembly thermal-barrier omission	Thermal barrier not required for foam that is part of a Class A, B or C roof covering installed per the code and manufacturer instructions, and either: Item 1, wood structural panel sheathing not less than 12.5 mm , exterior glue, edges blocked/T&G/approved; or Item 2, assembly passes NFPA 276 or UL 1256	Foam in a classified roof assembly	Class and underside-fire tests are assembly-specific	Conditional	Use the 12.5 mm sheathing path or a listed NFPA 276 / UL 1256 roof assembly; do not omit the interior barrier on walls by citing this roof clause	Verified
2603.4.1.6	Attic and crawl ignition covers	In attics or crawl spaces entered only for utility service, protect foam against ignition by 40 mm mineral fiber; 6 mm wood structural panel, particleboard or hardboard; 10 mm gypsum wallboard; corrosion-resistant steel 0.4 mm base metal; 40 mm self-supported spray-applied cellulose in attics only; or other approved material so the foam is not exposed. Covering consistent with type of construction	Foam in a service-only attic or crawl space	Not a substitute for the 2603.4 thermal barrier toward occupied rooms. 2603.9 tested assemblies may omit both barriers	Conditional	Show an ignition cover from the listed menu on attic/crawl foam; keep 12.5 mm thermal barrier toward dwellings	Verified
2603.4.1.7	Metal-faced non-rated doors	Foam core permitted in pivoted or side-hinged doors that are not required to have a fire protection rating, FSI 75 or less and SDI not more than 450 , facing not less than 0.8 mm aluminum or steel 0.4 mm base metal at any point	Non-rated foam-core swing doors	Fire-rated doors must be tested with the foam core in place	Conditional	Specify metal facing thickness on non-rated foam-core doors that are not dwelling-unit entrance doors under 2603.4.1.8	Verified
2603.4.1.8	R-2 dwelling entrance doors	In Group R-2 or R-3, foam-filled exterior entrance doors to individual dwelling units that do not require a fire-resistance rating shall be faced with aluminum, steel, fiberglass, wood or other approved materials	Foam-filled exterior entrance doors to R-2 dwelling units, not fire-rated	Need not comply with 2603.4.1.7 metal-thickness rule	Direct	Allow the listed facings on non-rated unit entrance doors; keep fire-rated unit doors on a tested listing	Verified
2603.4.1.9	Garage-door foam cores	Where garage doors are permitted without a fire-resistance rating and foam is the core, facing not less than 0.8 mm aluminum or 0.25 mm steel, or minimum 3.1 mm wood. Other facings: DASMA 107	Non-rated foam-core garage/vehicle doors	Exception: detached and attached garages associated with one- and two-family dwellings using foam complying with 2603.3 — omitted here as R-3	Conditional	Put facing thickness or a DASMA 107 report on any podium/parking garage door with a foam core	Verified
2603.4.1.10	Siding backer board	Foam not more than 22 mJ/m² (NFPA 259), maximum thickness 12.5 mm , separated from the interior by not less than 50 mm mineral fiber or equivalent, or applied as insulation with residing over existing wall construction	Foam used as siding backer without a 2603.4 thermal barrier	If 2603.3 and 2603.4 are already met, this clause is not the controlling path	Conditional	Do not use thin foam backer on a new tower wall as a thermal-barrier substitute unless the 22 mJ/m² , 12.5 mm and 50 mm mineral-fiber conditions are shown	Verified
2603.4.1.11	Interior-trim thermal-barrier omission	Foam used as interior trim in accordance with Section 2604 is permitted without a thermal barrier	Foam plastic interior trim complying with 2604	Density, size, area and FSI limits are in 2604.2, not here	Conditional	Route foam trim to Section 10 of this matrix; do not also demand 12.5 mm gypsum over the trim profile	Verified
2603.4.1.14	Structural-floor walking surface	Thermal barrier not required on the walking surface of a structural floor containing foam where the foam is covered by minimum nominal 12.5 mm wood structural panel or approved equivalent. Thermal barrier is still required on the underside where that underside is exposed to the interior	Foam in a structural floor system	Exception: foam used as part of an interior floor finish	Conditional	Cover the walking surface with 12.5 mm wood structural panel and keep the underside barrier toward the room below	Verified

7. Foam on Type I–IV exterior walls

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2603.5	Exterior-wall foam charging	Type I, II, III or IV exterior walls of any height: 2603.5.1 through 2603.5.7. Type V: 2603.2, 2603.3 and 2603.4. Fireblocking: Section 718.2. Cold-storage buildings required to be noncombustible and more than one story: 2603.5.1–2603.5.7	Foam in exterior walls	Type V path omitted for the tower shaft. 718.2 values are not imported	Conditional	Default any foam in the tower rainscreen to the Type I–IV any-height package, including NFPA 285	Verified
2603.5.1	Rated-wall foam evidence	Where the wall is required to have a fire-resistance rating, provide ASTM E119 or UL 263 data showing the rating is maintained	Foam in a fire-resistance-rated exterior wall	Rating hours are in Chapter 7 / Table 601, not here	External verification	Require an E119/UL 263 assembly that includes the installed foam thickness	Verified
2603.5.2	Exterior-wall interior barrier	Any foam plastic insulation shall be separated from the building interior by a 2603.4 thermal barrier unless specially approved under 2603.9	Foam in Type I–IV exterior walls	Exception: one-story buildings complying with 2603.4.1.4 (heading missing in this extract; not used on a high-rise)	Conditional	Keep the interior 12.5 mm / NFPA 275 barrier on tower foam walls; do not use the one-story exception	Verified
2603.5.3	Potential-heat cap	Potential heat of foam in any portion of the wall or panel shall not exceed the potential heat, in mJ/m² , of the foam in the wall assembly tested under 2603.5.5. Determine potential heat by NFPA 259	Foam in Type I–IV exterior walls	Exception: one-story buildings complying with 2603.4.1.4	Conditional	Match NFPA 259 potential heat to the NFPA 285-tested wall; do not invent a numeric cap	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2603.5.4	Exterior-wall component indices	Foam, exterior coatings and facings tested separately in the thickness intended for use, but not more than 100 mm , each with flame spread index 25 or less and smoke-developed index 450 or less, ASTM E84 or UL 723	Foam, coatings and facings on Type I–IV exterior walls	Prefabricated panels with minimum 0.5 mm aluminum facings and total thickness 6.3 mm or less may be tested as an assembly where the core is not exposed during construction	Conditional	Record component FSI 25 / SDI 450 at the installed thickness (test cap 100 mm); do not substitute the general 2603.3 FSI 75 on these walls	Verified
2603.5.5	Vertical and lateral fire propagation	The exterior wall assembly shall be tested in accordance with and comply with NFPA 285	Foam in Type I–IV exterior walls	Exception 1: one-story 2603.4.1.4. Exception 2: foam covered on each face by not less than 25 mm masonry or concrete, and either no airspace, or FSI not more than 25 with airspace not more than 25 mm	Conditional	Require an NFPA 285 listed wall for tower foam, or document the 25 mm masonry/concrete exception with the airspace rule	Verified
2603.5.6	Exterior-wall foam label	Edge or face of each piece, package or container of foam shall bear an approved-agency label with manufacturer/distributor identification, model or serial number or performance data, and agency identification	Foam used under 2603.5	Stricter than 2603.2 package labeling	Conditional	Require piece/package labels on foam boards and spray-foam drums used in the rainscreen	Verified
2603.5.7	Exterior-wall ignition	Exterior walls shall not exhibit sustained flaming when tested to NFPA 268. Where more than one thickness is intended, test the minimum and maximum thicknesses	Foam in Type I–IV exterior walls	Exception: assemblies protected on the outside with a 2603.4 thermal barrier; 25 mm concrete or masonry; 10 mm glass-fiber-reinforced concrete panels; metal-faced panels with 0.5 mm aluminum or 0.4 mm corrosion-resistant steel outer facings; 20 mm stucco complying with 2510; or 6 mm fiber-cement lap, panel or shingle siding complying with 1404.16	Conditional	Require NFPA 268 at min and max foam thickness, or show one listed exterior protective on the wall section	Verified

8. Foam roofing, plenums, termites, special approval and wind

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2603.6	Foam in roof coverings	Foam complying with 2603.2, 2603.3 and 2603.4 is permitted as part of a roof-covering assembly where the assembly with the foam is Class A, B or C when tested to ASTM E108 or UL 790	Foam in a roof covering	2603.4.1.5 and 2603.9 may modify the thermal barrier. Class values are the assembly rating, not imported from Chapter 15	Conditional	Put the E108/UL 790 class on the roof assembly that contains foam; keep 2603.2–2603.4 on the foam itself	Verified
2603.7	Exposed foam in plenums	Foam in plenums used as interior wall or ceiling finish or interior trim: FSI 25 or less and SDI 50 or less, ASTM E84 or UL 723 at maximum thickness and density intended for use, plus NFPA 286 meeting Section 803.1.1, or 2603.9 in lieu of NFPA 286	Foam finish or trim exposed in a plenum	Exception 1: FSI 75 / SDI 450 if separated from plenum airflow by a 2603.4 thermal barrier. Exception 2: same indices if separated by corrosion-resistant steel not less than 0.4 mm . Exception 3: same indices if separated by not less than 25 mm masonry or concrete. 803.1.1 criteria are not imported	Conditional	Default exposed plenum foam to FSI 25 / SDI 50 plus NFPA 286, or show a listed barrier and the relaxed indices	Verified
2604.1.1	Plenum foam charging	Foam in plenums as interior wall or ceiling finish: 2603.7. Foam in plenums as interior trim: 2604.2 and 2603.7	Foam finish or trim in a plenum	None stated beyond 2603.7 exceptions	Conditional	Combine 2604.2 trim geometry with 2603.7 plenum indices when foam trim is in a return plenum	Verified
2603.8	Termite clearance	In areas of very heavy termite infestation, extruded and expanded polystyrene, polyisocyanurate and other foam plastics shall not be installed on the exterior face or under interior or exterior foundation walls or slab foundations located below grade. Clearance between above-grade foam and exposed earth not less than 150 mm	Very heavy termite probability; foam at grade/foundation	Exception 1: walls, floors, ceilings and roofs entirely of noncombustible materials or preservative-treated wood. Exception 2: approved subterranean-termite protection of foam and structure. Exception 3: interior side of basement walls	Conditional	If the site is classified very heavy, keep foam 150 mm above earth and off below-grade exterior/underslab locations unless a numbered exception is demonstrated	Verified
2603.9	Special-approval tests	Foam need not comply with 2603.4 or 2603.6 where specifically approved based on large-scale tests such as NFPA 286 (with 803.1.1.1), FM 4880, UL 1040 or UL 1715, in the actual end-use configuration, maximum thickness intended for use, including seams, joints and typical details. Foam used as interior finish on this path shall also meet Chapter 8 FSI/SDI	Alternative to 2603.4 or 2603.6	Does not waive 2603.5 exterior-wall tests. Chapter 8 and 803.1.1.1 values are not imported	Conditional	Accept only a full-scale report that matches the installed thickness and details; still run 2603.5 if the foam is in a Type I–IV exterior wall	Verified
2603.10	Foam sheathing wind resistance	Foam complying with ASTM C578 and ASTM C1289 and used as exterior wall sheathing on framed wall assemblies shall comply with ANSI/FS 100 for wind pressure resistance	Foam insulating sheathing on framed exterior walls	ANSI/FS 100 pressures are not imported	External verification	Name ASTM C578/C1289 and ANSI/FS 100 on framed-wall foam sheathing; take design wind from Chapter 16	Verified

9. Cladding attachment through foam sheathing

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2603.11	Through-foam to masonry or concrete	Cladding per Chapter 14 and manufacturer instructions or an approved design. Attach foam to masonry/concrete per insulation manufacturer or approved design. Design furring and through-foam attachments for Chapter 16 loads, including cladding weight. Fasteners into masonry/concrete shall be approved for that substrate and installed per the fastener manufacturer	Cladding or furring through foam sheathing to masonry or concrete	Exception 1: cladding manufacturer approved instructions for foam over masonry/concrete. Exception 2: EIFS, Section 1407. Exception 3: anchored masonry or stone veneer, Section 1404. No Chapter 14/16 values imported	External verification	Engineer through-foam masonry/concrete connections; do not invent fastener spacing from this chapter	Verified
2603.12–2603.12.2	Through-foam to cold-formed steel	Cladding per Chapter 14 or approved design. Furring designed for Chapter 16. Direct attach: Table 2603.12.1. Furred attach: Table 2603.12.2. Horizontal wood furring: preservative-treated (2303.1.9) or naturally durable; corrosion-resistant fasteners (2304.10.6). Steel furring: minimum G60	Cladding through foam to CFS framing	Manufacturer foam-over-frame instructions; EIFS 1407; anchored veneer 1404. Tables 2603.12.1 and 2603.12.2 are OCR-destroyed in this extract	External verification	Do not issue CFS through-foam fastener size, spacing or foam-thickness limits until the published tables are verified	Verify source
2603.13–2603.13.2	Through-foam to wood framing	Cladding per Chapter 14. Furring designed for Chapter 16. Direct attach: Table 2603.12.1 as charged in this extract. Furred wood: Table 2603.13.2. Horizontal wood furring: preservative-treated or naturally durable; corrosion-resistant fasteners	Cladding through foam to wood framing	Same manufacturer / EIFS / veneer exceptions as 2603.12. Charging 2603.13.1 names Table 2603.12.1; the appended wood-framing tables are OCR-destroyed	External verification	Do not issue wood through-foam fastener schedules from this extract; verify published Tables 2603.12.1 / 2603.13.1 / 2603.13.2	Verify source

10. Interior plastic finish and trim

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2604.1	Interior plastic finish charging	Plastic materials installed as interior finish or trim shall comply with Chapter 8. Foam as interior finish only where approved under 2603.9, and shall also meet Chapter 8 FSI/SDI. Foam as interior trim: 2604.2	Interior plastic finish or trim	Chapter 8 class letters and 2603.9 test criteria are not imported	Conditional	Send foam finish through 2603.9 plus Chapter 8; send foam trim through 2604.2	Verified
2604.2.1–2604.2.4	Foam interior trim limits	Minimum density 320 kg/m³ . Maximum thickness 12.5 mm and maximum width 200 mm . Trim not more than 10 percent of the specific wall or ceiling area to which it is attached. Flame spread index not more than 75 , ASTM E84 or UL 723; smoke-developed index not limited	Foam plastic used as interior trim	NFPA 286 meeting 803.1.1.1 may replace the E84/UL 723 flame-spread test. 803.1.1.1 values are not imported	Conditional	Limit foam trim profiles to 12.5 mm × 200 mm , density 320 kg/m³ , coverage 10 percent , and FSI 75 unless a passing NFPA 286 finish test is submitted	Verified

11. Plastic veneer and siding

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2605.1	Interior plastic veneer	Where used within a building, plastic veneer shall comply with Chapter 8 interior finish	Interior plastic veneer	Chapter 8 classes are not imported	Conditional	Classify interior plastic veneer as interior finish; do not use 2605.2 height/area limits indoors	Verified
2605.2	Exterior plastic veneer height and area	Exterior plastic veneer other than plastic siding, on buildings of any construction type: comply with 2606.4; not attached to any exterior wall to a height greater than 15 m above grade; sections not more than 28 m² , separated not less than 1.2 m vertically	Exterior plastic veneer other than plastic siding	Exception: area, separation and smoke-density limits do not apply to plastic veneer on Type VB walls that are not required to have a fire-resistance rating. Type VB exception is not used on the tower shaft	Direct	Keep plastic veneer in the lower 15 m band in 28 m² sections with 1.2 m vertical breaks; do not run it as full-height tower cladding	Verified
2605.3	Plastic siding outbound	Plastic siding shall comply with Sections 1403 and 1404	Plastic siding	Chapter 14 thicknesses, FSD and wind limits are not imported	External verification	Send vinyl, polypropylene and other plastic siding to Chapter 14	Verified

12. Light-transmitting plastic specifications

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2606.1	Light-transmitting plastics charging	Sections 2606 through 2611 govern quality and methods of application of light-transmitting plastics. Foam plastics: Section 2603. Light-transmitting plastics that meet other code requirements for walls and roofs may be used under those other chapters	Light-transmitting plastic as a light-transmitting material	None stated	Conditional	Identify every plastic skylight, wall panel, glazing, diffuser and interior sign and send it to 2606 plus the matching 2607–2611 section	Verified
2606.2–2606.3	Approval and identification	Submit sufficient technical data for building-official approval. Each unit or package shall be identified with a mark or decal including material classification	Light-transmitting plastic products	None stated	Conditional	Require CC1/CC2 marks on product packaging and a data package for AHJ approval	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2606.4	Approved plastic properties	Self-ignition temperature 343 °C or greater, ASTM D1929. Smoke-developed index not greater than 450 , ASTM E84 or UL 723 as intended for use, or maximum average smoke density rating not greater than 75 , ASTM D2843 at the thickness intended for use. Class CC1: burning extent 25 mm or less at nominal 1.5 mm or the thickness intended for use, ASTM D635. Class CC2: burning rate 1 mm/s or less at nominal 1.5 mm or the thickness intended for use, ASTM D635	Light-transmitting plastics, including thermoplastic, thermosetting or reinforced thermosetting	None stated	Conditional	Put self-ignition, smoke and CC1/CC2 class on every light-transmitting plastic specification	Verified
2606.5–2606.6	Strength and fastening	Assemblies of adequate strength and durability for Chapter 16 loads. Submit stresses, maximum unsupported spans and related thickness/form data as required by the building official. Fastening adequate for Chapter 16 loads, with allowance for expansion and contraction	Light-transmitting plastic assemblies	Chapter 16 loads are not imported	External verification	Size plastic glazing, panels and fasteners from Chapter 16; show expansion joints on shop drawings	Verified

13. Light-diffusing systems, exits and bathroom glazing

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2606.7	Light-diffusing occupancy bans	Unless the building is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1, light-diffusing systems shall not be installed in the listed Group A / theater / I-2 / I-3 locations, or in interior exit stairways and ramps and exit passageways	Light-diffusing systems	903.3.1.1 throughout lifts the ban, including in exits. Group A / I-2 / I-3 items are omitted here	Direct	Do not put plastic light-diffusing ceilings in interior exit stairs, ramps or exit passageways unless the building is sprinklered throughout per 903.3.1.1	Verified
2606.7.1–2606.7.3	Diffuser support, drop-out and size	Support plastic diffusers from ceiling or roof construction with noncombustible hangers not less than No. 12 steel-wire gage (2.5 mm) galvanized wire or equivalent. Comply with Chapter 8 unless panels fall from mountings before igniting at not less than 93 °C below panel ignition temperature, and remain in place at 79 °C for not less than 15 minutes . Individual panels or units not more than 3 m in length nor 2.8 m² in area	Light-transmitting plastic diffusers	Chapter 8 classes are not imported	Conditional	Show 2.5 mm noncombustible hangers, drop-out temperatures and panel size 3 m / 2.8 m² on the diffuser specification	Verified
2606.7.4	Sprinklered diffuser area	In buildings sprinklered throughout per 903.3.1.1, protect plastic light-diffusing systems both above and below unless the sprinkler system is specifically approved for installation only above, or the system is listed and labeled to UL 723S. Areas so protected shall not be limited	Light-diffusing systems in a 903.3.1.1 building	Unsprinklered buildings keep 2606.7.3 size limits	Conditional	If 903.3.1.1 is locked, provide above-and-below sprinklers or a UL 723S listing before exceeding 2.8 m² panels	Verified
2606.7.5	Exit and corridor luminaires	Plastic panels in approved electrical luminaires shall comply with Chapter 8 unless they conform to 2606.7.2. Area of approved light-transmitting plastic in required exits or corridors shall not exceed 30 percent of the aggregate ceiling area in which the panels are installed, unless the building is sprinklered throughout per 903.3.1.1	Plastic light-transmitting or diffuser panels in luminaires	903.3.1.1 throughout removes the 30 percent cap	Conditional	Limit plastic luminaire lenses in unsprinklered required exits/corridors to 30 percent of that ceiling; coordinate with Chapter 8	Verified
2606.8	Plastic partitions	Light-transmitting plastics used in or as partitions shall comply with Chapters 6 and 8	Plastic in partitions	Chapter 6/8 values are not imported	External verification	Treat plastic partition glazing as a Chapter 6/8 interior assembly, not as 2607 wall panels	Verified
2606.9	Bathroom plastic glazing	Light-transmitting plastics are permitted as glazing in shower stalls, shower doors, bathtub enclosures and similar accessory units. Safety glazing in accordance with Chapter 24	Bathroom accessory glazing of approved plastic	Chapter 24 impact classes are not imported	Conditional	Allow CC1/CC2 plastic in showers/tubs only with a Chapter 24 safety-glazing mark	Verified
2606.10	Awnings, patio covers and fuel canopies	Awnings of light-transmitting plastics: Section 3105 and Chapter 32. Patio covers: Section 2606. Canopies at motor-fuel-dispensing facilities: Section 2606 as modified by 406.7.2	Those outdoor plastic structures	3105, 32 and 406.7.2 values are not imported	Conditional	Route tower-entry canopies through 2606 plus the named sections; do not import those outbound numbers	Verified

14. Light-transmitting plastic wall panels

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2607.1–2607.2	Wall-panel occupancy and construction type	Light-transmitting plastics shall not be used as wall panels in exterior walls of Groups A-1, A-2, H, I-2 and I-3. In other groups, including R-2, permitted where the walls are not required to have a fire-resistance rating and the installation conforms to this section. Erect and anchor on a foundation, waterproof or otherwise protect from moisture absorption, and seal with mastic or other approved waterproof coating. Comply with 2606. Exterior wall panels installed as provided herein shall not alter the type of construction classification	Light-transmitting plastic used as exterior wall panels	A-1/A-2/H/I-2/I-3 ban does not apply to R-2. Rated exterior walls cannot take these panels	Conditional	Use plastic wall panels only on non-rated R-2 exterior walls; keep weather seals and foundation anchorage on the typical	Verified
2607.3	Wall-panel height	Light-transmitting plastics shall not be installed more than 23 m above grade plane	Light-transmitting plastic wall panels	2607.5 restates the same 23 m cap even when sprinklered	Direct	Do not specify plastic wall panels on the tower shaft above 23 m ; the occupied floor is already above that height	Verified
2607.4	Wall-panel area and separation	Maximum single-panel area and minimum vertical/horizontal separation: Table 2607.4. Maximum percentage of wall area of any story in plastic wall panels: the smaller of Table 2607.4 or Section 705.8 unprotected openings	Plastic wall panels on non-rated walls	Exception 1: approved flame barriers extending 750 mm beyond the exterior wall in the plane of the floor omit vertical separation at the floor except the barrier’s vertical thickness. Exception 2: Type V weather-resistant plastic siding per 1405. Exception 3: greenhouse walls — omitted here. Table 2607.4 cells are concatenated; 705.8 percentages are not imported	External verification	Do not adopt Table 2607.4 percentages, m² or separations from this extract; verify the published table and compare with 705.8. Flame-barrier projections remain 750 mm	Verify source
2607.5	Sprinklered wall-panel increase	Where the building is sprinklered throughout per 903.3.1.1, Table 2607.4 maximum percentage and maximum square metres of a single area increase 100 percent , but plastic wall panels shall not exceed 50 percent of the wall area in any story, or the 705.8 unprotected-opening area, whichever is smaller. Installations shall not be more than 23 m above grade plane	903.3.1.1 building with plastic wall panels	Height cap is not waived by sprinklers. Table cells remain Verify source	Conditional	Even on a 903.3.1.1 building, keep plastic wall panels at or below 23 m and not more than 50 percent of the story wall (or 705.8, if smaller)	Verified
2607.6	Combined glazing and wall panels	Combinations of light-transmitting plastic glazing and plastic wall panels are subject to the area, height, percentage and separation rules applicable to plastic wall-panel installations	Plastic glazing and plastic wall panels on the same building	Uses 2607 / Table 2607.4, not the 2608 glazing percentages, for the aggregate	Conditional	Add plastic windows and plastic wall panels together against the wall-panel caps	Verified

15. Light-transmitting plastic glazing

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2608.2 Item 1	Plastic glazing area and pane size	On construction types other than Type VB, openings not required to be protected by Section 705 may be glazed with light-transmitting plastic complying with 2606. Aggregate area not more than 25 percent of the area of any wall face of the story. A single pane above the first story above grade plane not more than 1.5 m² , vertical dimension not more than 1.2 m	Plastic glazing in unprotected openings, not Type VB	Exception: 903.3.1.1 throughout increases allowable glazing to not more than 50 percent of the wall face of the story, with no limit on maximum dimension or area of a single pane. 705 protectives are not imported	Conditional	Keep unsprinklered plastic glazing at 25 percent of the story face and upper-story panes at 1.5 m² / 1.2 m ; use the 50 percent exception only if 903.3.1.1 is locked	Verified
2608.2 Item 2	Interstory flame barriers	Approved flame barriers extending 750 mm beyond the exterior wall in the plane of the floor, or vertical panels not less than 1.2 m in height, between glazed units in adjacent stories	Plastic glazing in unprotected openings, not Type VB	Exception: buildings sprinklered throughout per 903.3.1.1	Conditional	Show 750 mm projections or 1.2 m vertical panels between stories unless 903.3.1.1 applies	Verified
2608.2 Item 3	Plastic glazing height	Light-transmitting plastics shall not be installed more than 23 m above grade level	Plastic glazing in unprotected openings, not Type VB	Exception: buildings sprinklered throughout per 903.3.1.1	Conditional	Plastic glazing above 23 m is permitted only if the building is 903.3.1.1 throughout; otherwise keep it off the tower shaft	Verified

16. Plastic roof panels and skylights

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2609.1	Roof-panel permission	Light-transmitting plastic roof panels shall not be installed in Groups H, I-2 and I-3. In all other groups, including R-2, comply with any one of: 903.3.1.1 throughout; roof construction not required to have a fire-resistance rating by Table 601; or roof panels meeting Chapter 15 roof-covering requirements. Also comply with 2606	Plastic roof panels	Table 601 hours and Chapter 15 class are not imported	Conditional	Document which of the three permission paths is used before adding plastic roof panels	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2609.2	Roof-panel separation	Individual roof panels separated not less than 1.2 m measured in a horizontal plane	Plastic roof panels	Exception 1: 903.3.1.1 throughout. Exception 2: low-hazard buildings under 2609.4 Exception 2 or 3	Conditional	Space unsprinklered plastic roof panels 1.2 m apart in plan	Verified
2609.3	Roof-panel setback from protected walls	Where exterior wall openings are required to be protected by Section 705.8, a roof panel shall not be installed within 1.8 m of such exterior wall	Plastic roof panels near a wall with required opening protectives	No sprinkler exception stated	Conditional	Keep plastic roof panels 1.8 m from walls that need 705.8 protectives	Verified
2609.4	Roof-panel area table	Roof panels limited in area, and aggregate area limited as a percentage of the floor area of the room or space sheltered, in accordance with Table 2609.4	Plastic roof panels	Exception 1: Table 2609.4 areas increased 100 percent where 903.3.1.1 throughout. Exception 2: low-hazard buildings such as swimming-pool shelters not more than 465 m² with FSD not less than 3 m . Exception 3: plant-only greenhouses without public access, FSD not less than 1.2 m — omitted here. Exception 4: Group R-3 terrace/patio roofs — omitted here. Table 2609.4 is concatenated	External verification	Do not adopt Table 2609.4 CC1/CC2 m² or percent cells from this extract; the 100 percent sprinkler increase is usable only after the published table is verified	Verify source
2610.1–2610.1.1	Skylight charging	Skylight assemblies glazed with light-transmitting plastic shall conform to this section and 2606. Unit skylights: Section 2405.5	Plastic-glazed skylights	Exception: skylights in which the plastic conforms to the required roof-covering class in Section 1505, 2405.5 and 1505 values are not imported	Conditional	Send unit skylights to 2405.5 for structure and keep 2610 for fire geometry unless the 1505 class exception applies	Verified
2610.2	Skylight curb and edge protection	Mount the plastic above the roof plane on a curb constructed for the type of construction, but not less than 100 mm above the roof plane. Protect edges with metal or other approved noncombustible material, or show the dome/skylight resists ignition where the edge is exposed to a Class B brand (ASTM E108 or UL 790) on a specimen elevated per manufacturer instructions but not less than 100 mm	Plastic skylights	Exception 1: curbs not required on roofs with minimum slope three units vertical in 12 horizontal (25-percent slope) in Group R-3, and on buildings with a nonclassified roof covering — R-3 branch omitted. Exception 2: metal/noncombustible edge not required where nonclassified roof coverings are permitted	Conditional	Provide a 100 mm curb and noncombustible edge protection, or a Class B brand report at not less than 100 mm	Verified
2610.3	Skylight slope and dome rise	Flat or corrugated plastic skylights shall slope not less than four units vertical in 12 units horizontal (4:12). Dome-shaped skylights shall rise above the mounting flange not less than 10 percent of the maximum dome width, but not less than 75 mm	Flat/corrugated or domed plastic skylights	Exception: skylights that pass the Class B Burning Brand Test in ASTM E108 or UL 790	Conditional	Set flat plastic skylights at 4:12 or provide 75 mm / 10 percent dome rise unless a Class B brand listing is submitted	Verified
2610.4	Individual skylight area	Each skylight shall have a maximum area within the curb of 9 m²	Plastic skylights	Exception: 903.3.1.1 throughout, or smoke and heat vents in accordance with Section 910. Section 910 values are not imported	Conditional	Keep each unsprinklered, unvented plastic skylight at or below 9 m² inside the curb	Verified
2610.5	Aggregate skylight area	Aggregate skylight area not more than 33.3 percent of the floor area of the room or space sheltered where Class CC1 is used, and 25 percent where Class CC2 is used	Plastic skylights	Exception: aggregate limits increased 100 percent where 903.3.1.1 throughout or Section 910 smoke and heat vents are provided	Conditional	Cap unsprinklered CC1 skylights at 33.3 percent and CC2 at 25 percent of the sheltered floor; double only with 903.3.1.1 or 910 vents	Verified
2610.6	Skylight separation	Skylights separated from each other not less than 1.2 m measured in a horizontal plane	Plastic skylights	Exception 1: 903.3.1.1 throughout. Exception 2: Group R-3 multiple skylights over the same room within 2610.4 — omitted here	Conditional	Space unsprinklered plastic skylights 1.2 m apart in plan	Verified
2610.7	Skylight setback from protected walls	Where exterior wall openings are required to be protected in accordance with Section 705, a skylight shall not be installed within 1.8 m of such exterior wall	Plastic skylights near a protected exterior wall	None stated	Conditional	Keep plastic skylights 1.8 m from walls that need Section 705 opening protectives	Verified
2610.8	Combined roof panels and skylights	Combinations of plastic roof panels and skylights are subject to the area, percentage and separation requirements applicable to roof-panel installations	Plastic roof panels and skylights on the same roof	2609.4 / Table 2609.4 govern the aggregate	Conditional	Add skylights and plastic roof panels together against the roof-panel caps after Table 2609.4 is verified	Verified

17. Light-transmitting plastic interior signs

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2611.1	Interior-sign charging	Light-transmitting plastic interior signs limited as specified in 2606 and 2611.2 through 2611.4	Interior light-transmitting plastic signs	Exception: interior wall signs in covered and open mall buildings, Section 402.6.4 — omitted here; 402.6.4 values are not imported	Conditional	Apply 2611 to lobby/directory/tenant box signs; do not use mall 402.6.4 on the residential tower	Verified
2611.2	Sign aggregate area	Aggregate area of all light-transmitting plastics not more than 2.2 m²	Interior plastic signs	Exception: 903.3.1.1 throughout, aggregate not more than 9.3 m² provided all plastics are Class CC1	Conditional	Keep unsprinklered plastic sign faces at 2.2 m² aggregate; use 9.3 m² only with 903.3.1.1 and CC1	Verified
2611.3	Sign separation	Signs exceeding the 2611.2 aggregate shall be separated not less than 1200 mm horizontally and 2400 mm vertically	Multiple interior plastic signs whose combined plastic exceeds 2611.2	None stated	Conditional	Separate oversize sign groups by 1200 mm horizontally and 2400 mm vertically	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2611.4	Sign metal encasement	Backs of wall-mounted signs and nonilluminated portions of all signs regulated by this section shall be fully encased in metal	2611 interior plastic signs	None stated	Conditional	Show metal backs and metal-encased non-illuminated boxes on sign shop drawings	Verified

18. Fiber-reinforced polymer (exterior)

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2613.2	FRP labeling	Packages and containers of fiber-reinforced polymer and components delivered to the job site shall bear the label of an approved agency showing manufacturer name, product listing, product identification and end-use information	FRP delivered to site	None stated	Conditional	Require labeled FRP packages on the ornament/cladding submittal	Verified
2613.3–2613.4	FRP interior and light-transmitting	FRP used as interior finishes, decorative materials or trim: Chapter 8. FRP interior finish with foam cores: Chapter 8 and this chapter. FRP used as light-transmitting materials: 2606 through 2611 for the specific application	Interior FRP finish/trim or light-transmitting FRP	Chapter 8 values are not imported	Conditional	Send interior FRP to Chapter 8 (and 2603 if foam-cored); send translucent FRP to 2606–2611	Verified
2613.5	FRP on exterior walls	FRP permitted on exterior walls of any construction type when the polymers meet 2603.5. Fireblocking in accordance with Section 718	FRP on exterior walls	Exception 1: 2603.5 not required where aggregate FRP is not more than 20 percent of the specific wall, each architectural element and each contiguous set not more than 10 percent of that wall; FSI 25 or less (coatings/paints thinner than 0.9 mm applied directly to the FRP are not required to meet FSI); fireblocking per 718.2.6; installed directly to a noncombustible substrate or separated by 0.4 mm corrosion-resistant steel, 0.5 mm aluminum or other approved noncombustible material. Exception 2: 2603.5 not required on buildings 12 m or less above grade where 1405.1 is met; FSD 1.5 m or less, FRP not more than 10 percent of the wall, or FSD greater than 1.5 m with no area limit; FSI 200 or less (same 0.9 mm coating relief); 718.2.6 fireblocking. 1405.1 and 718 values are not imported	Conditional	Default tower FRP cladding to 2603.5 (NFPA 285). Use Exception 1 only for limited ornament. Do not use the 12 m Exception 2 path on the shaft	Verified

19. Reflective plastic core insulation

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
2614.1–2614.2	Reflective-core charging and identification	Reflective plastic core insulation shall comply with 2614 and with either 2614.3 or 2614.4. Packages and containers shall show manufacturer or supplier name, product identification and end-use information	Reflective plastic core (“bubble”) insulation	Identification is manufacturer information, not the 2603.2 approved-agency foam label	Conditional	Identify bubble-pack reflective insulation as 2614, not as 2603 foam	Verified
2614.3	Reflective-core surface burning	Flame spread index not more than 25 and smoke-developed index not more than 450 . ASTM E84 or UL 723, maximum thickness intended for use. Specimen preparation and mounting per ASTM E2599	Reflective plastic core insulation using the Steiner-tunnel path	Alternative path is 2614.4	Conditional	Require E84/UL 723 with E2599 mounting at the installed thickness; do not accept ordinary E84 mounting	Verified
2614.4	Reflective-core room-corner path	Comply with the acceptance criteria of Section 803.1.1.1 when tested to NFPA 286 or UL 1715 in the manner intended for use, at the maximum thickness intended for use	Reflective plastic core insulation using the room-corner path	803.1.1.1 numeric criteria are not imported	External verification	If E84/E2599 is not used, require NFPA 286 or UL 1715 to 803.1.1.1 at the installed thickness	Verified

20. Project-use controls

1. Use **Verified** rows for initial scoping after the row trigger is confirmed (foam actually in the wall, plastic glazing actually specified, and so on).
2. Treat every **Verify source** row as a hold point. Do not issue fastener schedules from Tables 2603.12.1 / 2603.12.2 / 2603.13.1 / 2603.13.2, or area/separation cells from Tables 2607.4 and 2609.4, until the published tables are read.
3. Do not assume NFPA 13 versus 13R. Apply 903.3.1.1 area, height and diffuser exceptions only when that standard is locked on the code data sheet.
4. Do not import Chapter 8 finish classes, Chapter 14 covering thicknesses, Section 705.8 opening percentages, Table 601 roof ratings, NFPA 285/268/275 pass/fail, or CS.md numbers into issued drawings from this matrix.
5. Do not use commentary or figure numbers (including 2611 figure **20 percent** wall-area examples, 2606.12 commentary **0.25 mm**, and 2603.4.1.6 commentary particleboard/hardboard thickness splits).
6. Do not reconstruct 2603.4.1.4 one-story metal-faced walls from the concatenated 2603.4.1.3 commentary block; that path is not used on this high-rise.
7. Record foam-wall, plastic-glazing and sprinkler decisions in the project Golden Thread; this matrix is not evidence of SCD NOC or stamped compliance.

21. Coverage summary

Internal inventory of the attached Chapter 26 extract (numbered code, exceptions, tables, footnotes; commentary excluded). Row-level records are not published.

- **Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)
- **Total independently checkable numeric records:** 186
- **Verified:** 151
- **Verify source:** 35

Counts by top-level section

Top-level section	Records
2601	0
2602	0
2603	81
2604	5
2605	3
2606	22
2607	27
2608	7
2609	10
2610	12
2611	4
2612	1
2613	12
2614	2

Appended-table coverage

Appended table	Records	Verify source records
Table 2603.12.1	1	1
Table 2603.12.2	1	1
Table 2603.13.1	1	1
Table 2603.13.2	1	1
Table 2607.4	22	22
Table 2609.4	4	4

Four cladding-fastener tables are OCR-destroyed and counted as one Verify-source record each (no cell adopted). Table 2607.4 flattened FSD/class/percentage/area/separation cells and Table 2609.4 concatenated CC1/CC2 cells are all Verify source. Figures 2603.1, 2603.4.1.6, 2603.4.1.13, 2607.4, 2609.2, 2609.3 and 2611.3(1)–(2) were not inventoried.

Coverage cross-check against SBC 201 Chapter 26 Plastics (2024)_CS.md was topics-only: foam thermal barrier and NFPA 285; plastic veneer height/area; CC1/CC2 light-transmitting plastics; wall panels, glazing, roof panels and skylights; FRP. No CS.md value was copied into a matrix cell.

22. Unresolved-source register

Hold points for the 35 **Verify source** inventory records. Counts are record counts, not distinct numeric values. No value in this register is a design-release figure.

Affected table / clause	Why unverified	Control note
2603.4.1.4 (5 records)	Numbered heading is missing. One-story metal-faced exterior-wall text is concatenated into the 2603.4.1.3 commentary block; later clauses cite 2603.4.1.4	Do not invent the numbered clause or adopt FSI/SDI/thickness/facing millimetres from that dump. Not used on a high-rise
Table 2603.12.1	Entire table is an OCR dump (TABLE 26.03.12.1)	Do not reconstruct CFS/wood direct-attach fastener size, spacing or foam thickness
Table 2603.12.2	Concatenated HTML (FURBING, ROAM); cells repeat and are unreadable	Do not reconstruct furred CFS fastener schedules
Table 2603.13.1	Page-1853 cladding-fastener table is concatenated; charging 2603.13.1 names Table 2603.12.1	Do not reconstruct wood-framing direct-attach cells; verify which table number the published code uses
Table 2603.13.2	TABLE 26-013.12 concatenated; penetration and foam-thickness cells not recoverable	Do not reconstruct wood-furring fastener schedules
Table 2607.4 (22 records)	Flattened cells concatenate FSD, CC class, percentage, m² and vertical/horizontal separation	Do not adopt percentage, m² or separation cells. 2607.5 100 percent / 50 percent / 23 m running text remains usable. 705.8 still caps openings
Table 2609.4 (4 records)	Concatenated CC12830CC29.325; individual-panel m² and aggregate percent not adopted	Do not repair a percent cell from memory. Keep 2609.2 1.2 m and 2609.3 1.8 m from running text