

SBC 201 Chapter 3 Use and Occupancy Classification — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise as a project statement. Chapter 3 does not define high-rise; occupied-floor height is not a value in this chapter.
- **Deliverable tier:** Project-use matrices in Sections 4–10 (design-check rows, not pasted inventory), plus project-use controls, a coverage summary and an unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 3, source file Reference\SBC 201 2024\source_reference\Chapter_03 – USE AND OCCUPANCY CLASSIFICATION.txt.
- **Extraction audit:** Skill extract. Project-use rows follow the chapter-extract row contract (noun-phrase checks, bold SI values, building-language triggers, named exceptions, check-specific actions). Internal inventory: **450** independently checkable numeric records (**60** Verified, **390** Verify source). Unresolved OCR is listed in the register and is not a design-release value.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped occupancy classification, fire-strategy, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from Chapter 2, Chapter 4, Chapter 5, Section 403, 406, 414, 415, 419, 420, 508, 509, SBC 801, SBC 1101/1102, commentary examples, Figure 308.1, or bibliography years. Where Chapter 3 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group R-2 and high-rise status are project statements, not independently verified classifications.
2. The exact Riyadh AHJ/permit pathway, project stage and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Automatic sprinkler protection is not selected. Chapter 3 classification of Group R-2 does not branch on NFPA 13 versus 13R. Sprinkler notes on Tables 307.1(1)–(2) are MAQ-increase branches only and are OCR-unresolved.
4. Mixed-use podium, amenity assembly, parking, occupied roof, live/work, unit type and care uses are unconfirmed. Those branches are shown, not assumed.
5. Commentary numbers are not adopted, including a 30-day transient stay, 0.45 m² per person, 10 percent mixed-occupancy, and the 67.5 m² assembly example.
6. Tables 307.1(1) and 307.1(2) are concatenated OCR. No reconstructed MAQ is adopted as a design-release value.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, use, occupant load, mixed-use/podium condition or exception exists.
Not typical	Unrelated occupancy-only rule; omitted from this deliverable unless the gap register already opened that use.
External verification	Chapter 3 points to another section/code/standard, or the project/AHJ basis must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 3 source text.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 3 application	Required project action
Unit type	Unconfirmed: dwelling units vs sleeping units	310.3 charges R-2 as sleeping units or more than two dwelling units; dwelling vs sleeping also selects later Chapter 4/11 paths	Freeze a unit schedule (apartment dwelling vs congregate sleeping) on the code data sheet
Transient vs permanent stay	Unconfirmed; serviced apartments / short-stay product not locked	310.2 is primarily transient; 310.3 is primarily permanent. A dual-purpose product must satisfy both (302.1)	Confirm the marketed length of stay; if both transient and permanent uses exist, classify for both R-1 and R-2
Mixed-use podium	Unconfirmed: retail, offices, parking, dining	302.1 sends multiple occupancy groups to Section 508 ; do not import 508 percentages here	Occupancy-by-room schedule for podium, amenities and parking
Amenity assembly	Unconfirmed: gym, prayer hall, indoor pool, party room, dining	303.1.1 / 303.1.2 reclassify small assembly; larger accessory rooms stay Group A and become mixed occupancy	Calculate occupant load and floor area for every amenity room before locking Group A vs B vs R-2
Occupied roof	Unconfirmed	302.1 classifies occupied roofs by the occupancy they most nearly resemble and sends geometry to 503.1.4	Name the roof use (assembly, residential amenity, or unoccupied) on the roof plan
Live/work	Unconfirmed	310.3 lists live/work units as Group R-2; 302.2 sends certain uses to Chapter 4 without naming Section 419 in the Chapter 3 code text	Confirm whether any unit includes a tenant-operated nonresidential use
In-unit day care / custodial care	Unconfirmed	305.2.2 keeps five or fewer children as the primary occupancy; 305.2.3 is Group R-3 for dwelling-unit day care; 308.5.4 is R-3 / SBC 1101/1102	Confirm whether any unit or amenity is a care facility; do not assume R-3 for an R-2 apartment
Building-level nursery / kindergarten	Unconfirmed	308.5.2 / 308.5.2.1 locate nursery/kindergarten on the ground floor, with a 1:12 / 1.5 m ramp branch to the first floor	If a nursery or kindergarten is added, apply 308.5.2; otherwise omit that geometry
Parking / repair	Unconfirmed public or private parking	Open/enclosed public parking is Group S-2 (311.3) and is sent to 406 ; repair garages are S-1 and sent to 406.8	Classify parking as public S-2 or private (312.2 / 406.3); keep repair out of the residential garage

Decision / gap	Current project basis	Why it controls Chapter 3 application	Required project action
Hazardous materials	Unconfirmed: pool chemicals, generator fuel, cleaning stores	307.1 is Group H only when MAQ in Tables 307.1(1)–(2) is exceeded in a control area per 414	Produce a control-area / chemical inventory; do not adopt OCR MAQ cells
Sprinkler / MAQ notes	Unconfirmed NFPA 13 vs 13R	Table 307.1 notes d/e/f/g increase or unlimited MAQ only on the 903.3.1.1 path; OCR unresolved	Do not use reconstructed MAQ multipliers; lock sprinkler standard with the fire engineer
NOC / fire strategy	Unconfirmed	Mixed occupancy, high-rise and H/MAQ cannot be concluded from Chapter 3 alone	Engage the qualified local code/fire consultants before design freeze

4. Classification mechanics

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
301.1	Chapter classification scope	This chapter controls classification of all buildings and structures as to occupancy and use	Every building and structure	None stated	Direct	Put occupancy group(s) on the code data sheet from this chapter, not from a later chapter’s title	Verified
302.1	Occupancy group assignment	Classify the structure into one or more occupancy groups in this section based on hazards and risks associated with the intended purpose	Every structure or portion	Unlisted purpose: classify as the occupancy it most nearly resembles	Direct	Assign Group R-2 to the residential tower once 310.3 is confirmed; do not leave floors unclassified	Verified
302.1	Multipurpose space	An area, room or space occupied at different times for different purposes shall comply with all applicable requirements associated with each purpose	Rooms with more than one programmed use	None stated	Conditional	If a lounge is also used as a banquet or prayer hall, apply every matching occupancy, not the lighter one only	Verified
302.1	Mixed occupancy groups	Structures containing multiple occupancy groups shall comply with Section 508	More than one occupancy group in the structure	Accessory assembly rooms that 303.1.2 keeps out of Group A are not classified as Assembly; 508 values are not in this chapter	External verification	Send podium, parking and over-threshold amenities to the Section 508 mixed-occupancy analysis; do not import 508 limits here	Verified
302.1	Occupied-roof classification	Occupied roofs shall be classified in the group the occupancy most nearly resembles, according to fire safety and relative hazard, and shall comply with Section 503.1.4	Occupied roofs	None stated	Conditional	Classify the roof terrace as the use it actually hosts; take occupied-roof construction limits from 503.1.4	Verified
302.2	Use designation / Chapter 4	Occupancy groups contain subordinate uses; certain uses require specific limitations and controls in Chapter 4 and elsewhere	Uses listed in 302.1 group descriptions	None stated	External verification	After the group is locked, apply the matching Chapter 4 special-occupancy section named by this chapter (for example 420 at 310.1, 406 at 311.3.1); do not import those values here	Verified

5. Group R-2 charging

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
310.1	Residential Group R	Group R is a building or portion used for sleeping purposes when not classified as Institutional Group I and when not regulated by SBC 1101/1102	Sleeping accommodation not Group I and not under SBC 1101/1102	310.4.1 and 310.4.2 SBC 1101/1102 options apply to R-3 care/lodging, not this tower	Direct	Keep the tower on SBC 201 Group R; do not apply the one- and two-family code to a high-rise apartment building	Verified
310.1	Group R Section 420	Group R occupancies not constructed in accordance with SBC 1101/1102 as permitted by 310.4.1 and 310.4.2 shall comply with Section 420	Group R not on the SBC 1101/1102 path	None stated	External verification	Send dwelling/sleeping-unit separation, sprinklers and alarms to Section 420; do not copy 420 ratings here	Verified
310.3	Group R-2 definition	Group R-2 occupancies containing sleeping units or more than two dwelling units where the occupants are primarily permanent in nature	Permanent residential occupancy of that form	Listed R-2 uses below; congregate living is R-2 only with more than 16 occupants	Direct	Confirm more than two dwelling units (or sleeping units) and primarily permanent occupancy on the code data sheet	Verified
310.3	Apartment-house classification	Apartment houses are included in Group R-2	Apartment houses with primarily permanent occupants	None stated in 310.3	Direct	Classify conventional apartment floors as Group R-2	Verified
310.3	Congregate living R-2	Congregate living facilities (non-transient) with more than 16 occupants are Group R-2	Non-transient congregate living	16 or fewer occupants is Group R-3 (310.4), not this tower’s default	Conditional	If staff housing or boarding is congregate, count occupants; over 16 stays R-2, 16 or fewer is not R-2	Verified
310.3	Other listed R-2 uses	Boarding houses (non-transient), dormitories, hotels (non-transient), motels (non-transient) and vacation timeshare properties are included in Group R-2	Those uses with primarily permanent occupants	Transient hotels/motels are Group R-1 (310.2)	Conditional	Reclassify only if the product is dormitory, non-transient hotel/motel, boarding or timeshare rather than apartments	Verified
310.3	Live/work units	Live/work units are included in Group R-2	Dwelling or sleeping unit with a tenant-operated nonresidential portion	None stated in 310.3; 302.2 still sends certain uses to Chapter 4	Conditional	If any unit is live/work, classify it Group R-2; take Chapter 4 live/work controls from that chapter, not from commentary	Verified

6. Transient, R-3 and R-4 branches

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
310.2	Group R-1 transient	Group R-1 occupancies contain sleeping units where the occupants are primarily transient in nature, including hotels and motels (transient)	Primarily transient sleeping units	Boarding/congregate (transient) with more than 10 occupants are also R-1; 10 or fewer is R-3	Conditional	If the tower sells short-stay/hotel rooms, classify those units R-1, or both R-1 and R-2 where 302.1 multipurpose applies	Verified
310.2	Transient congregate threshold	Boarding houses (transient) and congregate living facilities (transient) with more than 10 occupants are Group R-1	Transient congregate / boarding	10 or fewer occupants is Group R-3 (310.4)	Conditional	Do not use the R-1 congregate threshold for a permanent apartment house	Verified
310.4	Two-dwelling-unit R-3	Buildings that do not contain more than two dwelling units are Group R-3 when not classified as R-1, R-2, R-4 or I	One- or two-dwelling buildings	High-rise apartment houses exceed two dwelling units and stay R-2	Direct	Do not reclassify the tower as R-3; the two-dwelling cap is a different building type	Verified
310.4	Nontransient congregate R-3	Congregate living facilities (nontransient) with 16 or fewer occupants are Group R-3	Small nontransient congregate living	More than 16 occupants is R-2 (310.3)	Conditional	Use this branch only for a small staff-house or similar; not for the apartment tower	Verified
310.5	Group R-4 custodial care	Group R-4 is more than five but not more than 16 persons, excluding staff, residing on a 24-hour basis in a supervised residential environment and receiving custodial care	Supervised custodial care at that count	Construction as defined for Group R-3 except as otherwise provided; Conditions 1 and 2 in 310.5.1–310.5.2	Conditional	Classify assisted-living / group-home wings as R-4 or I-1, not R-2 apartments	Verified

7. Amenity and assembly spaces

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
303.1	Assembly Group A	Group A is gathering for civic, social or religious functions; recreation; food or drink consumption; or awaiting transportation	Assembly purpose	Small-building and small-space reclassifications in 303.1.1–303.1.2; Group E association in 303.1.3	Conditional	Test every amenity against 303.1 before calling it residential accessory	Verified
303.1.1	Small assembly tenant	A building or tenant space used for assembly purposes with occupant load less than 50 persons shall be classified as Group B	Entire building or tenant space used for assembly	None stated	Conditional	Classify a small café tenant as Group B when occupant load is below 50; at 50 or more it is Group A	Verified
303.1.2	Accessory assembly occupant load	A room or space used for assembly purposes with occupant load less than 50 persons and accessory to another occupancy shall be classified as Group B or as part of that occupancy	Accessory assembly room	Either this occupant-load path or the 303.1.2 area path may be used; 303.1.3 is Group E only	Conditional	For each amenity, compute occupant load; below 50 and accessory, keep it Group B or R-2	Verified
303.1.2	Accessory assembly floor area	A room or space used for assembly purposes that is less than 70 m² in area and accessory to another occupancy shall be classified as Group B or as part of that occupancy	Accessory assembly room	Independent of the occupant-load item; either threshold is sufficient	Conditional	If occupant load is 50 or more, still test floor area; under 70 m² and accessory, keep Group B or R-2	Verified
303.3	Food and drink assembly	Group A-2 includes banquet halls, gaming areas, and restaurants, cafeterias and similar dining facilities including associated commercial kitchens	Food and/or drink consumption	Occupant load less than 50 for a whole tenant is Group B (303.1.1); accessory small rooms use 303.1.2	Conditional	Classify residents’ dining, banquet and commercial kitchens as A-2 unless a 303.1.1 / 303.1.2 threshold is met	Verified
303.4	Recreation and worship assembly	Group A-3 includes, among others, gymnasiums (without spectator seating), indoor swimming pools (without spectator seating), and mosques / prayer halls	Worship, recreation or amusement not classified in A-1, A-2, A-4 or A-5	Spectator seating at an indoor pool or gym is Group A-4 (303.5); 303.1.2 may keep a small accessory room out of Group A	Conditional	Classify gym, prayer hall and indoor pool without spectators as A-3 unless 303.1.2 applies; add A-4 if spectator seating is provided	Verified
303.5	Indoor spectator assembly	Group A-4 is indoor sporting events and activities with spectator seating , including swimming pools	Indoor sport with a defined seating area	Without spectator seating the same pool or gym is A-3 (303.4)	Conditional	If the amenity pool or gym has spectator seating, classify A-4 and send the mix to Section 508	Verified
303.1.5	Special amusement	Special amusement areas shall comply with Section 411	Special amusement areas	None stated	Conditional	If a puzzle room or special amusement is added, use Section 411; do not import 411 values here	Verified

8. Podium, storage and parking

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
304.1	Business Group B	Group B is office, professional or service-type transactions, including storage of records and accounts	Office / professional / service use	Training and skill development is Group B where not classified as Group A	Conditional	Classify management offices, clinics and tutoring rooms as Group B unless occupant load pushes the room to Group A	Verified
304.1	Small dining as Group B	Dining facilities not more than 230 m² in area are included in Group B	Dining not associated with the A-2 restaurant list in 303.3	Food processing / commercial kitchens more than 230 m² and not associated with restaurants are Group F-1 (306.2)	Conditional	Size a non-restaurant dining room against 230 m² ; larger associated restaurant dining stays on the 303.3 / 303.1.1 path	Verified
306.2	Large commercial kitchen	Food processing establishments and commercial kitchens not associated with restaurants, cafeterias and similar dining facilities more than 230 m² in area are Group F-1	Detached or non-restaurant food processing above that area	Associated A-2 kitchens follow 303.3	Conditional	Do not classify a restaurant kitchen as F-1; use F-1 only for a standalone kitchen/plant over 230 m²	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
309.1	Mercantile Group M	Group M is display and sale of merchandise with stocks of goods accessible to the public	Retail / wholesale sales	Accessory storage may remain with the principal occupancy (311.1.1)	Conditional	Classify podium retail as Group M and send the R-2 / M mix to Section 508	Verified
309.2	Mercantile hazardous display	Aggregate quantity of nonflammable solid and nonflammable or noncombustible liquid hazardous materials stored or displayed in a single control area of Group M shall not exceed Table 414.2.5(1)	Group M control areas	Table 414.2.5(1) is not in this chapter	External verification	If podium retail sells pool chemicals or similar, take display limits from Table 414.2.5(1), not from OCR Table 307.1	Verified
309.3	Motor-fuel dispensing	Motor fuel-dispensing facilities shall comply with Section 406.7	Fuel-dispensing facilities	None stated	Conditional	If a filling station is on the plot, use 406.7; do not import those values here	Verified
311.1.1	Accessory storage	A room or space used for storage purposes that is accessory to another occupancy shall be classified as part of that occupancy	Accessory storage	Independent storage is Group S and mixed occupancy under 508	Direct	Classify typical residential stores, bin rooms and house tanks that serve the apartments as Group R-2, not S-1	Verified
311.1.2	Combustible storage	High-piled stock or rack storage, or attic, under-floor and concealed spaces used for storage of combustible materials, shall be in accordance with Section 413	Those storage conditions	None stated	Conditional	If combustible storage is high-piled or in concealed spaces, use Section 413; do not import 413 values here	Verified
311.3	Public parking Group S-2	Public parking garages, open or enclosed, are included in Group S-2	Public parking without repair-garage operations	Repair garages are Group S-1 (311.2) and shall comply with 406.8 (311.2.2)	Conditional	Classify podium/public parking as S-2; keep vehicle repair out of that garage	Verified
311.3.1	Parking garage construction	Public parking garages shall comply with Section 406.4 and with 406.5 (open) or 406.6 (enclosed)	Public parking garages	None stated	External verification	Detail open versus enclosed parking from Section 406; do not copy 406 openings or area figures here	Verified
312.2	Private garage / carport	Private garages and carports shall comply with Section 406.3	Private garages and carports	Public parking is 311.3.1, not this path	Conditional	Use 406.3 only for private residential garages, not a public podium garage	Verified
312.1	Small communications structure	Communication equipment structures with a gross floor area of less than 140 m² are included in Group U	Small communications buildings	Larger occupied equipment buildings follow the occupancy they most nearly resemble	Conditional	Classify a small site telecom hut under 140 m² as Group U	Verified
312.1	Tall fence	Fences more than 2.1 m in height are included in Group U	Fences above that height	None stated	Conditional	Show site fences over 2.1 m as Group U structures on the plot classification	Verified

9. Care uses in or with the tower

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
305.2	Group E day care	Group E day care is more than five children older than 2.5 years receiving educational, supervision or personal care for fewer than 24 hours per day	Day care of that size, age and duration	305.2.2 and 305.2.3 reduce small facilities; infants 2.5 years or less are I-4 unless 308.5.1 applies	Conditional	If a commercial day care is in the podium, classify E or I-4 from headcount, age and hours; do not call it R-2 amenity	Verified
305.2.2	Five-or-fewer day care	A facility having five or fewer children receiving such day care shall be classified as part of the primary occupancy	Day care at that headcount	305.2.3 dwelling-unit path is Group R-3	Conditional	Five or fewer children in an R-2 amenity or unit stay with the primary occupancy (R-2)	Verified
305.2.3	Dwelling-unit day care	A facility as above within a dwelling unit and having five or fewer children receiving such day care shall be classified as Group R-3	Day care inside a dwelling unit	Commentary discusses R-2 multifamily as 305.2.2; that commentary number/path is not adopted as a substitution	Conditional	Do not silently convert an R-2 apartment to R-3 for in-unit day care; lock the path with the AHJ	Verified
308.2.3	Custodial care as R-4	A facility housing not fewer than six and not more than 16 persons receiving custodial care shall be classified as Group R-4	24-hour custodial care at that count	More than 16 is Group I-1 (308.2); five or fewer is R-3 / SBC 1101/1102 (308.2.4)	Conditional	Assisted-living counts of 6–16 are R-4, not R-2	Verified
308.3.2	Small medical care	A facility with five or fewer persons receiving medical care shall be classified as Group R-3 or shall comply with SBC 1101/1102 if sprinklered per 903.3.1.3 or SBC 1101/1102 Section 2904	Medical care at that headcount	More than five incapable of self-preservation on a 24-hour basis is Group I-2 (308.3)	Conditional	A small in-home medical-care use is not Group R-2; it is R-3 or I-2 depending on headcount	Verified
308.5.3	Small I-4 as primary occupancy	A facility having five or fewer persons receiving custodial care shall be classified as part of the primary occupancy	Custodial care fewer than 24 hours, not in a dwelling unit	308.5.4 dwelling-unit path is R-3 / SBC 1101/1102	Conditional	Five or fewer day-care recipients in a common room stay with the primary occupancy	Verified
308.5.2–308.5.2.1	Nursery / kindergarten location	Classrooms and facilities for nursery and kindergarten stages (children under 6 years) shall be on the ground floor; first-floor location is permitted only with a ramp of maximum slope 1:12 , minimum clear width 1.5 meters , and two handrails suitable for children	Nursery or kindergarten classrooms	Ground-floor location needs no ramp branch	Conditional	If a nursery/kindergarten is added above ground floor, provide the 308.5.2.1 ramp; otherwise omit	Verified
308.5.1	Infant day care as Group E	Child day care for more than five but not more than 100 children 2.5 years or less of age may be Group E where care rooms are on a level of exit discharge serving those rooms and each care room has an exit door directly to the exterior	Infant/toddler day care at that count	Otherwise Group I-4 (308.5)	Conditional	Do not use this Group E relief unless every infant room has a direct exterior exit on the discharge level	Verified

10. Hazardous materials and Group H

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
307.1	Group H MAQ trigger	Group H is manufacturing, processing, generation or storage of physical or health-hazard materials in quantities in excess of those allowed in control areas complying with Section 414 , based on MAQ in Table 307.1(1) and Table 307.1(2)	Hazardous materials in the building	Roof/canopy storage is outdoor storage per SBC 801; 307.1.1 lists uses that are not Group H	Conditional	Inventory pool chemicals, fuel and cleaners against control areas; if MAQ is exceeded, classify H and use 415 / SBC 801	Verify source
307.1.1	Uses not Group H	Occupancies in the 16 listed items shall not be classified as Group H, but as the occupancy they most nearly resemble	Listed processes and storage arrangements	Closed piping for machinery; refrigeration systems; stationary batteries; fuel cells; and other listed items still follow Section 414 / SBC 801 as applicable	Conditional	Apply the matching 307.1.1 item (generator fuel piping, batteries, cleaning solvents) before calling a room Group H	Verified
307.1.1 Item 4	Closed-system cleaning	Cleaning establishments using combustible liquid solvents with flash point of 60°C or higher in listed closed systems, separated by 1-hour fire barriers (707) and/or 1-hour horizontal assemblies (711), shall not be Group H	That cleaning process	Item 5: solvent flash point 90°C or higher	Conditional	If a dry-cleaning tenant is added, lock flash point and 1-hour separation; do not default to Group H	Verified
307.2	Hazardous materials any quantity	Hazardous materials in any quantity shall conform to this code, including Section 414 , and SBC 801	Any quantity of hazardous materials	Group H buildings also meet Section 415	External verification	Even below MAQ, specify 414 / SBC 801 controls; do not import those quantities here	Verified
307.4–307.5	Flammable-liquid pressure split	Class I, II or IIIA flammable or combustible liquids in normally open containers/systems, or closed systems pressurized at more than 103.5 kPa , are Group H-2 when MAQ is exceeded; the same liquids in normally closed containers/systems at 103.5 kPa or less are Group H-3	Those liquids when Group H applies	Oxidizer Class 3 uses the same 103.5 kPa open/closed split	Conditional	For fuel rooms that become Group H, use the 103.5 kPa open/closed test to pick H-2 vs H-3	Verified
Tables 307.1(1)–307.1(2)	Control-area MAQ cells	Maximum allowable quantity per control area for physical-hazard and health-hazard materials	Control areas storing or using listed materials	Notes include sprinkler and cabinet increases (903.3.1.1), 50 percent / 5 liters consumer-product relief, and 90 kg / 75 liters Class 3 oxidizer maintenance allowance; cells and most notes are flattened OCR	External verification	Do not enter any reconstructed kilogram, litre or cubic-metre MAQ on drawings; verify the published tables	Verify source

11. Project-use controls

1. Use **Verified** rows for initial occupancy scoping after the row trigger is confirmed on the project (apartment house, amenity present, podium retail, parking type).
2. Treat every **Verify source** row as a hold point. Tables 307.1(1) and 307.1(2) are not design-release values.
3. Do not import mixed-occupancy percentages, incidental-use ratings, high-rise triggers, live/work area caps, parking-garage openings, or MAQ from Chapter 2, 4, 5, 9, 403, 406, 414, 419, 420, 508, 509, SBC 801 or SBC 1101/1102.
4. Do not adopt commentary as a requirement: 30-day stay, 0.45 m² per person, 10 percent of story, or the 67.5 m² assembly example.
5. Show sprinkler/MAQ branches until the fire engineer locks NFPA 13 versus 13R; do not assume a multiplier from notes d/e/f.
6. Record occupancy-by-room decisions in the project Golden Thread; this matrix is not evidence of SCD NOC or stamped compliance.

12. Coverage summary

Internal inventory of the attached Chapter 3 extract (numbered code, exceptions, tables, footnotes; commentary excluded). Row-level records are not published. Figures, including Figure 308.1, were not inventoried.

- **Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)
- **Total independently checkable numeric records:** 450
- **Verified:** 60
- **Verify source:** 390

Counts by top-level section

Top-level section	Records
301	0
302	0
303	3
304	1
305	6
306	1
307	8
308	20
309	0

Top-level section	Records
310	14
311	0
312	2

Appended-table coverage

Appended table	Records	Verify source records
Table 307.1(1) quantity cells	360	360
Table 307.1(1) flattened notes c, d, e, k	6	6
Table 307.1(1) note l	1	0
Table 307.1(2) quantity cells	24	24
Table 307.1(2) notes c, d, e	4	0

No Chapter 3 *_CS.md was present for a coverage cross-check. No CS.md value was copied into a matrix cell.

13. Unresolved-source register

Hold points for the 390 **Verify source** inventory records. Counts are record counts, not distinct numeric values. No value in this register is a design-release figure.

Affected table / clause	Why unverified	Control note
Table 307.1(1)	360 flattened physical-hazard MAQ cells across pages 0235–0236; concatenated storage/use columns; values such as 3455 / 10.45 are unreadable cell joins	Do not reconstruct kilograms, litres or cubic metres from memory or from IBC recall; verify the published table before any H vs non-H decision
Table 307.1(1) notes c, d, e, k	6 numeric footnote tokens (50 percent, 5 liters, two 100 percent increases, 90 kg, 75 liters) trapped in the same flattened HTML	Confirm consumer-product, sprinkler/cabinet and oxidizer-maintenance notes on the printed table; do not apply OCR multipliers
Table 307.1(2)	24 flattened health-hazard MAQ cells; gaseous/liquefied pairs concatenated (2501, 450375)	Verify corrosive / highly toxic / toxic MAQ on the published table; do not use OCR tokens
307.1 project-use row	Group H trigger depends on the unverified tables	Keep the 307.1 row as Verify source until the published MAQ is confirmed
303.6 heading	Group A-5 use list appears after 303.5 without a numbered heading (page 0204)	A-5 outdoor assembly is not typical for this tower; if an outdoor stadium is added, verify the printed 303.6 heading before citing