

SBC 201 Chapter 32 Encroachments into the Public Right-of-Way — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise; an occupied floor is stated to be more than 23 m above the relevant reference level.
- **Deliverable tier:** Project-use matrices in Sections 4–9 (design-check rows, not pasted inventory), plus a coverage summary and unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 32, source file Reference\SBC 201 2024\source_reference\Chapter_32 – ENCROACHMENTS INTO THE PUBLIC RIGHT-OF-WAY.txt.
- **Extraction audit:** Skill extract. Project-use rows follow the chapter-extract row contract (noun-phrase checks, bold SI values, building-language triggers, named exceptions, check-specific actions). Internal inventory: **21** independently checkable numeric records (**21** Verified, **0** Verify source). The attached extract has no appended tables and no OCR hold points.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, municipal right-of-way licence, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from Chapter 16, Section 3104, other public-property ordinances, commentary examples, figure captions, or the existing chapter summary. Where Chapter 32 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group R-2 and high-rise status are project statements, not independently verified classifications.
2. The exact Riyadh AHJ/permit pathway, street-lot-line survey, public-right-of-way owner, project stage and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Automatic sprinkler protection, mixed-use podium, storey count and construction type are unconfirmed. Chapter 32 does not branch on NFPA 13 versus 13R or on occupancy group.
4. This chapter governs projections **across a street lot line into the public right-of-way**. It does not set interior lot-line setbacks or fire-separation distance.
5. Whether any tower elevation sits on a street, alley or highway lot line is unconfirmed. If the building is set fully behind the lot line, the 3202 projection caps do not create a right to occupy the sidewalk.
6. Commentary pointers to Sections 1011.11 and 1014, Ministry of Transportation street-establishment notes, and figure captions (including the “2.5 meter” figure label) are not adopted as code cells.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, use, occupant load, or mixed-use/podium condition exists.
Not typical	Unrelated occupancy-only rule; omitted from this deliverable unless the gap register already opened that use.
External verification	Chapter 32 points to another section/code/authority, or the project/AHJ basis must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 32 source text.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 32 application	Required project action
Street lot line and ROW owner	Unconfirmed survey; applicable governing authority unnamed	3201.1–3201.3 apply only across a public right-of-way lot line; other public-property laws still govern	Lock the street/alley/highway lot line on the site plan and name the ROW owner before drawing any projection
Tower on the street line	Unconfirmed setback	3202 projection caps apply only where the structure actually crosses the lot line	Dimension building face to lot line on every street elevation; if the face is fully behind the line, do not occupy the sidewalk under 3202
Street-wall footings	Unconfirmed basement/foundation on the street line	3202.1.1 allows a 300 mm street-wall footing projection only at ≥ 2.4 m below grade	Structural engineer to set footing soffit depth and street-line projection on the foundation plan
Vaults / enclosed sidewalk spaces	Unconfirmed	3202.1.2 is entirely the applicable governing authority; no millimetre allowance is published	Do not design a sidewalk vault from this chapter; obtain authority terms first
Areaways	Unconfirmed light/vent wells at the sidewalk	3202.1.3 requires approved grates or guards; no bar spacing is stated	Cover any areaway in the public way; do not invent grate geometry here
Entrance steps	Unconfirmed	3202.2.1 caps steps at 300 mm with a 0.9 m guard or column flanks	Show lobby steps either fully on the lot or within the 3202.2.1 envelope
Awnings, canopies, marquees, signs	Unconfirmed	3202.2.3, 3202.3.1 and 3202.4 control clearance, sidewalk share, stanchions and Chapter 16 loads	Freeze canopy/sign scope on the ground-floor plan before applying 2.1 m, 4.5 m, two-thirds or 600 mm
Projecting windows, balconies, architectural features, mechanical equipment	Typical tower likely has windows and may have balconies; equipment unconfirmed	3202.3.2–3202.3.3 set the 25 mm/25 mm ratio, 1.2 m cap and 4.5 m unlimited band	Dimension every street-line projection on elevations against clearance above grade
Pedestrian walkway over the ROW	Unconfirmed skybridge or podium link	3202.3.4 needs governing-authority approval, 4.5 m soffit clearance and Section 3104	Do not draw a public-way walkway until the authority path and 3104 geometry are locked
Temporary vestibules / entrance awnings	Unconfirmed	3202.4 is authority-allowed, time-capped and dimension-capped	Treat seasonal vestibules as a separate licence, not a permanent lobby on the pavement
Sprinkler / mixed use / storeys	Occupied floor stated above 23 m; sprinkler and podium unconfirmed	Chapter 32 has no occupancy, sprinkler or storey branch	Do not wait on NFPA 13 vs 13R to apply 3201–3202; those decisions do not change this chapter

Decision / gap	Current project basis	Why it controls Chapter 32 application	Required project action
NOC / municipal ROW licence	Unconfirmed	3201.3 and several 3202 clauses require other laws or the applicable governing authority	Engage the qualified local/authority consultants before freezing street-line projections

4. Scope, measurement and drainage

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
3201.1	Public right-of-way scope	This chapter governs encroachment of structures into the public right-of-way	Structures that cross a street lot line into a public way	Interior lot-line setbacks are outside this chapter	Direct	Identify every street, alley or highway lot line on the site plan before drawing projections	Verified
3201.2	Projection measurement	Projection is the horizontal distance from the lot line to the outermost point of the projection	Any structure or portion projecting toward the public way	None stated	Direct	Dimension projections on elevations and sections from the street lot line to the outermost point, not from the wall face	Verified
3201.3	Other public-property laws	This chapter shall not be construed to permit violation of other laws or ordinances regulating the use and occupancy of public property	Encroachments otherwise permitted by Chapter 32	Other laws still govern	External verification	Obtain the applicable governing-authority licence for public-property use; do not treat a 3202 dimension as municipal consent	Verified
3201.4	Public-walkway drainage	Drainage water collected from a roof, awning, canopy or marquee, and condensate from mechanical equipment, shall not flow over a public walking surface	Roofs and projections that collect rain or condensate over a public walk	None stated	Direct	Pipe roof, awning, canopy, marquee and condenser drainage into the building system; keep outlets off the sidewalk	Verified

5. Below-grade encroachments

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
3202.1.1	Street-wall footing projection	Below-grade structural support shall not project beyond the lot lines, except that footings of street walls or their supports located not less than 2.4 m below grade shall not project more than 300 mm beyond the street lot line	Building erected on or at a street lot line	Exception limited to street-wall footings or their supports at that depth	Direct	Set street-wall footing soffit ≥ 2.4 m below grade and cap projection at 300 mm on the foundation plan	Verified
3202.1.2	Below-grade vaults	Construction and utilization of vaults and other enclosed spaces below grade shall be subject to the terms and conditions of the applicable governing authority	Below-grade vault or enclosed space in the public right-of-way	No dimensional limit is stated in this chapter	External verification	Do not draw a sidewalk vault until the applicable governing authority sets terms; no millimetre allowance is published here	Verified
3202.1.3	Areaway protection	Areaways shall be protected by grates, guards or other approved means	Areaway opening at the public right-of-way	No grate pattern or guard height is stated in this section	Conditional	Cover every areaway in the sidewalk with an approved grate or guard; do not invent bar spacing from this chapter	Verified

6. Encroachments above grade and below 2.4 m

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
3202.2	Low-level encroachment prohibition	Encroachments into the public right-of-way above grade and below 2.4 m in height shall be prohibited except as provided in 3202.2.1 through 3202.2.3	Projections above grade and below 2.4 m	Allowed items: steps, architectural features and awnings under 3202.2.1–3202.2.3. Temporary vestibules follow 3202.4 where the governing authority allows	Direct	Keep the first 2.4 m of air over the sidewalk clear except for the named low-level allowances	Verified
3202.2	Door and window projection	Doors and windows shall not open or project into the public right-of-way	Doors or windows on a street lot line	None stated	Direct	Hinge street-front doors to swing in or recess them; keep operable sashes inside the lot line	Verified
3202.2.1	Entrance step encroachment	Steps shall not project more than 300 mm and shall be guarded by approved devices not less than 0.9 m in height, or shall be located between columns or pilasters	Steps projecting into the public right-of-way	Guard-height path, or location between columns or pilasters	Conditional	If entrance steps sit on the sidewalk, cap projection at 300 mm and provide a 0.9 m guard or column/pilaster flanks	Verified
3202.2.2	Column and pilaster projection	Columns or pilasters, including bases and moldings, shall not project more than 300 mm	Columns or pilasters in the public right-of-way below 2.4 m	None stated	Direct	Limit street-line column, base and molding projection to 300 mm on the ground-floor elevation	Verified
3202.2.2	Belt course and sill projection	Belt courses, lintels, sills, architraves, pediments and similar architectural features shall not project more than 100 mm	Those features in the public right-of-way below 2.4 m	None stated	Direct	Cap low-level cornice, sill and similar trim at 100 mm beyond the street lot line	Verified
3202.2.3	Awning vertical clearance	Vertical clearance from the public right-of-way to the lowest part of any awning, including valances, shall be not less than 2.1 m	Awnings projecting over the public right-of-way	None stated	Conditional	Set the lowest valance at ≥ 2.1 m above the sidewalk on the canopy section	Verified

7. Encroachments 2.4 m or more above grade

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
3202.3.1	Awning and sign structural loads	Awnings, canopies, marquees and signs shall be constructed so as to support applicable loads specified in Chapter 16	Awnings, canopies, marquees or signs over the public right-of-way	No load values are stated in this chapter	External verification	Put Chapter 16 loads on the canopy or sign structural drawing; do not invent live, wind or seismic figures here	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
3202.3.1	Canopy sidewalk occupancy	Awnings, canopies, marquees and signs with less than 4.5 m clearance above the sidewalk shall not extend into or occupy more than two-thirds the width of the sidewalk measured from the building	Those elements with clearance less than 4.5 m above the sidewalk	Occupancy-fraction rule applies only below 4.5 m clearance	Conditional	On the ground-floor plan, keep any canopy or sign under 4.5 m within two-thirds of the sidewalk width from the building	Verified
3202.3.1	Canopy stanchion setback	Stanchions or columns that support awnings, canopies, marquees and signs shall be located not less than 600 mm in from the curb line	Vertical supports for those elements in the public right-of-way	None stated	Conditional	Keep every canopy or sign stanchion ≥ 600 mm from the curb on the sidewalk plan	Verified
3202.3.2–3202.3.3	Window balcony and equipment projection	Where clearance above grade is more than 2.4 m, 25 mm of encroachment is permitted for each additional 25 mm of clearance above 2.4 m , to a maximum of 1.2 m . Encroachments 4.5 m or more above grade are not limited by this chapter	Projecting windows, balconies, architectural features or mechanical equipment	Ratio-and-cap path below 4.5 m ; unlimited at 4.5 m or more	Direct	Dimension balcony, bay-window and equipment projection on each elevation against the 25 mm per 25 mm ratio and 1.2 m cap, or show ≥ 4.5 m clearance if the projection exceeds 1.2 m	Verified

8. Pedestrian walkways over the public right-of-way

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
3202.3.4	Pedestrian walkway over ROW	Installation of a pedestrian walkway over a public right-of-way shall be subject to approval of the applicable governing authority. Vertical clearance to the lowest part shall be not less than 4.5 m	Pedestrian walkway spanning a public right-of-way	Construction details are in Section 3104 ; those values are not imported	External verification	Do not draw a skybridge until the governing authority approves it; keep soffit ≥ 4.5 m and take remaining geometry from 3104	Verified

9. Temporary encroachments

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
3202.4	Temporary vestibule duration and projection	Where allowed by the applicable governing authority, vestibules and storm enclosures shall not be erected for more than 7 months in any 1 year and shall not encroach more than 0.9 m nor more than one-fourth of the sidewalk width beyond the street lot line	Temporary vestibule or storm enclosure on the sidewalk	Lesser of 0.9 m and one-fourth sidewalk width; requires governing-authority allowance	Conditional	If a seasonal vestibule is proposed, time it to 7 months per year and cap projection at the lesser of 0.9 m and one-fourth sidewalk width	Verified
3202.4	Temporary entrance awning	Temporary entrance awnings shall have clearance not less than 2.1 m to the lowest portion of the hood or awning where supported on removable steel or other approved noncombustible support	Temporary entrance awning over the public right-of-way	Supports must be removable steel or other approved noncombustible	Conditional	Set the temporary hood soffit at ≥ 2.1 m and specify removable steel or approved noncombustible posts	Verified

10. Project-use controls

1. Use **Verified** rows for initial scoping after the street lot line is confirmed and the row trigger exists on the drawings.
2. There are no **Verify source** rows in this extract. The attached Chapter 32 text is clean numbered code with no appended tables. Page-split sentences at 3202.1, 3202.3 and 3202.4 concatenate without missing values.
3. Do not import Chapter 16 loads, Section 3104 walkway geometry, or other public-property ordinance dimensions into issued drawings from this matrix.
4. Do not treat commentary on Ministry of Transportation street establishment, Sections 1011.11 / 1014 handrails, or figure captions as numbered code cells.
5. A 3202 millimetre or fraction allowance is not a municipal licence. 3201.3 and the applicable governing authority still control private use of the public way.
6. Record street-lot-line, canopy, balcony-projection and ROW-licence decisions in the project Golden Thread; this matrix is not evidence of SCD NOC, SBPS approval or stamped compliance.

11. Coverage summary

Internal inventory of the attached Chapter 32 extract (numbered code, exceptions, tables, footnotes; commentary excluded). Row-level records are not published.

- **Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)
- **Total independently checkable numeric records:** 21
- **Verified:** 21
- **Verify source:** 0

Counts by top-level section

Top-level section	Records
3201	0
3202	21

No appended tables in the attached extract.

Coverage cross-check against SBC 201 Chapter 32 Encroachments into the Public Right-of-Way (2024)_CS.md was topics-only: chapter scope and measurement; drainage off public walks; below-grade footings, vaults and areaways; the **2.4 m** low-level prohibition; steps, columns, belt courses and awnings; canopy sidewalk share and stanchion setback; window/balcony/equipment ratio and **4.5 m** unlimited band; pedestrian walkways; temporary vestibules; other laws and the applicable governing authority. No CS.md value was copied into a matrix cell.

12. Unresolved-source register

No OCR, flattened-table, page-split or footnote-attachment hold points. The attached extract contains unambiguous numbered code paragraphs and no tables.

Affected table / clause	Why unverified	Control note
—	None	No Verify source inventory records